

Manual M14D, Section 7.5

7.5 Cold Weather Generation Resource Preparation

Welcome to the Cold Weather Generation Resource Preparation section of the PJM Manual for Generator Operational Requirements. In this section you will find the following information:

- Description of the Generation Resource Operational Exercise.
- Usage of the Generation Resource Cold Weather Checklist.

7.5.1 Generation Resource Operational Exercise

In preparation for winter operations, PJM will request that generation resource owners/operators (“resource owner”) exercise some of their generation resources to determine whether they are capable of reliably operating and responding to PJM’s dispatch instructions. This exercise will be conducted prior to the onset of cold weather to assist in identifying and correcting start-up, operational, and fuel switching (if applicable) problems. Alternatively, a generation resource owner may elect to self-schedule a resource to validate its cold weather operation.

Prior to November 1 of each year, PJM will compile a list of generation resources eligible to participate in the exercise. Generation resources will be eligible if they have not been operated by PJM or the resource owner for eight weeks or more prior to November 1 of that calendar year. PJM will provide the list to the generation resource owner (or its MOC) by November 10. By November 20 of each year, the generation resource owner will provide PJM the list of generation resources that the owner wants to exercise, and the following information, in order to qualify to participate in the exercise:

- 1) The preferred dates, times, and fuel that the generation resource owner is willing to operate the generation resource within the month of December; and,
- 2) The minimum MW and minimum run time to be used during the exercise.
(Note: If the minimum MW and/or minimum run time submitted by the generation resource owner is greater than the eMKT applicable parameter(s) the generation resource owner must include a justification for the difference.)



If a generation resource is initially determined to be eligible by PJM as of October 31, but subsequently operates between November 1 and the date the generation resource is scheduled to participate in the exercise, the generation resource will no longer be eligible to participate. PJM will review on a two week rolling basis the operation of generation resources and if a generation resource has not operated within the most recent eight week period PJM may add that generation resource to the eligibility list and inform the generation resource owner to determine if the generation resource should be included in the exercise. Generation resources such as nuclear powered, wind turbines, hydro powered, and large super critical steam generation resources would normally be excluded from this exercise since these types of generation resources are expected to be operating during the winter season prior to an extreme winter event, and normally would not be inactive after November 1.

PJM will only schedule generation resources if they will be operating on their cost-based schedules for the duration of the exercise. For that reason, generation resources that expect to operate economically in the month of December will be excluded from the list of resources that can participate in the exercise.

Within the month of December, PJM will notify the generation resource owner in advance by 10:00 am the day prior that a generation resource the owner has selected will be scheduled to operate for the next day.

If the projected temperature in the Transmission Zone in which the generation resource is located is above 35 degrees Fahrenheit on the day the generation resource is scheduled to exercise, PJM may elect to cancel the operation of the generation resource. In such case, the generation resource owner has the option to self-schedule the generation resource if desired.

PJM will track and analyze generation resource performance during this exercise and compare it with historical GADS data to gauge the effectiveness of this exercise and make recommendations for any potential changes to the exercise.

On a day-ahead basis, PJM will post the total amount of generation scheduled hourly to operate under this exercise. The total MW of generation expected to be included daily in this exercise will not be greater than approximately 1000 MW.

7.5.2 Generation Resource Cold Weather Checklist

Attachment N of Manual M14D contains the PJM generation resource cold weather preparation checklist. This checklist, or a similar one developed and maintained by the generation resource owner, should be used annually prior to the winter season to



prepare its generation resources for extreme cold weather event operation. Prior to December 15th of each year the generation resource owner's Operating Committee (OC) representative or designate shall report to the OC chair via email that the represented generation resources have completed the items on the checklist, or a substantially equivalent one developed by the generation owner. The OC representative or designate shall include a list of resources that are included in his or her representation and may also include a signed copy of the checklist used by the generation resource owner.

DRAFT