

Operations Assessment Task Force 2020 Summer Study

PJM Operating Committee
Todd Bickel
June 4, 2020

- Case Parameters
- Significant Facility Changes
- 50/50 Non-diversified peak load study results
- Sensitivity Study Results


50/50 Non-diversified Peak Load Base Case

LAS Load Forecast	153,463 MW
Preliminary RTO Net Interchange	2,200 MW** (Exporting)
PJM RTO Installed Capacity	187,343 MW (preliminary)
Discrete Generator Outages	12,496 MW

** 2,200 MW of net interchange is modeled in the OATF base case and accounts for historical and forecasted Pseudo Tie data.

PEAK LOAD ANALYSIS

- No reliability issues identified.



- No reliability issues identified for base case and N-1 analysis.
- Re-dispatch and switching required to control local thermal or voltage violations in some areas.
- All networked transmission voltage violations were controlled by capacitors. All other voltage violations were caused by radial load.

Sensitivity Studies	Impact
External contingencies that could impact PJM reliability	No reliability concerns
N-1-1 Relay trip conditions	No cascading outage concerns identified <ul style="list-style-type: none"> All networked transmission overloads were controlled pre-contingency
Max-Cred Contingency Analysis	No reliability concerns
Transfer Interface Analysis	No reliability concerns
BGE/PEPCO Import Capability	No reliability concerns
90/10 Load Forecast study (157,861 MW)	No uncontrollable or unexpected issues observed at the elevated load levels.

Reactive Interface Transfer Analysis

Interface	Summer 2020 Limit (MW)	Back-off (MW)
Eastern	8576	300
Central	2217	200
Western	5264	200
Bed-Blackoak	1610	50
AP South	4016	100
AEP-DOM	4778	100
Cleveland	3613	200
CE-EAST	2822	200
5004/5005	2917	50