

Dominion Virginia Electric Power (DOM)

1. **Churchland #4 115/13 kV Transformer Sectionalized** – Restores the Churchland – Hodges Ferry 115 kV line and Churchland #3 230/115 kV transformer for a fault on the Churchland #4 115/13 kV transformer.
 - Retire September 8th, 2020
2. **Burton-Virginia Beach 27 sectionalized** – Restores Long Creek transformer # 1 & 2 and either the 27 line from Long Creek-Virginia Beach or the 27 line from Burton-Long Creek following a permanent fault on a section of the 27 line.
 - Effective January 6th, 2021

FirstEnergy West (FE-W)

1. **Brunswick-Stoney-Granger-West Akron 138 kV** – Restore Brunswick-Stoney or West Akron-Granger-Stoney following a fault on West Akron-Granger-Stoney or Brunswick-Stoney respectively.
 - Effective January 6th, 2021
2. **Niles Central Muni-Garden-Elm-Packard 138 kV** – Restore Niles Central Muni-Garden or Packard-Elm-Garden following a fault on Packard-Elm-Garden or Niles Central Muni-Garden respectively.
 - Effective January 6th, 2021
3. **Bayshore-Oregon-Maclean 138 kV** – Restore Bayshore-Oregon or Maclean-Oregon following a fault on Maclean-Oregon or Bayshore-Oregon respectively.
 - Effective January 6th, 2021
4. **Allen Junction-Silica Tap-Reynolds-University of Toledo-Vulcan 138 kV** – Restore Allen Junction-Silica Tap-Reynolds or Vulcan-University of Toledo-Reynolds following a fault on Vulcan-University of Toledo-Reynolds or Allen Junction-Silica Tap-Reynolds respectively.
 - Effective January 6th, 2021