

Transmission Planning Resilience Update

Grace Niu
Lead Engineer, Transmission Planning
Planning Committee
January 10, 2023

www.pjm.com | Public PJM © 2023



- Background
- Critical Substation Planning Analysis (CSPA)
- 2022 CSPA result
- Next Steps



- Resilience strategic initiation in 2018
- Planning Committee
 - Critical Infrastructure Stakeholder Oversight (CISO): August 12, 2019
 - 16 Special meetings: January 2020 March 2021
 - Avoidance of introducing new facilities (Critical Substation Planning Analysis): approved in June 2021



Critical Substation Planning Analysis (CSPA)

- Manual 14B: Section 2.9
- Objective: Identification instability, uncontrolled separation, or cascading resulting in one or more of the following outcomes:
 - Loss of load approaching 1000 MW
 - Three levels of facility trips
 - Includes line, transformers and generators
 - Tripped elements should include 69 kV and above facilities
 - Case fails to converge
- CSPA Do No Harm (DNH) study
 - Evaluate all proposed system reinforcements, ensure no new critical facilities are inadvertently created
 - If a proposed project fails CSPA DNH, technical specifications of a proposal may be modified



- RTEP 2027 summer case
- CIP-014 Contingencies: 479
- CSPA DNH study
 - No new critical facilities are inadvertently created by proposed RTEP projects



- Support Transmission Owner's M-4 projects
 - PJM Tariff Attachment M-4: approved in March 2020
 - PJM provides review, verification and consultation
- CIP-14 verification
 - Transmission Owners identify critical substations
 - PJM: third-party verification



- Improve study process
- Continue CSPA DNH study
- Support stakeholder resilience effort



SME/Presenter: Grace Niu

Grace.Niu@pjm.com

Transmission Planning Resilience Update



Member Hotline

(610) 666 - 8980

(866) 400 - 8980

custsvc@pjm.com

