



Market Efficiency Update

Transmission Expansion Advisory Committee
January 11, 2018

- Acceleration Analysis Results
- 2016/17 RTEP Window Status Update
- BGE Group Results

Acceleration Analysis

- **Scope**
 - Determine which reliability upgrades, if any, have an economic benefit if accelerated or modified.
- **Study Years**
 - 2018 and 2022 set of economic input assumptions used to study impacts of approved RTEP projects
- **Process**
 - Compare simulated market congestion for near term vs. future topology
 - Estimate economic impact of accelerating planned upgrades

- Finalized PROMOD modeling work for 2018 and 2022 AS-IS cases
- Completed PROMOD simulations
 - 2018 and 2022 study years with 2018 Topology (AS-IS Topology)
 - 2018 and 2022 study years with 2022 Topology (RTEP Topology)
- Compared the board approved reliability upgrades with the congestion reductions between the AS-IS and the RTEP Base cases.



Acceleration Analysis: 2018 Load, Generation and Economic Assumptions

Congestion Decreases Associated With Approved Reliability Projects - 2018 Study Year			2018 Study Year		
			2018 Topology	2022 Topology	Congestion Savings (\$ Millions)
Constraint Name	AREA	TYPE	Year 2018 Congestion (\$ Millions)	Year 2018 Congestion (\$ Millions)	
05TANNER345-08M.FORT345	AEP/DEOK	LINE	\$24.5	\$0.0	\$24.5
ROXBURY 138/115	PENELEC	XFMR	\$3.4	\$0.0	\$3.4
27YORKANA230-BRIS230	ME/PPL	LINE	\$4.0	\$0.0	\$4.0
CNASTONE500-PCHBTM1S500	PJM500	LINE	\$74.3	\$5.8	\$68.5
NWEST230-CONASTON230	BGE	LINE	\$8.3	\$0.0	\$8.3
SAHA34TP230-GRACETON230	PPL/BGE	LINE	\$13.0	\$0.0	\$13.0
PCHBTM 500/230	PECO	XFMR	\$11.5	\$0.0	\$11.5

Upgrade Associated with Congestion Reduction	ISD
RTEP B2831: Upgrade the Tanner Creek - Miami Fort 345 kV circuit.	2021
RTEP B2743:Build new 230 kV double circuit line between Rice and Ringgold 230 kV	2020
RTEP B2691:Reconductor three spans limiting Brunner Island - Yorkana 230 kV line	In Service
RTEP B2766: Upgrade substation equipment at Conastone & Peachbottom 500 kV	2021
RTEP B2752.7:Reconductor/Rebuild the two Conastone - Northwest 230 kV lines and upgrade terminal equipment	2020
RTEP B2690:Reconductor two spans of the Graceton - Safe Harbor 230 kV transmission line. Includes termination point upgrades	2018
RTEP B2694:Increase ratings of Peach Bottom 500/230 kV transformer	2019

Note: For a particular flowgate, the congestion savings for the 2018 study year are calculated as the difference in simulated congestion between the PROMOD case with AS-IS topology and the PROMOD case with the RTEP topology.



Acceleration Analysis: 2022 Load, Generation and Economic Assumptions

Congestion Decreases Associated With Approved Reliability Projects - 2022 Study Year			2022 Study year		
			2018 Topology	2022 Topology	Congestion Savings (\$ Millions)
Constraint Name	AREA	TYPE	Year 2022 Congestion (\$ Millions)	Year 2022 Congestion (\$ Millions)	
05TANNER345-08M.FORT345	AEP/DEOK	LINE	\$5.2	\$0.0	\$5.2
ROXBURY 138/115	PENELEC	XFMR	\$9.3	\$0.0	\$9.3
27YORKANA230-BRIS230	ME/PPL	LINE	\$7.3	\$0.0	\$7.3
CNASTONE500-PCHBTM1S500	PJM500	LINE	\$4.4	\$0.0	\$4.4
NWEST230-CONASTON230	BGE	LINE	\$2.4	\$0.0	\$2.4
SAHA34TP230-GRACETON230	PPL/BGE	LINE	\$3.4	\$0.0	\$3.4
PCHBTM 500/230	PECO	XFMR	\$60.0	\$0.0	\$60.0

Upgrade Associated with Congestion Reduction	ISD
RTEP B2831: Upgrade the Tanner Creek - Miami Fort 345 kV circuit.	2021
RTEP B2743: Build new 230 kV double circuit line between Rice and Ringgold 230 kV	2020
RTEP B2691: Reconductor three spans limiting Brunner Island - Yorkana 230 kV line	In Service
RTEP B2766: Upgrade substation equipment at Conastone & Peachbottom 500 kV	2021
RTEP B2752.7: Reconductor/Rebuild the two Conastone - Northwest 230 kV lines and upgrade terminal equipment on both ends	2020
RTEP B2690: Reconductor two spans of the Graceton - Safe Harbor 230 kV transmission line. Includes termination point upgrades	2018
RTEP B2694: Increase ratings of Peach Bottom 500/230 kV transformer	2019

Note: For a particular flowgate, the congestion savings for the 2022 study year are calculated as the difference in simulated congestion between the PROMOD case with AS-IS topology and the PROMOD case with the RTEP topology.

- RTEP B2766 was selected for acceleration from 2021 to 2020
 - Upgrade substation equipment at Conastone & Peach Bottom 500 kV
 - Estimated annual congestion savings: \$4.4 million
 - Acceleration cost: 0\$
- No other reliability upgrades were selected for acceleration*
 - did not provide significant congestion benefits in the acceleration analysis, or
 - ISD is in near future, or
 - project scope too large to accelerate



**Update will be provided if any of facilities may be accelerated.*

2016-2017 Long Term Window

- Posted Final Update Market Efficiency Base Case
 - Included Crane generator retirement along with corresponding reliability upgrade
 - Updated the load forecast to reflect the 2018 PJM Load Forecast.
 - Added constraint to balance PJM-NY PARs (matching the RTEP planning model).
 - Added BGE flowgates resulted from contingency analysis across all BGE proposals



- Analysis Status
 - RPM Projects analysis (completed)
 - Interregional Projects analysis (completed)
 - Reactive Proposals Group (completed)
 - PPL projects analysis (90% completed)
 - BGE projects (90% completed)
 - Due to lack of congestion on the project targeted constraint, none of the other proposals were considered for further analysis.

- Target determination of recommended projects: Feb 2018



BGE Group Results

- Results were presented at November 2017 TEAC*
 - More than half of the proposals did not pass the B/C ratio threshold
 - Some proposals did not fully address the congestion driver or shifted congestion downstream.
 - The highest B/C ratios were achieved by the upgrade proposals.
- <http://www.pjm.com/-/media/committees-groups/committees/teac/20171109/20171109-teac-market-efficiency-update.ashx>
- Based on results presented at November 2017 TEAC, PJM focused the analysis on the BGE upgrades 5D and 5E (see next slide)
 - Used updated base case posted on January 2018.
 - Projects modeled using the submitted assumptions
 - B/C ratios computed using the submitted in-service cost of components

Proposal	5D	5E
In-Service cost (\$M)	\$ 20.40	\$ 25.40
In-service Year	2021	2021
B/C Ratio	8.2	8.1
Fully Solves Target Congestion	Yes	Yes
Creates Other BGE Congestion	Yes (NEAST – RAPHAEL)	No
Map		

- PJM intends to recommend BGE's proposal 5E for board approval.
 - Reconductor the Conastone to Graceton 230kV lines. Upgrade substation equipment at Conastone. Add bundled conductors to the Graceton-Bagley-Raphael Road 230kV double circuit lines. Reconductor the Raphael Road to Northeast 230 kV double circuit lines. Upgrade substation equipment at Windy Edge substation.
- PJM will include BGE's proposal 5E in the base case and will determine if other proposals provide additional benefits when added incrementally to 5E.
- Other steps
 - Finalize Cost/Constructability Analysis
 - Finalize Reliability Analysis
 - Run sensitivities on gas and load forecast
- Final results to be presented at the next TEAC meeting

Appendix A

BGE Proposed Upgrades 5A – 5E

Project ID: 201617_1-5A

Proposed by: BGE

Proposed Solution:
 Reconductor the Conastone to Graceton 230 kV lines.
 Upgrade substation equipment at Conastone.

kV Level: 230 kV


In-Service Cost (\$M): \$5.97

In-Service Date: 2020

Target Zone: BGE

ME Constraints:
 CONASTONE - GRACETON 230 kV

Notes:



Project ID: 201617_1-5B

Proposed by: BGE

Proposed Solution:
Add bundled conductors to the Graceton-Bagley-Raphael Road 230 kV double circuit lines.

kV Level: 230 kV


In-Service Cost (\$M): \$14.20

In-Service Date: 2021

Target Zone: BGE

ME Constraints:
GRACETON - BAGLEY 230 kV

Notes:



Project ID: 201617_1-5C

Proposed by: BGE

Proposed Solution:
 Reconductor the Conastone to Graceton 230 kV lines.
 Upgrade substation equipment at Conastone. Add bundled conductors to the Graceton - Bagley-Raphael Road 230 kV double circuit lines.

kV Level: 230 kV


In-Service Cost (\$M): \$20.30

In-Service Date: 2021

Target Zone: BGE

ME Constraints:
 CONASTONE - GRACETON - BAGLEY 230 kV

Notes:



Project ID: 201617_1-5D

Proposed by: BGE

Proposed Solution:

Reconductor the Conastone to Graceton 230 kV lines. Upgrade substation equipment at Conastone. Add bundled conductors to the Graceton-Bagley-Raphael Road 230kV double circuit lines. Upgrade substation equipment at Windy Edge substation.

kV Level: 115/230 kV

In-Service Cost (\$M): \$20.40


In-Service Date: 2021

Target Zone: BGE

ME Constraints:

CONASTONE - GRACETON - BAGLEY 230 kV

Notes:



Project ID: 201617_1-5E

Proposed by: BGE

Proposed Solution:
 Reconductor the Conastone to Graceton 230kV lines.
 Upgrade substation equipment at Conastone. Add bundled conductors to the Graceton-Bagley-Raphael Road 230kV double circuit lines. Reconductor the Raphael Road to Northeast 230 kV double circuit lines. Upgrade substation equipment at Windy Edge substation.

kV Level: 115/230 kV


In-Service Cost (\$M): \$25.40

In-Service Date: 2021

Target Zone: BGE

ME Constraints:
 CONASTONE - GRACETON - BAGLEY 230 kV

Notes:



- Revision History
 - V1 – 1/9/2018 – Original Version Posted to PJM.com
 - V2 -1/10/2018 – Slides 6, 7: corrected B2831 in-service date from 2018 to 2021