

# Subregional RTEP Committee – Mid-Atlantic FirstEnergy (Penelec) Supplemental Projects

July 16, 2020

## Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** PN-2020-016

**Process Stage:** Needs Meeting 07/16/2020

**Project Driver:**

*Equipment Material Condition, Performance and Risk*


*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

System Performance Projects Global Factors

- System reliability and performance
- Substation/line equipment limits
- Upgrade Relay Schemes
- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

**Continued on next slide...**



**Problem Statement:**

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement part and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Need Number	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
PN-2020-016	Hooversville – Somerset HD 115 kV Line	164 / 190	202 / 245	Line Trap, Line Relaying, Substation Conductor, CTs

# Solution

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** PN-2020-010

**Process Stage:** Solution Meeting 07/16/2020

**Previously Presented:** Need Meeting 5/21/2020

**Project Driver:**

*Equipment Material Condition, Performance and Risk*

*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

System Performance Projects Global Factors


- System reliability and performance
- Substation/line equipment limits

Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

**Continued on slide 9&10...**

## Penelec Transmission Zone M-3 Process Hooversville - Tower 51 115 kV Line



**Need Number:** PN-2020-012

**Process Stage:** Solution Meeting 07/16/2020

**Previously Presented:** Need Meeting 5/21/2020

**Project Driver:**

*Equipment Material Condition, Performance and Risk*

*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

System Performance Projects Global Factors

- System reliability and performance

- Substation/line equipment limits


Upgrade Relay Schemes

- Relay schemes that have a history of misoperation
- Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
- Communication technology upgrades
- Bus protection schemes

**Continued on slide 9&10...**

# Penelec Transmission Zone M-3 Process

## Morgan Street – Franklin Tap - Air Products – Geneva 115 kV



**Need Number:** PN-2020-015, and APS-2020-008

**Process Stage:** Solution Meeting 07/16/2020

**Previously Presented:** Need Meeting 5/21/2020

**Project Driver:**

*Equipment Material Condition, Performance and Risk*


*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

System Performance Projects Global Factors

- System reliability and performance
  - Substation/line equipment limits
- Upgrade Relay Schemes
- Relay schemes that have a history of misoperation
  - Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
  - Communication technology upgrades
  - Bus protection schemes

**Continued on slide 9&10...**



**Problem Statement:**

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement part and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

Need Number	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
PN-2020-010	Hooversville – Tower 51 115 kV Line	137 / 172	178 / 214	Disconnect Switches, CTs, Substation Conductor, Line Trap, Line Relaying
PN-2020-012	Morgan Street – Franklin Tap 115 kV Line	221 / 239	232 / 282	Substation Conductor, Line Relaying, Line Trap
	Franklin Tap – Air Products 115 kV Line	202 / 245	202 / 245	N/A
	Air Products – Geneva 115 kV Line	202 / 239	202 / 245	Line Relaying
PN-2020-015 APS-2020-008	Blairsville East – Social Hall 138 kV Line	225 / 287	243 / 294	Substation Conductor, CTs, Line Relaying, Line Trap

**Proposed Solution:**

Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Estimated Cost (\$ M)	Target ISD
PN-2020-010	Hooversville–Tower 51 115 kV Line	178 / 214	<ul style="list-style-type: none"> <li>Hooversville 115 kV Substation – Replace line trap, line relaying, and substation conductor</li> <li>Tower 51 115 kV Substation – Replace line trap line relaying, substation conductor, disconnect switches, circuit breaker, and CTs</li> </ul>	\$1.1M	03/31/2022
PN-2020-012	Morgan Street–Franklin Tap 115 kV Line	232 / 282	<ul style="list-style-type: none"> <li>Morgan Street 115 kV Substation – Replace line trap, line relaying, substation conductor, breaker and bus disconnect switches, and circuit breaker</li> </ul>	\$2.5M	05/27/2022
	Franklin Tap – Air Products 115 kV Line	202 / 245	N/A		
	Air Products – Geneva 115 kV Line	202 / 245	<ul style="list-style-type: none"> <li>Geneva 115 kV Substation – Replace line trap, line relaying, breaker and bus disconnect switches, and circuit breakers</li> </ul>		
PN-2020-015 APS-2020-008	Blairsville East – Social Hall 138 kV Line	243 / 294	<ul style="list-style-type: none"> <li>Blairsville East 138 kV Substation – Replace line trap and line relaying</li> <li>Social Hall 138 kV Substation – Replace line trap, line relaying, substation conductor, circuit breaker, and CTs</li> </ul>	\$0.8M	06/01/2021

**Alternatives Considered:** Maintain existing condition

**Project Status:** Conceptual

**Model:** 2020 RTEP model for 2025 Summer (50/50)

# Questions?



# Appendix

# High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

7/6/2020 – V1 – Original version posted to pjm.com