

<b>Effective Date</b>	5/28/2020
<b>Impacted Manual #(s)/Manual Title(s):</b> Manual 01, Control Center and Data Exchange Requirements	
<b>Conforming Order(s):</b> N/A	
<b>Associated Issue Tracking Title:</b> N/A	
<b>Committee Approval Path - What committee(s) have already seen these changes?</b>	
<b>First Read</b> <ul style="list-style-type: none"> <li>4/13 – SOS</li> <li>4/16 – OC</li> <li>4/17 – RSCS (informational)</li> </ul> <b>Second Read/Endorsement</b> <ul style="list-style-type: none"> <li>5/18 – SOS</li> <li>5/14 – OC</li> <li>5/15 – RSCS/TTMS (informational)</li> </ul>	
<b>MRC 1<sup>st</sup> read date:</b>	4/30/2020
<b>MRC voting date:</b>	5/28/2020
<b>Impacted Manual sections:</b>	
Attachment A: Data Specification and Collection Attachment B: Schedule of Data Submittals	
<b>Reason for change:</b>	
<ul style="list-style-type: none"> <li>Cover to Cover Periodic Review</li> </ul>	
<b>Summary of the changes:</b>	
<ul style="list-style-type: none"> <li>Cover to Cover Periodic Review.</li> <li>Attachment A: Added external entities PJM shares network model information with.</li> <li>Attachment A: To comply with TOP-003, added a new column in the data specification tables that reflects the periodicity of providing the mentioned data where applicable.</li> <li>Attachment A: Removed Row B.5 Black Start Test Data from Table B since this is not an EMS service.</li> <li>Attachment A: Removed Row B.16 AVR/PSS Excitation control since this is not an output from PJM.</li> <li>Attachment A: Changed Row B.3.5 Frequency input from 'Required' to 'Optional' for PJM Member Generating Entities.</li> <li>Attachment A: Changed Row B.3.6 Status of BES Circuit Breakers from 'Required' to 'Mandatory if not Attainable by Existing Telemetry' for PJM Member Generating Entities.</li> <li>Attachment B: Removed references to EOP-005-3 R3 and R4, as these are already covered by Manual 36 Attachment G.</li> </ul>	