## **System Operations Subcommittee**

# **PJM Operations Summary**

## **December 2021 Operations**

## **December Events:**

- 1 Synchronized Reserve Events
- 2 Shared Reserve Events
- 3 PCLLRW Events
- 2 Non-Market PCLLRW Events
- 2 High System Voltage Events

CPS1: 142.89% CPS2: 88.37% BAAL: 99.87%

<sup>1</sup>PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month with a target value for this performance goal at 99% on a daily and monthly basis. NERC rules limit the recovery period to no more than 30 minutes for a single event.

**Synchronized Reserve (1 Event)** 

Effective Start Time	Effective End Time	Message	Region
12.08.2021	12.08.2021	100% Synchronized Reserve Event has been initiated for the	PJM-RTO
09:04	09:11	PJM RTO region.	

**Shared Reserve (2 Event)** 

Effective	Effective		
Start Time	End Time	Message	Region
12.23.2021	12.23.2021	PJM provided 83 MW of NPCC Shared Reserves	NPCC
09:01	12:13		
12.17.2021	12.17.2021	PJM provided 198 MW of NPCC Shared Reserves	NPCC
16:32	17:05		

PCLLRW (3 Events)

Effective	Effective		
Start Time	End Time	Message	Region
12.13.2021	12.13.2021	A Post Contingency Local Load Relief Warning has been issued to	FE-ATSI
09:38	09:56	maintain MILLIRON 138 KV *E02 at 127.0 KV in the FE(ATSI) for	
		Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	
12.09.2021	12.09.2021	A Post Contingency Local Load Relief Warning has been issued to	DOM
07:15	08:16	maintain JARRATT 115 KV G at 105.0 KV in the DOM for	
		Transmission Contingency Control.	
		Additional Comments: Post Contingency Switching available	
12.02.2021	12.05.2021	A Post Contingency Local Load Relief Warning has been issued to	FE-AP
15:28	13:20	maintain WILLAMET 138 KV *E01 at 127.0 KV in the FE(APS) for	
		Transmission Contingency Control.	
		Additional Comments: Load -No Generation or Switching	
		available	

#### **System Operations Subcommittee**

#### **PJM Operations Summary**

## **December 2021 Operations**

Non – Market PCLLRW (2 Events)

Effective	Effective		
Start Time	End Time	Message	Region
12.20.2021	12.21.2021	A Non-Market Post Contingency Local Load Relief Warn has been	AEP
06:15	18:43	issued to maintain HIGHLND2-MARTIDPL HIG-09M1 at 68.0 MVA	DAY
		in the AEP for Transmission Contingency Control.	
		Additional Comments: Load -No Generation or Switching	
		available	
12.17.2021	12.17.2021	A Non-Market Post Contingency Local Load Relief Warn has been	AEP
07:35	18:09	issued to maintain HIGHLND2-MARTIDPL HIG-09M1 at 68.0 MVA	DAY
		in the AEP for Transmission Contingency Control.	
		Additional Comments: Load -No Generation or Switching	
		available	

**High System Voltage (2 Events)** 

Effective	Effective		
Start Time	<b>End Time</b>	Message	Region
12.26.2021 00:15	12.26.2021 00:20	8 -,	WESTERN
12.26.2021 00:15	12.26.2021 09:31	A High System Voltage Action has been issued for the Western region of the PJM RTO.	WESTERN

# Voltage Reduction Warning (0 Event(s))

**Voltage Reduction (0 Event(s))** 

Manual Load Dump Event (0 Event(s))

Manual Load Dump Warning (0 Event(s))

Max Emergency Gen Alert (0 Event(s))

Max Emergency Generation (0 Event(s))

Min Gen Alert (0 Event(s))

Min Gen Declaration (0 Event(s))

**Local Min Generation Event (0 Event(s))** 

**Hot Weather Alert (0 Event(s))** 

Cold Weather Alert (0 Event(s))

**HLV Schedule Warning (0 Event(s))** 

**HLV Schedule Action (0 Event(s))** 

**Primary Reserve Warning (0 Event(s))** 

Manual Load Dump Warning (0 Event(s))

**Emergency Energy Request (0 Event(s))**