

Effective Date	October 1, 2022
Impacted Manual #(s)/Manual Title(s):	
M-14-D: Generator Operational Requirements, Revision 61	
Conforming Order(s):	
None	
Associated Issue Tracking Title:	N/A
Committee Approval Path - What committee(s) have already seen these changes?	
Planned committee reviews/endorsements: SOS: August 3, 2022, September 1, 2022 RSCS: August 19, 2022 OC: August 11, 2022, September 8, 2022 (Endorsement) MRC: August 24, 2022, September 21, 2022 (Endorsement)	
MRC 1st read date:	August 24, 2022
MRC voting date:	September 21, 2022
Impacted Manual sections:	
See detailed list below	
Reason for change:	
<p>Section 7.3.5: Fuel, Emissions and Operational Data Reporting</p> <ul style="list-style-type: none"> • Seasonal Fuel and Emissions Reporting <ul style="list-style-type: none"> ○ Added Generating Facility minimum design temperature annual verification • Real Time Reporting <ul style="list-style-type: none"> ○ Added reference to new Emergency Procedure: “Cold Weather Advisory” ○ Added requirement for Generation Owners to enter/review/update Generating Facility cold weather operating limit temperature in Markets Gateway <p>Attachment N: Cold Weather Preparation Guideline and Checklist</p> <ul style="list-style-type: none"> • Added recommendation to take into account the effects of precipitation and wind during cold weather preparation. 	