## System Operations Subcommittee

## **PJM Operations Summary**

### April 2023 Operations

#### April Events: 11 PCLLRW Events 2 Non-Market PCLLRW Events 1 Geomagnetic Disturbance Warning 4 High System Voltage

### CPS1: 129.71% CPS2: 83.66% BAAL: 99.82%

<sup>1</sup>PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month with a target value for this performance goal at 99% on a daily and monthly basis. NERC rules limit the recovery period to no more than 30 minutes for a single event.

Effective	Effective			
Start Time	End Time	Message	Region	
04.24.2023	04.24.2023	A Post Contingency Local Load Relief Warning has been issued		
07:50	14:41	to maintain DURBIN 138 KV 138-1 at 127.0 KV in the FE(APS) for		
		Transmission Contingency Control. Additional Comments: Load -		
		No Generation or Switching available		
04.22.2023	04.22.2023	A Post Contingency Local Load Relief Warning has been issued	een issued DOM	
15:09 16:17		to maintain PLEASNTV TX3 XFORMER at 681.0 MVA in the DOM		
		for Transmission Contingency Control. Additional Comments:		
		Post Contingency Switching available		
04.21.2023	04.21.2023	A Post Contingency Local Load Relief Warning has been issued	DOM	
14:34	19:53	to maintain BRAMBLET-EVRGREEN 2172B at 1059.0 MVA in the		
		DOM for Transmission Contingency Control. Additional		
		Comments: Load -No Generation or Switching available	DOM	
04.21.2023	04.21.2023	A Post Contingency Local Load Relief Warning has been issued		
12:34	18:33	to maintain IDYLWOO4-CLARK4 202A at 560.0 MVA in the DOM		
		for Transmission Contingency Control. Additional Comments:		
		Load -No Generation or Switching available		
04.20.2023	04.20.2023	A Post Contingency Local Load Relief Warning has been issued	ued DOM	
18:15	21:24	to maintain IDYLWOO4-CLARK4 202A at 533.0 MVA in the DOM		
		for Transmission Contingency Control. Additional Comments:		
		Load -No Generation or Switching available		
04.20.2023	04.20.2023	A Post Contingency Local Load Relief Warning has been issued	DOM	
16:43	21:24	to maintain BRAMBLET-EVRGREEN 2172B at 1059.0 MVA in the		
		DOM for Transmission Contingency Control. Additional		
		Comments: Load -No Generation or Switching available		
04.13.2023	04.13.2023	A Post Contingency Local Load Relief Warning has been issued	DOM	
17:38	20:34	to maintain BULLRUN TX3 XFORMER at 195.0 MVA in the DOM for		
		Transmission Contingency Control. Additional Comments: Load -		
		No Generation or Switching available		
04.13.2023	04.13.2023	A Post Contingency Local Load Relief Warning has been issued	DOM	
17:10	17:38	to maintain BULLRUN TX3 XFORMER at 195.0 MVA in the DOM for		
		Transmission Contingency Control. Additional Comments: Load -		
		No Generation or Switching available		
04.12.2023	04.12.2023	A Post Contingency Local Load Relief Warning has been issued	EKPC	
11:58	15:02	to maintain ROWAN_CO 138 KV ND_151 at 127.7 KV in the EKPC		

# System Operations Subcommittee

# **PJM Operations Summary**

# April 2023 Operations

		for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	
04.10.2023 21:27	04.14.2023 22:33	A Post Contingency Local Load Relief Warning has been issued to maintain MIER 138 KV BB_17947 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP
04.05.2023 06:17	04.05.2023 12:18	A Post Contingency Local Load Relief Warning has been issued to maintain NWASHNTN 69 KV *H02 at 63.5 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP

## Non-Market PCLLRW (2 Events)

Effective	Effective		
Start Time	End Time	Message	Region
04.14.2023 16:23	04.14.2023 22:36	A Non-Market Post Contingency Local Load Relief Warn has been issued to maintain SMAWA-UPPERSAD at 133.0 MVA in the RECO for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	RECO
04.04.2023 18:55	04.10.2023 12:27	A Non-Market Post Contingency Local Load Relief Warn has been issued to maintain EXPRESSW-PERKINST EXP-PERT at 78.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP

## Geomagnetic Disturbance (1 Event)

Effective Start Time	Effective End Time	Message	Region
04.23.2023 15:29	04.24.2023 08:00	A Geomagnetic Disturbance Warning has been issued for 15:29 on 04.23.2023 through 08:00 on 04.24.2023. A GMD warning of K7 or greater is in effect for this period.	PJM-RTO

### High System Voltage (4 Event)

Effective	Effective		
Start Time	End Time	Message	Region
04.29.2023	04.30.2023	A High System Voltage Action has been issued	PJM-RTO
23:30	10:00		
04.29.2023	04.29.2023	A High System Voltage Action has been issued	PJM-RTO
03:03	08:05		
04.22.2023	04.23.2023	A High System Voltage Action has been issued	PJM-RTO
22:55	13:20		
04.22.2023	04.22.2023	A High System Voltage Action has been issued	PJM-RTO
00:40	08:00		

Voltage Reduction Warning (0 Event(s)) Voltage Reduction (0 Event(s)) Manual Load Dump Event (0 Event(s)) Manual Load Dump Warning (0 Event(s))

## System Operations Subcommittee

### PJM Operations Summary

## April 2023 Operations

Max Emergency Gen Alert (0 Event(s))Max Emergency Generation (0 Event(s))Min Gen Alert (0 Event(s))Min Gen Declaration (0 Event(s))Non-Market PCLLRW (0 Event(s))Local Min Generation Event (0 Event(s))Hot Weather Alert (0 Event(s))HLV Schedule Warning (0 Event(s))HLV Schedule Action (0 Event(s))Primary Reserve Warning (0 Event(s))Manual Load Dump Warning (0 Event(s))Emergency Energy Request (0 Event(s))