

Old Dominion Electric Cooperative (ODEC) and American Municipal Power, Inc. ("AMP") Initial General Comments/Questions on Supplemental Projects Presented During the January 7, TEAC

Stakeholders need background and supporting documentation from each Transmission Owner for their Supplemental Projects. This would include, but not limited to:

1. Underlying need for this project: aging infrastructure, operational needs, reliability, etc. Transmission Owners need to provide information to explain the bigger picture on the Supplemental Project and the basis for its need.
2. Alternatives reviewed by the Transmission Owner and reasons and justifications for why they choose this particular solution
3. Criteria, guidelines or models used in the Transmission Owners' analysis
4. Justification for in-service dates as these dates impact others' abilities to schedule outages with PJM
5. Better maps, including at a minimum, one high level map and more detailed maps that show both existing and proposed facilities for the Supplemental Project
6. Details on the status of the project: planning stage, right of way acquisition phase, design phase, ordering equipment stage, construction, etc.