

A large, light gray, stylized sun graphic is positioned on the left side of the slide. It features a central white circle with rays extending outwards, forming a semi-circle at the top and a larger, more complex shape at the bottom. The rays are represented by various geometric shapes like triangles and trapezoids.

MISO Regional Issues Review

MISO-PJM IPSAC

A large, light gray, stylized sunburst or fan-like graphic is positioned on the left side of the slide. It consists of numerous triangular segments radiating from a central point, creating a semi-circular shape. The segments are separated by thin white gaps. The graphic is partially obscured by the text.

MTEP Reliability Projects

MTEP15 Report

- MTEP15 Finalized in December 2015
- Full Report and Appendices [Posted](#)
 - Includes reliability and economic studies

MTEP16 Active Projects – Reliability

- 328 Projects Targeted for Appendix A
- 137 Projects Targeted for Appendix B
- [Complete MTEP16 Active Project List](#)
- Additional Project Information in December Subregional Planning Meetings
 - [East](#)
 - [Central](#)
 - [South](#)
 - [West](#)



Market Congestion Planning Study


Market Congestion Planning Study (MCPS)

- MTEP16 MCPS Need Identification
 - North/Central Region
 - South Region
- Latest Info from 1/21/16 Economic Planning Users Group (EPUG)
 - [Meeting Material](#)

A large, light gray graphic on the left side of the page, resembling a stylized sunburst or a fan. It consists of numerous triangular segments radiating from a central point, with some segments being longer than others, creating a sense of depth and movement. The graphic is partially cut off by the left edge of the page.

North/Central MCPS


MCPS North Central Congested Flowgates



MCPS North/Central Congested Flowgates

- **North/Central Congested Flowgates Selected for MTEP16 MCPS Study:**
 - E: Huntley – Blue Earth 161kV
 - M: Wapello 161/69kV XFMR
 - O: Nason Point – Ina 138kV
 - P: Lake George – Aetna 138kV
 - Q: New Carlisle – Bosserman 138kV
 - R: Goodland – Remington 69kV
 - T: Roxana – Praxair 138kV
 - X: Quad Cities – Rock Creek 345kV

West (MN/IA) Congested Flowgates



West (MN/IA) Congested Flowgates: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MW-year)				
				BAU	HD	LD	RCP	SRCP
E	Huntley – Blue Earth 161kV	Wilmarth – Fieldon 345kV	ALTW – NSP	225.2	576.3	64.4	1,173.2	2,318.2
M	Wapello 161/69kV XFMR	Wapello 161/69kV XFMR	ALTW - ALTW	185.0	284.4	1.2	40.3	31.3
X	Quad Cities – Rock Creek 345kV* ^Δ	Quad Cities – Sub 91 345kV	COMED - ALTW	100.12	90.45	42.34	7.75	4.62
		No Outage						

*Binding under multiple contingencies


^Δ New top flowgate since 12112015 EPUG meeting

Southern Illinois Congestion: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MW-year)				
				BAU	HD	LD	RCP	SRCP
O	Nason Point – Ina 138kV	East West Frankfort – West Mt Vernon 345kV	AMIL - AMIL	726.8	534.3	552.6	775.0	1,237.1

- **90% of the congestion on Nason Point – Ina 138kV can be relieved by a ~\$50k terminal equipment upgrade that increases ratings from 143/143 MVA to 159/204 MVA**
- **Solution ideas that seek to address this flowgate will be studied with this upgrade in their base case**

Northern Indiana Congested Flowgates



Northern Indiana Congested Flowgates: PROMOD Annual Shadow Price in 2030


ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MW-year)				
				BAU	HD	LD	RCP	SRCP
P	Lake George – Aetna 138kV	Lake George – Miller 138kV	NIPS - NIPS	391.8	479.1	196.7	348.6	64.8
Q	New Carlisle – Bosserman 138kV	Olive – Bosserman 138kV	AEP - AEP	165.6	578.4	91.1	481.5	1,155.6
R	Goodland – Remington 69kV	Goodland – Reynolds 138kV	NIPS - NIPS	69.7	117.2	44.5	146.7	148.5
T	Roxana – Praxair 138kV ^Δ	Dumont – Wilton 765kV	NIPS - NIPS	50.3	8.5	70.0	43.1	133.5

Δ New top flowgate since 12112015 EPUG meeting



South MCPS

MTEP16 MCPS South Congested Flowgates




MCPS South Congested Flowgates

- **South Congested Flowgates Selected for MTEP16 MCPS Study:**

- A: Esso – Delmont 230kV
- B: Panama – Wilton 230kV
- C: Waterford – Little Gypsy 230kV
- D: Snakefarm – Labarre 230kV
- E: Scott – Judice 138kV
- F: Coughlin – Plaisance 138kV
- G: Bayou Cove – Hebert 138kV
- H: Mossville – Marshall 138kV
- I: Layfield – Hartburg 500kV
- J: Sam Rayburn – Fork Creek 138kV
- K: Sarepta – Minden 115kV
- L: Swartz – Alto 115kV
- M: Carson Rd – Delhi 115kV
- O: Plantation – S. Ferriday Tap 115kV
- P: Red Gum – Natchez 115kV
- Q: Lakeover 500/115kV XFMR T1
- R: Attala – Conehoma 115kV
- S: S. Grenada – Elliott 115kV
- T: Wyatt – Parnell Rd 115kV
- U: Morrilton East – Gleason 161kV
- V: Trumann West – Trumann 161kV

Amite South/DSG Congested Flowgates




Amite South/DSG Congested Flowgates: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MWh)				
				BAU	HD	LD	RCP	SRCP
A	Esso – Delmont 230kV*	Big Cajun – Webre 500kV	EES-LA	74.2	402.3	34.2	32.6	34.9
		Exxon – Downtown 230kV						
		Willow Glen – Coly 500kV						
		Willow Glen – Pecue 230kV						
B	Panama – Wilton 230kV	Willow Glen – Waterford 500kV + Waterford:3	EES-LA	136.1	29.5	193.8	36.0	32.0
C	Waterford – Little Gypsy 230kV*	Waterford – Little Gypsy 230kV + Little Gypsy:2/3	EES-LA	64.6	330.2	173.0	255.2	279.8
		Waterford – Little Gypsy 230kV + Nine Mile:4/5/6						
D	Snakefarm – Labarre 230kV	Little Gypsy – Wesco 230kV + Nine Mile:4/5/6	EES-LA	34.1	105.0	17.9	171.3	275.5

*Binding for multiple contingencies

WOTAB/Western Congested Flowgates




WOTAB/Western Congested Flowgates: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MWh)				
				BAU	HD	LD	RCP	SRCP P
E	Scott – Judice 138kV	Meaux – Sellers Rd 230kV	EES-LA – LAGN	190.0	163.2	16.8	46.0	46.4
F	Coughlin – Plaisance 138kV	Cocodrie – Ville Platte 230kV	CLEC	15.3	35.5	24.9	157.3	180.4
G	Bayou Cove – Hebert 138kV	Nelson – Richard 500kV + Nelson:4/6	LAGN – EES-LA	17.4	59.2	41.4	46.6	49.4
H	Mossville – Marshall 138kV*	Hartburg – Cypress 500kV + Sabine:4	EES-LA	14.8	188.8	35.4	49.9	28.1
		Hartburg – Cypress 500kV + SRW Cogen						
		Hartburg – Sulphur Lane 500kV						
		Hollywood – Nelson 138kV + SRW Cogen						
I	Layfield – Hartburg 500kV*	Nelson – Richard 500kV + Nelson:4/6	EES-LA – EES-TX	32.2	51.4	63.1	88.6	78.2
		Webre – Wells 500kV + Nelson:4/6						
J	Sam Rayburn – Fork Creek 138kV*	Hartburg – Cypress 500kV + Frontier	EES-TX	72.9	56.7	54.5	103.6	141.5
		Hartburg – Cypress 500kV + Lewis Creek:1/2						
		Hartburg – Cypress 500kV + Sabine:3/4/5						
		Hartburg – Cypress 500kV + SRW Cogen						
		Hartburg – Layfield 500kV + SRW Cogen						
		Urland – Woodville 138kV + Lewis Creek:2						

*Binding for multiple contingencies

Remainder of LRZ9 Congested Flowgates




Remainder of LRZ9 Congested Flowgates: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MWh)				
				BAU	HD	LD	RCP	SRCP
K	Sarepta – Minden 115kV*	Dolet Hills 345/230kV XFMR	EES-LA	230.4	708.0	179.6	532.6	865.8
		El Dorado – Mt. Olive 500kV						
L	Swartz – Alto 115kV	Baxter Wilson – Perryville 500kV	EES-LA	113.5	128.0	50.8	159.9	138.7
M	Carson Rd – Delhi 115kV	Baxter Wilson – Perryville 500kV	EES-LA	61.5	86.6	43.9	255.1	312.1
O	Plantation – S. Ferriday Tap 115kV	Plantation – Vidalia 115kV	EES-LA	208.7	269.3	158.2	180.3	218.1
P	Red Gum – Natchez 115kV	Plantation – Vidalia 115kV	EES-LA – EES- MS	31.1	28.8	23.7	35.0	51.9

*Binding for multiple contingencies


LRZ10 Congested Flowgates



LRZ10 Congested Flowgates: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MWh)				
				BAU	HD	LD	RCP	SRCP
Q	Lakeover 500/115kV XFMR T1	Ray Braswell – Lakeover 500kV	EES-MS	96.2	93.7	65.5	71.5	65.5
R	Attala – Conehoma 115kV	Lakeover – McAdams 500kV	EES-MS	60.0	58.6	22.7	84.9	85.6
S	S. Grenada – Elliott 115kV	McAdams – Wolf Creek 500kV	EES-MS	196.6	256.1	107.2	155.9	129.8


LRZ8 Congested Flowgates



LRZ8 Congested Flowgates: PROMOD Annual Shadow Price in 2030

ID	Monitored Element	Contingency Element(s)	Area (From - To)	2030 Total Annual Shadow Price (k\$/MWh)				
				BAU	HD	LD	RCP	SRCP
T	Wyatt – Parnell Rd 115kV	Mt. Olive – El Dorado 500kV	EES-ARK	50.4	63.5	7.7	169.1	152.5
U	Morrilton East – Gleason 161kV	Pleasant Hill – Mayflower 500kV	EES-ARK	45.0	132.9	12.1	1,125	1,840
V	Trumann West – Trumann 161kV*	Dell – Sans Souci 500kV Sans Souci – Driver 500kV	EES-ARK	1,393	1,695	1,242	2,861	2,993

*Binding for multiple contingencies



Generation Interconnection

MISO Generation Study Impacts on PJM

- MISO and PJM Coordinate Generation Interconnection Queues
- Each RTO Tests the Impact of New Generation on the Other's Area
- Latest Information: <http://www.miso-pjm.com/coordinated-queue-studies.aspx>