

MISO Response to Interconnection Projects Data Request from May 10, 2013 JCM Meeting

Data Request: A stakeholder requested information relating to currently installed wind generation in MISO footprint. How many of the 12000 MWs of wind interconnection projects were coordinated with PJM and of those how many of them required upgrades in PJM. MISO indicated they would review and provide information.

MISO Response: Following table shows amount of wind generation in MISO which was coordinated with PJM.

Coordination Status of Inservice Wind	Total MW output
Coordinated	2853.15
Not Affecting PJM	7098.4
MEC Wind processed before their integration into MISO Market	2000
Total	11951.55

For a number of coordinated projects, if there were constraints on the PJM side they were mitigated after modeling the MISO's Multi Value Projects and approved PJM Byron Wayne 345kV line. An example of this can be found in the publicly posted report available at the below link.

https://www.midwestiso.org/_layouts/MISO/ECM/Redirect.aspx?ID=149852