



DR Regulation Certification Process Modifications

Background:

- Injections are not allowed to be DR.

Regulation Description:

- CSP must provide PJM a description/document explaining exactly how the location(s) in the registration will regulate.
- If location(s) have potential to inject, CSP must include written description of how it will prevent injections.

For Munis/Co-ops:

If location(s) in Muni/Co-op have potential to inject at point of interconnection with transmission owner (TO):

- CSP must provide PJM with verification they have informed the TO of the project.
- CSP must verify all interconnection points with EDC/TO so that net load can be properly metered to ensure no injections occur.