



# CP non-Summer Compliance Reduction Calculation in eLRS

Jack O'Neill  
11/11/2016  
DRS Meeting

- LM CP non-summer compliance reduction calculations are based on CBL rather than PLC
  - FSL example: Hourly Reduction = (**CBL**-Metered Load) \* Loss Factor
- PJM will use a stand-alone CBL calculator to compute CBL
  - Use default CBL: 3 Day Types with SAA
    - A request for alternate CBL will require creation of an economic registration
- CSP will submit data sufficient to calculate the CBL
  - Generally, hourly load data for the event day and prior 10 days

Change from previous process plan that would have required Economic registrations

- CP compliance data submission in non-summer period:
  - CSP uploads hourly load data into eLRS
    - Event day plus 10 prior days
  - PJM will look for prior event days in advance of running the CBL calculator so that they can be excluded from CBL calculation
  - PJM runs CBL calculator which will calculate the CBL for the Event hours
  - PJM will use the result in the capacity compliance reduction calculations
- PJM will provide CBL values to CSPs for reference

**CSP submits data for event day and 10 prior days**