PJM Manual M10 – Pre-Scheduling Operations Draft Revisions Summary

August / September 2015

PJM Committees

PJM©2015

Summary of M10 Rev. 32 Draft Revisions

Section 2.2.2 – (Planned Outages) Rules and Regulations

Added NOTE 1 referencing the requirement for a PJM Member to provide an estimated "early return time" for informational purposes for Planned Outages. (EL15-29-000 filing associated with CP)

- eDART will be changed to include this functionality in the future.
- The information will be required when a Forecasted Planned outage is submitted.
- This early return time is intended to be informational and will not affect the Planned Outage estimated end date.
- PJM may request an update to this time during potential PJM Emergency conditions.
- PJM may request this information for current Planned and Forecasted Planned outages if required.

PJM©2015

Summary of M10 Rev. 32 Draft Revisions

Section 2.2.2 – (Planned Outages) Rules and Regulations

Added NOTE 2 - If PJM withholds or withdraws its approval of a Generator Planned Outage, PJM will coordinate any delays or withdraws of approval of a Generator Planned Outage and will also coordinate rescheduling the outage. (EL15-29-000 filing associated with CP)

PJM©2015

Summary of M10 Rev. 32 Draft Revisions

Section 2.3.2 – (Maintenance Outages) Rules and Regulations

Added NOTE 1 referencing the authority of PJM to withhold or withdraw approval, or rescind approval of an already underway Generator Maintenance Outage of a Generation Capacity Resource with at least 72 hours advance notice only as necessary to ensure the adequacy of reserves or the reliability of the PJM Region (EL15-29-000 filing associated with CP)

- If the generator is not available for normal operation by 72 hours after the notice of the recall of the Maintenance Outage, the remaining time the resource continues on the outage will be classified as a Generator Forced Outage.
- eDART will be changed to include this functionality in the future

PJM©2015

Summary of M10 Rev. 32 Draft Revisions

Section 2.3.2 – (Maintenance Outages) Rules and Regulations

Added NOTE 2 referencing the requirement for Maintenance Outages to be submitted no later than three days prior to the operating day in which the Maintenance Outage is scheduled to begin. If submitted with less than three days' notice the outage will initially be designated as "Pending Evaluation", instead of automatic approval.

Exhibit 1: Pre-Scheduling, Scheduling, and Dispatching Timeline

Removed reference to Planned Outage tickets at D-3 (3 days before outage)

Business rule clarification presented at the 4/7/15 OC meeting - Not related to the EL-29-000 filing associated with CP.

PJM©2015

Next Steps – M10 Rev. 32 Draft Revisions

- SOS – First read took place 7/29, Second read 8/26
- OC – Discussion 7/7, First read 8/11, Endorsement 9/8
- MRC – First read 8/27, Endorsement 10/1
- Manual M10, Revision 32 Effective Date – 10/2/2015

PJM©2015