

M-03 Revision for Ratings Methodology

Phil D'Antonio
June 9, 2015

- PJM requires a separation between Emergency and Load Dump ratings in order to enhance PJM Operator awareness. In the event where the TO calculated Load Dump and Emergency Ratings are the same, the Emergency Rating submitted by Transmission Owners (TOs) shall be, at a minimum, 3% lower than the submitted LD rating. If this change results in a normal rating that is higher than the LTE rating the TO shall, at a minimum, make the normal rating equal to the LTE rating.

Questions?