



Effective Date	06/01/2016
Impacted Manual #(s)/Manual Title(s):	
Manual 13: Emergency Operations	
Conforming Order(s):	
Associated Issue Tracking Title:	
Committee Approval Path - What committee(s) have already seen these changes?	
MRC 1 st read date:	04/28/2016
MRC voting date:	05/26/2016
Impacted Manual sections:	
2.3.1 2.3.2 and 5.2 3.3 and 3.4 3.7 5.4 5.4.1 5.7 Appendix G	
Reason for change:	
Periodic Review Replace references to Load Serving Entity (LSE) with Distribution Provider (DP) due to NERC retirement of LSE term. Added new Step 7 to sections 2.3.2 and 5.2	
Summary of the changes:	

- Periodic Review
- Removed various references to Load Serving Entity (LSE) due to NERC retirement of the term and replaced them with Distribution Provider (DP) references.
- Section 2.3.1
 - Update RECO voltage reduction capabilities
- Section 2.3.2 & Section 5.2
 - Added note to issue an EEA1 per EOP-002-2 if non-firm sales are curtailed due to emergency capacity conditions.
 - Added the term “Action” to Step 4A for consistency
 - Correctly referenced non-critical, not non-essential, station light and power.
 - Added a new Step 7: Deploy All Resources Action and renumbered subsequent “Steps”
- Section 3.3 Cold Weather Alert & Section 3.4 Hot Weather Alert
 - Added bullet to tie back to M-10 regarding updates to the ‘early return time’ for Planned generator outages.
- Section 3.7 GMD Operating Plan
 - Noted that TO GMD plans should be submitted via the process indicated in M-1 Attachment B
- Section 5.4
 - Updated “NOTE” to point to Section 5.7 for the Load Shed Directive process/
- Section 5.4.1
 - Added a NOTE to clarify priority for controlling the contingency overload and then running the Post Contingency Exceedance Analysis if needed.
 - Removed superfluous reference to M-03
- Section 5.7: Load Shed Procedure
 - This is a new section of the manual that was previously contained within M-03. The language was shorted for ease of use.
- Attachment G Capacity Emergency Matrix
- Deleting this attachment. All information is already contained within Section 2.3.2.