



Effective Date	April 1, 2017
Impacted Manual #(s)/Manual Title(s):	
PJM Manual 37: Reliability Coordination	
Conforming Order(s):	
N/A	
Associated Issue Tracking Title:	N/A
Committee Approval Path - What committee(s) have already seen these changes?	
<p>First read:</p> <ul style="list-style-type: none"> SOS: February 2, 2017 OC: February 6, 2017 <p>Endorsement:</p> <ul style="list-style-type: none"> SOS: March 2, 2017 OC: March 7, 2017 	
MRC 1st read date:	February 23, 2017
MRC voting date:	March 23, 2017
Impacted Manual sections:	
Sections 2.2, 2.3, 2.4.2, 3.1, 4.1, 5.1, and Attachment A: PJM Reliability Plan	
Reason for change:	
Annual Review and NERC Compliance related updates.	
Summary of the changes:	
<ul style="list-style-type: none"> Section 2.2, updated Data Requirements section noting that PJM's data specifications for external Reliability Coordinators can be found in M-01, Attachment A and existing JOAs. Section 2.4.2, added clarification to the Change Management Process indicating authority of the PJM Shift Supervisor for Planned maintenance involving PJM telecommunication, monitoring and analysis tools. Updated NERC Standard/Requirement references in Sections 2.3, 4.1, 5.1 and within 	

Attachment A: PJM Reliability Plan.

- Section 3.1, spelled out MMWG and OATF acronyms.
- Section 5.1, corrected MISO's name.
- Attachment A, PJM Reliability Plan:
 - Deleted reference to ITC Integration.
 - Added Attachment D.
 - Section A: changes reference for PJM Directives to PJM Operating Instructions.
 - Section C: noted that PJM Day-Ahead Reliability Analysis reports are posted to the secure PJM site.
 - Section D: updated timing of SDX download to every 15 minutes.
 - Section E:
 - Updated to note PJM controls to the BAAL Standard (removed field trial reference)
 - Updated SPS reference to RAS
 - Added clarification to the automated eDART process for unplanned transmission outages
 - Section H: updates ISN reference to EIDSN
 - Section I: added to PJM System Operators tools list to include DIMA and IEP
 - Section J: updated PJM control room staffing requirements
- Cover to Cover Periodic Review