

<b>Effective Date</b>	4/1/2017
<b>Impacted Manual #(s)/Manual Title(s):</b>	
Manual 13: Emergency Operations	
<b>Conforming Order(s):</b>	
<b>Associated Issue Tracking Title:</b>	
<b>Committee Approval Path - What committee(s) have already seen these changes?</b>	
SOS and OC	
<b>MRC 1<sup>st</sup> read date:</b>	2/23/17
<b>MRC voting date:</b>	3/23/17
<b>Impacted Manual sections:</b>	
<ul style="list-style-type: none"> <li>• Introduction:</li> <li>• Sections 2 and 5</li> <li>• Section 7</li> <li>• Attachment K</li> </ul>	
<b>Reason for change:</b>	
EOP-011(new standard)	
<b>Summary of the changes:</b>	
<ul style="list-style-type: none"> <li>• Introduction: specified that M-13 is the PJM Emergency Operating Plan as required by EOP-011</li> <li>• Updates to Section 2 and 5 for EOP-011 compliance <ul style="list-style-type: none"> <li>◦ EEA3 to be issued for Manual Load Dump Warning and Voltage Reduction Action per revised thresholds</li> </ul> </li> <li>• Creation of Section 7 TOP Operating Plan Submission and Review for EOP-011 compliance</li> <li>• Modified all references to manual load shedding throughout the manual to clarify this</li> </ul>	

should be implemented while minimizing overlap with automatic load shedding (EOP-011 update)

- Updated EOP-002 references to EOP-011
- Deleted Appendices 4 and 5 from Attachment K. Updated link to the NERC Event Analysis documentation.
- Updated all Load Dump references to Load Shed