

## **PJM PSEUDO-TIE M2M QUALIFICATION PRELIMINARY RESULTS**

The following document pertains solely to the PJM Pseudo-Tie Market-to-Market (M2M) Qualification Test and contains preliminary results as of January 15<sup>th</sup>, 2021. Results identify physical external resources that pass the preliminary M2M Qualification Test and do not represent a list of resources that qualify as a PJM Pseudo-Tie resource. Additional criteria and information pertaining to Pseudo-Tie resources can be found on the [PJM Dynamic Transfers](#) web page.

### **Pseudo-Tie Qualification M2M Test High Level Description**

- Step 1: PJM performs Congestion Management Process (CMP) defined Coordination Tests on all eligible flowgates due to the addition of a requested Pseudo-Tie in the PJM footprint. This includes all existing and potential flowgates defined in the Book of Flowgates (BOF) as well as all flowgates for surrounding Balancing Authorities.
- Step 2: Once the full list of eligible flowgates is defined, PJM evaluates each flowgate to determine if PJM has at least one internal dispatchable resource with at least a 1.5% impact on each eligible flowgate.
- Step 3: If any eligible flowgate is identified as not having a PJM resource with at least a 1.5% impact, the M2M Test is failed and the resource is ineligible to Pseudo-Tie into PJM.

### **Disclaimers**

1. Results are preliminary; final results for each resource will be evaluated as per the documented Dynamic Transfer Process available here: [Pseudo-Tie Transfer Process Flow](#).
2. Posted results represent the M2M Test only; additional criteria required for qualification is available here: [PJM OATT Attachment DD Section 5.5A](#).
3. The M2M Test includes coordinated flowgates impacting all market and non-market entities.
4. Eligible coordinated flowgates (includes currently coordinated and potentially coordinated) for the M2M Test are determined in accordance with the appropriate FERC approved agreements with external entities.

**Preliminary M2M Test Results**

Resource Name	Area Name
1HRWFG2 J468	AMIL
1SANDYBSOLGL	CPLE
Belfast	CPLE
Benson	CPLE
Beulaville	CPLE
Colfax Peaker	DECO
Craven County Wood Energy	CPLE
Dover	CPLE
Edwards 22 kV Unit 3	AMIL
Edwardsport	CIN
Edwardsport Ct1	CIN
Edwardsport Ct2	CIN
Fayetteville PWC #1	CPLE
Fayetteville PWC #2	CPLE
Fayetteville PWC #3	CPLE
Fayetteville PWC #4	CPLE
Fayetteville PWC #5	CPLE
Fayetteville PWC #6	CPLE
Fayetteville PWC #7	CPLE
Fayetteville PWC #8	CPLE
Fayetteville PWC #9	CPLE
Four Oaks	CPLE
Fowler 2	CIN
Fuquay	CPLE

Godwin	CPLE
Grantham	CPLE
Harris Plant	CPLE
Industrial Customer	CPLE
Kornegay	CPLE
LaGrange	CPLE
Lee CC #1A	CPLE
Lee CC #1B	CPLE
Lee CC #1C	CPLE
Lee CC #S1	CPLE
Liberty	CPLE
Lillington	CPLE
Mount Olive West	CPLE
New Bern West	CPLE
Newton Grove	CPLE
Palisades	CONS
Princeton	CPLE
Rhems	CPLE
Roslin Solar	CPLE
Sanford Garden Street	CPLE
Selma	CPLE
Siler City Sub	CPLE
Turnbull Creek Solar	CPLE
Warsaw	CPLE
Warsaw Solar	CPLE
Wayne Cty. #10	CPLE
Wayne Cty. #11	CPLE
Wayne Cty. #12	CPLE

Wayne Cty. #13	CPL
Wayne Cty. #15	CPL
Wheatland 1	CIN
Wheatland 2	CIN
Wheatland 3	CIN
Wheatland 4	CIN