

Manual 12 – Balancing Operations

New Section

4.5.8 Performance Scores for Regulation Resources During a Synchronized Reserve Event

Regulation Resources choosing to respond to a Synchronized Reserve event will receive synchronized reserve compensation based on Manual 11, Section 4.2.11.

Resources that choose to respond to a reserve event for their reserve zone in an hour when they are cleared or assigned regulation are expected to return to their regulating band within 2 minutes of the end of the Synchronized Reserve event. From the start of the event, through the event, and for the 2 minutes after the end of the event, the performance scores for all regulating resources in the reserve zone where the Synchronized Reserve Event takes place will be null.

PJM Actions:

- PJM logs the time of the start and end of a Synchronized Reserve event.
- PJM will score performance for all regulating resources as null for the period during the Synchronized Reserve event and 2 minutes after the end of the event for those resources in that reserve zone.

PJM Member Actions:

- If the resource owner chooses to respond to an event the resource will return to the regulating band as soon as possible after the end of the reserve event.