




# Manual 14C Periodic Review and Updates (Revision 15)

Augustine Caven  
Manager, Infrastructure Coordination  
Markets & Reliability Committee  
February 23, 2023

- Cover to Cover Periodic Review
- Section 1 - Added Pre-ISA project milestones on Site Permits, Acquisition of Major Electrical Equipment, and Fuel Delivery and Water agreements.
- Section 4 - Added posting requirement of historical ITO interconnection standards.

- Included the following pre-ISA milestones
  - Site Permits** – The Interconnection Customer must demonstrate that it has obtained any necessary local, county, and state site permits.
  - Acquisition of major electrical equipment** – The Interconnection Customer must demonstrate that it has signed a memorandum of understanding for the acquisition of generating units (including wind turbines and solar inverters) and other major electrical equipment such as main power transformers/GSUs, breakers, control buildings, PV Tracking equipment, PV panels, etc. for the project.
  - Fuel Delivery and Water Agreements** - The Interconnection Customer must demonstrate that it has entered a fuel delivery agreement and water agreement, if necessary, and that it controls any necessary rights-of-way for fuel and water interconnections.

- Added the following language for the posting of historical Interconnection Transmission Owner (ITO) interconnection standards -
  - In supporting interconnection projects which refer to a specific ITO Standard revision, all historical ITO interconnection standards versions shall be also be available on a separate link under the directory titled “Design, Engineering & Construction” at <http://pjm.com/planning/design-engineering/to-tech-tandards.aspx>



Presenter:  
Augustine Caven

[Augustine.Caven@pjm.com](mailto:Augustine.Caven@pjm.com)

## M14C Periodic Review and Updates (Revision 15)



### Member Hotline

(610) 666 – 8980

(866) 400 – 8980

[custsvc@pjm.com](mailto:custsvc@pjm.com)

**PROTECT THE  
POWER GRID  
THINK BEFORE  
YOU CLICK!**



Be alert to  
malicious  
phishing emails.

**Report suspicious email activity to PJM.**  
(610) 666-2244 / [it\\_ops\\_ctr\\_shift@pjm.com](mailto:it_ops_ctr_shift@pjm.com)

