



Summary of Proposed Language for Manual 13: Emergency Operations

Kevin Hatch
PJM Operating Committee
January 13, 2021

- **Revision 78 (03/01/2021)**
- Periodic Review:
- Section 2.2 Reserve Requirements
 - Updated note for the amount of contingency reserves that can be made up of interruptible load from 25% to 33%
- Section 2.3 Capacity Shortages
 - Modified note #3 and deleted note #5 due to the retirement of Limited DR, Extended Summer DR and Base DR

- Section 3.9 Assessing Gas Infrastructure Contingency Impacts On the Electric System
 - Removed reference to pre-defined gas contingencies being identified in M03 CEI version
- Section 5.2 Transmission Security Emergency Procedures
 - Modified note #3 and deleted note #5 due to the retirement of Limited DR, Extended Summer DR and Base DR
- Section 5.4 Post-Contingency Local Load Relief Warning
 - Added detail to the members action section that TO dispatchers shall check the PCLLRW application to ensure that no PCLLRW status are deficient

- Attachment A Public Notification Agreements
 - Updated baseline PJM information in Public Notification statements such as the amount of people in PJM's footprint, miles of transmission lines, & CEO
- Attachment H
 - Updated image for Exhibit 11: eDART Min Gen Calculation Worksheet
 - Updated image for Exhibit 12: eDART ERG Reporting Form
- Attachment J
 - Updated reporting email addresses for EOP-004 & OE-417 forms

- OC: 1st Read: December 3, 2020
- OC: Endorsement: January 13, 2021
- MRC 1st Read: December 17, 2020
- SOS read: January 8, 2021
- MRC Voting Date: January 27, 2021

Facilitator:
Darlene Phillips, Darlene.Phillips@pjm.com

Secretary:
Danielle Croop, Danielle.Croop@pjm.com

SME/Presenter:
Kevin Hatch Kevin.Hatch@pjm.com



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com