



Executive Summary Manual Changes

Effective Date	11/16/22
Impacted Manual #(s)/Manual Title(s):	
Manual 13 Emergency Operations	
Conforming Order(s):	
None	
Associated Issue Tracking Title:	Max Emergency Changes for Resource Limitation Reporting
Committee Approval Path - What committee(s) have already seen these changes?	
First read at this OC meeting	
MRC 1st read date:	10/24
MRC voting date:	11/16
Impacted Manual sections:	
Section 6.4	
Reason for change:	
Redline changes based on the PJM Package associated with the Max Emergency Changes for Resource Limitation Reporting Issue Charge	
Summary of the changes:	
<ul style="list-style-type: none"> • Permit coal resources owners to offer their units as Maximum Emergency if their fuel inventories below 240 hours (10 days) with the following conditions: <ol style="list-style-type: none"> 1. PJM has not issued a Hot or Cold Weather Alert, Conservative Ops 2. If PJM denies the use of Maximum Emergency for any reason, including but not limited to a potential thermal or voltage violation, to avoid running a CEJA limited unit with no economic hours remaining, a black start concern, tornado/hurricanes, extreme weather, GMD activity, etc. 	

3. A unit offered as Maximum Emergency can remain in that state until the inventory level reaches 21 days (or if the owner elects to remove the unit earlier) OR if any of the aforementioned conditions occur
 - Clarify that a unit may only be offered as Maximum Emergency consistent with the provisions of PJM OA, Schedule 1/Tariff, Attachment K-Appendix, Section 1.10.1A and after taking actions to actively manage their fuel supplies and run time
 - Include specific documentation and reporting requirements for utilization of Maximum Emergency
 - Clarify when resources with Environmental Limits can offer as Maximum Emergency
 - Provide examples for what does and does not qualify as a “temporary MW addition” for use of Maximum Emergency
 - Provide examples for what does and does not qualify as a “temporary emergency condition at the plant” for use of Maximum Emergency