




# Manual 03, Revision 64 Transmission Operations

Dean Manno, Sr. Engineer II  
Transmission Operations

Operating Committee  
April 13, 2023

- **Revision 64 (05/31/2023):**
  - Periodic Review
  - Changed manual ownership from Simon Tam to Nicole Scott.
  - Introduction Section – Removed EMS User’s Manual as a reference.
  - Section 4.2.10 – Added language for clarity.
  - Section 4.4 – Updated “RFC” references to now reference “RF”.
  - Attachment A – Updated “RFC” references to now reference “RF” and Removed Kincaid Scheme due to retirement.
  - Attachment C – Updated submission process email address.



**SME/Presenter:**

Dean Manno,

[dean.manno@pjm.com](mailto:dean.manno@pjm.com)

**Manual 03, Rev 64 – Periodic Review**



**Member Hotline**

(610) 666 – 8980

(866) 400 – 8980

[custsvc@pjm.com](mailto:custsvc@pjm.com)

# Appendix

## **Revision 63.1 (12/13/2022):**

- BGE: Removed common trench and special rating sections 1.5.2 and 1.5.3
- ComEd: Deleted Kincaid Stability procedure due to retirement.
- ComEd: Updated Transformer Operations at 138 kV Line Tie Breaker Substations procedure.
- ComEd: Added new Mulberry Bus Tie Operation procedure.
- PSEG: Updated Artificial Island Stability procedure.
- Revision History: Corrected typo in Revision 62.2 date.

## **Revision 63.2 (03/30/2023):**

- Changed manual ownership from Simon Tam to Nicole Scott.
- Introduction Section: Deleted EMS User Manual as a reference document.
- AE: Updated “Section 1.2.1 Directional Ratings” with latest rating information
- DPL: Updated “Section 1.3.1 Directional Ratings” with latest rating information
- AEP: Added “West Bellaire 345 kV Reactors” section.
- ComEd: Updated the Powerton Stability Trip Schemes procedure.
- ComEd: Removed inadvertently copied language from section 1.6.22.
- DVP: Updated Ladysmith/Doswell table for clarity.
- FE-East: Updated Keystone-Conemaugh 5003 Re-Close procedure.
- PSEG: Updated Artificial Island Stability procedure.

**PROTECT THE  
POWER GRID  
THINK BEFORE  
YOU CLICK!**



Be alert to  
malicious  
phishing emails.

**Report suspicious email activity to PJM.**  
(610) 666-2244 / [it\\_ops\\_ctr\\_shift@pjm.com](mailto:it_ops_ctr_shift@pjm.com)

