



# Sub Regional RTEP Committee PJM Mid-Atlantic Reliability Update

November 17, 2022

# Second Review

## Baseline Reliability Projects

**Process Stage:** Second Review

**Criteria:** Summer Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** The New Church – Piney 138 kV circuit overloaded for line fault stuck breaker contingency

Violations were posted as part of the 2022 Window 1: FG# GD-S626

**Existing Facility Rating:** 172SN/226SE, 198WN/255WE MVA

**Proposed Facility Rating:** 392SN/485SE, 452WN/546WE MVA

**Recommended Solution:**

Rebuild the New Church - Piney Grove 138 kV line. (B3749)


**Estimated Cost:** \$63 M

**Alternatives**

- Operate at higher conductor temperature (and perform clearance mitigations if necessary) – [Option not viable per DPL T&S due to age and condition of the line]
- Reconductor New Church - Piney Grove (21.78 mi) – [Option not viable per DPL T&S due to age and condition of the line]
- Add a 2nd breaker next to existing Loretto 130 CB to eliminate contingency issue [overcrowding at Loretto substation, this would require significant reconfiguration in the yard]

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** Summer and Light Load Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer and Light Load cases

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** The Seward – Florence 115 kV is overloaded for multiple contingencies.

Violations were posted as part of the 2022 Window 1: FG# -GD-LL25, FG# - GD-S535, FG# - GD-S537 and FG# - GD-S536

**Existing Facility Rating:** 137SN/172E, 180WN/206WE MVA

**Proposed Facility Rating:** 232SN/282SE, 263WN/334WE MVA

**Recommended Solution:**

Upgrade Seward Terminal Equipment of the Seward-Blairsville 115 kV Line to increase the line rating such that the Transmission Line conductor is the limiting component. (B3750)


**Estimated Cost:** \$0.43 M

**Alternatives**

N/A

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** Summer and Winter Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer and Winter cases

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** the Roxbury – AE1-071 115 kV line is overloaded for several contingencies.

Violations were posted as part of the 2022 Window 1:

FG# - 22 Summer flowgates,

FG# - 50 Winter flowgates,

**Existing Facility Rating:** 133SN/160E, 150WN/190WE MVA

**Proposed Facility Rating:** 273SN/333SE, 309WN/395WE MVA

**Recommended Solution:**

Rebuild 6.4 miles of the Roxbury - Shade Gap 115 kV line from Roxbury to the AE1-071 115 kV ring bus with single circuit 115 kV construction. (B3751)


**Estimated Cost:** \$15.03 M

**Alternatives**

N/A

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** Summer and Winter Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer and Winter cases

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** the AE1-071 - Shade Gap 115 kV line is overloaded several contingencies.

Violations were posted as part of the 2022 Window 1:

FG# - 2 Summer flowgates,

FG# - 38 Winter flowgates,

**Existing Facility Rating:** 133SN/160E, 150WN/190WE MVA

**Proposed Facility Rating:** 273SN/333SE, 309WN/395WE MVA

**Recommended Solution:**

Rebuild 7.2 miles of the Shade Gap - AE1-071 115 kV line section of the Roxbury - Shade Gap 115 kV line. (B3752)


**Estimated Cost:** \$17.43 M

**Alternatives**

N/A

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** FERC Form 715

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** The Tyrone North 115/46 kV transformer #2 is overloaded for breaker outage.

Violations were posted as part of the 2022 Window 1: FG# PN-T2

**Existing Facility Rating:** 43SN/53SE, 54WN/64WE MVA

**Proposed Facility Rating:** 97SN/102SE, 117WN/126WE MVA

**Recommended Solution:**

Replace the Tyrone North 115 /46 kV transformer with a new standard 75 MVA top rated bank and upgrade the entire terminal to minimum 100 MVA capability for both SN and SE rating. (B3753)


**Estimated Cost:** \$2.82 M

**Alternatives**

N/A

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** FERC Form 715

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** Low voltage violation in the Belleville 46 kV vicinity for multiple single contingencies.

Violations were posted as part of the 2022 Window 1: FG# PN-VM1, FG# PN-VM2, FG# PN-VM3, FG# PN-VM4, FG# PN-VM5 and FG# PN-VM6

**Recommended Solution:**

At Maclane tap: Construct a new three breaker ring bus to tie into the Warrior Ridge - Belleville 46 kV D line and the 1LK line. (B3754)



**Estimated Cost:** \$10.09 M

**Alternatives**

-Construct/Build a new 2 mile 46 kV line section to make a Lewistown - Warrior Ridge 46 kV line but it did not resolve all of the issues.

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027





**Process Stage:** Second Review

**Criteria:** FERC Form 715

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer and Winter

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** Low voltage and voltage drop violation at Locust 69 kV station for a bus contingency.

Violations were posted as part of the 2022 Window 1: FG# PSEG-VM1, FG# PSEG-VD3 and FG# PSEG-VD13

**Recommended Solution:**

Convert Locust Street 69kV from a Straight Bus to a Ring Bus. (B3755)

**Estimated Cost:** \$30 M


**Alternatives**

Adding Capacitor banks at Locust station:

- Current straight bus design cannot accommodate connection of capacitor banks in the appropriate locations to address all contingencies.
- Modification of existing bus to a ring requires significant underground modification. Temporary construction contingencies are required to maintain system reliability.

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** FERC Form 715

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer and Winter

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** Voltage drop violation at Maple Shade 69 kV station for multiple line fault stuck breaker contingencies.

Violations were posted as part of the 2022 Window 1: FG# PSEG-VD1, FG# PSEG-VD2 and FG# PSEG-VD1

**Recommended Solution:**

Convert Maple Shade 69kV from a Straight Bus to a Ring Bus. (B3756)

**Estimated Cost:** \$33.9 M


**Alternatives**

-Adding capacitor banks at Maple Shade:

- Current straight bus design cannot accommodate connection of capacitor banks in the appropriate locations to address all contingencies.
- Modification of existing bus to a ring requires significant underground circuit reconfiguration to provide ample space. Temporary construction contingencies are required to maintain system reliability.

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



**Process Stage:** Second Review

**Criteria:** FERC Form 715

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Summer

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** Voltage drop violation at Harts Lane station for several multiple N-1-1 contingencies.

Violations were posted as part of the 2022 Window 1: FG# PSEG-VD10 and

FG# PSEG-VD11

**Proposed Facility Rating:** 95SN/131SE, 95WN/131WE MVA

**Recommended Solution:**

Construct a new 69kV line from 14th Street to Harts Lane. (B3758)

**Estimated Cost:** \$34.4 M

**Alternatives**


-Install Capacitor bank at Harts Lane:

- Harts Lane already has a capacitor bank, however, reported voltage drop is too great for an additional capacitor bank to be an effective solution.

-Alternative circuit to Brunswick has a more challenging route and provides no benefit to the rest of the area 69kV system.

**Required In-Service:** 6/1/2027

**Projected In-Service:** 6/1/2027



# Questions?



2022

- The Next 2022 Mid-Atlantic SRRTEP meetings are as followed
- 12/14

V1 – 11/10/2022 – Original slides posted

V2 – 11/15/2022 – removed a slide related to Medford and South Hampton flowgates, the project will e presented in the future.