

PECO 2022  
Submission of Supplemental Projects for  
Inclusion in the Local Plan

**Need Number:** PE-2020-001

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Previously Presented:**

Need Meeting – TEAC – 3/10/20

Solution Meeting – TEAC – 11/2/21

**Project Driver:**

Equipment Material Condition, Performance, and Risk


**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

230kV tie line 220-10 (Whitpain[PECO] – Bucksmont[PPL]) has obsolete relays

- It is becoming difficult to service existing electromechanical relays. They are being phased out of the system.



**Need Number:** PE-2020-001

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Selected Solution:**

Upgrade relays, communication, metering & replace station conductor on 220-10 (Whitpain – Buxmont) line

- Before solution ratings: 418/519 MVA (SN/SE) [PECO portion]  
500/597 MVA (WN/WE) [PECO portion]
- After solution ratings: 463/578 MVA (SN/SE) [PECO portion]  
521/639 MVA (WN/WE) [PECO portion]


**Estimated cost:** \$.5M

**Projected In-Service:** 11/2/21

**Supplemental Project ID:** s2673

**Project Status:** Under Construction

**Model:** 2026 RTEP



**Need Number: PE-2020-002**

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Previously Presented:**

Need Meeting – TEAC – 3/10/20

Solution Meeting – TEAC – 11/2/21

**Project Driver:**

Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

230kV line 220-52 (Whitpain – Jarrett) has obsolete relays

- It is becoming difficult to service existing electromechanical relays. They are being phased out of the system.

PECO Transmission Zone  
220-52 (Whitpain – Jarrett) Relay Replacement



**Need Number:** PE-2020-002

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Selected Solution:**

Upgrade relays, communication, metering & replace station conductor on 220-52 (Whitpain – Jarrett) line

- Before solution ratings: 812/964 MVA (SN/SE)  
893/1003 MVA (WN/WE)
- After solution ratings: 812/964 MVA (SN/SE)  
893/1036 MVA (WN/WE)

**Estimated cost:** \$1.04M

**Projected In-Service:** 12/22/21

**Supplemental Project ID:** s2674

**Project Status:** Engineering

**Model:** 2026 RTEP





**Need Number: PE-2021-005**

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Previously Presented:**

Need Meeting – TEAC – 10/5/2021

Solution Meeting – TEAC – 11/2/21

**Project Driver:**

Operational Flexibility and Efficiency

**Specific Assumption Reference:**


- Enhancing system functionality, flexibility, visibility, or operability
- Increasing system capacity

**Problem Statement:**

Cromby #5 230/69 kV transformer facility ratings were reduced on 3/13/21 as part of an internal review

- New SN/SE = 126 MVA / 156 MVA
- Previous SN/SE = 155 MVA / 194 MVA
- Difference SN/SE = -29 MVA (19%) / -38 MVA (20%)

PECO Operations is requesting that Cromby #5 230/69 kV facility be upgraded in an expedited fashion due to real time operations issues encountered during 2021 summer operations and in preparation for maintenance outages of facilities in the area.



**Need Number: PE-2021-005**

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Selected Solution:**

Replace a piece of station cable on the 69 kV side of the Cromby #5 230/69 kV transformer facility

- Before solution ratings: 126/156 MVA (SN/SE)  
155/179 MVA (WN/WE)
- After solution ratings: 155/194 MVA (SN/SE)  
200/234 MVA (WN/WE)


**Estimated cost:** \$0.1M

**Projected In-Service:** 10/17/21

**Supplemental Project ID:** s2675

**Project Status:** Completed

**Model:** 2026 RTEP



**Need Number:** PE-2021-006

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Previously Presented:**

Need Meeting – TEAC – 11/2/21

Solution Meeting – TEAC – 11/30/21

**Project Driver:**

Equipment Material Condition, Performance, and Risk


**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

230kV line 220-69 (Plymouth Meeting – Upper Merion) has obsolete relays

- It is becoming difficult to service existing outdated relays. They are being phased out of the system.







PECO Transmission Zone  
220-69 (Plymouth Meeting – Upper Merion) Relay Replacement

**Need Number:** PE-2021-006

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 3/17/2022

**Selected Solution:**

Upgrade relays, communication, metering & removal of wave trap on 220-69 (Plymouth Meeting – Upper Merion) line

- Before solution ratings: 418/519 MVA (SN/SE)  
500/581 MVA (WN/WE)
- After solution ratings: 418/519 MVA MVA (SN/SE)  
513/597 MVA (WN/WE)


**Estimated cost:** \$1.9M

**Projected In-Service:** 10/7/21

**Supplemental Project ID:** s2676

**Project Status:** Completed

**Model:** 2026 RTEP



**Need Number:** PE-2021-007

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Previously Presented:**

Need Meeting – TEAC – 11/18/2021

Solution Meeting – TEAC – 1/20/2022

**Project Driver:**


Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

Chester 69kV circuit breaker #60 installed in 1957 is in deteriorating condition, has lack of replacement parts, and elevated maintenance cost.





PECO Transmission Zone  
Chester 69 kV Circuit Breaker #60 Replacement

**Need Number:** PE-2021-007

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Selected Solution:**

Replace Chester 69 kV circuit breaker #60

- Before solution ratings: 2000A, 29kA [PECO portion]
- After solution ratings: 3000A, 40kA [PECO portion]

**Estimated cost:** \$.65M

**Projected In-Service:** 12/23/2022

**Supplemental Project ID:** s2710

**Project Status:** Engineering

**Model:** 2026 RTEP

Chester



**Need Number: PE-2022-001**

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Previously Presented:**

Need Meeting – TEAC – 2/8/2022

Solution Meeting – TEAC – 3/8/2022

**Project Driver:**


Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

Newlinville 230 kV circuit breaker #260 installed in 1970 is in deteriorating condition, has lack of replacement parts, and elevated maintenance cost.



**Need Number: PE-2022-001**

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Selected Solution:**

Replace Newlinville 230 kV circuit breaker #260

- Before solution ratings: 3000A, 45.2kA [PECO portion]
- After solution ratings: 3,000A and 63kA [PECO portion]


**Estimated cost:** \$.78M

**Projected In-Service:** 4/1/2022

**Supplemental Project ID:** s2716

**Project Status:** Completed

**Model:** 2026 RTEP



**Need Number: PE-2022-002**

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Previously Presented:**

Need Meeting – TEAC – 2/17/2022

Solution Meeting – TEAC – 3/17/2022

**Project Driver:**


Equipment Material Condition, Performance, and Risk

**Specific Assumption Reference:**

- Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions
- Programmatic replacement of breakers, relays, wood poles, cables, etc.

**Problem Statement:**

Cromby 138 kV oil circuit breaker #370 installed in 1953 is in deteriorating condition, has lack of replacement parts, and elevated maintenance cost.



**Need Number:** PE-2022-002

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Selected Solution:**

Replace Cromby 138 kV circuit breaker #370 and wire drops

- Before solution ratings: 1200A, 14.7kA [PECO portion]
- After solution ratings: 3,000A and 63kA [PECO portion]


**Estimated cost:** \$.65M

**Projected In-Service:** 9/23/2022

**Supplemental Project ID:** s2714

**Project Status:** Completed

**Model:** 2026 RTEP



**Need Number:** PE-2022-003

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 10/10/22

**Previously Presented:**

Need Meeting – TEAC – 3/17/2022

Solution Meeting – TEAC – 4/19/2022

**Project Driver:**

Customer Service


**Specific Assumption Reference:**

- System configuration changes due to new or expansion of existing distribution substations

**Problem Statement:**

- Distribution Capacity Planning needs to increase transformer capacity at Bryn Mawr Substation in order to relieve nearby 13 kV substations and allow for the retirement of 34/4 kV units in the surrounding area. A total of approximately 22 MVA will be added to substation consisting of load transfers from other substations and some 34/4 kV unit retirements.

Existing load = 65 MVA  
 Added load = 22 MVA [Expected 6/1/25]  
 Total load = 87 MVA







PECO Transmission Zone  
Bryn Mawr 3rd 138/13 kV Transformer

**Need Number:** PE-2022-003

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan  
10/10/22

**Selected Solution:**

- Install 3rd Bryn Mawr 138/13 kV 62 MVA transformer with high side breaker
- Install two 3000A 63kA 138 kV breakers on the Bryn Mawr straight bus to create two double breaker bus ties
- Install two 3000A 63kA 138 kV line breakers on 130-35 & 130-36 lines at Bryn Mawr end
- Issue ratings for 130-42 Eddystone – Llanerch 138 kV line as a 2-section line

| <u>Before solutions ratings (MVA):</u>                      | <u>SN/SE</u> | <u>WN/WE</u> |
|-------------------------------------------------------------|--------------|--------------|
| 130-42 Eddystone - Llanerch                                 | 225/279      | 239/288      |
| <u>After solutions ratings (As a 2-segment line) (MVA):</u> | <u>SN/SE</u> | <u>WN/WE</u> |
| 130-42 Eddystone – Eddystone 50 Tap                         | 310/388      | 406/468      |
| 130-42 Eddystone 50 Tap - Llanerch                          | 225/279      | 239/288      |


**Estimated cost:** \$3M

**Projected In-Service:** 6/1/25

**Supplemental Project ID:** s2805

**Project Status:** Engineering

**Model:** 2026 RTEP



# Revision History

3/17/2022 – V1 – Posted Local plan for s2673, s2674, s2675 and s2676

3/17/2022 – V2 – Posted Local plan for s2710, s2716, s2714 and s2730

11/16/2022 – V3 – replaced upgrade # for s2730 – new # is s2805