



# ***CONNECTING***

*Energy Infrastructure*

ITCI Planning Criteria

John M. Kopinski  
Principal Engineer, Regional Planning



*12/18/2020*

# ITC INTERCONNECTION (ITCI)

## ITC Facilities in PJM

ITC owns and operates PJM network transmission facilities in southwest Michigan:

- 345kV Substation
- 345kV Transmission Line

PJM integration activities completed on June 1, 2016

Also Connects to ITC Owned Facilities in MISO (METC)

Zero Revenue Requirement Assets (No Regulated Rate)



# ITCI Planning Criteria (PJM)

- ITCI Uses the Same Planning Criteria as the Michigan MISO Assets (ITCT & METC)
- ITCI Planning Criteria Augments PJM Planning Criteria
- **2020 Changes to Planning Criteria (March 2020)**
  - Clarification of System Adjustment Procedures
  - Minor Revisions to the Generator Stability Study Criteria
- **Some ITCI Criteria Differences From PJM Criteria Include:**

P1 Contingencies That Include a Prior Shutdown Considered for Shoulder Peak (85% peak load)

Max/Min Voltages  
0.97/1.07 pu for P0 and  
0.92/1.07 pu for P1-P7

P2.2 Bus Section Fault Considered to be a 3-Phase Fault to Ground

P4 Contingencies Considered to be a 2-Phase Fault to Ground

Some Additional Restrictions on Consequential Load Loss

End of Life Criteria

# ITCI – Project Identification

- Annual Michigan planning assessment conducted to identify any system issues and corresponding projects
- Asset management programs to identify and replace equipment that is obsolete, failed, or at an end-of-life condition

# ITCI Planning Criteria (PJM)

- ITCI Planning Criteria Is Posted on PJM's Webpage:

<https://www.pjm.com/-/media/planning/planning-criteria/itc-holdings-planning-criteria.ashx?la=en>

- ITCI Facility Connection Requirements Is Posted on PJM's Webpage:

<http://www.pjm.com/-/media/planning/plan-standards/itci/itc-holdings-facility-connection-requirements.ashx?la=en>



# **CONNECTING**

*Energy Infrastructure*

