



# Reliability Analysis Update

Wenzheng Qiu, Hamad Ahmed and Julia Spatafore  
Sub Regional RTEP Committee - PJM West  
October 14, 2022

# Changes to Existing Projects

## Baseline Reliability Projects



# AEP Transmission Zone: Baseline B3104 Cost Increase

**B3104:** Previously presented on 03/07/2019 TEAC

**Problem Statement:** Polaris - Westerville 138 kV line is overloaded for multiple N-1-1 contingency pairs with the Conesville unit 4 deactivation.

**B3104 scope:** Perform a sag study (~ 3.6 miles) to increase the Summer Emergency rating to 310 MVA

- Current rating: SN 223 MVA / SE 226 MVA
- New rating: SN 223 MVA / SE 310 MVA

**Original Estimated Cost:** \$0.5M -> **New Estimated Cost:** \$3.82M


**Required IS Date:** 6/1/2020

**Original Projected IS Date:** 6/1/2020 -> **New Projected IS Date:** 1/24/2023

**Reason for the Cost and IS Date Change:** After LIDAR was completed it was determined that the full scope of work is required in order to meet the desired ratings noted above. The scope includes: Ten structure replacements, three distribution poles modifications, re-sag two spans of existing conductor, and one existing street light relocation.

The scope of work combined with material procurement issues led to delays in the project's initial timeline. The projected timeline of the project has continued to be updated in the PJM construction tracker as changes have occurred.

In order to alleviate the possible overload condition until such time the permanent solution can be implemented, a potential operating procedure was identified to open the 138 kV line between Genoa and Spring Road SW to offload the Polaris – Westar line if the loading rises above the emergency rating in real time operations.



# Recommended Solution

## Baseline Reliability Projects

**Process Stage:** Recommended Solution

**Criteria:** AEP 715 Criteria

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Winter RTEP case



**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-T1, 2022W1-AEP-T2

In 2027 RTEP winter case, the Darrah – Barnett 69 kV line is overloaded under a N-1-1 contingency scenario

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
Darrah – Barnett 69 kV	50/50/63/63






# AEP Transmission Zone: Baseline Darrah – Barnett 69 kV Line Rebuild

## Recommended Solution:

- Rebuild the existing Darrah - Barnett 69 kV line, approximately 2.8 miles and replace a riser at Darrah Station. (B3722)

**Transmission Estimated Cost:** \$6.98M

**Ancillary Benefits:** Supplemental needs on the Darrah – Barnett 69 kV line section: Darrah - Owens Illinois Circuit originally installed in 1954, currently has 213 conditions on 86 structures




## Preliminary Facility Rating:

Branch	SN/SE/WN/WE (MVA)
Darrah – Barnett 69 kV	93/114/118/134

**Required IS Date:** 12/1/2027

**Projected IS Date:** 12/1/2027

**Previously Presented:** 9/16/2022



# AEP Transmission Zone: Baseline George Washington-Kammer 138kV Line Rebuild

**Process Stage:** Recommended Solution

**Criteria:** Summer Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer RTEP case


**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S1032

In 2027 RTEP Summer case, the George Washington-Kammer 138 kV line is overloaded under a contingency scenario in generation deliverability test.

## Existing Facility Rating:

Branch	SN/SE/WN/WE (MVA)
George Washington – Kammer 138kV	446/621/563/698



### Recommended Solution:

- Rebuild the George Washington – Kammer 138kV circuit, except for 0.1-mile of previously-upgraded T-line outside each terminal station (6.7 miles of total upgrade scope). Remove the existing 6-wired steel lattice towers and supplement the right-of-way as needed. (B3723)

**Transmission Estimated Cost:** \$18.3M

**Ancillary Benefits:** Addresses M-3 facility condition needs (AEP-2021-OH013), as presented in 3/19/2021 and 5/19/2022 W-SRREP

### Preliminary Facility Rating:


Branch	SN/SE/WN/WE (MVA)
George Washington – Kammer 138kV	730/747/791/791

**Required IS Date:** 6/1/2027

**Projected IS Date:** 6/1/2024


**Previously Presented:** 9/16/2022

### Existing:



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

### Proposed:





**Process Stage:** Recommended Solution

**Criteria:** AEP 715 Criteria



**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-T5 through T9

In 2027 RTEP summer case, the Cloverdale-Ingersoll Rand-Monterey Avenue 69 kV line sections are overloaded under multiple N-1-1 contingency scenarios.



## Recommended Solution:

- Install 138 kV circuit switcher on the high-side of Transformer #2 at Roanoke Station (previously proposed as a portion of s2469.7, posted in 2021 AEP local plan) . (B3724)



**Transmission Estimated Cost:** \$0.1M

**Ancillary Benefits:** Separates the transformer and bus zones of protection. Included as part of s2469.7 previously, now converted to baseline

**Required IS Date:** 6/1/2027

**Projected IS Date:** 6/1/2027

**Previously Presented:** 9/16/2022



**Process Stage:** Recommended Solution

**Criteria:** Generation Deliverability


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S1030

In 2027 RTEP Summer case, Hayes to Avery 138 kV line is overloaded due to a tower contingency



Branch	SN/SE/WN/WE (MVA)
Hayes to Avery 138 kV	233/282/263/333

### Recommended Solution:

Rebuild and reconductor the Avery-Hayes 138 kV line (approx. 6.5 miles) with 795 KCMIL 26/7 ACSR (b3721)

**Transmission Estimated Cost:** \$10.4M

**Ancillary Benefits:** Capacity increase for future growth


**Alternatives:** None

### Preliminary Facility Rating:

Branch	SN/SE/WN/WE (MVA)
Hayes to Avery 138 kV	278/339/315/401

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027





# ATSI Transmission Zone: Baseline Abbe – Johnson 69 kV line

**Process Stage:** Recommended Solution

**Criteria:** First Energy 715 Criteria


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-ATSI-T1

In 2027 RTEP Summer case, Johnson to Redman 138 kV line is overloaded due to a P2-1 contingency



Branch	SN/SE/WN/WE (MVA)
Abbe to Johnson 138 kV	76/92/87/111

# ATSI Transmission Zone: Baseline

## Abbe – Johnson 69 kV line

### Recommended Solution:

- Rebuild the Abbe-Johnson #2 69 kV Line (approx. 4.9 miles) with 556 kcmil ACSR conductor
- Replace (3) disconnect switches (A17, D15 & D16) and line drops and revise relay settings at Abbe.
- Replace (1) disconnect switch (A159) and line drops and revise relay settings at Johnson.
- Replace (2) MOAB disconnect switches (A4 & A5), (1) disconnect switch (D9), and line drops at Redman. (b3720)

**Transmission Estimated Cost: \$10.9M**

**Ancillary Benefits:** Capacity increase for future growth


**Alternatives:** None

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
Abbe to Johnson 138 kV	111/134/125/159

**Required in-service date: 6/1/2027**

**Projected in-service date: 6/1/2026**



# First Review

## Baseline Reliability Projects

# AEP Transmission Zone: Baseline McComb 40kV Breaker J Replacement

**Process Stage:** First Review Solution

**Criteria:** AEP 715 Criteria

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 RTEP short circuit case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-SC1

In 2027 RTEP short circuit case, 40 kV circuit breaker 'J' at McComb station was identified as being overdutied.

**Existing Facility Rating:** 18kA





**Proposed Solution:**

Replace 40kV breaker J at McComb station with a new 3000A 40kA breaker

**Transmission Estimated Cost:** \$0.5M

**Alternatives:** None


**Ancillary Benefits:** Breaker J was identified as part of the need under AEP-2019-OH020.








**Preliminary Facility Rating:** 40kA

**Required in-service date:** 6/1/2027


**Projected in-service date:** 6/1/2025

**Existing:**



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

**Proposed:**



**Process Stage:** First Review Solution

**Criteria:** AEP 715 Criteria


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP summer case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-VM22 through 2022W1-AEP-VM39. 2022W1-AEP-VD25 through 2022W1-AEP-VD33; 2022W1-AEP-VD38 through 2022W1-AEP-VD47.

In 2027 RTEP summer case, low voltage and voltage-drop violations on the 34.5kV system between North Coshocton, Newcomerstown, and West New Philly stations, including Allegheny Pipe, East Coshocton, Gen Tire, Isleta, Morgan Run, North Coshocton, Newcomerstown, W Lafayette, Copper head 34.5kV buses, under multiple N-1-1 contingency scenarios.





# AEP Transmission Zone: Baseline Morgan Run 34.5kV Cap Bank

## Proposed Solution:

Install a 6 MVAR, 34.5kV cap bank at Morgan Run station.

**Transmission Estimated Cost:** \$0.37M


**Alternatives:** An alternative solution would be adding another source to the 34.5kV system bounded by North Coshocton, Newcomerstown and West New Philly. In order to resolve the specific N-1-1 contingencies of concern, the source would need to be near North Coshocton or Newcomerstown. A 2nd 69-34.5kV transformer could be installed at either station, however, this would be more costly than a 34.5kV cap bank, as high-side 69kV breaker(s) would be needed, along with relays, etc. In addition, AEP's long-term plan is to convert 34.5kV areas to 69kV or 138kV, so it is not recommended to add a new source to this 34.5kV area at this time, given the relatively small amount of customer load served from the system. Estimated cost: \$10M

**Ancillary Benefits:** Improved year-round operating voltages on the 34.5kV system; increased SCADA voltage data for AEP Operations personnel, increasing the accuracy of state-estimation, etc.

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027

## Existing:



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

## Proposed:





# AEP Transmission Zone: Baseline Summerhill-Willow Grove 69kV Line Rebuild

**Process Stage:** First Review Solution

**Criteria:** AEP 715 Criteria

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP summer case


**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-T10

In 2027 RTEP summer case, The Summerhill-Willow Grove Switch 69kV line segment is overloaded for an N-1-1 contingency pair.

**Existing Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
05SUMMERHI -05WILLGRSS 69kV	50/50/63/63





# AEP Transmission Zone: Baseline Summerhill-Willow Grove 69kV Line Rebuild

## Proposed Solution:

Rebuild the 1.8 mile 69kV T-line between Summerhill and Willow Grove Switch.  
Replace 4/0 ACSR conductor with 556 ACSR.

**Transmission Estimated Cost:** \$5.1M

## Preliminary Facility Rating:


Branch	SN/SE/WN/WE (MVA)
05SUMMERHI -05WILLGRSS 69kV	82/90/107/113

**Alternatives:** Reconductor the 69kV T-Line with the existing wood poles, instead of doing a full rebuild. However, due to the age/condition of the facilities, a full rebuild is recommended.

**Ancillary Benefits:** Addresses potential M-3 facility condition needs, as documented by field personnel and AEP Asset Renewal groups. Existing structure conditions include broken down leads, broken molding, and cracked cross-bracing. This portion of line was originally constructed in 1946, primarily with wooden H-frame structures. The line has experienced over 680k CMI between 2015-2021 with 8 momentary and 2 permanent outages. There are 37 structures (46% of the line) with at least one open condition. There are 67 open conditions along the line.

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027



**Process Stage:** First Review Solution

**Criteria:** AEP 715 Criteria


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP summer case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-VD34 through 2022W1-AEP-VD37

In 2027 RTEP summer case, voltage-drop violations at Rarden switch, Otway station, Tick Ridge station, and Rarden station 69kV buses under a N-1-1 contingency scenario.



## Proposed Solution:

Install a 7.7 MVAR, 69kV cap bank at both Otway station and Rosemount station to resolve N-1-1 voltage-drop violations


**Transmission Estimated Cost: \$1.73M**

**Alternatives: None**

**Required in-service date: 6/1/2027**


**Projected in-service date: 6/15/2026**

### Existing:



Legend	
500 kV	
345 kV	
138 kV	
69 kV	
34.5 kV	
23 kV	
New	

### Proposed:



**Process Stage:** First Review Solution

**Criteria:** AEP 715 Criteria


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP summer/winter cases

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-T3, 2022W1-AEP-T4, 2022W1-AEP-VM1 through 2022W1-AEP-VM3, 2022W1-AEP-VD1 through 2022W1-AEP-VD4

In 2027 RTEP summer/winter case, Thermal overload on the Arrowhead - Hillman Highway 69 kV line under multiple N-1-1 contingency pairs. In 2027 RTEP winter case, Voltage Mag. and Voltage Drop Violations at Arrowhead, Damascus, Hillman and South Abingdon 69kV buses under a N-1-1 contingency pair.





## Proposed Solution:

- Terminate the existing Broadford – Wolf Hills #1 138 kV line into Abingdon 138 kV Station. This line currently bypasses the existing Abingdon 138 kV Station.
- Install two new 138 kV circuit breakers on each new line exit towards Broadford and towards Wolf Hills #1
- Install one new 138 kV circuit breaker on line exit towards South Abingdon for standard bus sectionalizing


**Transmission Estimated Cost: \$8.48M**

**Ancillary Benefits:** Operational flexibility is improved with the additional sources into Abingdon

**Alternatives:** Rebuild the existing Arrowhead - Hillman Highway 69 kV line and install a new 34.6 MVAR Capacitor at South Abingdon 138 kV Station. Estimated cost: \$15M

**Required in-service date: 6/1/2027**

**Projected in-service date: 6/1/2027**



**Process Stage:** First Review Solution

**Criteria:** AEP 715 Criteria


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 RTEP Winter case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-AEP-VM4 through 2022W1-AEP-VM21, 2022W1-AEP-VD5 through 2022W1-AEP-VD24

In 2027 Winter RTEP case, Dorton, Pike 29, Rob Fork, Burdine, Henry Clay, Draffin 46KV buses (along the Cedar Creek - Elwood and Breaks - Dorton – Elwood 46KV circuits) experience voltage magnitude and drop violations under multiple N-1-1 contingency scenarios.



## Proposed Solution:

### Transmission Components:


- Establish 69kV bus and new 69 kV line CB at Dorton substation. \$1.13 M
- At Breaks substation, reuse 72kV breaker A as the new 69kV line breaker. \$0.71 M
- Rebuild ~16.7 mi Dorton – Breaks 46kV line to 69kV. \$58.52
- Retire ~17.2 mi Cedar Creek – Elwood 46kV circuit. \$11.15 M
- Retire ~ 6.2 mi Henry Clay – Elwood 46kV line section. \$4.3 M
- Retire Henry Clay 46 kV substation and replace with Poor Bottom 69 kV station. Install a new 0.7 mi double circuit extension to Poor Bottom 69kV. \$3.42 M
- Retire Draffin substation and replace with a new substation. Install a new 0.25 mi double circuit extension to New Draffin substation. \$2.01M
- Remote End work at Jenkins substation. \$0.03 M
- Provide Transition fiber to Dorton, Breaks, Poor Bottom, Jenkins and New Draffin substations. \$0.41M
- Henry Clay S.S Retirement: \$ 0.3 M
- Cedar Creek substation work: \$0.44 M
- Breaks substation retire 46kV equipment: \$0.25 M
- Retire Pike 29 SS and Rob Fork SS: \$0.42 M

**Total Transmission Estimated Cost: \$83M**

### Distribution Components:

- Serve Pike 29 and Rob Fork customers from nearby 34kV Distribution sources. \$ 2.23 M (D cost)
- Poor Bottom substation install: \$8.46 M (D cost)
- Henry Clay 46kV substation retirement: \$0.82 M (D cost)
- New Draffin 69kV substation install: \$6.66 M (D cost)
- Draffin 46kV substation retirement: \$0.68 M (D cost)

**Total Distribution Estimated Cost: \$18.9M**





**Alternatives:** Install 9.6 MVAR 46kV Cap Bank at Dorton substation. This cap bank must be served off the 46kV Bus. Also, install 12.9 MVAR Cap Bank at Cedar Creek substation 46kV Bus. While this fixes the baseline issues identified, it does not address the supplemental needs as identified and mitigated with the proposed solution. (Estimated Cost: \$2.58 M)

**Ancillary Benefits:** This proposal completely addresses identified supplemental needs on Cedar Creek – Elwood 46kV under Need AEP-2019-AP032 (presented 8/29/2019 W-SRRTEP), and Identified supplemental needs on Breaks – Dorton – Elwood 46kV circuit under AEP-2020-AP012 (presented 2/21/2020 W-SRRTEP). The proposal proposes retirement of roughly 23.4 mi of obsolete 46kV line.

**Required in-service date:** 12/1/2027

**Projected in-service date:** 7/31/2027



**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S601 and 2022W1-GD-S943

In 2027 RTEP Summer case, Charleroi to Dry Run 138 kV line is overloaded due to a breaker and bus contingency.

Branch	SN/SE/WN/WE (MVA)
Charleroi – Dry Run 138 kV	292/314/325/343





# APS Transmission Zone: Baseline Charleroi - Dry Run 138 kV

## Proposed Solution:

Replace limiting terminal equipment.

**Transmission Estimated Cost: \$0.38M**

**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.


**Alternatives:** None

## Preliminary Facility Rating:

Branch	SN/SE/WN/WE (MVA)
Charleroi – Dry Run 138 kV	308/376/349/445

**Required in-service date: 6/1/2027**

**Projected in-service date: 6/1/2027**



**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S633 and 2022W1-GD-S949

In 2027 RTEP Summer case, Dry Run to Mitchell 138 kV line is overloaded due to a breaker and bus contingency.

Branch	SN/SE/WN/WE (MVA)
Dry Run - Mitchell 138 kV	292/314/325/343





# APS Transmission Zone: Baseline Dry Run – Mitchell 138 kV

## Proposed Solution:

Replace limiting terminal equipment.

**Transmission Estimated Cost: \$0.40M**

**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.


**Alternatives:** None

## Preliminary Facility Rating:

Branch	SN/SE/WN/WE (MVA)
Dry Run – Mitchell 138 kV	308/376/349/445

**Required in-service date: 6/1/2027**

**Projected in-service date: 6/1/2027**





**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S608, 2022W1-GD-S945, 2022W1-GD-S615 and 2022W1-GD-S616.

In 2027 RTEP Summer case, Charleroi to Dry Run 138 kV line is overloaded due to three breaker and one bus contingency.



Branch	SN/SE/WN/WE (MVA)
Glen Falls – Bridgeport Hill 138 kV	176/209/217/229

**Proposed Solution:**

Replace limiting terminal equipment.

**Transmission Estimated Cost:** \$1.88M

**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.


**Alternatives:** None

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
Glen Falls – Bridgeport Hill 138 kV	221/268/250/317

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027



**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S1033

In 2027 RTEP Summer case, Yukon to Charleroi # 1 138 kV line is overloaded due to a tower contingency.

Branch	SN/SE/WN/WE (MVA)
Yukon - Charleroi No.1 138 kV	292/314/325/343



**Proposed Solution:**

Replace limiting terminal equipment.

**Transmission Estimated Cost: \$0.7M**

**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.


**Alternatives:** None

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
Yukon - Charleroi No.1 138 kV	308/376/349/445

**Required in-service date: 6/1/2027**

**Projected in-service date: 6/1/2027**



**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S1029

In 2027 RTEP Summer case, Yukon to Westraver 138 kV line is overloaded due to a tower contingency.

Branch	SN/SE/WN/WE (MVA)
Yukon - Westraver 138 kV	292/314/325/343
Westraver – Charleroi 138 kV	274/314/325/343



**Proposed Solution:**

Replace limiting terminal equipment.

**Transmission Estimated Cost:** \$0.45M

**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.


**Alternatives:** None

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
Yukon - Westraver 138 kV	308/376/349/445
Westraver – Charleroi 138 kV	297/365/345/441

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027



# APS Transmission Zone: Baseline Cherry Run - Harmony Jct tap 138 kV

**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 Summer and Winter RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S565 and 2022W1-GD-S940

In 2027 RTEP Summer case, Cherry Run to Harmony Junction tap 138 kV line is overloaded due to one breaker and one bus contingency.

Branch	SN/SE/WN/WE (MVA)
Cherry Run - Harmony Jct tap 138 kV	210/229/229/229
Marlowe – Harmony Jct tap 138 kV	225/295/325/343
Bedington – Harmony Jct tap 138 kV	294/350/349/401



# APS Transmission Zone: Baseline Cherry Run - Harmony Jct tap 138 kV

## Proposed Solution:

- At Bedington Substation: Replace substation conductor, wavetrap, CT's and upgrade relaying
- At Cherry Run Substation: Replace substation conductor, wavetrap, CT's, disconnect switches, circuit breaker and upgrade relaying
- At Marlowe: Replace substation conductor, wavetrap, CT's and upgrade relaying

**Transmission Estimated Cost:** \$4.66M


**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.

**Alternatives:** None

Branch	SN/SE/WN/WE (MVA)
Cherry Run - Harmony Jct tap 138 Kv	221/268/250/317
Marlowe – Harmony Jct tap 138 kV	308/376/349/445
Bedington – Harmony Jct tap 138 kV	308/376/349/445

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027







# APS Transmission Zone: Baseline Shanor – Krendale 138 kV

**Process Stage:** First Review Solution

**Criteria:** Generation Deliverability

**Assumption Reference:** 2027 RTEP assumption


**Model Used for Analysis:** 2027 Summer RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-GD-S28

In 2027 RTEP Summer case, Shanor to Krendale 138 kV line is overloaded due to single contingency.

Branch	SN/SE/WN/WE (MVA)
Shanor – Krendale 138 kV line	353/422/419/459



### Proposed Solution:

- Replace one span of 1272 ACSR from Krendale substation to structure 35 (~630 ft)
- Replace one span of 1272 ACSR from Shanor Manor to structure 21 (~148 ft)
- Replace 1272 ACSR risers at Krendale & Shanor Manor Substations
- Replace 1272 ACSR Substation Conductor at Krendale Substation
- Replace relaying at Krendale Substation
- Revise Relay Settings at Butler & Shanor Manor Substations.

**Transmission Estimated Cost:** \$1.75M

**Ancillary Benefits:** Upgrading the limiting terminal equipment will increase the ratings of the line.


**Alternatives:** None

**Preliminary Facility Rating:**

Branch	SN/SE/WN/WE (MVA)
Shanor – Krendale 138 kV line	443/535/500/607

**Required in-service date:** 6/1/2027

**Projected in-service date:** 12/1/2023



**Process Stage:** First Review Solution

**Criteria:** Baseline Analysis


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer and Winter RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-N1-WT83 & 2022W1-N1-ST5

In 2027 RTEP Summer and winter case, Elko to Ridgeway 138 kV line is overloaded to P5 contingency.



## Proposed Solution:

- At Carbon Center Substation: Replace and add relaying to ensure there is redundancy for 230 kV and 138 kV bus & stuck breaker faults to avoid remote-end clearing. The new redundant relaying shall meet the TPL-001-4 non-redundant relays standard.

**Transmission Estimated Cost:** \$0.57M


**Ancillary Benefits:** Installation of redundant relaying will prevent outage scenarios and improve reliability of the transmission system.

**Alternatives:** None

**Preliminary Facility Rating:** N/A

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027



**Process Stage:** First Review Solution

**Criteria:** Baseline Analysis

**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer and Winter RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-N1-ST3, 2022W1-N1-ST4, 2022W1-N1-ST14, 2022W1-N1-ST15, 2022W1-N1-SVM1, 2022W1-N1-SVM2, 2022W1-N1-SVM5 through 2022W1-N1-SVM10, 2022W1-N1-SVM13 through 2022W1-N1-SVM16, 2022W1-N1-SVD3, 2022W1-N1-SVD4, 2022W1-N1-SVD7 through 2022W1-N1-SV12, 2022W1-N1-SV15, 2022W1-N1-SV16, 2022W1-N1-SV19, 2022W1-N1-SV20, 2022W1-N1-WT20, 2022W1-N1-WT21, 2022W1-N1-WT67, 2022W1-N1-WT68, 2022W1-N1-WVM3, 2022W1-N1-WV4, 2022W1-N1-WV11, 2022W1-N1-WV12, 2022W1-N1-WV15 to 2022W1-N1-WV18, 2022W1-N1-WV21, 2022W1-N1-WV22, 2022W1-N1-WV29, 2022W1-N1-WV30, 2022W1-N1-WV33, 2022W1-N1-WV34, 2022W1-N1-WV39, 2022W1-N1-WV40, 2022W1-N1-WVD3, 2022W1-N1-WVD4, 2022W1-N1-WVD15, 2022W1-N1-WVD16, 2022W1-N1-WVD19, 2022W1-N1-WVD20, 2022W1-N1-WVD21, 2022W1-N1-WVD22, 2022W1-N1-WVD25, 2022W1-N1-WVD26, 2022W1-N1-WVD37, 2022W1-N1-WVD38, 2022W1-N1-WVD43 & 2022W1-N1-WVD44

In 2027 RTEP Summer and winter case, Thermal overloads voltage drop violations and voltage magnitude violations at multiple 138 kV buses due to two P5 contingencies.



**Proposed Solution:**

- At Meadow Brook Substation: Replace and add relaying to ensure there is redundancy for 500 kV and 138 kV bus & stuck breaker faults to avoid remote-end clearing. The new redundant relaying shall meet the TPL-001-4 non-redundant relays standard

**Transmission Estimated Cost:** \$0.21M

**Ancillary Benefits:** Installation of redundant relaying will prevent outage scenarios and improve reliability of the transmission system.

**Alternatives:** None

**Preliminary Facility Rating:** N/A

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027



**Process Stage:** First Review Solution

**Criteria:** Baseline Analysis


**Assumption Reference:** 2027 RTEP assumption

**Model Used for Analysis:** 2027 Summer and Winter RTEP case

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:** 2022W1-N1-SVM3, 2022W1-N1-SVM4, 2022W1-N1-SVM11, 2022W1-N1-SVM12, 2022W1-N1-SVD1, 2022W1-N1-SVD2, 2022W1-N1-SVD5, 2022W1-N1-SVD6, 2022W1-N1-SVD13, 2022W1-N1-SVD14, 2022W1-N1-SVD17, 2022W1-N1-SVD18, 2022W1-N1-WT88, 2022W1-N1-WT89, 2022W1-N1-WVM1, 2022W1-N1-WVM2, 2022W1-N1-WVM5 through 2022W1-N1-WVM10, 2022W1-N1-WVM13, 2022W1-N1-WVM14, 2022W1-N1-WVM19, 2022W1-N1-WVM20, 2022W1-N1-WVM23 through 2022W1-N1-WVM28, 2022W1-N1-WVM31, 2022W1-N1-WVM32, 2022W1-N1-WVM35 through 2022W1-N1-WVM38, 2022W1-N1-WVD1, 2022W1-N1-WVD2, 2022W1-N1-WVD5 through 2022W1-N1-WVD14, 2022W1-N1-WVD17, 2022W1-N1-WVD18, 2022W1-N1-WVD23, 2022W1-N1-WVD24, 2022W1-N1-WVD27 through 2022W1-N1-WVD36, 2022W1-N1-WVD39 through 2022W1-N1-WVD42, 2022W1-N1-WVD45 & 2022W1-N1-WVD46

In 2027 RTEP Summer and winter case, Thermal overloads voltage drop violations and voltage magnitude violations at multiple 138 kV buses due to two P5 contingencies.



## Proposed Solution:

- At Bedington Substation: Replace and add relaying to ensure there is redundancy for 500 kV and 138 kV bus & stuck breaker faults to avoid remote-end clearing. The new redundant relaying shall meet the TPL-001-4 non-redundant relays standard.

**Transmission Estimated Cost:** \$0.28M


**Ancillary Benefits:** Installation of redundant relaying will prevent outage scenarios and improve reliability of the transmission system.

**Alternatives:** None

**Preliminary Facility Rating:** N/A

**Required in-service date:** 6/1/2027

**Projected in-service date:** 6/1/2027







# EKPC Transmission Zone: Baseline Fawkes-Duncannon Lane Tap 69 kV Rebuild

**Process Stage:** First Review

**Criteria:** EKPC 715 Criteria

**Assumption Reference:** EKPC Assumptions Presentation slides 3-10

**Model Used for Analysis:** EKPC's internal models representing 2026/27 winter peak conditions that were used for EKPC's annual system screening analysis for 2022 planning cycle. Includes Cooper Units 1 and 2 off with replacement generation imported from the north of EKPC system.

**Proposal Window Exclusion:** Below 200 kV Exclusion

**Problem Statement:**

The Fawkes-Duncannon Lane Tap 69 kV line (LGEE-EKPC tie line) is overloaded for an N-1 outage.

Violation was posted as part of the 2022 Window 1: FG# 2022W1-EKPC-T1


**Existing Facility Rating:** 89SN/98SE, 128WN/134WE MVA

**Proposed Facility Rating:** 114SN/127SE, 166WN/174WE MVA

**Proposed Solution:**

Rebuild EKPC's Fawkes-Duncannon Lane Tap 556.5 ACSR 69 kV line section (7.2 miles) using 795 ACSR.

**Estimated Cost:** \$8.5 M





# EKPC Transmission Zone: Baseline Fawkes-Duncannon Lane Tap 69 kV Rebuild

## Alternatives:

1. Increase the maximum operating temperature of the existing 556.5 MCM ACSR conductor in the KU Fawkes-Duncannon Lane Tap 69 KV line section from 212 degrees Fahrenheit to 302 degrees Fahrenheit.

Estimated cost: \$1.5M

2. Establish a new normally-open interconnection with LGE/KU south of the Crooksville Junction tap point.

Estimated cost: \$10.5 M


3. Construct a new 138 kV line from the EKPC Fawkes substation to the Crooksville Junction tap point and construct a new 138/69 KV substation near this location for connection to the existing KU Fawkes-West Berea 69 KV circuit.

Estimated cost: \$24.8 M

**Ancillary Benefits:** Replacement of aging infrastructure associated with line section.

**Required In-Service:** 12/1/2026

**Projected In-Service:** 12/31/2024



SME/Presenter:

Wenzheng Qiu

[Wenzheng.Qiu@pjm.com](mailto:Wenzheng.Qiu@pjm.com)

Hamad Ahmed;

[Hamad.Ahmed@pjm.com](mailto:Hamad.Ahmed@pjm.com)

Julia Spatafore;

[Julia.Spatafore@pjm.com](mailto:Julia.Spatafore@pjm.com)

**SRRTEP-W Reliability Analysis Update**



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

[custsvc@pjm.com](mailto:custsvc@pjm.com)

- V1 – 10/10/2022 – Original slides posted
- V2 – 10/13/2022 – Slide #25, correct the estimated cost from \$8.23M to \$8.48M

**PROTECT THE  
POWER GRID  
THINK BEFORE  
YOU CLICK!**



Be alert to  
malicious  
phishing emails.

**Report suspicious email activity to PJM.**  
(610) 666-2244 / [it\\_ops\\_ctr\\_shift@pjm.com](mailto:it_ops_ctr_shift@pjm.com)

