

# Transmission Expansion Advisory Committee – PEPCO Supplemental Projects

August 4, 2020

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** PEP-2020-001

**Process Stage:** Need Meeting 8/4/2020

**Project Driver:**

Equipment Material Condition, Performance and Risk


**Specific Assumption Reference:**

Transmission infrastructure replacements (EOL/condition/obsolescence) that are consistent with efficient asset management decisions

**Problem Statement:**

230kV circuits 23067 & 23087 from Oak Grove to Talbert (~10 miles), constructed in 1968, are exhibiting severe material condition issues:

- All structures are currently rusting and are at risk for structural failure
- All structures need replacement of insulators, conductor, all hardware, lattice coating, foundation/lattice leg repairs, tower attachment points/vangs
- 20% structures need immediate grounding replacement, foundation replacement and lattice/bent member repairs
- Tested insulator samples no longer meet mechanical design rating



# Questions?



# Appendix

# High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

7/24/2020 - V1 – Original version posted to pjm.com