



Reliability Analysis Update

Sami Abdulsalam, Director
PJM Transmission Planning

Transmission Expansion Advisory Committee
August 6, 2024

- 2024 Window 1 Updates
 - Timeline
 - Summary of 2029 vs 2032 System Model Comparison
 - P5 Contingencies – Update
 - Next Steps

2024 RTEP Window 1 Updates

- Current schedule

- 2024 RTEP proposal Window 1 opened on July 15th, 2024, and will close on September 13th, 2024
 - First addendum posted on July 25th
 - Posting of the 8 year study files and updated problem statement on August 2nd
 - Targeting to release the sensitivity cases August 16th
- 60 day window
- Window summary and solutions to be brought forward to the TEAC starting in Oct. 2024 and through Jan. 2025
- Board approvals in Feb 2025



2024 RTEP 2029 vs. 2032 Summary

- Right size solutions of the 5-Year RTEP needs
- Capture Long-Lead Items
- Check/Confirm impact of “forecast” generation on transmission needs identified in the 5-Years model
 - Model reasonably anticipated generation “forecast” in Dominion
 - Confirm whether forecast resources available in the west supports needed West-East transfers
 - Evaluate whether forecast generation offsets regional path transfer need (DOM and MAAC resources)

- Increase load to align with the 2032 load forecast:
 - 4.5 GW increase in Dominion
 - 1.4 GW increase in MAAC
 - 0.65 GW increase in West
- Include the remainder of the NJ SAA OSW, and associated upgrades
- Additional generation to accommodate the significant load increase, including but not limited to:
 - CVOW
 - Chesterfield
- Generation deactivations, notably:
 - Elwood and Elgin



Area Interchange - Ties (2029 vs 2032)

SUMMER

Row Labels	MW Flow 2029	MW Flow 2032	MW Change
Dominion	-6,886	-8,093	-1,207
MAAC	403	2,559	2,155
West	9,019	7,927	-1,093

WINTER

Row Labels	MW Flow 2029	MW Flow 2032	MW Change
Dominion	-10,298	-12,409	-2,111
MAAC	4,616	5,556	940
West	8,077	9,285	1,208



Need for continued reinforcement of West/APS-DOM transfer path

Consistent need for high West/APS – MAAC transfer capability




Load and Gen Dispatch Increase – Summer (2029 to 2032)


PJM	MW Increase Load
Dominion	3,673
MAAC	716
West	216
Grand Total	4,606

PJM	MW Increase Gen Dispatch
Dominion	2,681
MAAC	2,817
West	-872
Grand Total	4,626

Year Over Year Load Increase



Year Over Year Gen Dispatch Increase






Load and Gen Dispatch Increase – Winter (2029 to 2032)


PJM	MW Increase Load
Dominion	3,883
MAAC	2,204
West	340
Grand Total	6,427

PJM	MW Increase Gen Dispatch
Dominion	1,929
MAAC	3,271
West	1,611
Grand Total	6,811

Year Over Year Load Increase



Year Over Year Gen Dispatch Increase







New Generator Additions In 2032 As Compared to 2029 Case

Row Labels	Increase in Pmax (MW)
DVP	3,878
Solar	100
Thermal and Other	1,138
Wind	2,640
MAAC	3,742
Wind	3,742
PJM West	292
Solar	292
Grand Total	7,912

New Generators in 2032 By PJM Region



New Generators in 2032 by Gen Type






Deactivated Generation In 2032 As Compared To 2029 Case


- This encapsulates the Elgin/Elwood generators

Row Labels	Decrease in Pmax (MW)
PJM West	1833.1
Thermal and Other	1833.1
Grand Total	1833.1


2029 vs. 2032 RTEP Window 1 Summer Comparison



2029 vs. 2032 RTEP Window 1 Winter Comparison



Forecast Generation Impact – Internal DOM upgrades: 2032





New Thermal Overloads (2032) Not including unsolved contingencies

	Summer	Winter	Light Load
Above 345 kV	14	6	9
Below 345 kV	50	32	26
Transformers	12	10	5
Total New overloads	76	48	40

*PJM is in the process of validating the overloads with the TO's

** PJM is also in the process of validating if facilities are conductor limited

- AEP is forecasting load growth in the next 5 to 8 years (up to 2032)
- Forecast update submissions ongoing and will be captured part of the 2025 PJM Load Forecast (to be published in Dec 2024/ Jan 2025)
- PJM will bring forward additional information regarding load and generation assumptions to the August TEAC.
- This sensitivity analysis to be conducted by PJM will focus on ensuring selection of the right solutions out of 2024W1 RTEP – will not introduce new needs/solutions.

- Consistent regional long lead reliability needs between 5 and 8 year timeframes
- 500 kV that do not have long lead will be excluded (ex. transformers, breaker contingency driven and shorter developments)
- 230 kV long lead needs (that are more tied to regional transfers)
- Solutions to common needs between 5 and 8 years will have to be right-sized to address both needs.
- Instances where longer lead solutions could address multiple near-term needs.

- PJM has determined that the P5 CAPs fall under the exemption for thermal reliability violations on transmission substation equipment (OA, Schedule 6, section 1.5.8(p))
 - The substation equipment exemption is limited to a narrow set of transmission facilities (*i.e.*, existing transmission substation equipment, including ancillary protective devices, where the substation requirement is the limiting element giving rise to the reliability violation)
 - Such violations are resolved as a replacement in kind to existing transmission substation equipment
 - In the case of P5 violations, the ancillary protective devices (e.g., battery, relay, communication systems, CT/PT, DC trip) are the limiting elements giving rise to the reliability violation
- The solution to the violations, including redundancy, lack of alarming, or DC supply issues including monitoring and alarming, is to incorporate local redundancy or implement needed alarms/protection/DC supply enhancements within existing substation equipment.

- AEP/Western Load growth sensitivity model (to inform selection of needed transmission) will be posted around August 16th
- 2024W1 RTEP will be running for 60 days and targeting PJM Board Approvals (Feb 2025)
 - TEAC 1st and 2nd reads to span between Oct 2024 and Jan 2025

Facilitator:

Jason Connell,
Jason.Connell@pjm.com

Secretary:

Tarik Bensala,
Tarik.Bensala@pjm.com

SME/Presenter:

Sami Abdulsalam,
Sami.Abdulsalam@pjm.com

Reliability Analysis Update



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

Version No.	Date	Description
1	8/1/2024	<ul style="list-style-type: none"> Original slides posted
2	8/5/2024	<ul style="list-style-type: none"> Added slide 15: Forecast Generation Impact – Internal DOM upgrades: 2032. Updated the Y-axis on slides 8,9,10.

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

