



# MISO identified regional issues and planned solutions near the MISO-PJM Seam

Supplemental material for *Annual Issues Review*  
*IPSAC meeting*

February 17, 2022

# Notes



- This presentation provides an overview/highlight of significant MISO MTEP transmission projects near the MISO-PJM seam which have been either approved in MTEP21 Appendix A or proposed for MTEP22
- It is not a comprehensive review of all planned projects in MISO. For the complete list of information see the following public documents:
  - MTEP21 Report (notably, *Appendix A*):  
<https://www.misoenergy.org/planning/planning/mtep21/>
  - *MTEP Projects Under Evaluation* status report:  
<https://cdn.misoenergy.org/MTEP%20Projects%20Under%20Evaluation368757.xlsx>
  - Planning Advisory Committee (PAC) Materials  
<https://www.misoenergy.org/stakeholder-engagement/committees/planning-advisory-committee/>
  - Subregional Planning Meeting (SPM) Materials  
<https://www.misoenergy.org/stakeholder-engagement/committees/subregional-planning-meeting/>


# MTEP21 Approved Project Highlights –

## MISO East and Central Subregion

# AmerenMO


# AmerenMO: Two (2) BRPs proposed to address reliability issues on bulk energy system

- TO proposed project
- MISO identified reliability need
- Need + Project



# New Belleau 138 kV Capacitor Bank solves a transient voltage response issue

- **P19969 - Baseline Reliability Project**
- **Project description**
  - Install 120 Mvar capacitor bank at Belleau 138 kV
- **System Need**
  - Without the cap bank, could not meet the 90% of nominal or higher 10 seconds after fault clearing required by Ameren Criteria.
- **Estimated Cost: \$3.5M**
- **Expected ISD: June 1, 2025**
- **Target Appendix: A in MTEP21**
- **Alternatives:** Ameren considered several alternatives; however, this was the best and most efficient project
- **NTA Eligibility:** No, needed for Transient Voltage Recovery



# AmerenMO - P19969 New Belleau 138 kV Capacitor Bank – Analysis Summary


Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Voltage Violation (p.u.)	Comment
[AECI] Enon 161 kV bus	161	P6-1-1	0.95	Post-project voltage is 0.98 p.u.
[AECI] O'Fallon 161 kV bus	161	P6-1-1	0.95	Post-project voltage is 0.98 p.u.
[AECI] Lake Street 161 kV bus	161	P6-1-1	0.95	Post-project voltage is 0.98 p.u.
[AMMO] Pointe Prarie 161 kV bus	161	P6-1-1	0.95	Post-project voltage is 0.99 p.u.

This project is also needed to aid in transient recovery in the same O'Fallon Missouri area. A separate dynamics stability analysis was performed to confirm that this project addresses the stability issues.

**Preliminary Recommendation:** Move to Appendix A

# New Galena 161 kV Capacitor Bank solves P6-2-2 low voltage issues

- **P20156 - Baseline Reliability Project**
- **Project description**
  - Install 28.8 Mvar capacitor bank at Galena 161 kV.
- **System Need**
  - Baseline reliability to address P6-2-2 event, which is the loss of two BES transformers.
- **Estimated Cost:** \$900k
- **Expected ISD:** December 1, 2022
- **Target Appendix:** A in MTEP21
- **Alternatives:** Ameren considered several alternatives; however, this was the best and most efficient project
- **NTA Eligibility:** No, load serving needs





# AmerenMO – P20156 New Galena 161 kV Capacitor Bank– Analysis Summary


Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Voltage Violation (p.u.)	Comment
[AMMO] Galena 161 kV bus	161	P6-2-2	0.90	Post-project voltage is 0.94 p.u.
[AMMO] Buick Mine 161 kV bus	161	P6-2-2	0.90	Post-project voltage is 0.94 p.u.
[AMMO] Cominco 161 kV bus	161	P6-2-2	0.90	Post-project voltage is 0.94 p.u.
[AMMO] Buick Smelter 161 kV bus	161	P6-2-2	0.90	Post-project voltage is 0.94 p.u.

**Preliminary Recommendation:** Move to Appendix A

# AmerenIL


# AmerenIL: Three (3) BRPs proposed to address reliability issues on bulk energy system

- TO proposed project
- MISO identified reliability need
- Need + Project



# Rebuild [AMIL] Hickok—[AMIL] N. LaSalle 138 kV line solves P6-1-1 thermal overload

- **P18889 - Baseline Reliability Project**
- **Project description**
  - Address an overload on the Hickok—North LaSalle 138 kV line (1659) upon completion of the N. Utica Statcom.
- **System Need**
  - Rebuild this line
- **Estimated Cost:** \$10 M
- **Expected ISD:** December 1, 2023
- **Target Appendix:** A in MTEP21
- **Alternatives:** Ameren considered several alternatives; however, this was the best and most efficient project
- **NTA Eligibility:** Yes




# AmerenIL – P18889 Rebuild [AMIL] Hickok—[AMIL] N. LaSalle 138 kV line – Analysis Summary

Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[AMIL] Hickok—[AMIL] North LaSalle 138 kV line	138	P6-1-1	103	Post-project loading is 40%.

**Preliminary Recommendation:** Move to Appendix A

# Rebuild [AMIL] Tanner—[AMIL] Jasper 138 kV line solves P6-1-1 thermal overload

- **P19956 - Baseline Reliability Project**
- **Project description**
  - Replace limiting switch 1602L at Tanner with 2000A switch.
- **System Need**
  - P6-1-1 Event: 104% loading 2024 Summer peak based on 2019 analysis.
- **Estimated Cost: \$9 M**
- **Expected ISD: December 1, 2022**
- **Target Appendix: A in MTEP21**
- **Alternatives:** Ameren considered several alternatives; however, this was the best and most efficient project
- **NTA Eligibility:** No, load serving needs




# AmerenIL – P19956 Rebuild [AMIL] Tanner—[AMIL] Jasper 138 kV line – Analysis Summary

Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[AMIL] Tanner—[AMIL] Jasper 138 kV line	138	P6-1-1	176	Post-project loading is 60%.

**Preliminary Recommendation:** Move to Appendix A

# New [AMIL] REOS 138 kV substation solves P6-1-1 thermal overloads

- **P20184 - Baseline Reliability Project**
- **Project description**
  - Ring bus North of RS Wallace that ties together RS Wallace - Spring Bay and CAT2 - Hines 138 kV lines.
- **System Need**
  - Baseline reliability (P6-1-1) event loss of two 138 kV lines.
- **Estimated Cost:** \$9.5 M
- **Expected ISD:** December 1, 2024
- **Target Appendix:** A in MTEP21
- **Alternatives:** P20157: Reconductor Edwards-CAT 138 kV line
- **NTA Eligibility:** No, load serving needs





# AmerenIL – P20184 New [AMIL] REOS 138 kV substation – Analysis Summary


Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[AMIL] Edwards—[AMIL] CAT 138 kV line	138	P6-1-1	103	Post-project loading is 83%.

**Preliminary Recommendation:** Move to Appendix A

# Big Rivers Electric Corporation (BREC)

# BREC: Two (2) BRP proposed to address reliability issues on bulk energy system

- TO proposed project
- MISO identified reliability need
- Need + Project



# BREC: New [BREC] Ensor 161/69 kV substation solve(s) *P1-2 and P1-3 voltage and thermal issue*

- **P3439 Baseline Reliability Project**

- **Project description**

Construct new 161/69 kV substation with 56 MVA transformer. Include a 69 kV 30 Mvar capacitor.

- **System Need**

Address low voltage issues for the loss of a NERC defined P1-2 contingency event and 111% loading for P1-3 contingency event in 2026 Summer peak.


- **Estimated Cost: \$5.0M**

- **Expected ISD: December 31, 2024**

- **Target Appendix: A in MTEP21**

- **Alternatives:** BREC considered several transmission alternatives. However, this upgrade was found to be the best and cheapest option to address this reliability issue.

- **NTA Eligibility: yes**



# BREC — New [BREC] Ensor 161/69 kV substation — Analysis Summary

Voltage Violations				
Substation	Voltage Level (kV)	Contingency Category	Voltage Violation (p.u.)	Comment
[BREC] Local 69 kV Buses	69	P1-2	0.92	Post-project voltage is 0.92 p.u.
[BREC] Newman 161 kV	161	P1-2	0.92	Post-project voltage is 0.93 p.u.
[BREC] Daviess County 161 kV	161	P1-2	0.92	Post-project voltage is 0.94 p.u.

Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[BREC] Daviess County 161/69 kV transformer	161	P1-3	111	Post-project loading is 82%.

# BREC: New [BREC] Hancock County Capacitor Bank addition solve(s) *P1-2 voltage issue*

- **P21387 Baseline Reliability Project**

- **Project description**

Add a 35 MVar capacitor bank on the 69 kV bus at the existing Hancock County substation.

- **System Need**

Low voltage mitigation at Daviess County 161 kV bus for loss of [BREC] Reid-[BREC] Daviess 161 kV line.


- **Estimated Cost:** \$0.5M

- **Expected ISD:** October 1, 2022

- **Target Appendix:** A in MTEP21

- **Alternatives:** BREC considered several transmission alternatives. However, this upgrade was found to be the best and cheapest option to address this reliability issue.

- **NTA Eligibility:** yes



# BREC — New [BREC] Hancock County Capacitor Bank Addition — Analysis Summary


Voltage Violations				
Substation	Voltage Level (kV)	Contingency Category	Voltage Violation (p.u.)	Comment
[BREC] Davis 161 kV Bus	161	P1-2	0.92	Post-project voltage is 0.94 p.u.
[BREC] Newman 161 kV Bus	161	P1-2	0.92	Post-project voltage is 0.93 p.u.

# Duke Energy (DEI)



# Duke: Three (3) BRPs proposed to address reliability issues on bulk energy system

- TO proposed project
- MISO identified reliability need
- Need + Project



# Duke: Rebuild [DEI] Purdue NW Tap—[DEI] Purdue 138 kV line solve(s) *P4-2 thermal issue*

- **P20230 Baseline Reliability Project**

- **Project description**

Rebuild [DEI] Purdue NW Tap—[DEI] Purdue 138 kV line with summer emergency rating 243 MVA

- **System Need**

P4-2 Event: 111% loading in year 2023 summer peak


**Estimated Cost: \$9.5M**

- **Expected ISD: December 31, 2023**

- **Target Appendix: A in MTEP21**

- **Alternatives:** DEI considered several transmission alternatives. However, this upgrade was found to be the best and cheapest option to address this reliability issue

- **NTA Eligibility: yes**



# Duke — Rebuild [DEI] Purdue NW Tap—[DEI] Purdue 138 kV line — Analysis Summary

Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[DEI] Purdue NW Jct Tap 2- [DEI] West Lafayette Airport 138 kV line	138	P4-2	111	Post-project loading is 73%.
[DEI] Purdue - [DEI] West Lafayette Airport 138 kV line	138	P4-2	103	Post-project loading is 67%.

# Duke: Rebuild [DEI] Lafayette South—[DEI] Shadeland 138 kV solve(s) *P6-1-1 and P7 thermal issue*

- **P20247 Baseline Reliability Project**

- **Project description**

Rebuild [DEI] Lafayette South—[DEI] Shadeland 138 kV line with summer emergency rating of 291 MVA

- **System Need**

P6-1-1 and P7 Events: 99% loading in year 2026 summer peak


**Estimated Cost:** \$6.4M

- **Expected ISD:** June 1, 2023

- **Target Appendix:** A in MTEP21

- **Alternatives:** DEI considered several transmission alternatives. However, this upgrade was found to be the best and cheapest option to address this reliability issue.

- **NTA Eligibility:** yes



# Duke —Rebuild [DEI] Lafayette South—[DEI] Shadeland 138 kV line — Analysis Summary

Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[DEI] Lafayette South—[DEI] Shadeland 138 kV line	138	P6-1-1	99	Post-project loading is 61%.
[DEI] Lafayette South—[DEI] Shadeland 138 kV line	138	P7	99	Post-project loading is 61%.

# Duke: New [DEI] Dresser 345 kV Redundant Ckt Breaker solve(s) P4-3 thermal issue

- **P20248 Baseline Reliability Project**

- **Project description**

New [DEI] Dresser 345 kV Redundant circuit breaker addition between Bank-1 and Bank-2 with fully redundant protection scheme per future TPL-001-5 P5 contingency definition.

- **System Need**

- P2/P4 Events: Thermal violation: [DEI] Dresser 345/138kV Bk3 transformer


- **Estimated Cost: \$8.0M**

- **Expected ISD: June 1, 2023**

- **Target Appendix: A in MTEP21**

- **Alternatives:** Duke is currently investigating feasibility of a less expensive project that would add relaying/control logic for an auto-isolation and restoration scheme.

- **NTA Eligibility: yes**



# Duke —New [DEI] Dresser 345 kV Redundant Circuit Breaker — Analysis Summary

Thermal Violations				
Substation	Voltage Level (kV)	Contingency Category	Max Loading (%)	Comment
[DEI] Dresser 345/138 kV transformer	345	P4-3	102	Post-project loading is 61%.

# METC

Projects are tabulated for space considerations. Complete project details available with [East SPM3 materials](#)



# MISO MTEP21 Recommendations show 37 projects recommended for Appendix A and 20 projects recommended for Appendix B

Project ID	Project Name	Project Type	Target Appendix	Expected ISD	Cost [\$M]	Recommendation
19958	Whiting 2nd 138-120kV Transformer	BRP	A	12/31/2024	6.7	Appendix B
19960	Rebuild Dort (Calvary) - Garfield 138kV	BRP	A	12/31/2024	18.1	Appendix B
19964	Sag Remediate Arthur Jct. - Tallmadge 138kV	BRP	A	12/31/2023	0.66	Appendix B
19970	Rebuild Alma - Vestaburg 138 kV 477 ACSR	BRP	A	12/31/2024	2.8	Appendix A
20015	Rebuild Bingham - Cornell 138 kV	BRP	A	6/1/2025	31	Appendix B
20016	Rebuild Eureka - Deja Jct 138 kV	BRP	A	6/1/2025	19	Appendix B
20017	Rebuild Alma - Regal #1 138 kV	BRP	A	6/1/2025	11	Appendix B
20018	Rebuild Bullock - Shale 138 kV	BRP	A	6/1/2025	33	Appendix A

# MISO MTEP21 Recommendations show 37 projects recommended for Appendix A and 20 projects recommended for Appendix B

Project ID	Project Name	Project Type	Target Appendix	Expected ISD	Cost [\$M]	Recommendation
20019	Rebuild Bullock - Edenville Jct 138 kV	BRP	A	6/1/2025	21.1	Appendix B
20020	Gaylord - Mio Dam 138kV Rebuild	BRP	A	6/1/2025	75.1	Appendix B
20021	Rebuild Bullock - Salt River 138 kV	BRP	A	12/31/2024	29.31	Appendix B
20022	Rebuild Salt River - Summerton 138 kV	BRP	A	12/31/2024	12.33	Appendix B
20031	Sag Remediate Corwith - Rondo 138kV	BRP	A	6/1/2025	1.7	Appendix B
20033	Sag Remediate Weadock - Carter Jct 138 kV	BRP	A	6/1/2025	0.88	Appendix A
20034	Sag Remediate Higgins - Mio Dam 138kV	BRP	A	6/1/2025	1.005	Appendix B
20041	Sag Remediate Bard Road - Higgins 138kV	BRP	A	6/1/2025	0.8	Appendix B

# MISO MTEP21 Recommendations show 37 projects recommended for Appendix A and 20 projects recommended for Appendix B

Project ID	Project Name	Project Type	Target Appendix	Expected ISD	Cost [\$M]	Recommendation
20048	Sag Remediate Bard Rd - Grout Jct 138kV	BRP	A	6/1/2025	0.26	Appendix B
20049	Rebuild and Sag Remediate Gallagher - Twining 138kV	BRP	A	6/1/2025	0.97	Appendix A
20050	Vanderbilt 138 kV Station Equipment Upgrades	BRP	A	6/1/2025	0.11	Appendix B
20051	Whittemore 138 kV Trainer Upgrade	BRP	A	6/1/2025	0.084	Appendix B
20052	Summerton 138 kV 500 Bus Upgrade	BRP	A	12/31/2023	0.37	Appendix B
20053	Warren 138 kV 188 Bus Upgrade	BRP	A	12/31/2023	0.15	Appendix A
20054	Warren 138 kV 377 Equipment Upgrades	BRP	A	12/31/2023	1.05	Appendix A
20117	Rebuild Monroe – Lallendorf 345 kV (METC)	BRP	A	12/31/2024	45.7	Project Withdrawn

# MISO MTEP21 Recommendations show 37 projects recommended for Appendix A and 20 projects recommended for Appendix B

Project ID	Project Name	Project Type	Target Appendix	Expected ISD	Cost [\$M]	Recommendation
20119	Sag Remediate Claremont - Cornell #2 138kV	BRP	A	6/1/2025	0.25	Appendix B
20120	Wackerly 138 kV Station Equipment Upgrades	BRP	A	12/31/2023	0.14	Appendix A
20131	Sag Remediate Lemoyne – Majestic 345 kV	BRP	A	12/31/2023	0.50	Appendix B
20160	Delaney 138 kV 177 Bus Upgrades	BRP	A	6/1/2025	0.16	Appendix B

# Open issues with corrective action plan

Thermal Violations					
Monitored Facility	Voltage Level (kV)	Contingency Category	Highest N-1 (%)	Highest N-1-1 (%)	Corrective Action Plan
Savidge [256104] – Sternberg [256836] Ckt 1	138	P6	---	102.64	METC to submit a project in MTEP22
Lawndale [256193] – Murphy [256499] Ckt 1	138	P7, P6	96.4	113.95	METC to submit a project in MTEP22
Emmet [256137] – Livingston [256201] Ckt 1	138	N1, P6	116.34	109.24	HVDC guide - No project needed
Gallagher [256148] – Ogemaw Jct [256777] Ckt 1	138	N1, P6	105.83	105.78	METC to submit a project in MTEP22
Emmet [256137] – Oden [263656] Ckt 1	138	N1,P6	123.11	138.9	METC submitted a Project to MTEP22 – Age & Condition Related (Non-BRP)

# ITCT

Projects are tabulated for space considerations. Complete project details available with [East SPM3 materials](#)

# MISO MTEP21 Recommendations show 25 projects recommended for Appendix A and 13 projects recommended for Appendix B

Project ID	Project Name	Project Type	Target Appendix	Expected ISD	Cost [\$M]	Recommendation
20109	Sterling - Mustang 1 Tap 120 kV Rebuild	BRP – Line Rebuild	A	12/31/2024	0.516	Appendix B
20110	Pontiac - Sunbird 120 kV Rebuild	BRP – Line Rebuild	A	12/31/2024	7.0	Appendix B
20111	Superior - Wayne #1 and #2 120 kV Rebuild	BRP – Line Rebuild	A	12/31/2024	18.4	Appendix B
20116	Monroe - Lallendorf 345 kV Rebuild (ITCT)	BRP – Line Rebuild	B	12/31/2024	7.8	Appendix B
21206*	Coventry to Hager 120 kV Projects	BRP – Line Rebuild	A	12/31/2023	10.95	Appendix A
15959* (MTEP20)	Hager – Sunset 120 kV Rebuild	BRP – Line Rebuild	A	12/31/2025	9.66	Appendix B
20150	Monroe – Lulu 345 kV Sag Remediation (ITCT)	BRP – Sag Remediation	A	12/31/2024	0.72	Appendix B
15874	Custer 120 kV – Upgrade GA Station Equipment	BRP – Station Equipment	A	12/31/2022	0.15	Appendix B

P#21206 proposed Alternative for MTEP20 Appendix A P#15959. MISO's independent analysis recommends P#21206 for Appendix A and P#15959 for Appendix B.

ITC to move P#15959 to Appendix B in Portal and MOD

# MISO MTEP21 Recommendations show 25 projects recommended for Appendix A and 13 projects recommended for Appendix B

Project ID	Project Name	Project Type	Target Appendix	Expected ISD	Cost [\$M]	Recommendation
20115	Bloomfield 120 kV HG Upgrades	BRP – Station Equipment	A	12/31/2022	0.056	Appendix B
20105	Atlanta 120 kV Reactors	BRP - Reactor	A	12/31/2024	2.8	Appendix B
20182*	Northeast 120 kV 55 MVAR Reactor	BRP - Reactor	A	12/31/2023	1.32	Appendix B
20183*	Stephens 345 kV 55 MVAR Reactor	BRP - Reactor	A	12/1/2023	3.5	Appendix B
20185*	Warren 120 kV 55 MVAR Reactor	BRP - Reactor	A	12/31/2023	1.7	Appendix B
20186*	Mack 120 kV 55 MVAR Reactor	BRP - Reactor	A	12/31/2023	1.7	Appendix B

\*Stakeholders will be notified of any change of status



MTEP22 Projects and  
Issues Under Review –

MISO East and Central  
Subregion

# Preliminary projects and issues are detailed in 1<sup>st</sup> Subregional planning meeting (SPM) materials

- East Subregional SPM 1 February 3, 2022  
<https://www.misoenergy.org/events/east-subregional-planning-meeting-espm---february-3-2022/>
- Central Subregional SPM 1 January 31, 2022  
<https://www.misoenergy.org/events/central-subregional-planning-meeting-cspm---january-31-2022/>
- MTEP22 powerflow models expected March 2022. Please see [MISO modeling page](#) for updates