



Manual 01 Revision 36 – First Read

Bilge Derin
Engineer – Real-Time Data Mgmt
RSCS Meeting
November 16, 2017





M01 R36 Changes Summary

Section	Change to/Updated	Impact
2.3.1	NERC references updated	Minor
2.7	NERC references updated	Minor
3.2	Com methods during outages changed	Moderate
3.8	Transfer of M13 text on outages to M01	Minor
Attach. A	New info service for system restoration planning	Minor

- The following NERC Standards have been retired:
 - TOP-004-2
 - TOP-006-2, TOP-006-3
 - TOP-007-1
 - TOP-008-1
- References to these standards have been updated or removed in M01 Sections 2.3.1 and 2.7.

Section 2.3.1: Transmission Monitoring Capability

Edits (1/1):

PJM relies on Transmission Owners to serve as a backup to PJM, monitoring BES facilities, when the PJM EMS is inoperable (~~TOP-007-1~~). PJM Transmission Owners shall notify PJM dispatch within 15 minutes when their TO analysis packages are unavailable (~~TOP-004-2 R4~~TOP-010(i)-1 R3.2). In general, PJM may be in an unknown state when both PJM and TO analysis packages are unavailable.

Section 2.7: PJM Member Back Up Capability Required to Support PJM in its TOP Role

Edits (1/6):

If a PJM member primary EMS capability becomes unavailable, PJM will need back up capability (may include backup EMS or backup functionality or staffing critical substations, etc.) from the Transmission Owner to be available (within ~~1-hour~~ 2 hours per EOP-008-1 R1.5) from that member so that PJM can continue to perform its obligations as the TOP during such interruptions.

Section 2.7: PJM Member Back Up Capability Required to Support PJM in its TOP Role

Edits (2/6):

NERC Standard ~~TOP-004, R1~~TOP-001-3 R12, R14 requires the TOP to operate within the limits of its IROLs and SOLs. If the data for monitoring the IROLs and SOLs passes through the PJM member EMS and that capability becomes lost, then the PJM member is required to have a backup capability to ensure that the necessary data continues to be provided to PJM.

Section 2.7: PJM Member Back Up Capability Required to Support PJM in its TOP Role

Edits (3/6):

During the TO transition to its back up facility, PJM will continue to monitor the TO Transmission System to the extent data quality permits [per EOP-008-1 R1.6.2](#).

Section 2.7: PJM Member Back Up Capability Required to Support PJM in its TOP Role

Edits (4/6):

~~NERC Standard TOP-004, R6 requires the TOP to have formal policies and procedures to ensure transmission reliability. If the PJM member is unable to execute operating procedures that may be implemented by PJM, such as switching or load shedding, due to the unavailability of its EMS or other operational tools, then the PJM member is required to have a backup capability to be able to execute these actions.~~

Section 2.7: PJM Member Back Up Capability Required to Support PJM in its TOP Role

Edits (5/6):

NERC Standard ~~TOP-006, R1, R2, R5-7~~, TOP-003-3 R19, R20 requires data to be provided to PJM to ensure reliability. If such data is interrupted by unavailability of the PJM member EMS, then the PJM member is required to have a backup capability to ensure that the necessary data continues to be provided to PJM.

Section 2.7: PJM Member Back Up Capability Required to Support PJM in its TOP Role

Edits (6/6):

NERC Standard ~~TOP-008, R1-4~~TOP-001-3 R12, R14 requires PJM to take immediate action to mitigate potential and actual IROL or SOL violations. Many of those actions require the PJM member to execute actions requested by PJM. If the unavailability of the PJM member EMS or other tools prevents the execution of those actions, then the PJM member is required to have back up capability to ensure that it can execute PJM requested actions.

Section 3.2.3: EMS Data Exchange

Summary:

- The restructuring of requirements for Member actions during EMS data exchange (data link or RTU) planned and unplanned outages, continued from R35.
- Follow up activities are more conclusive on the type of failure and the capabilities of the Member.
- Two new subsections have been created for better clarity.
 - Requirements for electronic and verbal alternate communications
- Thresholds for types of data to be sent and the change in values that necessitate an update have been lowered.
 - This change increases the level of activity and communication required during an outage.

IF an *RTU/device* fails and a subset of data over an ICCP/DNP link to PJM is failed (not updating, bad quality, inaccurate, etc.)

THEN manually replace the values on the data link

OR if not feasible then begin verbal communications

OR if not feasible then begin file transfer based communications

IF an *EMS Link* fails and all data on the link is failed (not updating, bad quality, inaccurate, etc.)

THEN begin file transfer based communications

OR if not feasible then begin verbal communications

Features of **Electronic** Alternate Data Communications:

- Certain data to be sent every 30 minutes:
 - Tie Line Flows, both internal and external
 - Transmission MW and MVAR flows and bus voltages at ≥ 100 kV
 - Generation MW and MVAR flows at ≥ 25 MW capacity
- Certain system events or changes that require immediate verbal communication
- If transferring files instead of manual replacement, required meta-data to be included in file

Features of **Verbal** Alternate Data Communications:

- Member to check at least every 30 minutes for significant changes compared to last communicated value to PJM
 - The loss of any equipment $\geq 100\text{kV}$
 - A change of ≥ 25 MW of any generator MW flow
 - A change of ≥ 100 MW flow at $\geq 500\text{kV}$
 - A change of ≥ 50 MW flow at $< 500\text{kV}$
 - A transformer tap position change at $\geq 230\text{kV}$
 - A breaker status change at $\geq 100\text{kV}$
- Member to verbally communicate only changed values

Section 3.8: Planning, Coordination and Notification of System Changes and Events

Summary:

- Text in M13 1.3 (Emergency Operations, EMS/ICCP Link Outages) has been transferred to M01 3.8 to better align the requirements.
- The requirements have not changed and still define PJM and PJM member (TOs and GOs) responsibilities and actions in the case of both planned and unplanned outages.
- Includes important notes on outage scheduling and restrictions.

Excerpt from current version of M1, Attachment A, Table A

A: Generation Scheduling Services						
	Information Services	PJM Member Regional Transmission Owner	PJM Member Generating Entity	PJM Member Load Serving Entity	PJM Member Marketer	Neighboring Control Areas
A.11	Daily Generator Bid Confirmations (cost, availability, etc.) via Markets Gateway		2			
A.12	Selected Generators (next day schedule)[distributed to selected generator owners] via Markets Gateway		2			

Suggested addition to Table A

A.13	System restoration planning data, e.g. unit start times, ramp rates, start-up loads, low load operating capabilities		8			
------	--	--	---	--	--	--

- **First Read**
 - 11/2 – SOS Joint
 - 11/7 – OC
 - 11/16 – DMS Joint (Informational)
 - 11/16 – RSCS (Informational)
 - 12/7 – MRC
- **Second Read**
 - 12/7 – SOS Joint
 - 12/12 – OC
 - 12/21 – MRC



Questions

- Bilge Derin, Bilge.Derin@pjm.com
- Ryan Nice, Ryan.Nice@pjm.com