



Summary of M-03A Rev. 17 Changes

RSCS

November 15, 2018



M03A, Rev. 17 1st Read Changes

Overall:

- Section 3.2.1: Clarity added concerning extent of external BES facilities considered for modeling.

Section 3.2.1 – External Modeling:

Clarified 3rd paragraph:

To determine the extent of external BES equipment to be considered for modeling, a planning case Distribution Factor (DFAX) report is periodically run and reviewed for each external area. **The analysis and review identifies all equipment with at least a 3% DFAX.** The identified equipment is used to determine the external facilities that may be included in the PJM external model.