



Stakeholder

Actions Requested:

- Share this communication internally within your organization to anyone who may need this information.
- Note that materials below have been updated

CORRECTION - In reference to the notification below that was previously communicated on Sep. 27, **please note that the links within the referenced email document have been updated to reflect the accurate information.**

You are receiving this email in accordance with NERC Reliability standard PRC-002 R5. PJM, as the Reliability Coordinator is required to identify BES Elements for which dynamic Disturbance recording (DDR) data is required.

R5. Each Reliability Coordinator shall:

5.1. Identify BES Elements for which dynamic Disturbance recording (DDR) data is required, including the following:

5.1.1. Generating resource(s) with:

5.1.1.1. Gross individual nameplate rating greater than or equal to 500 MVA.

5.1.1.2. Gross individual nameplate rating greater than or equal to 300 MVA where the gross plant/facility aggregate nameplate rating is greater than or equal to 1,000 MVA.

5.1.2. Any one BES Element that is part of a stability (angular or voltage) related System Operating Limit (SOL).

5.1.3. Each terminal of a high voltage direct current (HVDC) circuit with a nameplate rating greater than or equal to 300 MVA, on the alternating current (AC) portion of the converter.

5.1.4. One or more BES Elements that are part of an Interconnection Reliability Operating Limit (IROL).

5.1.5. Any one BES Element within a major voltage sensitive area as defined by an area with an in-service undervoltage load shedding (UVLS) program.

5.2. Identify a minimum DDR coverage, inclusive of those BES Elements identified in Part 5.1, of at least:

5.2.1. One BES Element; and

5.2.2. One BES Element per 3,000 MW of the Reliability Coordinator's historical simultaneous peak System Demand.

5.3. Notify all owners of identified BES Elements, within 90 calendar days of completion of Part 5.1, that their respective BES Elements require DDR data.

5.4. Re-evaluate all BES Elements within its Reliability Coordinator Area at least once every five calendar years in accordance with Parts 5.1 and 5.2, and notify owners in accordance with Part 5.3.

PJM has completed the identification of BES Elements and is providing them in Attachment B of PJM Manual 03B.

The TO or GO required to comply with the standard is identified under the Responsible NERC Entity Name column.

PJM would like to request all TOs & GOs to review the list and if any errors or omissions are identified, please notify PJM immediately so that we can follow up with the needed updates/corrections.

Please use the following link to download the email message indicated below:

[Manuals Manual 03B Revision 66.2.msg](#)

Within the attached email, click the "Clean Version" link to view Manual 03B. The PRC-002 list is in Attachment B.

Please respond directly to [Stan Sliwa](#) with any questions or comments.

This has been sent to: SOS-G, SOS-T, OC, PC, RSCS

Was this email helpful?   | [Manage Preferences](#)

© 1999-2024, All rights reserved.

Member Relations: [\(610\) 666 8980](#) | [\(866\) 400 8980](#)

This email was sent to: elizabeth.davis@pjm.com

Email not displaying properly, view it in a [browser](#).

This e-mail communication and any attachments hereto are intended only for use by the addressees named herein and may contain legally privileged and/or confidential information. Please notify the sender immediately by email if you have received this email by mistake and permanently delete all copies of this email from your computer system. Any dissemination, distribution or copying of this e-mail and any attachments hereto is strictly prohibited. Email transmission cannot be guaranteed to be secure or error-free, as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. PJM, therefore, accepts no liability for the content of this email, or for the consequences of any actions taken on the basis of the information provided, unless that information is subsequently confirmed in writing. If verification is required, please request a hard-copy version.