



Effective Date	01/02/2018
<b>Impacted Manual #(s)/Manual Title(s):</b>	
Manual 01, Control Center and Data Exchange Requirements	
<b>Conforming Order(s):</b> N/A	
<b>Associated Issue Tracking Title:</b> N/A	
<b>Committee Approval Path - What committee(s) have already seen these changes?</b>	
<p>First Reads</p> <ul style="list-style-type: none"> <li>• 11/2/2017 – SOS Joint</li> <li>• 11/7/2017 – OC</li> <li>• 11/16/2017 – DMS Joint (Informational)</li> <li>• 11/16/2017 – RSCS (Informational)</li> <li>• 12/7/2017 – MRC</li> </ul> <p>Second Reads</p> <ul style="list-style-type: none"> <li>• 12/7/2017 – SOS Joint</li> <li>• 12/12/2017 – OC</li> <li>• 12/21/2017 – MRC</li> </ul>	
<b>MRC 1<sup>st</sup> read date:</b>	12/7/2017
<b>MRC voting date:</b>	12/21/2017
<b>Impacted Manual sections:</b>	
<p>Section 2.3.1 Transmission Monitoring Capability            Section 2.7 PJM Member Back Up Capability Required to Support PJM in its TOP Role            Section 3.2 Energy Management System (EMS) Data Exchange            Section 3.8 Planning, Coordination and Notification of System Changes and Events            Attachment A Data Specification and Collection</p>	
<b>Reason for change:</b>	
<p>Section 2.3.1: update due to retired NERC standards            Section 2.7: update due to retired NERC standards            Section 3.2: clarification on desired procedures during EMS data outages            Section 3.8: moving existing requirements for ICCP link outages from Manual 13 to Manual 01            Attachment A: adding a new service under Generation Scheduling Services.</p>	
<b>Summary of the changes:</b>	
<ul style="list-style-type: none"> <li>• Section 2.3.1: updated references to TOP-004 and TOP 007.</li> <li>• Section 2.7: updated references to TOP-004, TOP-006 and TOP-008.</li> <li>• Section 3.2: revised language to clarify EMS data communication methods to PJM during data link or RTU/telemetry devices outages.</li> <li>• Section 3.8: revised language to absorb the language being removed from PJM Manual 13 regarding requirements during ICCP/DNP outages.</li> <li>• Attachment A: Added new information service regarding TO system restoration planning.</li> </ul>	