



EMUSTF

UTC Biddable Points Determination Criteria

Keyur Patel

Sr. Lead Engineer, Day-Ahead Market Operations

Energy Market Uplift Senior Task Force

June 10, 2016

- Historically, starting point for the source-sink paths for UTC transactions was the list of source and sink points that were available for interchange transaction sources and sinks on the PJM OASIS.
- Removed from the above nodes are all load busses below 69 KV
- Removed from resulting nodes are all generator busses at which no generators with 100 MW or more are connected
- Removed from resulting set of nodes are all electrically equivalent nodes

More information can be found in below FERC filings/orders

- <http://www.pjm.com/~media/documents/ferc/orders/2013/20130809-er13-1654-000.ashx>
- <http://www.pjm.com/~media/documents/ferc/2013-filings/20130906-er13-1654-001.ashx>
- <http://www.pjm.com/~media/documents/ferc/2013-filings/20130610-er13-1654-000.ashx>