



RMDSTF Regulation Requirement

PJM's Proposal Development

Madalyn Beban, Market Design &
Economics

RMDSTF

December 20, 2022


- Introduced an initial dynamic regulation requirement proposal
 - Baseline MW with seasonal, weather alert adders
 - Influenced by annually installed renewable MW
 - Defines new on- and off-peak hours
- **Received requests to dig into the underlying data**
 - **Seasonality of load and renewables**
 - **ACE breakdown and investigation**
- Received additional considerations
 - Interactions with other proposal elements
 - Timeframe for communicating the requirement (1 day ahead)

- Load Hourly Deltas
 - Year over year and seasonal averages
- Solar/Wind Hourly Actuals and Deltas
 - Year over year average hourly patterns for “peak” season
- Historic Area Control Error Statistics
 - Various statistics for 1-min ACE, basic and using thresholds

Note: Seasonal designations for the data in this presentation are as follows:


- Spring March 1 – June 15
- Summer June 15 – September 15
- Fall September 15 – December 31
- Winter December 31 – March 1

Year over Year Hourly Load Delta Patterns




- Note the change in 2021 profile versus historic—cause TBD

Seasonal Hourly Load Delta Patterns




- Used hourly load actuals for **calendar year 2021** only


Year over Year Hourly Summer Solar Actuals




Year over Year Hourly Summer Solar Deltas




Year over Year Hourly Winter Wind Actuals



Year over Year Hourly Winter Wind Deltas




- Determine a threshold for ACE below which we might consider control error “acceptable”
 - ACE outside of this threshold may be prioritized for the purposes of determining regulation need
- Initial proposal is a threshold of **+/- 247 MW**
 - Estimate based on the NERC guidelines around frequency response obligation (FRO) allocations for PJM (2021-2022)
 - Link to 2023 report: [BAL-003-2 FRO Allocation for OY2023](#)
- This threshold is tentative and subject to change pending PJM Operations feedback



- Slight left skew, tends toward the right of 0 MW

Distribution of ACE Minutes by Year: 2020



- Very similar shapes for 2019, 2018—omitted from this presentation

	2018	2019	2020	2021
Mean	64	73	70	78
St. Deviation	245	234	224	238
25%	-71	-58	-55	-55
Median (50%)	54	61	58	65
75%	188	190	180	195

Note: ACE statistics provided here are rounded to whole numbers.

- Statistics confirm the year-over-year similarity

Percentage of Time in ACE Threshold “Buckets” by Year

Threshold Range	2018	2019	2020	2021
+/- 247 MW	75%	76%	79%	75.8%
+/- 494 MW	19%	18.6%	17%	18.5%
+/- 741 MW	4%	4%	3%	4%
+/- 988 MW	1%	1%	0.9%	1.2%
> +/- 988 MW	0.5%	0.4%	0.3%	0.4%

- Each row is 1x, 2x, 3x, 4x, and >4x the +/-247 threshold



Hours with Greatest Statistical ACE Outliers by Year

2018	
HE	Rel. Freq.
10	7%
14	7%
18	6%
6	6%
7	6%

2019	
HE	Rel. Freq.
6	11%
5	8%
18	7%
14	7%
0	6%

2020	
HE	Rel. Freq.
5	12%
11	8%
6	7%
10	7%
0	6%

2021	
HE	Rel. Freq.
0	9%
5	7%
16	7%
6	6%
15	5%



Percentage of Time in ACE Threshold “Buckets” by Season

Threshold Range	Spring	Summer	Fall	Winter
+/- 247 MW	76%	75%	76%	76%
+/- 494 MW	18%	19%	18%	18%
+/- 741 MW	4%	4%	4%	4%
+/- 988 MW	1%	1%	1%	1%
> +/- 988 MW	0.4%	0.5%	0.3%	0.4%

- Each row is 1x, 2x, 3x, 4x, and >4x the +/-247 threshold



Hours with Greatest Statistical ACE Outliers by Season

Spring

HE	Rel. Freq.
6	8%
5	7%
0	6%
10	5%
22	5%

Summer

HE	Rel. Freq.
14	10%
0	9%
15	9%
11	7%
13	6%

Fall

HE	Rel. Freq.
18	10%
5	10%
17	9%
6	8%
16	7%

Winter

HE	Rel. Freq.
5	12%
17	10%
6	9%
18	7%
7	6%

- Additional follow-up to be had based on November and other feedback
 - **Impact of single signal on the regulation requirement**
 - Statistics on historic forecast performance for wind, solar, load
 - Statistics on intrahour system volatility
 - Distribution of spin events over time

Facilitator:
Michael Herman,
michael.herman@pjm.com

SME/Presenter:
Madalyn Beban,
madalyn.beban@pjm.com

Regulation Requirement



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

