



# Overview of Generation Reactive Capability in Planning Model

Phil Yum  
Senior Lead Engineer  
System Planning Modeling & Support Department




## Current Reactive Modeling Procedure - RTEP power flow case

### 1. Use a mix and match approach.

- In service units: use latest tested d-curves to determine reactive capabilities.
- Future ISA units including uprating queue generation project: use PJM tariff PF requirement.

### 2. Inverter Based Resource - Wind/Solar units.

- Reactive capability were proportionally divided based on its Capacity and Energy split.
- For several TOs, PFs are used instead of tested d-curves.





## PF Rules Part 1- RTEP Power Flow Case

	Power Factor Requirement	Location	Modeling Required?
<b>ISA and above (From AC2 queue)</b>			
Synchronous generator (more than 20 MW)	0.95 leading - 0.90 lagging	Generation Terminal	Yes
Synchronous generator (equal or less than 20 MW)	0.95 leading - 0.90 lagging	Point of Interconnection	Yes
Wind generation	0.95 leading - 0.95 lagging	High side of main GSU	Yes
Solar generation	0.95 leading - 0.95 lagging	High side of main GSU	Yes
MTX project	0.95 leading - 0.95 lagging	Point of Interconnection	Yes
<b>Increase in Generating Capacity or Energy output</b>			
Synchronous generator	1.0 unity - 0.90 lagging		Yes
non synchronous generator	1.0 unity - 0.95 lagging		Yes



## PF Rules Part 2- RTEP Power Flow Case

	Power Factor Requirement	Location	Modeling Required?
<b>ISA and above (From AB1 queue to AC1 queue)</b>			
Synchronous generator (more than 20 MW)	0.95 leading - 0.90 lagging	Generation Terminal	Yes
Synchronous generator (equal or less than 20 MW)	0.95 leading - 0.90 lagging	Point of Interconnection	Yes
Wind generation	0.95 leading - 0.95 lagging	Generation Terminal	Yes
Solar generation	0.95 leading - 0.95 lagging	Generation Terminal	Yes
MTX project	0.95 leading - 0.95 lagging	Point of Interconnection	Yes
<b>Increase in Generating Capacity or Energy output</b>			
Synchronous generator	1.0 unity - 0.90 lagging		Yes
non synchronous generator	1.0 unity - 0.95 lagging		Yes



## PF Rules Part 3- RTEP Power Flow Case

	Power Factor Requirement	Location	Modeling Required?
<b>ISA and above (Before AB1 queue)</b>			
Synchronous generator (more than 20 MW)	0.95 leading - 0.90 lagging	Generation Terminal	Yes
Synchronous generator (equal or less than 20 MW)	0.95 leading - 0.90 lagging	Point of Interconnection	Yes
Wind generation	0.95 leading - 0.95 lagging	Point of interconnection	Per ISA
Solar generation	0.95 leading - 0.95 lagging	Point of interconnection	Per ISA
MTX project	0.95 leading - 0.95 lagging	Point of Interconnection	Yes
<b>Increase in Generating Capacity or Energy output</b>			
Synchronous generator	1.0 unity - 0.90 lagging		Yes
non synchronous generator	1.0 unity - 0.95 lagging		NO

Phil Yum;  
Phil.Yum@pjm.com  
(610) 666-4661

**Please send questions/comments to  
the above contact.**



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com