

Pennsylvania Act 129 Program: Summer 2017 Performance

Eric Matheson

Pennsylvania Public Utility Commission

April 13, 2018

Performance Obligations: 4-hour average vs. Performance During 5 CP

Date	Statewide MW Total (4-hour Average)	Statewide MW Performance During 5CP Hour
6/13/2017	524	542
7/20/2017	485	528
7/21/2017	413	484
2017 Average	474	518

Performance by Event by Hour by Utility

MW	13-Jun-17				20-Jul-17				21-Jul-17				Obligation	
	Hour Ending				Hour Ending				Hour Ending					85%
	15	16	17	18	15	16	17	18	15	16	17	18		
Duquesne	54	70	56	78	44	78	74	72	24	64	64	67	42	36
PPL	114	120	120	127	129	132	132	133	126	129	129	127	92	78
PECO	104	130	133	108	131	142	152	126	125	123	131		161	137
MetEd	49	50	48	45	52	48	45	44	44	45	43	39	49	42
Penn Power	48	47	49	52	7	16	41	43	-1	9	41	25	17	14
West Penn	100	134	136	124	41	91	85	81	37	63	77	15	64	54
Total	469	551	542	534	404	507	528	499	355	433	484		425.0	361.3

Average Performance vs. Peak CP Hour Performance

MW	13-Jun-17		20-Jul-17		21-Jul-17		Oblig.	85%
	4-hr. Avg	CP Hr.	4-hr. Avg	CP Hr.	4-hr. Avg	CP Hr.		
Duquesne	64	56	67	74	55	64	42	36
PPL	120	120	132	132	128	129	92	78
PECO	119	133	137	152	122	131	161	137
MetEd	48	48	47	45	43	43	49	42
Penn Power	49	49	27	41	18	41	17	14
West Penn	123	136	75	85	48	77	64	54
Total	524	542	485	528	413	484	425	361