

Nuclear Bus Voltage Limits

Nuclear Generation Owners Overview



Nuclear Bus Voltage Limits

In compliance with NERC standard NUC-001, Nuclear Generation Owners (NGOs), develop Nuclear Plant Interface Requirements (NPIRs)

– NPIRs, in part, define safe shutdown voltage limits

Applicable Transmission entities monitor the transmission system as not to violate the NPIRs


To gain efficiencies for TOs, NGOs, and PJM, Nuclear Bus Voltage Limits will be maintained in eDART




Nuclear Bus Voltage Limits


Stand alone application within eDART, limited to NGOs and applicable TOs


- New eDART ticket type: Nuclear Bus Voltage Limit Change
- Current limits and upcoming limit changes will be visible to all applicable entities
- eDART will be the primary input for NPIR voltage limit changes;
 Manual 3 Attachment C available as backup





www.pjm.com | Public







þjm

The Unit Setup Report provides an overview of the pre-determined voltage limits for all unit groups.

- Indicates the Default monitored values on a per voltage level basis, including the PJM specific value shown in blue and indicated with the letter 'P'.
- Displays all unit group specific scenarios and the associated voltage limits.



Unit Setup Report

	Nuclear Voltage Limit Unit Setup Report													
	Default monitored values are displayed on a per voltage level basis. The PJM specific values are shown in blue and indicated with the letter 'P'.													
NUCLEAR TEST PJM	NUCLEAR TEST PJM TEST													
Default/Scenario Name	Default/Scenario Name Station Voltage Bus Name Keyword Norm. Min kV Norm. Max kV Emerg. Min kV Emerg. Max kV Load Dump Volt. Drop Warn. % Volt. Drop Viol. %													
Default	Default LACKAWAN 500 KV 536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0 5.0 8.0													
Default	Default LACKAWAN 230 KV 230.0 242.0 (P: 239.0) 230.0 (P: 227.0) 242.0 217.0 2.0 5.0													
Default	LACKAWAN	69 KV		69.0	72.0	66.0	75.0	60.0	1.0	4.0				
LTC in manual	LACKAWAN	500 KV		536.5	550.0 (P: 547.0)	535.0 (P: 533.5)	550.0	475.0	9999	9999				
Single unit operation	LACKAWAN	500 KV		536.5	540.0	535.0 (P: 533.5)	550.0	475.0	5.0	8.0				
LTC in manual	TC in manual LACKAWAN 230 KV 230.0 242.0 (P: 227.0) 242.0 217.0 9999 9999													
	Refresh Help Main Menu													



Effective Limits

The Effective Limits Report allows the user the ability to see applicable limits for a chosen timeframe. The filter will take into account any current and future tickets.

	Nuclear Voltage Limit Effective Limits Report																
	Unit: Include Historical: Effective Date/Time: 11/10/2020 10:56 (MWDD/YYYY) (HH24:MI)																
	Apply Filter Help Main Menu																
	PJM specific values are shown in blue and indicated with the letter 'P'.																
Company	Unit	Ticket ID	Туре	Status	Start Date	End Date	Station	Voltage	Bus Name Keyword	Scenario	Norm. Min kV	Norm. Max kV	Emerg. Min kV	Emerg. Max kV	Load Dump	Volt. Drop Warn. %	Volt. Drop Viol. %
Service Services	PERSONAL SPECIAL SPECI	<u>70</u>	Permanent	Completed	11/03/2020 17:25	11/17/2020 17:41	Re-control	230 KV		test 12 inactive	229.2 (P: 228.1)	240.0 (P: 239.5)	226.0 <mark>(P:</mark> 225.5)	243.0 (P: 242.5)	214.0 (P: 213.5)	1.1	1.6
	13 KV New Default 13.6 (P: 13.6) 9999 (P: 9999) 13.6 (P: 13.6) 9999 (P: 9999) 1.0 (P: 1.0) 1.2 2.2																
	Apply Filter Help Main Menu																



The Create Ticket screen allows for creating and submitting new Nuclear Voltage Limit tickets that will be used by the Transmission Owner (TO) and PJM in their forward looking studies and in real-time.

- The submitter will be able to see the Default, Current and Adjusted limits.
- Additional fields include, Start Date and Time, End Date and Time and GO Comments.



	Nuclear Voltage Limit New Ticket													
	Company: PJM TEST Unit: NUCLEAR TEST V													
	Default limits represent the base limits PJM and the TO will operate to during normal station configuration. Current limits represent the limits PJM and the TO are currently monitoring for. Adjusted limits show the limits associated with selected change. PJM specific values are shown in blue and indicated with the letter 'P'.													
Station	Station Voltage Bus Name Keyword Scenario Type Norm. Min kV Norm. Max kV Emerg. Min kV Emerg. Max kV Load Dump Volt. Drop Warn. % Volt. Drop Viol. %													
	Default 536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0 5.0 8.0													
LACKAWAN	ACKAWAN 500 KV													
	No Change Adjusted 536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0 5.0 8.0													
					Default	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0		
LACKAWAN	230 KV				Current									
			No Change	~	Adjusted	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0		
					Default	69.0	72.0	66.0	75.0	60.0	1.0	4.0		
LACKAWAN														
	No Change Adjusted 69.0 72.0 66.0 75.0 60.0 1.0 4.0													
						Help	Refresh	lain Menu						



- The submitter will be able to select from multiple scenarios for each voltage level:
 - No Change
 - New Default permanent change to the default values
 - Unlisted temporary limits not covered by pre-approved scenarios
 - Unit specific pre-approved scenarios (i.e. LTC in manual)



Create Ticket – Scenario Selection

	Nuclear Voltage Limit New Ticket													
			Company: PJ	MTEST			VIII: NUC	LEAR TEST 👻						
	Default limits represent the base limits PJM and the TO will operate to during normal station configuration. Current limits represent the limits PJM and the TO are currently monitoring for. Adjusted limits show the limits associated with selected change. PJM specific values are shown in blue and indicated with the letter "P".													
Station														
LACKAWAN	500 KV			Default Current	536.5	550.0 (P: 547.0)	535.0 (P: 533.5)	550.0	475.0	5.0	8.0			
			LTC in manual 👻	Adjusted	536.5	550.0 (P: 547.0)	535.0 (P: 533.5)	550.0	475.0	9999	9999			
LACKAWAN	230 KV			Default Current	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0			
			No Change	Adjusted	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0			
LACKAWAN	69 KV		New Default Unlisted LTC in manual	Default Current	69.0	72.0	66.0	75.0	60.0	1.0	4.0			
			No Change 👻	Adjusted	69.0	72.0	66.0	75.0	60.0	1.0	4.0			
Ticket Type: Te	mporary	Est. Start Date:		GO Come	nents:			PJM Commen	ts:					
	Est. End Date: (MM/DD/YYYY) (H024.M)													
	Sademit Form Holp Refersh Main Meru													



Create Ticket – Unlisted and New Default Scenario

- The user will be able to manually enter values when the Unlisted/New Default scenarios are selected
 - Data validation rules will verify:
 - Normal Min kV >= Emergency Min kV
 - Normal Max kV <= Emergency Max kV
 - Emergency Max kV >= Load Dump
 - Voltage Drop Warning <= Voltage Drop Violation
 - The PJM dispatcher will enter the Voltage Drop Warning Percentage when reviewing the ticket



Create Ticket – Unlisted and New Default Scenario

	Nuclear Voltage Limit New Ticket													
	Company: PJM TEST Unit: NUCLEAR TEST V													
	Default limits represent the base limits PJM and the TO will operate to during normal station configuration.													
	Current limits represent the limits PJM and the TO are currently monitoring for. Adjusted limits show the limits associated with selected change. PJM specific values are shown in blue and indicated with the letter 'P'.													
Station														
	Default 536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0 5.0 8.0													
LACKAWAN	536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0													
	VCKAWAN 500 KV Unlisted V Adjusted													
				Default	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0			
LACKAWAN	230 KV			Current										
			No Change 👻	Adjusted	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0			
				Default	69.0	72.0	66.0	75.0	60.0	1.0	4.0			
LACKAWAN	69 KV			Current										
			No Change 👻	Adjusted	69.0	72.0	66.0	75.0	60.0	1.0	4.0			
		Ticket Ty	pe: Temporary Est. Star	t Date:		GO								
						Com	nents:							
	Est. End Date:													
	(MMCD/YYYY) (HPQ4M)													
				Salarat	orm Help	Retesh	Main Menu							



Create Ticket – Pre-approved Scenario

• The values are pre-populated for any pre-approved scenario

	Nuclear Voltage Limit New Ticket												
	Company: PJM TEST Unit: NUCLEAR TEST V												
	Default limits represent the base limits PJM and the TO will operate to during normal station configuration. Current limits represent the limits PJM and the TO are currently monitoring for. Adjusted limits show the limits associated with selected change. PJM specific values are shown in blue and indicated with the letter 'P'.												
Station	Scenario Type Norm. Min kV Norm. Max kV Emerg. Min kV Emerg. Max kV Load Dump Volt. Drop Warn. % Volt. Drop Viol. %												
LACKAWAN	Default 536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0 5.0 8.0 CKAWAN 500 KV Current 500 KV 500 KV <td< td=""></td<>												
	LTC in manual Adjusted 536.5 550.0 (P: 547.0) 535.0 (P: 533.5) 550.0 475.0 9999 9999												
LACKAWAN	CKAWAN 230 KV Current Default 230.0 242.0 (P: 239.0) 230.0 (P: 227.0) 242.0 217.0 2.0 5.0												
			No Change 👻	Adjusted	230.0	242.0 (P: 239.0)	230.0 (P: 227.0)	242.0	217.0	2.0	5.0		
LACKAWAN	69 KV			Default Current	69.0	72.0	66.0	75.0	60.0	1.0	4.0		
			No Change 👻	Adjusted	69.0	72.0	66.0	75.0	60.0	1.0	4.0		
	Ticket Type: Temporary Est. Start Date: GO Comments:												
	Est. End Date: (MM/DD/YYYY) (HR24.MI)												
			(Submit Form		Refresh	Main Menu						



Create Ticket – Ticket Submittal

- PJM requires a start date/time, end date/time and GO Comments in order to submit the ticket for PJM review
 - For New Default Ticket Type is Permanent and the end date/time is not required

Ticket Type: Temporary	Est. Start Date:			GO Comments:	
	Est. End Date:	(MM/DD/YYYY)	(HH24:MI)		/
	Sub	mit Form	Help	Refresh	Main Menu




Create Ticket – Adding Files

- Files can be added to a ticket once it has been submitted
 - Select the Files button

Est. Start Date:	01/05/2021	00:00	GO Comments:	Sample ticket	submission	PJM Comments	
Est. End Date:	01/06/2021	23:59					
	(MM/DD/YYYY)	(HH24:MI)					
		Submit	Form	Help Ref	resh History Log	Files(0)	Main Menu

- Choose the file to upload
- Select Submit File





Review Tickets

The Review Tickets screen allows the users to search for historical, current, and future Nuclear Voltage Limit tickets. The available filter choices allow the user to be specific if desired, or complete a broad search by not selecting any additional information.

	Nuclear Voltage Limit Ticket Review											
Co	ompany		Unit		Permanent/Temporary			Include Historical				
PJM TEST 🗸		NUCLE	UCLEAR TEST V OPerm. OTemp. OBo			Both						
Ticket ID	Status	Late Tickets	Upcoming Tickets	Recent Tickets	Occured During							
	Approved Completed Implemented PJM Admin Closure Received				From: (M	IM/DD/YYY	To: Y)	: (MM/DD/YYYY)				
	Apply Filter Refresh Main Menu											



Ticket Status

- Submitted new ticket status when submitted to PJM.
- Received initial review of ticket by PJM completed.
- Denied voltage limit change reviewed and not approved by PJM.
- Approved voltage limit change reviewed and approved by PJM.
- Cancelled by Company NGO cancelled the tickets.
- PJM Admin Closure PJM cancelled the ticket.
- Revised Received or Approved ticket has been changed by NGO.



- Implemented PJM EMS updated with new limits from approved ticket.
- Implemented w/o Approval PJM EMS updated with new limits from un-approved ticket.
- Completed PJM EMS updated with new limits that no longer match implemented temporary ticket or new permanent ticket created



Late Tickets

The Late Tickets reports shows tickets that either:

- Are past their Start date but have not been Implemented or Cancelled.
- Are past their End Date but have not been Completed or Cancelled.

Nuclear Voltage Limit Late Ticket Report													
	3				1		2						
licket ID	Unit		GO Name	Perm/Temp	Start Da	ate	End Da	te	Status				
94 NUCLEAR TEST PJM TEST Temporary 11/17/2020 00:00 11/18/2020 00:00 Received 129 NUCLEAR TEST PJM TEST Temporary 11/17/2020 17:41 11/18/2020 17:41 Implemented													
<u>129</u>	NUCLEAR	TEST	PJM TEST	Temporary	11/17/2020	17:41	11/18/2020	17:41	Implemented				
<u>100</u>	NUCLEAR	TEST	PJM TEST	Temporary	11/20/2020	00:00	11/20/2020	23:59	Submitted				
<u>96</u>	NUCLEAR	TEST	PJM TEST	Temporary	11/27/2020	11:11	11/28/2020	12:00	Submitted				
Apply Filter Help Main Menu													



Implemented w/o Approval

The Implemented without Approval screen shows tickets which are created when the currently active limits in eDART does not match the limits monitored by PJM.

	N	luclear Voltage Limit Implem	ented w/	o Approval T	icket Report							
	3			1	2							
Ticket ID	Unit	GO Name	Perm/Temp	Start Date	End Date	Status						
<u>139</u>	In the second second	Energy Hoter 112	Temporary	12/11/2020 12:18	12/12/2020 12:18	Implemented w/o Approval						
<u>137</u>	line i N	Philipping Support and the set	Temporary	12/11/2020 12:18	12/12/2020 12:18	Implemented w/o Approval						
	Apply Filter Help Main Menu											



Upcoming Tickets

The Upcoming Tickets report will show all tickets scheduled to start in the next 7 days.

	Nu	clear Voltage Limit	Upcomin	g Ticket Rep	ort								
	3 1 2												
Ticket ID	Unit	GO Name	Perm/Temp	Start Date	End Date	Status							
<u>98</u>	Also and Children	Earlie Desentine Ex., U.C.	Temporary	12/14/2020 11:00	12/15/2020 11:00	Submitted							
		Apply Filter	Help	Main Menu									



Recently Completed

The Recently Completed report will show all tickets completed in the last 7 days.

Nuclear Voltage Limit Recently Completed Ticket Report						
	3			1	2	
Ticket ID	Unit	GO Name	Perm/Temp	Start Date	End Date	Status
<u>119</u>	1.849 States	Forthe Growentine Co., U.C.	Temporary	11/17/2020 17:41	12/07/2020 15:17	Completed
<u>121</u>	R.A. CHERTON	Parallel Instanting Co., etc.	Temporary	11/17/2020 17:41	12/07/2020 15:17	Completed
<u>123</u>		Deep Station 1.10	Temporary	11/17/2020 17:41	12/11/2020 12:18	Completed
<u>131</u>	6	FUECE any Person and Tasks	Temporary	12/07/2020 14:27	12/11/2020 12:18	Completed
Apply Filter Help Main Menu						