

PA Central Reactive Transfer Interface

Details

PJM has created the PA Central Interface, which will be effective on October 1, 2018. PJM anticipates the PA Central Interface will be used to control voltage contingencies associated with high transfers during transmission outages of one of the interface lines and when topology warrants. The interface will be effective until further notice.

The PA Central Interface is NOT an IROL transfer interface. The PJM EMS will calculate a transfer limit for the interface. The PA Central Interface will be used to set Day-Ahead and Real Time LMP. The PA Central Interface will be modeled in both the Day Ahead and Real Time markets and will not be modeled in FTR markets.

Interface Definition

Type	Company	Zone	Station	Voltage	Name	Eq. End
LE	PL	PL	LACKAWAN	500 KV	HOP-LAC	B
LE	PL	PL	SUNBURY	500 KV	JUN-SUN	B
LE	PL	PL	SUSQUEHA	500 KV	SUS-WES	A