



## PJM Interconnection

### Winter 2022/23 Weather Normalized RTO Coincident Peaks (MW)

Zone	Peak	5CP Average	Adjustment Factor
<b>AE</b>	<b>1,430</b>	1,413	1.012
AECO	1,334.1		
Vineland	95.9		
<b>AEP</b>	<b>22,190</b>	19,720	1.125
<b>APS</b>	<b>8,900</b>	8,141	1.093
<b>ATSI</b>	<b>9,510</b>	9,323	1.020
<b>BGE</b>	<b>5,720</b>	5,068	1.129
<b>COMED</b>	<b>12,890</b>	13,037	0.989
<b>DAYTON</b>	<b>2,840</b>	2,585	1.099
<b>DEOK</b>	<b>4,380</b>	3,887	1.127
<b>DLCo</b>	<b>1,920</b>	1,866	1.029
<b>DOM</b>	<b>21,210</b>	18,322	1.158
<b>DPL</b>	<b>3,540</b>	3,169	1.117
DPLCO	3,486.9		
EASTON	53.1		
<b>EKPC</b>	<b>2,580</b>	2,139	1.206
<b>JCPL</b>	<b>3,320</b>	3,211	1.034
<b>METED</b>	<b>2,630</b>	2,397	1.097
<b>OVEC</b>	<b>60</b>	62	0.971
<b>PECO</b>	<b>6,240</b>	5,730	1.089
<b>PENLC</b>	<b>2,760</b>	2,555	1.080
<b>PEPCO</b>	<b>5,280</b>	4,473	1.180
PEP	4,454.4		
SMECO	825.6		
<b>PLGrp (PL, UGI)</b>	<b>7,390</b>	6,667	1.109
<b>PS</b>	<b>5,970</b>	5,848	1.021
<b>RECO</b>	<b>190</b>	183	1.036
<b>PJM RTO</b>	<b>130,950</b>	119,796	1.093

### Winter 2022/23 RTO Coincident Peaks (5CP)

Note: All times are listed in Hour Ending EPT

PJM RTO			
Day	Date	Hour	MW
Friday	12/23/2022	19:00	134,951
Friday	2/3/2023	20:00	121,005
Wednesday	12/21/2022	8:00	115,644
Monday	12/19/2022	19:00	114,245
Tuesday	12/20/2022	8:00	113,135

**PJM INTERCONNECTION**  
**Winter 2022/23 - Coincident Peaks, By Zone (MW)**

Date	12/23/2022	2/3/2023	12/21/2022	12/19/2022	12/20/2022	Average
Hour End (EPT)	19:00	20:00	8:00	19:00	8:00	
AE	1,534.6	1,479.1	1,304.0	1,452.1	1,294.5	1,412.8
AEP	23,004.5	18,993.9	19,167.2	18,428.0	19,008.0	19,720.3
APS	9,329.5	8,281.3	7,942.4	7,578.3	7,572.9	8,140.9
ATSI	10,217.6	9,583.5	8,751.5	9,269.8	8,792.2	9,322.9
BGE	5,780.0	5,259.9	4,943.7	4,594.7	4,763.5	5,068.4
COMED	14,893.4	13,391.8	11,964.4	13,226.2	11,707.7	13,036.7
DAYTON	3,014.3	2,472.0	2,467.0	2,479.0	2,491.0	2,584.7
DEOK	4,935.6	3,684.2	3,646.9	3,639.9	3,527.5	3,886.8
DLCo	2,038.9	1,907.9	1,773.8	1,865.4	1,745.0	1,866.2
DOM	20,282.1	17,992.6	18,439.7	16,567.9	18,328.7	18,322.2
DPL	3,459.4	3,360.3	3,161.8	2,872.5	2,991.4	3,169.1
EKPC	3,236.7	1,874.7	2,047.7	1,734.6	1,799.1	2,138.6
JCPL	3,435.8	3,397.7	2,943.3	3,350.6	2,928.1	3,211.1
METED	2,475.6	2,510.4	2,384.7	2,354.0	2,262.5	2,397.4
OVEC	37.0	75.0	59.0	71.0	67.0	61.8
PECO	6,167.7	5,957.5	5,478.7	5,669.1	5,377.3	5,730.0
PENLC	2,717.1	2,615.1	2,533.2	2,485.9	2,426.0	2,555.5
PEPCO	4,937.5	4,661.0	4,414.8	4,035.8	4,314.9	4,472.8
PPL-EU	6,914.5	6,824.9	6,436.2	6,272.7	5,993.2	6,488.3
PS	6,144.2	6,296.0	5,447.3	5,932.2	5,420.3	5,848.0
RECO	196.3	193.0	169.6	191.6	166.9	183.5
UGI	198.7	193.7	167.5	174.0	157.2	178.2
<b>PJM RTO</b>	<b>134,951.0</b>	<b>121,005.3</b>	<b>115,644.3</b>	<b>114,245.2</b>	<b>113,134.7</b>	<b>119,796.1</b>
PLGrp	7,113.3	7,018.6	6,603.7	6,446.6	6,150.4	6,666.5
EASTON	53.4	50.3	49.6	40.5	44.4	
SMECO	793.8	713.7	718.7	590.0	685.7	
VINELAND	93.5	96.2	92.1	99.2	91.3	

Revised 5-Apr-23