

All EE Providers that submit an EE M&V plans for the 25/26 BRA and future auctions should provide the following support information as part of their M&V plan and PIMV report. This information will supplement or clarify the information requested by PJM in [M&V Plan template](#) and the [PIMV Report Template](#).

- 1) EE Providers shall only submit Nominated MW values for the approved installation periods¹ in their M&V plan. PJM will only accept PIMV Reports for eligible installation periods approved in the M&V plan.
- 2) For the 24/25 installation period and forward, the standard baseline for residential general lighting is an LED lightbulb unless there is a more stringent applicable standard. This reflects the standard practice² for the sale and installation of residential general lighting³.
- 3) EE Provider must explain in their 25/26 MV Plan how they intend to provide reasonable assurance that claimed EE Resources cannot be claimed by any other EE provider. The 25/26 PIMV Report must reflect such assurance for all claimed EE Resources.
- 4) M&V Plans should be submitted to the RPM Hotline (rpm_hotline@pjm.com) and to the Independent Market Monitor (IMM) (rpmacr@monitoringanalytics.com). The submission deadline is published in the RPM Auction Calendar. PJM will consider any comments on the M&V Plans from the IMM if the IMM provides to PJM well in advance of the PJM deadline to respond to EE Providers.
- 5) EE Providers are required to use the Nominated EE Value Template with their M&V plan submission (<https://www.pjm.com/-/media/markets-ops/rpm/rpm-auction-info/nominated-ee-value-template.ashx>). Any submittal received where the EE Provider does not use the current template, will not be accepted by PJM.

¹ <https://www.pjm.com/-/media/markets-ops/rpm/rpm-auction-info/approved-installation-periods-by-auction.ashx>

² New Jersey 2020 and 2021 Retail Lighting Sales Data Analysis, Apex Analytics and Demand-Side Analytics, memo dated July 7, 2022.

³ PJM Manual 18b, Section 8.1