

Coastal Wind Link – 1 Sewaren 320kV Collector (Final)

General Information

| | |
|---|--|
| Proposing entity name | PSEGRT |
| Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project? | No |
| Joint proposal ID | 1 |
| Company proposal ID | Coastal Wind Link – PSEG & Orsted |
| PJM Proposal ID | 397 |
| Project title | Coastal Wind Link – 1 Sewaren 320kV Collector (Final) |
| Project description | <p>The Sewaren 320kV Collector is an offshore transmission solution designed to deliver up to 1200 MW of clean, reliable OSW energy to the State of New Jersey. The Project is comprised of one HVDC system. The Project's offshore converter platform (OCP) is designed to serve 1200 MW of OSW generation from lease areas in the NY Bight. The Project's POI is located at PSE&G's Sewaren Switching Station. The Project will use a High Voltage (HV) system based on HVDC Voltage Source Converter (VSC) technology. The HVDC system will consist of an OCP, a single HVDC export cable system (all elements bundled together into a single marine corridor), and an onshore HVDC converter. Upon award of the project to the Project team, a project company ("Coastal Wind Link") will be formed as a joint venture between PSEGRT and Orsted NATH and will be the Designated Entity for the project.</p> |
| Email | Raymond.DePillo@pseg.com |
| Project in-service date | 12/2029 |
| Tie-line impact | Yes |
| Interregional project | No |
| Is the proposer offering a binding cap on capital costs? | Yes |

Additional benefits

1) The selection of the POI was based on a comprehensive analysis of station headroom and network upgrades in order to determine the optimal POI for future phases of OSW generation. 2) PSEG investigated 200+ properties to site an onshore converter station. The Project team has secured exclusive rights on property to site the converter station. 3) The Project team has obtained detailed site information on the selected landing location including the location of existing utilities and cables to inform landfall design and is in ongoing discussions with the landowner to determine optimal site layout and secure property rights. 4) Optimization of UG route considered mileage, permitting ease, and critical crossings. Field visits allowed PSEG's underground transmission experts to advance route design and estimates. 5) Design of the subsea cable route incorporated feedback from the NJDEP and USACE, seabed conditions, shipping lanes, fishing areas, crossings with existing cables, construction concerns, known UXO areas, and known areas of wrecks. Site investigation experience off the coast of New Jersey has allowed the team to mature route design prior to detailed surveying. 6) The Project team has met with various agencies to discuss permitting scenarios for this first-of-a-kind offshore transmission system. A comprehensive permitting plan has been created to fast-track project execution, and the team has prepared the IHA and ROW/RUE applications necessary. 7) The team worked with leading OEMs to design a symmetrical monopole system. The project is interlink-capable, offering reliability benefits to NJ's future offshore transmission system, while lowering OREC costs, as curtailment risk is reduced.

Project Components

1. S1 320kV Sewaren POI Upgrades
2. S2 320kV Sewaren AC Tie Line
3. S3 320kV Sewaren Onshore Converter
4. S4 320kV Sewaren Offshore/Onshore HVDC Cable
5. S5 320kV Sewaren Offshore Converter

Substation Upgrade Component

| | |
|---------------------|---|
| Component title | S1 320kV Sewaren POI Upgrades |
| Project description | Provide attachment facilities for Sewaren to accommodate an injection off 1200MW of offshore wind energy. |
| Substation name | Sewaren Switching Station |
| Substation zone | PSE&G |

Substation upgrade scope

To bring up to 1200 MW of offshore wind energy into Sewaren Switching Station, the existing 230-kV A-Frame structure will be upgraded to house a tri-bundled conductor. This will require modifications involving the existing 230-kV A-Frames, which will be reinforced for the extra loading. (Refer to Appendix B for the Sewaren Switching Station POI one line and bus plan arrangement). PSEG would be required to design and construct the 230-kV modifications to accommodate the offshore wind power injection. Connection to Sewaren would be via 230kV strain bus.

Transformer Information

None

New equipment description

PSE&G would be required to design and construction modifications of the existing A-Frame, 230-kV overhead strain bus to 3 conductors per phase. New 230kV SF6 AC breaker, disconnect switches and Current Transformers will be installed Please see Appendix B for the full equipment list

Substation assumptions

The switching station is currently a five bay breaker and a half configuration with five 230-kV lines and a spare position in bus section 7. The site requires expansion due to additional 230-kV incoming lines as part of the network upgrades. However, the station can expand the breaker and half arrangement farther north, where the old 138-kV station and the retired generation collector bus used to be located.

Real-estate description

The scope associated with the POI upgrades can be located all on existing PSE&G property Refer to Section 5 in the Bid for the real estate analysis

Construction responsibility

PSEG

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Competitive

Permitting / routing / siting

Competitive

ROW / land acquisition

Competitive

Materials & equipment

Competitive

Construction & commissioning

Competitive

Construction management

Competitive

Overheads & miscellaneous costs

Competitive

| | |
|----------------------------------|-----------------|
| Contingency | Competitive |
| Total component cost | \$18,066,725.00 |
| Component cost (in-service year) | \$21,627,461.00 |

Greenfield Transmission Line Component

| | |
|---------------------|--|
| Component title | S2 320kV Sewaren AC Tie Line |
| Project description | Construct a 230kV OH AC tie-line between the onshore converter station and the 230kV Sewaren Switching Station |
| Point A | Sewaren DC/AC Converter Station |
| Point B | Sewaren Substation |
| Point C | |

| | Normal ratings | Emergency ratings |
|-------------------------------|---|-------------------|
| Summer (MVA) | 1200.000000 | 1200.000000 |
| Winter (MVA) | 1200.000000 | 1200.000000 |
| Conductor size and type | Three 1590MCM ACSR conductors per phase | |
| Nominal voltage | AC | |
| Nominal voltage | 230-kV | |
| Line construction type | Overhead | |
| General route description | The AC connection between two facilities will consist of a short (approximately 250 feet or less) 230-kV AC overhead transmission line (overhead strain bus connection). | |
| Terrain description | The connection is within the existing switching station property. | |
| Right-of-way width by segment | The Sewaren OnSS will be located adjacent to the Sewaren POI (i.e., the Sewaren Switching Station). As a result, the AC connection between the two facilities will consist of a short (approximately 250 feet or less) 230-kV AC overhead transmission line (overhead strain bus connection). | |

| | |
|--|---|
| Electrical transmission infrastructure crossings | Electrical infrastructure crossings may be required depending on final line routing and design. |
| Civil infrastructure/major waterway facility crossing plan | The extent of detail civil infrastructure planning will be determined pending final design. |
| Environmental impacts | The PSEG/Ørsted Team conducted an assessment of anticipated permits associated with the Project and supported the evaluation of siting, routing, and development scenarios throughout the Project development process. The permitting and environmental assessments included a review of Federal, regional, State, and local regulatory requirements that could potentially impact each of the individual Project components. These assessments reflect in-depth analyses of the proposed Project plan reviewed with available GIS data, a detailed understanding of applicable regulations, and significant professional experience with projects of similar scope and in this same locality. As part of this Project analyses, potential Project sites and routes were discussed with a myriad group of experienced planning, engineering and construction professionals to find a competitive route that minimized environmental and built environment concerns. Refer to Appendix K for the environmental protection plan |
| Tower characteristics | Overhead strain bus will be installed between a-frames at Sewaren switching station and the onshore converter station |
| Construction responsibility | Proposer |
| Benefits/Comments | |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | Competitive |
| Permitting / routing / siting | Competitive |
| ROW / land acquisition | Competitive |
| Materials & equipment | Competitive |
| Construction & commissioning | Competitive |
| Construction management | Competitive |
| Overheads & miscellaneous costs | Competitive |
| Contingency | Competitive |
| Total component cost | \$648,594.00 |

Component cost (in-service year) \$793,896.00

Greenfield Substation Component

Component title S3 320kV Sewaren Onshore Converter

Project description

Substation name Sewaren Onshore Converter

Substation description The converter station will be a ± 320 -kVDC/230-kVAC 1200 MW facility that will be fed by the HVDC export cable system and linked to Sewaren Switching Station via a 230-kV overhead strain bus connection.

Nominal voltage DC

Nominal voltage ± 320 -kV DC/230-kV AC 1200 MW facility

Transformer Information

| | Name | Capacity (MVA) | |
|--------------|---------------------------|-----------------------|-----------------|
| Transformer | Converter Transformer Ph1 | 460 | |
| | High Side | Low Side | Tertiary |
| Voltage (kV) | 350 | 230 | 34.5 |
| | Name | Capacity (MVA) | |
| Transformer | Converter Transformer Ph2 | 460 | |
| | High Side | Low Side | Tertiary |
| Voltage (kV) | 350 | 230 | 34.5 |
| | Name | Capacity (MVA) | |
| Transformer | Converter Transformer Ph3 | 460 | |

| | High Side | Low Side | Tertiary |
|-----------------------------|---|--------------------------|-----------------|
| Voltage (kV) | 230 | 350 | 34.5 |
| Major equipment description | The main features and equipment include ±320-kV 1200MW Converter Station, Three (3) Active Single Phase Transformers, One (1) Spare Transformer, Cooler for Converter, Control Building, Spare Parts Building. For additional information on Switching, Metering, & Control Devices, AC power equipment, DC/AC inverters, relay and communication etc. please see section 3 in the bid. | | |
| | Normal ratings | Emergency ratings | |
| Summer (MVA) | 1200.000000 | 1200.000000 | |
| Winter (MVA) | 1200.000000 | 1200.000000 | |
| Environmental assessment | Overview - The Project Team conducted an assessment of anticipated permits associated with the Sewaren route and have supported the evaluation of routing and development scenarios throughout the project development process. The permitting and environmental assessments have included a review of Federal, regional, State, and local regulatory requirements that could potentially impact each of the individual project scenarios. For onshore facility siting and routing, the Project Team evaluated land ownership with a dedicated approach to minimize disturbance to Green Acres, wetlands, flood hazard areas, known historic and cultural sites, threatened and endangered species, known contaminated sites, and known sensitive receptors. The site is located in a Flood Zone will require design to meet FEMA+1. No Wetlands and no impacts to threatened and endangered species. Please see Appendix K for additional information. | | |

Outreach plan

The team has developed a comprehensive communication process for all transmission projects to adequately keep stakeholders engaged at all levels, including public officials, municipal officials, environmental organizations, business customers, residents, etc. This process ensures constant and detailed communication efforts throughout all phases of a project, including pre, mid and post-construction activities. This Combined Team is currently working together on the Ocean Wind project and combined has actual permitting experience for the offshore wind environment and vast New Jersey-based permitting experience with firsthand relationships across the Federal and State government. The team has been able to gain a thorough understanding of the various concerns typically raised by either directly impacted or peripheral parties, such as disruptions during construction, concerns around electromagnetic fields (EMF), property value, traffic impacts and other potential matters. However, more importantly, the team has been able to identify solutions for each potential concern, and has strong insight on how to mitigate public apprehension and construction impacts. The team has developed a specific outreach plan tailored towards the Offshore Wind Transmission Project that will be implemented to foster the success of the project. The team's strategy outreach plan uses multiple and concurrent communication methods to reach and inform and address diverse audiences and knowledge levels. A variety of communication tactics will be used, tailored to each stakeholder audience and its particular communication style and preference. Messages and actions will be customized for each stakeholder group. Communications will be designed to provide adequate information to stakeholders. All timings of these communications will be aligned with the project's schedule pre- and post-bid submission. Please refer to Appendix S for the community engagement plan

Land acquisition plan

The subject property is a portion of the former power generating station for PSEG Power and current Sewaren Switching Station located along the Port Reading Reach of the Arthur Kill. The parcel contains approximately 120+ acres of land, and the solution would use four (4) parcel areas over a portion of approximately 10 acres of the site, dependent upon the solution. This property is owned by a PSEG affiliate, PSEG Power, LLC. PSEG Power is a deregulated entity, and the Project Team has reached agreement with its sister company to secure rights to the necessary real estate if granted an award. The Project Team is confident that the unique rights available to us ensure that the Projects are constructible if awarded by PJM and the BPU.

Construction responsibility

Proposer

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Competitive

Permitting / routing / siting

Competitive

ROW / land acquisition

Competitive

Materials & equipment

Competitive

| | |
|----------------------------------|------------------|
| Construction & commissioning | Competitive |
| Construction management | Competitive |
| Overheads & miscellaneous costs | Competitive |
| Contingency | Competitive |
| Total component cost | \$405,934,703.03 |
| Component cost (in-service year) | \$496,874,466.00 |

Greenfield Transmission Line Component

| | |
|---------------------|--|
| Component title | S4 320kV Sewaren Offshore/Onshore HVDC Cable |
| Project description | |
| Point A | HS-21 |
| Point B | Sewaren DC/AC Converter Station |
| Point C | |

| | Normal ratings | Emergency ratings |
|---------------------------|--|-------------------|
| Summer (MVA) | 1200.000000 | 1200.000000 |
| Winter (MVA) | 1200.000000 | 1200.000000 |
| Conductor size and type | Offshore ±320kV HVDC XLPE 3000mm ² Cu. Onshore ± 320kV HVDC XLPE 3000mm ² Cu | |
| Nominal voltage | DC | |
| Nominal voltage | ±320kV | |
| Line construction type | Underground, Submarine | |
| General route description | Offshore: Approximately 92.1-miles in route length in a direction generally north, then west from HS-21 through the Atlantic Ocean then Raritan Bay and into the Raritan River to meet the shore Onshore: Approximately 6.3 miles, extending principally beneath public road ROWs from Keasbey, through Perth Amboy Township, to the new converter station in Sewaren | |

| | |
|--|---|
| Terrain description | Offshore: The HVDC submarine route was carefully selected to avoid challenging geotechnical conditions, physical obstructions, and known significant environmental features, while efficiently siting the offshore cable system. Onshore: Along almost all of the route, the onshore HVDC cables will be buried beneath public roads. |
| Right-of-way width by segment | Offshore: Approximately 92.1 miles (HS-21 to the RA-1 Landfall). 60' typical cable width (disturbed) Onshore: 6.3 mile length installed UG with 5'-0" Minimum Width for duct banks |
| Electrical transmission infrastructure crossings | Electrical infrastructure crossings may be required depending on final line routing and design. |
| Civil infrastructure/major waterway facility crossing plan | The installation process will typically involve the following tasks: - Trench Excavation/Duct Bank Installation. The cable trench will be excavated to dimensions of approximately 6 to 10 feet deep and 5 to 7 feet wide (for trench depths requiring shoring to stabilize the sidewalls). - Splice Vault Excavation/Installation. At intervals along the cable route, areas will be excavated for the installation of below-grade of reinforced-concrete splice vaults, within which cable sections will be connected. - Proofing/Cable Installation. After successful proofing, the transmission cables will be installed and spliced within the vaults. Special Crossings - Along the HVDC and AC cable routes, where open trenching is not viable, special crossing techniques will be used to install the cable while minimizing environmental impacts. - Jack & Bore (J&B). This method will be used to install the cable system beneath certain infrastructure or other features that cannot be open cut (e.g., a railroad or highway). - Bridge Attachment. This method is applicable in areas where an open-cut installation is not practical and the cable system can instead be attached to an existing bridge, thereby effectively spanning features such as water resources or highway underpasses. - Horizontal Directional Drilling (HDD). This method is typically used to install cable where open cut is not feasible (usually when crossing water bodies or highways), where there is no suitable bridge to attach to, and where J&B is not feasible (water body or too long of a crossing). Please see section 4.4 in the proposal for further information |
| Environmental impacts | The PSEG/Ørsted Team conducted an assessment of anticipated permits associated with the Project and supported the evaluation of siting, routing, and development scenarios throughout the Project development process. The permitting and environmental assessments included a review of Federal, regional, State, and local regulatory requirements that could potentially impact each of the individual Project components. These assessments reflect in-depth analyses of the proposed Project plan reviewed with available GIS data, a detailed understanding of applicable regulations, and significant professional experience with projects of similar scope and in this same locality. This Project was designed to minimize impacts to physical resources on shore, in large part by undergrounding the HVDC cable system primarily within road ROWs. . This approach would result in only temporary impacts to wetlands and water bodies with no offshore and no permanent wetlands impacts expected. Please see Appendix K |
| Tower characteristics | N/A, the route will be entirely UG |
| Construction responsibility | Proposer |

Benefits/Comments

Component Cost Details - In Current Year \$

| | |
|----------------------------------|--------------------|
| Engineering & design | Competitive |
| Permitting / routing / siting | Competitive |
| ROW / land acquisition | Competitive |
| Materials & equipment | Competitive |
| Construction & commissioning | Competitive |
| Construction management | Competitive |
| Overheads & miscellaneous costs | Competitive |
| Contingency | Competitive |
| Total component cost | \$830,232,304.00 |
| Component cost (in-service year) | \$1,016,225,590.00 |

Greenfield Substation Component

| | |
|------------------------|--|
| Component title | S5 320kV Sewaren Offshore Converter |
| Project description | |
| Substation name | Sewaren Offshore Converter Platform (OCP HS-21) |
| Substation description | The OCP that will feed the Sewaren OnSS will be located adjacent to the Hudson South BOEM lease area in the New York Bight. The OCP is made up of two main components: the substructure and the topside. The substructure—the lattice structure that is fixed to the seabed—is commonly referred to as the jacket. The topside is the steel enclosure on top of the jacket that contains the electrical equipment. |
| Nominal voltage | DC |
| Nominal voltage | ±320-kV |

Transformer Information

| | | | |
|-----------------------------|--|--------------------------|-----------------|
| | Name | Capacity (MVA) | |
| Transformer | T1 | 744 | |
| | High Side | Low Side | Tertiary |
| Voltage (kV) | 330 | 275 | 23 |
| | Name | Capacity (MVA) | |
| Transformer | T2 | 744 | |
| | High Side | Low Side | Tertiary |
| Voltage (kV) | 330 | 275 | 23 |
| Major equipment description | <p>The OCP will house the equipment necessary to receive AC electrical power from the connected wind farm, convert it to HVDC and export it to the onshore station via HVDC sub-sea and land cable. The main HV components include AC switchgear, transformers, DC converter towers, DC reactors and DC switchgear. Please refer to Appendix B for the full equipment list</p> | | |
| | Normal ratings | Emergency ratings | |
| Summer (MVA) | 1200.000000 | 1200.000000 | |
| Winter (MVA) | 1200.000000 | 1200.000000 | |
| Environmental assessment | <p>Overview - The Project Team conducted an assessment of anticipated permits associated with the Sewaren route and have supported the evaluation of routing and development scenarios throughout the project development process. The permitting and environmental assessments have included a review of Federal, regional, State, and local regulatory requirements that could potentially impact each of the individual project scenarios. For offshore facility siting and routing, the Project Team reviewed available GIS data for the presence of marine mammals, fishing and shipping lanes, benthic habitat, anchorage areas, known obstructions, existing cables, and bathymetry. Please refer to Exhibit K.</p> | | |

Outreach plan

The team has developed a comprehensive communication process for all transmission projects to adequately keep stakeholders engaged at all levels, including public officials, municipal officials, environmental organizations, business customers, residents, etc. This process ensures constant and detailed communication efforts throughout all phases of a project, including pre, mid and post-construction activities. This Combined Team is currently working together on the Ocean Wind project and combined has actual permitting experience for the offshore wind environment and vast New Jersey-based permitting experience with firsthand relationships across the Federal and State government. The team has been able to gain a thorough understanding of the various concerns typically raised by either directly impacted or peripheral parties, such as disruptions during construction, concerns around electromagnetic fields (EMF), property value, traffic impacts and other potential matters. However, more importantly, the team has been able to identify solutions for each potential concern, and has strong insight on how to mitigate public apprehension and construction impacts. The team has developed a specific outreach plan tailored towards the Offshore Wind Transmission Project that will be implemented to foster the success of the project. The team's strategy outreach plan uses multiple and concurrent communication methods to reach and inform and address diverse audiences and knowledge levels. A variety of communication tactics will be used, tailored to each stakeholder audience and its particular communication style and preference. Messages and actions will be customized for each stakeholder group. Communications will be designed to provide adequate information to stakeholders. All timings of these communications will be aligned with the project's schedule pre- and post-bid submission.

Land acquisition plan

The project will complete a Right of Use / Right of Way (RUE/ROW) application with BOEM to be granted authorization to place the offshore collector platform in the area between Hudson South A and Hudson South B lease areas. The platforms will be placed outside of the lease areas such that additional authorization from the lease holders will not be necessary.

Construction responsibility

Proposer

Benefits/Comments

Component Cost Details - In Current Year \$

Engineering & design

Competitive

Permitting / routing / siting

Competitive

ROW / land acquisition

Competitive

Materials & equipment

Competitive

Construction & commissioning

Competitive

Construction management

Competitive

| | |
|----------------------------------|--------------------|
| Overheads & miscellaneous costs | Competitive |
| Contingency | Competitive |
| Total component cost | \$1,040,277,350.00 |
| Component cost (in-service year) | \$1,273,326,103.00 |

Congestion Drivers

None

Existing Flowgates

| FG # | From Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|-------------|--------------|---------------|------------|-------------|-----|---------|---------|--------------------|----------|
| 28-GD-W1 | 270072 | FUR RUN_500 | 270073 | FUR RUN_230 | 1 | 500/230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-W2 | 270072 | FUR RUN_500 | 270073 | FUR RUN_230 | 2 | 500/230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 270072 | FUR RUN_500 | 270073 | FUR RUN_230 | 1 | 500/230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 270072 | FUR RUN_500 | 270073 | FUR RUN_230 | 2 | 500/230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-W21 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-W22 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 2 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 2 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-W23 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-W124 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 28-GD-W125 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230 | 225 | Gen Deliv (winter) | Included |
| 35-GD-W22 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 1 | 230/230 | 225/225 | Gen Deliv (winter) | Included |
| 35-GD-W23 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 2 | 230/230 | 225/225 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 1 | 230/230 | 225/225 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 232012 | HOPE CREEK | 232014 | LSPWR CABLE | 2 | 230/230 | 225/225 | Gen Deliv (winter) | Included |

| FG # | From Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|-------------|--------------|---------------|------------|-------------|-----|---------|---------|--------------------|----------|
| 35-GD-S2-W1 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230/230 | 225/225 | Gen Deliv (winter) | Included |
| 35-GD-W24 | 232014 | LSPWR CABLE | 232013 | SILVER RUN | 1 | 230/230 | 225/225 | Gen Deliv (winter) | Included |
| 28-GD-S2-S8 | 206302 | 28OYSTER C | 206297 | 28MANITOU | 1 | 230 | 228 | Gen Deliv (Summer) | Included |
| 28-GD-S2-S9 | 206302 | 28OYSTER C | 206297 | 28MANITOU | 1 | 230 | 228 | Gen Deliv (Summer) | Included |
| 28-GD-S2-S1 | 206302 | 28OYSTER C | 206297 | 28MANITOU | 2 | 230 | 228 | Gen Deliv (Summer) | Included |
| 28-GD-W18 | 206236 | 28GILBERT | 208091 | SFLD | 1 | 230 | 228/229 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 206236 | 28GILBERT | 208091 | SFLD | 1 | 230/230 | 228/229 | Gen Deliv (winter) | Included |
| 28-GD-W9 | 206305 | 28RAR RVR | 218331 | KILMER_I | 1 | 230 | 228/231 | Gen Deliv (winter) | Included |
| 28-GD-W11 | 206305 | 28RAR RVR | 218331 | KILMER_I | 1 | 230 | 228/231 | Gen Deliv (winter) | Included |
| 28-GD-W7 | 206305 | 28RAR RVR | 218331 | KILMER_I | 1 | 230 | 228/231 | Gen Deliv (winter) | Included |
| 28-GD-W13 | 206305 | 28RAR RVR | 218331 | KILMER_I | 1 | 230 | 228/231 | Gen Deliv (winter) | Included |
| 28-GD-W14 | 206305 | 28RAR RVR | 218331 | KILMER_I | 1 | 230 | 228/231 | Gen Deliv (winter) | Included |
| 28-GD-S66 | 206316 | 28WINDSOR | 219752 | CLRKSVLL_1 | 1 | 230 | 228/231 | Gen Deliv (Summer) | Included |
| 28-GD-S2-S3 | 206316 | 28WINDSOR | 219752 | CLRKSVLL_1 | 1 | 230 | 228/231 | Gen Deliv (Summer) | Included |
| 28-GD-W15 | 214277 | RICHMOND35 | 214012 | WANEETA3 | 1 | 230 | 230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 214277 | RICHMOND35 | 214012 | WANEETA3 | 1 | 230 | 230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 200066 | PCHBTM1N | 270072 | FUR RUN_500 | 1 | 500 | 230/225 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 200066 | PCHBTM1N | 270072 | FUR RUN_500 | 1 | 500/500 | 230/225 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 214277 | RICHMOND35 | 214012 | WANEETA3 | 1 | 230/230 | 230/230 | Gen Deliv (winter) | Included |
| 35-GD-W16 | 214277 | RICHMOND35 | 214012 | WANEETA3 | 1 | 230/230 | 230/230 | Gen Deliv (winter) | Included |
| 35-GD-W5 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500/500 | 230/232 | Gen Deliv (winter) | Included |
| 35-GD-W6 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500/500 | 230/232 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500/500 | 230/232 | Gen Deliv (winter) | Included |
| 35-GD-S2-W3 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500/500 | 230/232 | Gen Deliv (winter) | Included |
| 35-GD-S2-W5 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500/500 | 230/232 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 218345 | ALDENE_6 | 216911 | SPRINGRD_3 | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-W12 | 218345 | ALDENE_6 | 216911 | SPRINGRD_3 | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S72 | 219104 | CLRKSVLL_2 | 217150 | LAWRENCE | 1 | 230 | 231 | Gen Deliv (Summer) | Included |

| FG # | From Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|-------------|--------------|---------------|------------|-------------|-----|---------|---------|------------------------|----------|
| 28-GD-L14 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Light Load - Gen Deliv | Included |
| 35-GD-L14 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Light Load - Gen Deliv | Included |
| 28-GD-S64 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (Summer) | Included |
| 28-GD-S65 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (Summer) | Included |
| 28-GD-W109 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-W108 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-W3 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-W8 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-W6 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-S1 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (Summer) | Included |
| 28-GD-S2-S2 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (Summer) | Included |
| 28-GD-S2-W7 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-W6 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S73 | 200006 | DEANS C | 218306 | DEANS | 3 | 500/230 | 231 | Gen Deliv (Summer) | Included |
| 28-GD-W17 | 218333 | LNELSN_I | 218301 | MIDDLESEX_I | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 218333 | LNELSN_I | 218301 | MIDDLESEX_I | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 218333 | LNELSN_I | 218301 | MIDDLESEX_I | 1 | 230 | 231 | Gen Deliv (winter) | Included |
| 35-GD-S2-S6 | 218307 | ALDENE_2 | 218430 | STANTER_1 | 1 | 230/230 | 231/231 | Gen Deliv (Summer) | Included |
| 35-GD-S2-S9 | 218307 | ALDENE_2 | 218430 | STANTER_1 | 1 | 230/230 | 231/231 | Gen Deliv (Summer) | Included |
| 35-GD-S2-S8 | 218345 | ALDENE_6 | 216911 | SPRINGRD_3 | 1 | 230/230 | 231/231 | Gen Deliv (Summer) | Included |
| 35-GD-W13 | 218345 | ALDENE_6 | 216911 | SPRINGRD_3 | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W9 | 218345 | ALDENE_6 | 216911 | SPRINGRD_3 | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |

| FG # | From Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|-------------|--------------|---------------|------------|-------------|-----|---------|---------|--------------------|----------|
| 35-GD-W4 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-W7 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-W9 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-S2 | 218306 | DEANS | 218304 | BRUNSWCK | 1 | 230/230 | 231/231 | Gen Deliv (Summer) | Included |
| 35-GD-S14 | 218300 | LINDEN | 219046 | TOSCO_3 | 1 | 230/230 | 231/231 | Gen Deliv (Summer) | Included |
| 35-GD-S13 | 218343 | TOSCO_2 | 218441 | VFT_2 | 1 | 230/230 | 231/231 | Gen Deliv (Summer) | Included |
| 28-GD-S2-S1 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230 | 231/234 | Gen Deliv (Summer) | Included |
| 28-GD-S2-W1 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230 | 231/234 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230 | 231/234 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230 | 231/234 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230 | 231/234 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 220073 | FUR RUN_230 | 220963 | CONASTON | 2 | 230 | 232/225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 220073 | FUR RUN_230 | 220963 | CONASTON | 1 | 230 | 232/225 | Gen Deliv (winter) | Included |
| 28-GD-W19 | 270073 | FUR RUN_230 | 220963 | CONASTON | 1 | 230 | 232/225 | Gen Deliv (winter) | Included |
| 28-GD-W20 | 270073 | FUR RUN_230 | 220963 | CONASTON | 2 | 230 | 232/225 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W1 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W2 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W3 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-W4 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-W5 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-W110 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-W111 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-W112 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-W16 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W9 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |

| FG # | From Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|--------------|--------------|---------------|------------|-------------|-----|---------|---------|--------------------|----------|
| 28-GD-S2-W32 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-W37 | 200064 | PCHBTM1S | 200004 | CNASTONE | 1 | 500 | 232/230 | Gen Deliv (winter) | Included |
| 28-GD-S2-S13 | 227934 | CARDIFF2 | 227945 | LEWIS #2 | 1 | 138 | 234 | Gen Deliv (Summer) | Included |
| 28-GD-S2-S13 | 227945 | LEWIS #2 | 227902 | LEWIS #1 | 1 | 138 | 234 | Gen Deliv (Summer) | Included |
| 35-GD-S2-S8 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230/230 | 234/231 | Gen Deliv (Summer) | Included |
| 35-GD-S2-W7 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230/230 | 234/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W3 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230/230 | 234/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W1 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230/230 | 234/231 | Gen Deliv (winter) | Included |
| 35-GD-S2-W9 | 227900 | CARDIFF C | 219100 | NEWFRDM | 1 | 230/230 | 234/231 | Gen Deliv (winter) | Included |

New Flowgates

| FG # | From Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type |
|-----------|--------------|---------------|------------|-------------|-----|---------|---------|--------------------|
| FG-397-1 | 216950 | ROSELAND | 206257 | WHIPPANY | 1 | 230 | PSEG | Gen Deliv (winter) |
| FG-397-2 | 218469 | METUCHEN | 218357 | PRSNVAV_Z | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-3 | 218357 | PRSNVAV_Z | 218352 | MDWRD_Z | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-4 | 218352 | MDWRD_Z | 218304 | BRUNSWCK | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-5 | 218311 | SEWAREN | 218353 | MINUEST_R | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-6 | 218353 | MINUEST_R | 218300 | LINDEN | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-7 | 218469 | METUCHEN | 218355 | NEWDOVR_H | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-8 | 218355 | NEWDOVR_H | 218320 | FANWOOD_1 | 1 | 230 | PSEG | Gen Deliv (Summer) |
| FG-397-9 | 218300 | LINDEN | 217958 | LINDEN_345 | 1 | 345/230 | PSEG | Gen Deliv (winter) |
| FG-397-10 | 219052 | FANWOOD_2 | 218504 | FRONTST_2 | 1 | 230 | PSEG | Gen Deliv (winter) |
| FG-397-11 | 218502 | FRONTST_4 | 216950 | ROSELAND | 1 | 230 | PSEG | Gen Deliv (winter) |

Financial Information

Capital spend start date

06/2022

Construction start date

11/2024

Project Duration (In Months) 90

Cost Containment Commitment

Cost cap (in current year) \$2,277,092,952.00

Cost cap (in-service year) \$2,787,220,055.00

Components covered by cost containment

1. S2 320kV Sewaren AC Tie Line - Proposer
2. S3 320kV Sewaren Onshore Converter - Proposer
3. S4 320kV Sewaren Offshore/Onshore HVDC Cable - Proposer
4. S5 320kV Sewaren Offshore Converter - Proposer

Cost elements covered by cost containment

| | |
|---------------------------------|-----|
| Engineering & design | Yes |
| Permitting / routing / siting | Yes |
| ROW / land acquisition | Yes |
| Materials & equipment | Yes |
| Construction & commissioning | Yes |
| Construction management | Yes |
| Overheads & miscellaneous costs | Yes |
| Taxes | No |
| AFUDC | No |
| Escalation | No |

Additional Information

Project is offering a guaranteed availability date of December 31st 2029 subject to the terms in the cost commitment legal language. Construction Cost Cap Amount will be adjusted for inflation beyond existing expectations based on changes in the Handy-Whitman Index; Cost Cap may increase or decrease based on changes to Handy-Whitman Index. Construction Cost Cap Amount will be adjusted based on changes in foreign exchange rates; Cost Cap may increase or decrease based on changes in foreign exchange rates. Construction Cost Cap may be adjusted based on changes to in taxes or duties that differ from assumptions. Specific cost cap commitments can be found in Section 1.7 of the SAA submittal and the attached legal language.

Is the proposer offering a binding cap on ROE?

Yes

Would this ROE cap apply to the determination of AFUDC?

Yes

Would the proposer seek to increase the proposed ROE if FERC finds that a higher ROE would not be unreasonable?

No

Is the proposer offering a Debt to Equity Ratio cap?

Yes

Additional cost containment measures not covered above

Project has proposed specific cost cap language in the SAA submittal, and is also submitting proposed legal language in the PJM planner. As an overview, the Project is capping costs which it can control, and excluding costs that it cannot. Excluded costs broadly fall into the following categories: Foreign exchange costs in excess of assumptions, inflation and tax costs in excess of assumptions, and excess costs driven by delays in government and regulatory approvals. As specified in the submitted legal language, the Project team would need to demonstrate to the BPU how these changes impacted the price and schedule of the Proposal before any adjustments would be made. Changes caused by delay, inaction, or lack of reasonable diligence on the part of the Project team would not be reason for a cost cap or schedule adjustment.

Additional Comments

None