



PJM Interconnection, L.L.C.
2750 Monroe Blvd.
Audubon, PA 19403

Pauline Foley
Associate General Counsel
T: (610) 666-8248 | F: (610) 666-8211
pauline.foley@pjm.com

August 29, 2019

Honorable Kimberly D. Bose, Secretary
Federal Energy Regulatory Commission
888 First Street, N.E., Room 1A
Washington, D.C. 20426

*Re: PJM Interconnection, L.L.C., Docket No. ER19-2708-000
[30-Day Comment Period Requested]*

Dear Secretary Bose:

In accordance with PJM Open Access Transmission Tariff, Schedule 12 (“Tariff” or “Schedule 12”)¹ and Amended and Restated Operating Agreement of PJM Interconnection, L.L.C., Schedule 6, section 1.6 (“Operating Agreement” or “Schedule 6”), and pursuant to section 205 of the Federal Power Act,² PJM Interconnection, L.L.C. (“PJM”) hereby submits amendments to the Tariff, Schedule 12-Appendix A to incorporate cost responsibility assignments for 51 baseline upgrades in the recent update to the Regional Transmission Expansion Plan (“RTEP”) approved by the PJM Board of Managers (“PJM Board”) on July 30, 2019.³ PJM requests that the revised Tariff sections become effective on November 27, 2019, **90 days after the date of this filing**.

¹ All capitalized terms that are not otherwise defined herein have the meaning as defined in the Tariff, Operating Agreement, and Reliability Assurance Agreement among Load Serving Entities in the PJM Region (“RAA”).

² 16 U.S.C. section 824d.

³ Of the 51 baseline upgrades approved by the PJM Board on July 30, 2019, 42 baseline upgrades are incorporated in the update to the RTEP as new baseline upgrades.

I. DESCRIPTION OF FILING

A. Description of the PJM Board Approved Updated RTEP Upgrades

On July 30, 2019, the PJM Board approved changes to the RTEP, which included approximately \$400 million in additional baseline transmission enhancements and expansions. With these approvals, the PJM Board has authorized a total of more than \$39 billion in investments since 2000.

B. Schedule 12 Requirements to Designate Cost Responsibility Assignments

This filing represents PJM's forty-ninth filing of cost responsibility assignments for new RTEP baseline upgrades since the Federal Energy Regulatory Commission ("Commission") directed such filings under Schedule 12. Pursuant to Schedule 12, PJM is required to designate in Tariff, Schedule 12-Appendix A cost responsibility assignments for all transmission enhancements and expansions included in the RTEP.⁴ Similarly, Schedule 12 requires that within 30 days of the PJM Board's approval of each RTEP, or addition to the RTEP, PJM shall designate in Schedule 12-Appendix A, and in a report filed with the Commission, the "Responsible Customers" that will be subject to charges related to transmission enhancements and expansions included in the RTEP.⁵

Schedule 12 further provides that customers designated to be responsible for assignments of cost responsibility that PJM files with the Commission shall have 30 days from the date of such filing to submit comments regarding the proposed cost responsibility assignments.⁶

⁴ See Tariff, Schedule 12, section (b)(viii) (PJM "shall designate in the Schedule 12-Appendix A . . . the cost responsibility assignments determined pursuant to this Schedule 12").

⁵ *Id.*; See also Operating Agreement, Schedule 6, section 1.6.

⁶ *Id.*

C. Description of Proposed Amendments to Schedule 12-Appendix A

On March 22, 2013, the Commission accepted revisions to Schedule 12 modifying the cost allocation methodologies for transmission projects included in the RTEP.⁷ These revisions were filed by the PJM Transmission Owners in compliance with Order No. 1000 and revised the methodologies for allocating cost responsibility for all RTEP transmission expansions, including reliability and economic projects, replacement projects, and high voltage direct current transmission projects. These revisions only apply to the cost allocations for projects included in the RTEP on a prospective basis and do not disturb the cost allocations for projects previously included in the RTEP. Therefore, the cost responsibility assignments for RTEP projects approved after the March 22 Order are segregated in a separate appendix from the previously-approved cost responsibility assignments for RTEP upgrades. Going forward, cost responsibility assignments for all new RTEP projects are located in Schedule 12-Appendix A.

As required by Schedule 12, PJM hereby submits amendments to Schedule 12-Appendix A to include the new cost responsibility assignments for RTEP upgrades approved by the PJM Board on July 30, 2019.⁸ The revised Tariff sections containing new language, including new cost responsibility assignments, are reflected in redline and clean format in Attachments B and C, respectively, to this transmittal letter.⁹

⁷ *PJM Interconnection, L.L.C., et al.*, 142 FERC ¶ 61,214 at PP 411, 448 (2013) (“March 22 Order”).

⁸ See Tariff, Schedule 12, section (b)(viii).

⁹ The revised Tariff sections do not include any proposed rates or charges for recovery of any system upgrade costs. In accordance with Tariff, Schedule 12, recovery of the costs of such facilities that the RTEP requires Transmission Owners to construct, own and/or finance is governed by the Transmission Owners’ established rates.

1. Assignment of Cost Responsibility for Regional Facilities

The new transmission enhancements or expansions included in this most recent update to the RTEP approved by the PJM Board on July 30, 2019, are not Regional Facilities.¹⁰ Thus, PJM does not include any cost responsibility assignments for such facilities in Schedule 12-Appendix A with this filing.

2. Assignments of Cost Responsibility for Lower Voltage Facilities Needed for Reliability

a. Cost Responsibility Assignments that Address Transmission Enhancements Costing More than \$5 Million and Require DFAX Analysis

Consistent with the Tariff, Schedule 12, PJM submits amendments to the Tariff, Schedule 12-Appendix A to include the cost responsibility assignments for transmission enhancements or expansions that are not Regional Facilities (“Lower Voltage Facilities”).¹¹ Eight (8) enhancements or expansions¹² included in this filing, approved by the PJM Board on July 30, 2019, are Lower Voltage Facilities required to address reliability needs for which PJM applied the solution-based DFAX analysis described in the Tariff, Schedule 12, section (b)(iii).

b. Cost Responsibility Assignments for Transmission Enhancements that Address Reliability Violations on Transmission Facilities Operating At or Below 200 kV

By order dated August 26, 2016,¹³ the Commission accepted, subject to condition, PJM’s April 1, 2016 filing exempting from PJM’s competitive proposal window process, except under

¹⁰ Regional Facilities include transmission enhancements and expansions that, among other things, will operate at or above 500 kV or will be double-circuit 345 kV facilities as defined in PJM Tariff, Schedule 12, section (b)(i).

¹¹ See Tariff, Schedule 12, section (b)(ii)(A) (“If the Lower Voltage Facility is a Reliability Project, [PJM] shall use the DFAX analysis described in section (b)(iii) of this Schedule 12 . . .”).

¹² The Lower Voltage Facilities include: b3012.1, b3012.2, b3012.3, b3012.4, b3108.1, b3108.2, b3108.3 and b3109.

¹³ *PJM Interconnection, L.L.C.*, 156 FERC ¶ 61,132 (Aug. 26, 2016) (“August 26 Order”).

certain circumstances, reliability violations on transmission facilities operating below 200 kV.¹⁴ In its September 26, 2016 compliance filing, PJM, as authorized by the PJM Transmission Owners acting through the Consolidated Transmission Owners Agreement, proposed to amend Schedule 12 to include a new Tariff, Schedule 12, section (b)(xvi), to provide that solutions for reliability violations on a facility operating at or below 200 kV not included in a competitive proposal window pursuant to Schedule 6, section 1.5.8(c) will be allocated 100 percent to the zone in which the transmission facilities are located. On February 2, 2017, the Commission accepted, effective August 26, 2016, the proposed revisions to both the Tariff, Schedule 12 and the PJM Operating Agreement, Schedule 6.

Consistent with Tariff, Schedule 12, section (b)(xvi), PJM proposes revisions to Schedule 12-Appendix A to include cost responsibility assignments 100 percent to the zone in which the facilities are to be located for four (4) reliability enhancements to address reliability violations on transmission facilities operating at or below 200 kV that were not included in a competitive proposal window.¹⁵

c. Cost Responsibility Assignments that Address FERC Form No. 715
Local Planning Criteria

On February 12, 2016, the Commission accepted on rehearing, effective May 25, 2015, the PJM Transmission Owners' proposal to allocate 100 percent of the costs of a certain category of RTEP projects, which would not otherwise be included in the RTEP but for the fact they solely address local transmission owner planning criteria, to the zone of the Transmission Owner that

¹⁴ *PJM Interconnection, L.L.C.*, Revisions to PJM Operating Agreement, Schedule 6, Section 1.5 (Lower Voltage Facilities Threshold), Docket No. ER16-1335-000 (April 1, 2016).

¹⁵ The following upgrades are transmission facilities operating at or below 200 kV that were not included in a competitive proposal window: b3011.7, b3104, b3105 and b3106.

filed the criteria in its FERC Form No. 715.¹⁶ Consistent with Schedule 12, section (b)(xv), which details the cost allocation methodology for projects selected solely to address FERC Form No. 715 criteria, PJM proposes revisions to Schedule 12-Appendix A to include cost responsibility assignments for thirty-four (34) Lower Voltage Facility enhancements or expansions that solely address FERC Form No. 715 local planning criteria.¹⁷

d. Cost Responsibility Assignments that Address Transmission Enhancements Costing Less than \$5 Million

Schedule 12, section (b)(vi) provides that, notwithstanding Schedule 12, sections (b)(i), (b)(ii), (b)(iv) and (b)(v), cost responsibility for an enhancement or expansion for which the good faith estimate of the cost of such enhancement or expansion included for the first time in the RTEP does not equal or exceed \$5 million shall be assigned to the zone where the enhancement or expansion is to be located. Consistent with Schedule 12, section (b)(vi), PJM proposes revisions to Schedule 12-Appendix A to include cost responsibility assignments for three (3) enhancements or expansions needed for reliability.¹⁸ Therefore, consistent with Schedule 12, section (b)(vi), cost responsibility for such enhancements or expansions shall be allocated 100 percent to the zone of the Transmission Owner where the enhancements or expansions are to be located.

¹⁶ *PJM Interconnection, L.L.C.*, 154 FERC ¶ 61,096 at P 13 (Feb. 12, 2016) (“February 12 Order”). On August 3, 2018, the United States Court of Appeals for the District of Columbia found that the Commission acted arbitrarily and capriciously by accepting the cost allocation methodology for Regional Facilities addressing FERC Form No. 715 criteria and remanded the open orders back to the Commission for review. *See Old Dominion Electric Cooperative v. FERC*, No. 17-1040 (D.C. Cir. 2018). Such decision should have no impact on the 13 upgrades filed herein and approved by the PJM Board on February 12, 2019, as they are all Lower Voltage Facilities.

¹⁷ The following upgrades were selected solely to address Form 715 criteria: b3096, b3097, b3098, b3099, b3100, b3101, b3102, b3103.1, b3103.2, b3103.3, b3103.4, b3103.5, b3103.6, b3103.7, b3103.8, b3110.1, b3110.2, b3111, b3112, b3113, b3114, b3116, b3118.1, b3118.2, b3118.3, b3118.4, b3118.5, b3118.6, b3118.7, b3118.8, b3118.9, b3118.10, b3208, and b3209.

¹⁸ The Lower Voltage Facilities allocated pursuant to Schedule 12, section (b)(vi) include the following reliability upgrade: b1570.4, b2970.5, and b3115.

e. Cost Responsibility Assignments that Address Spare Parts, Replacement Equipment and Circuit Breakers

The Tariff, Schedule 12, section (b)(iv)(C) provides that cost responsibility for circuit breakers and associated equipment independently included in the RTEP and not a part of the design specifications of a transmission element of a Required Transmission Enhancement shall be assigned to the zone of the owner of the spare part, if the owner of the spare part is a Transmission Owner listed in Tariff, Attachment J.

PJM proposes revisions to Schedule 12-Appendix A to include cost responsibility assignment for two (2) enhancements needed to address spare parts, replacement equipment and circuit breakers.¹⁹ Therefore, consistent with Tariff, Schedule 12, section (b)(iv)(C), cost responsibility for such enhancements shall be allocated 100 percent to the zone of the Transmission Owner of the spare parts.

D. Cost Responsibility Assignment Summary

For informational purposes, PJM also includes as Attachment A to this transmittal letter a Cost Responsibility Assignment Summary for the enhancements or expansions approved by the PJM Board on July 30, 2019. In addition to specifying the cost responsibility assignments for the enhancements or expansions, the summary sheets provide the criteria violation and test, a description of the upgrade, in-service date, estimated upgrade costs, and the entity designated with construction responsibility for each enhancement or expansion.

II. COMMENT PERIOD

The Tariff, Schedule 12 section (b)(viii) provides that customers designated to be responsible for assignments of cost responsibility shall have 30 days from the date of such filing

¹⁹ The upgrades allocated pursuant to Schedule 12, section (b)(iv)(C) include: b2686.4 and b3064.2.

to seek review regarding the proposed cost responsibility assignments. Consistent with this provision, PJM requests that the comment date for this filing be set 30 days from the date of this filing, *i.e.*, September 28, 2019.²⁰ To accommodate such a comment date, PJM requests an effective date of November 27, 2019 (90 days from the date of this filing) for all revised Tariff sections submitted in this docket.²¹

III. DOCUMENTS ENCLOSED

PJM encloses the following:

1. This transmittal letter;
2. Attachment A – Cost Responsibility Assignment Summary sheets;
3. Attachment B – Revised Tariff, Schedule 12-Appendix A (in redlined form); and
4. Attachment C – Revised Tariff, Schedule 12-Appendix A (in clean form).

IV. CORRESPONDENCE AND COMMUNICATIONS

Correspondence and communications with respect to this filing should be sent to the following persons:

Craig Glazer
Vice President–Federal Government Policy
PJM Interconnection, L.L.C.
1200 G Street, N.W., Suite 600
Washington, D.C. 20005
Ph: (202) 423-4743
Fax: (202) 393-7741
craig.glazer@pjm.com

Pauline Foley
Associate General Counsel
PJM Interconnection, L.L.C.
2750 Monroe Blvd.
Audubon, PA 19403
Ph: (610) 666-8248
Fax: (610) 666-4281
pauline.foley@pjm.com


²⁰ Since September 28, 2019 falls on a Saturday, comments are due on Monday, September 30, 2019. *See* 18 C.F.R. § 385.2007(a)(2) (2018).

²¹ *See, e.g., PJM Interconnection, L.L.C., Errata Notice of Extending Comment Period*, Docket Nos. ER06-456-018, *et al.* (Dec. 2, 2008) (granting extension of time for filing protests or comments to accommodate Schedule 12 of the PJM Tariff); *PJM Interconnection, L.L.C., Errata Notice Extending Comment Date*, Docket No. ER08-229-000 (Nov. 30, 2007) (same); *PJM Interconnection, L.L.C., Notice Extending Comment Date*, Docket No. ER07-1186-000 (July 31, 2007) (same).

V. SERVICE

PJM has served a copy of this filing on all PJM Members and on the affected state utility regulatory commissions in the PJM Region by posting this filing electronically. In accordance with the Commission's regulations,²² PJM will post a copy of this filing to the FERC filings section of its internet site, located at the following link: <http://www.pjm.com/documents/ferc-manuals/ferc-filings.aspx> with a specific link to the newly-filed document, and will send an e-mail on the same date as this filing to all PJM Members and all state utility regulatory commissions in the PJM Region²³ alerting them that this filing has been made by PJM and is available by following such link. If the document is not immediately available by using the referenced link, the document will be available through the referenced link within twenty-four hours of the filing. Also, a copy of this filing will be available on the Commission's eLibrary website located at the following link: <http://www.ferc.gov/docs-filing/elibrary.asp> in accordance with the Commission's regulations and Order No. 714.

Respectfully submitted,

By:  _____

Craig Glazer
Vice President – Federal Government Policy
PJM Interconnection, L.L.C.
1200 G Street, NW, Suite 600
Washington, DC 20005
Ph: (202) 423-4743
Fax: (202) 393-7741
craig.glazer@pjm.com

Pauline Foley
Associate General Counsel
PJM Interconnection, L.L.C.
2750 Monroe Blvd.
Audubon, PA 19403
Ph: (610) 666-8248
Fax: (610) 666-4281
pauline.foley@pjm.com

*Counsel for
PJM Interconnection, L.L.C.*

²² See 18 C.F.R. sections 35.2(e) and 385.201(f)(3) (2018).

²³ PJM already maintains, updates, and regularly uses electronic mailing lists for all PJM Members and affected state commissions.

Attachment A

Cost Responsibility Assignment Summary Sheets

Baseline Upgrade b1570.4

- Overview of Reliability Problem
 - Criteria Violation: Overload of Staunton Tap - Eldean 138 kV line and Quincy - East Sidney - Shelby 138 kV line and low voltage at several buses in North West area of Dayton
 - Contingency: Loss of Shelby - Miami 345 kV line with stuck breaker at Shelby, loss of Darby 138/69 kV transformer and Urbana 138/69 kV transformer and various pairs of contingencies
 - Criteria test: NERC TPL-003 Category C (Thermal)
- Overview of Reliability Solution
 - Description of Upgrade: Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 4.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b2686.4

- Overview of Reliability Problem
 - Criteria Violation: The Remington CT 230kV breaker "2114T2155" is overdutied.
 - Contingency: Fault at Remington CT
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the Remington CT 230 kV breaker "2114T2155" with a 63 kA breaker
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 0.30 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b2970.5

- Overview of Reliability Problem
 - Criteria Violation: Overload of Ringgold 230/138 kV No.3 and No.4 transformers
 - Contingency: multiple contingencies
 - Criteria test: Generator Deliverability, baseline and N-1-1 thermal

- Overview of Reliability Solution
 - Description of Upgrade: Convert Garfield 138/12.5 kV substation to 230/12.5 kV
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 2.20 M
 - Construction Responsibility: APS

- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to APS

Baseline Upgrade b3011.7

- Overview of Reliability Problem
 - Criteria Violation: Overduty of Elwyn Z-70 138 kV line breaker at Dravosburg
 - Contingency:
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the line terminal equipment and line breaker #85 at Dravosburg 138 kV substation in the Elwyn Z-70 line position/bay, with the breaker duty as 63 kA
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 0.90 M
 - Construction Responsibility: DL
- Cost Allocation
 - The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to DL.

Baseline Upgrade b3012.1

- Overview of Reliability Problem
 - Criteria Violation: Overload of multiple 138 kV facilities in AP and DL zones and overload of the Wylie Ridge 500/345 kV transformer
 - Contingency: Various contingencies in AP and DL zones
 - Criteria test: Generator Deliverability
- Overview of Reliability Solution
 - Description of Upgrade: Construct two new 138 kV ties with the single structure from APS's new substation to Duquesne's new substation. The estimated line length is approximately 4.7 miles. The line is planned to use multiple ACSS conductors per phase
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 23.10 M
 - Construction Responsibility: APS
- Cost Allocation
 - Baseline upgrades b3012.1 through b3012.4 constitute a single reliability project. The cost for this baseline upgrade is allocated 38.21% to ATSI and 61.79% to DL.

Transmission Zone	Planned Load (MW)	DFAX	DFAX Allocation
ATSI	12,954	0.0117	38.21%
DL	2,870	0.0856	61.79%

Baseline Upgrade b3012.2

- Overview of Reliability Problem
 - Criteria Violation: Overload of multiple 138 kV facilities in AP and DL zones and overload of the Wylie Ridge 500/345 kV transformer
 - Contingency: Various contingencies in AP and DL zones
 - Criteria test: Generator Deliverability
- Overview of Reliability Solution
 - Description of Upgrade: Construct two new ties from a new FirstEnergy substation to a new Duquesne substation by using two separate structures - Duquesne portion
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 4.60 M
 - Construction Responsibility: DL
- Cost Allocation
 - Baseline upgrades b3012.1 through b3012.4 constitute a single reliability project. The cost for this baseline upgrade is allocated 38.21% to ATSI and 61.79% to DL.

Transmission Zone	Planned Load (MW)	DFAX	DFAX Allocation
ATSI	12,954	0.0117	38.21%
DL	2,870	0.0856	61.79%

Baseline Upgrade b3012.3

- Overview of Reliability Problem
 - Criteria Violation: Overload of multiple 138 kV facilities in AP and DL zones and overload of the Wylie Ridge 500/345 kV transformer
 - Contingency: Various contingencies in APS and DL zones
 - Criteria test: Generator Deliverability
- Overview of Reliability Solution
 - Description of Upgrade: Construct a new Elrama - Route 51 138 kV No.3 line: reconductor 4.7 miles of the existing line, and construct 1.5 miles of a new line to the reconducted portion. Install a new line terminal at APS Route 51 substation
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 18.10 M
 - Construction Responsibility: APS
- Cost Allocation
 - Baseline upgrades b3012.1 through b3012.4 constitute a single reliability project. Only DL zone has greater than 1% distribution factor for this baseline upgrade. The cost for this baseline upgrade is allocated 100% to DL.

Baseline Upgrade b3012.4

- Overview of Reliability Problem
 - Criteria Violation: Overload of multiple 138 kV facilities in AP and DL zones and overload of the Wylie Ridge 500/345 kV transformer
 - Contingency: Various contingencies in APS and DL zones
 - Criteria test: Generator Deliverability
- Overview of Reliability Solution
 - Description of Upgrade: Establish the new tie line in place of the existing Elrama - Mitchell 138 kV line
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 1.00 M
 - Construction Responsibility: DL
- Cost Allocation
 - Baseline upgrades b3012.1 through b3012.4 constitute a single reliability project. Only DL zone has greater than 1% distribution factor for this baseline upgrade. The cost for this baseline upgrade is allocated 100% to DL.

Baseline Upgrade b3064.2

- Overview of Reliability Problem
 - Criteria Violation: The West Mifflin 138kV breakers “Z-94”, “Z-74”, “Z-14”, and “Z-13” are overdutied.
 - Contingency:
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the West Mifflin 138 kV breakers “Z-94”, “Z-74”, “Z-14”, and “Z-13” with 63 kA breakers
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 3.10 M
 - Construction Responsibility: DL
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to DL

Baseline Upgrade b3096

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Loss of 230 kV Line #2164 creates a radial line carrying in excess of 100 MW.
Loss of 230 kV Line #2063 drops load at Moore DP.
 - Contingency: Loss of Line #2164 segment between Clifton and Keene Mill
Loss of Line #2063
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 22.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3097

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Loss of 115kV Line #86 segment between Chesterfield and Centralia creates a radial line that exceeds the 700 MW-Mile planning criteria.
 - Contingency: Loss of Line #86 segment between Chesterfield and Centralia
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 7.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3098

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Loss of 115kV Line #141 creates a radial line that exceeds the 700 MW-Mile planning criteria. Loss of Line #28 strands generation at Cushaw
 - Contingency: Loss of Line #141 and Loss of line #28
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 20.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3099

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Thermal overload of Kingsport 34.5 kV sub-transmission network
 - Contingency: Loss of the 138/34.5 kV Holston transformer No. 5 and loss of the Nagel-Reedy Creek 138 kV line
 - Criteria test: AEP Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.70 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3100

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Thermal overload of the Chemical transformer #2
 - Contingency: under a N-1-1 contingency condition involving the loss of the Chemical transformer #6 (which includes the loss of transformer #4, Chemical – Turner 138 kV line and Chemical – Ortin 138 kV, due to the loss of 138 kV bus #1) paired with the loss of the Capitol Hill – Chemical 138 kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace the 138kV MOAB switcher “YY” with a new 138kV circuit switcher on the high side of Chemical transformer No.6
 - Required Upgrade In-Service Date: December 01, 2022
 - Estimated Upgrade Cost: \$ 0.70 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3101

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Overload of Fort Robinson – Moccasin Gap 69 kV line section
 - Contingency: loss of the Hill – Gate City 69 kV line section, Hill 138/69/34.5 kV transformer or the Clinch River – Nagel 138 kV circuit
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson - Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)
 - Required Upgrade In-Service Date: December 01, 2023
 - Estimated Upgrade Cost: \$ 3.00 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3102

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Overload of Fremont 138/69 kV transformers #1 and #2
 - Contingency: loss of the Garden Creek – Clinch River 138 kV circuit paired with a loss of one of the aforementioned 138/69 kV transformers at Fremont, or loss of the Clinchfield 138/69 kV transformer paired with a loss of one of the aforementioned 138/69 kV transformers at Fremont.
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace existing 50 MVA 138/69 kV transformers #1 and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers
 - Required Upgrade In-Service Date: December 01, 2022
 - Estimated Upgrade Cost: \$ 4.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.1

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation – Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 10.25 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.2

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 4.47 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.3

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.18 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.4

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.88 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.5

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers “A”, “B”, and “G.” Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV breakers. Install a new 138/69 kV transformer
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 18.73 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.6

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 21.12 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.7

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Build a new 69 kV line from Armstrong Cork – Jay station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 2.35 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3103.8

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - - Overload of Delaware – Bosman 34.5kV, Bosman – Hartford 34.5kV, Armstrong Cork – Fulkerson 69kV line, and Fulkerson – 3M
 - Contingency: loss of the Jay and Deer Creek 138/69/34.5kV banks or loss of Deer Creek 138/69/34.5kV transformer and Bosman – Delaware 34.5kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 12.78 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3104

- Overview of Reliability Problem
 - Criteria Violation: Overload of the Polaris - Westerville 138 kV line
 - Contingency: Multiple N-1-1 contingencies
 - Criteria test: N-1-1
- Overview of Reliability Solution
 - Description of Upgrade: Perform a sag study on the Polaris - Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to AEP.

Baseline Upgrade b3105

- Overview of Reliability Problem
 - Criteria Violation: Overload of the Delaware - Hyatt 138 kV line
 - Contingency: Loss of Delaware - Vassel 138 kV (N-1-0) and the loss of Vassel 345/138 kV transformer (N-1-0)
 - Criteria test: N-1-1
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 16.00 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to AEP.

Baseline Upgrade b3106

- Overview of Reliability Problem
 - Criteria Violation: Overload of Hyatt - Maliszewski 138 kV
 - Contingency: Loss of Hyatt 345/138 kV 1A & 1B transformers followed by the loss of Hyatt - Maliszewski #2 138 kV or Loss of Marysville 765/345 kV #2 transformer followed by Hyatt - Maliszewski #2 138 kV.
 - Criteria test: N-1-1 thermal
- Overview of Reliability Solution
 - Description of Upgrade: Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to AEP.

Baseline Upgrade b3108.1

- Overview of Reliability Problem
 - Criteria Violation: High voltage across the Dayton system
 - Contingency:
 - Criteria test: Operational Performance
- Overview of Reliability Solution
 - Description of Upgrade: Install 100 MVAR reactor at Miami 138 kV substation
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 5.00 M
 - Construction Responsibility: Dayton
- Cost Allocation
 - The upgrade benefits load entirely within the zone receiving the allocation. The distribution factor would be based on an interface entirely within the zone receiving the allocation. Therefore no distribution factor table is provided. The cost for this baseline upgrade is allocated 100% to Dayton.

Baseline Upgrade b3108.2

- Overview of Reliability Problem
 - Criteria Violation: High voltage across the Dayton system
 - Contingency:
 - Criteria test: Operational Performance
- Overview of Reliability Solution
 - Description of Upgrade: Install 100 MVAR reactor at Sugarcreek 138 kV substation
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 5.00 M
 - Construction Responsibility: Dayton
- Cost Allocation
 - The upgrade benefits load entirely within the zone receiving the allocation. The distribution factor would be based on an interface entirely within the zone receiving the allocation. Therefore no distribution factor table is provided. The cost for this baseline upgrade is allocated 100% to Dayton.

Baseline Upgrade b3108.3

- Overview of Reliability Problem
 - Criteria Violation: High voltage across the Dayton system
 - Contingency:
 - Criteria test: Operational Performance
- Overview of Reliability Solution
 - Description of Upgrade: Install 100 MVAR reactor at Hutchings 138 kV substation
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 5.00 M
 - Construction Responsibility: Dayton
- Cost Allocation
 - The upgrade benefits load entirely within the zone receiving the allocation. The distribution factor would be based on an interface entirely within the zone receiving the allocation. Therefore no distribution factor table is provided. The cost for this baseline upgrade is allocated 100% to Dayton.

Baseline Upgrade b3109

- Overview of Reliability Problem
 - Criteria Violation: Overload of Bethel – Brookside and Brookside – Sawmill 138 kV line sections
 - Contingency: Multiple contingencies
 - Criteria test: N-1 and N-1-1
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild 5.2 miles Bethel - Sawmill 138 kV line including ADSS
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 34.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - No zone has greater than 1% distribution factor for this baseline upgrade. The cost for this baseline upgrade is allocated 100% to AEP.

Baseline Upgrade b3110.1

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Load drop more than 311 MW
 - Contingency: Loss of the Line #2008 segment between Loudoun and Dulles and a breaker failure at Reston
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 14.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3110.2

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria - Overduty of the Bull Run 230 kV breakers “200T244” and “200T295”
 - Contingency: Fault at Bull Run
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace the Bull Run 230 kV breakers “200T244” and “200T295” with 50 kA breakers
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 0.54 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3111

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Instability at TSS 946 University Park E.C.
 - Contingency: 3-phase-to-ground fault at the 80% of 138 kV line L6603 from E. Frankfort 138kV blue bus w/ delayed clearing at E. Frankfort 138 kV blue bus
 - Criteria test: ComEd Stability
- Overview of Reliability Solution
 - Description of Upgrade: Install high-speed backup clearing scheme on the E. Frankfort – Matteson 138 kV line (L6603)
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: ComEd
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to ComEd

Baseline Upgrade b3112

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Overload of the Dublin-Sawmill 138 kV circuit
 - Contingency: Loss of Bethel-Davidson & Davidson-Roberts 138 kV circuits
 - Criteria test: N-1-1
- Overview of Reliability Solution
 - Description of Upgrade: Construct a single circuit 138 kV line (approx.3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station.
 - Required Upgrade In-Service Date: June 01, 2020
 - Estimated Upgrade Cost: \$ 39.29 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3113

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - End of Life
 - Contingency: Loss of 115kV Line #72 segment between Plaza and Chesterfield and Loss of 115kV Line #53 segment between Kevlar and Chesterfield
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 3.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3114

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - End of Life
 - Contingency: Loss of 115kV Line #81
 - Criteria test: Dominion FERC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change
 - Required Upgrade In-Service Date: June 01, 2019
 - Estimated Upgrade Cost: \$ 25.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3115

- Overview of Reliability Problem
 - Criteria Violation: Three Mile Island 1 deactivation
 - Contingency:
 - Criteria test: necessary substation work associated with deactivating the unit
- Overview of Reliability Solution
 - Description of Upgrade: Provide new station service to control building from 230 kV bus (served from plant facilities presently)
 - Required Upgrade In-Service Date: September 30, 2019
 - Estimated Upgrade Cost: \$ 1.50 M
 - Construction Responsibility: ME
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to ME

Baseline Upgrade b3116

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Thermal overload of Mullens 138/46 kV transformer No.4
 - Contingency: loss of the Bradley – Jehu Branch 138 kV line plus the loss of the Tams Mountain – Mullens 138 kV line
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment
 - Required Upgrade In-Service Date: December 01, 2022
 - Estimated Upgrade Cost: \$ 3.00 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.1

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 9.30 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.2

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Perform 138 kV remote end work at Grangston station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.3

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Perform 138 kV remote end work at Bellefonte station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.4

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Relocate the Chadwick – Leach 69 kV circuit within Chadwick station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.5

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 1.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.6

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to constructability aspects
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.7

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Reconductor Chadwick-Leach and Chadwick-England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconducted circuits would maintain acceptable clearances
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 3.30 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.8

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Replace the 20 kA 69 kV circuit breaker 'F' at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0
 - Construction Responsibility: AEP
- Cost Allocation
 - This is a distribution project and there is no transmission related cost. The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.9

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild 336 ACSR portion of Leach - Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 1.50 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3118.10

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations
 - Contingency: Multiple contingencies
 - Criteria test:
- Overview of Reliability Solution
 - Description of Upgrade: Replace 69 kV line risers (towards Chadwick) at Leach station
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 0.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3208

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Multiple thermal and voltage violations in the Winter peak case
 - Contingency: Multiple contingencies
 - Criteria test: AEP Planning Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Retire approximately 38 miles of the 44 mile Clifford - Scottsville 46 kV circuit. Build new 138 kV "in and out" to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls - Riverville (approx. 10 miles) and Riverville - Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)
 - Required Upgrade In-Service Date: December 01, 2022
 - Estimated Upgrade Cost: \$ 85.00 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Baseline Upgrade b3209

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation - Overloads of the Berne-Monroe and Monroe-South Decatur 69 kV lines
 - Contingency: Loss of the Magley-Decatur 69 kV line and the Lincoln 138/69/34.5 kV transformer
 - Criteria test: N-1-1
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR in order to alleviate the overload and address a deteriorating asset.
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 16.60 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

Attachment B

Schedule 12 – Appendix A of the
PJM Open Access Transmission Tariff

(Marked / Redline Format)

SCHEDULE 12 – APPENDIX A

(5) Mid-Atlantic Interstate Transmission, LLC for the Metropolitan Edison Company Zone

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2006.1.1	Loop the 2026 (TMI – Hosensack 500 kV) line in to the Lauschtown	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: PPL (100%)</p>
b2006.2.1	Upgrade relay at South Reading on the 1072 230 V line	ME (100%)
b2006.4	Replace the South Reading 69 kV '81342' breaker with 40kA breaker	ME (100%)
b2006.5	Replace the South Reading 69 kV '82842' breaker with 40kA breaker	ME (100%)
b2452	Install 2nd Hunterstown 230/115 kV transformer	APS (8.30%) / BGE (14.70%) / DEOK (0.48%) / Dominion (36.92%) / ME (23.85%) / PEPCO (15.75%)

Mid-Atlantic Interstate Transmission, LLC for the Metropolitan Edison Company Zone (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2452.1	Reconductor Hunterstown - Oxford 115 kV line		APS (8.30%) / BGE (14.70%) / DEOK (0.48%) / Dominion (36.92%) / ME (23.85%) / PEPCO (15.75%)
b2452.3	Replace the Hunterstown 115 kV breaker '96192' with 40 kA		ME (100%)
b2588	Install a 36.6 MVAR 115 kV capacitor at North Bangor substation		ME (100%)
b2637	Convert Middletown Junction 230 kV substation to nine bay double breaker configuration.		ME (100%)
b2644	Install a 28.8 MVAR 115 kV capacitor at the Mountain substation		ME (100%)
b2688.1	Lincoln Substation: Upgrade the bus conductor and replace CTs.		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)
b2688.2	Germantown Substation: Replace 138/115 kV transformer with a 135/180/224 MVA bank. Replace Lincoln 115 kV breaker, install new 138 kV breaker, upgrade bus conductor and adjust/replace CTs.		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)

Mid-Atlantic Interstate Transmission, LLC for the Metropolitan Edison Company Zone (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.4	Upgrade terminal equipment at Hunterstown 500 kV on the Conemaugh – Hunterstown 500 kV circuit	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2752.4	Upgrade terminal equipment and required relay communication at TMI 500 kV: on the Beach Bottom – TMI 500 kV circuit	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2749	Replace relay at West Boyertown 69 kV station on the West Boyertown – North Boyertown 69 kV circuit	ME (100%)
b2765	Upgrade bus conductor at Gardners 115 kv substation; Upgrade bus conductor and adjust CT ratios at Carlisle Pike 115 kV	ME (100%)
b2814	Install a 3rd 230/69 kV 224 MVA Transformer at Lyons and install new terminal equipment for existing Lyons - East Penn(865) 69 kV Line	ME (100%)
b2950	Upgrade limiting 115 kV switches on the 115 kV side of the 230/115 kV Northwood substation and adjust setting on limiting ZR relay	ME (100%)
<u>b3115</u>	<u>Provide new station service to control building from 230 kV bus (served from plant facilities presently)</u>	<u>ME (100%)</u>

SCHEDULE 12 – APPENDIX A

(14) Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2117	Reconductor 0.33 miles of the Parkersburg - Belpre line and upgrade Parkersburg terminal equipment	APS (100%)
b2118	Add 44 MVAR Cap at New Martinsville	APS (100%)
b2120	Six-Wire Lake Lynn - Lardin 138 kV circuits	APS (100%)
b2142	Replace Weirton 138 kV breaker “Wylie Ridge 210” with 63 kA breaker	APS (100%)
b2143	Replace Weirton 138 kV breaker “Wylie Ridge 216” with 63 kA breaker	APS (100%)
b2174.8	Replace relays at Mitchell substation	APS (100%)
b2174.9	Replace primary relay at Piney Fork substation	APS (100%)
b2174.10	Perform relay setting changes at Bethel Park substation	APS (100%)
b2213	Armstrong Substation: Relocate 138 kV controls from the generating station building to new control building	APS (100%)
b2214	Albright Substation: Install a new control building in the switchyard and relocate controls and SCADA equipment from the generating station building the new control center	APS (100%)
b2215	Rivesville Switching Station: Relocate controls and SCADA equipment from the generating station building to new control building	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2216	Willow Island: Install a new 138 kV cross bus at Belmont Substation and reconnect and reconfigure the 138 kV lines to facilitate removal of the equipment at Willow Island switching station	APS (100%)
b2235	130 MVAR reactor at Monocacy 230 kV	APS (100%)
b2260	Install a 32.4 MVAR capacitor at Bartonville	APS (100%)
b2261	Install a 33 MVAR capacitor at Damascus	APS (100%)
b2267	Replace 1000 Cu substation conductor and 1200 amp wave trap at Marlowe	APS (100%)
b2268	Reconductor 6.8 miles of 138kV 336 ACSR with 336 ACSS from Double Toll Gate to Riverton	APS (100%)
b2299	Reconductor from Collins Ferry - West Run 138 kV with 556 ACSS	APS (100%)
b2300	Reconductor from Lake Lynn - West Run 138 kV	APS (100%)
b2341	Install 39.6 MVAR Capacitor at Shaffers Corner 138 kV Substation	APS (100%)
b2342	Construct a new 138 kV switching station (Shuman Hill substation), which is next the Mobley 138 kV substation and install a 31.7 MVAR capacitor	APS (100%)
b2343	Install a 31.7 MVAR capacitor at West Union 138 kV substation	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2362	Install a 250 MVAR SVC at Squab Hollow 230 kV	APS (100%)
b2362.1	Install a 230 kV breaker at Squab Hollow 230 kV substation	APS (100%)
b2363	Convert the Shingletown 230 kV bus into a 6 breaker ring bus	APS (100%)
b2364	Install a new 230/138 kV transformer at Squab Hollow 230 kV substation. Loop the Forest - Elko 230 kV line into Squab Hollow. Loop the Brookville - Elko 138 kV line into Squab Hollow	APS (100%)
b2412	Install a 44 MVAR 138 kV capacitor at the Hempfield 138 kV substation	APS (100%)
b2433.1	Install breaker and a half 138 kV substation (Waldo Run) with 4 breakers to accommodate service to MarkWest Sherwood Facility including metering which is cut into Glen Falls Lamberton 138 kV line	APS (100%)
b2433.2	Install a 70 MVAR SVC at the new WaldoRun 138 kV substation	APS (100%)
b2433.3	Install two 31.7 MVAR capacitors at the new WaldoRun 138 kV substation	APS (100%)
b2424	Replace the Weirton 138 kV breaker 'WYLIE RID210' with 63 kA breakers	APS (100%)
b2425	Replace the Weirton 138 kV breaker 'WYLIE RID216' with 63 kA breakers	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2426	Replace the Oak Grove 138 kV breaker 'OG1' with 63 kA breakers	APS (100%)
b2427	Replace the Oak Grove 138 kV breaker 'OG2' with 63 kA breakers	APS (100%)
b2428	Replace the Oak Grove 138 kV breaker 'OG3' with 63 kA breakers	APS (100%)
b2429	Replace the Oak Grove 138 kV breaker 'OG4' with 63 kA breakers	APS (100%)
b2430	Replace the Oak Grove 138 kV breaker 'OG5' with 63 kA breakers	APS (100%)
b2431	Replace the Oak Grove 138 kV breaker 'OG6' with 63 kA breakers	APS (100%)
b2432	Replace the Ridgeley 138 kV breaker 'RC1' with a 40 kA rated breaker	APS (100%)
b2440	Replace the Cabot 138kV breaker 'C9-KISKI VLY' with 63kA	APS (100%)
b2472	Replace the Ringgold 138 kV breaker 'RCM1' with 40kA breakers	APS (100%)
b2473	Replace the Ringgold 138 kV breaker '#4 XMFR' with 40kA breakers	APS (100%)
b2475	Construct a new line between Oak Mound 138 kV substation and Waldo Run 138 kV substation	APS (100%)
b2545.1	Construct a new 138 kV substation (Shuman Hill substation) connected to the Fairview –Willow Island (84) 138 kV line	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2545.2	Install a ring bus station with five active positions and two 52.8 MVAR capacitors with 0.941 mH reactors	APS (100%)
b2545.3	Install a +90/-30 MVAR SVC protected by a 138 kV breaker	APS (100%)
b2545.4	Remove the 31.7 MVAR capacitor bank at Mobley 138 kV	APS (100%)
b2546	Install a 51.8 MVAR (rated) 138 kV capacitor at Nyswaner 138 kV substation	APS (100%)
b2547.1	Construct a new 138 kV six breaker ring bus Hillman substation	APS (100%)
b2547.2	Loop Smith- Imperial 138 kV line into the new Hillman substation	APS (100%)
b2547.3	Install +125/-75 MVAR SVC at Hillman substation	APS (100%)
b2547.4	Install two 31.7 MVAR 138 kV capacitors	APS (100%)
b2548	Eliminate clearance de-rate on Wylie Ridge – Smith 138 kV line and upgrade terminals at Smith 138 kV, new line ratings 294 MVA (Rate A)/350 MVA (Rate B)	APS (100%)
b2612.1	Relocate All Dam 6 138 kV line and the 138 kV line to AE units 1&2	APS (100%)
b2612.2	Install 138 kV, 3000A bus-tie breaker in the open bus-tie position next to the Shaffers corner 138 kV line	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2612.3	Install a 6-pole manual switch, foundation, control cable, and all associated facilities		APS (100%)
b2666	Yukon 138 kV Breaker Replacement		APS (100%)
b2666.1	Replace Yukon 138 kV breaker “Y-11(CHARL1)” with an 80 kA breaker		APS (100%)
b2666.2	Replace Yukon 138 kV breaker “Y-13(BETHEL)” with an 80 kA breaker		APS (100%)
b2666.3	Replace Yukon 138 kV breaker “Y-18(CHARL2)” with an 80 kA breaker		APS (100%)
b2666.4	Replace Yukon 138 kV breaker “Y-19(CHARL2)” with an 80 kA breaker		APS (100%)
b2666.5	Replace Yukon 138 kV breaker “Y-4(4B-2BUS)” with an 80 kA breaker		APS (100%)
b2666.6	Replace Yukon 138 kV breaker “Y-5(LAYTON)” with an 80 kA breaker		APS (100%)
b2666.7	Replace Yukon 138 kV breaker “Y-8(HUNTING)” with an 80 kA breaker		APS (100%)
b2666.8	Replace Yukon 138 kV breaker “Y-9(SPRINGD)” with an 80 kA breaker		APS (100%)
b2666.9	Replace Yukon 138 kV breaker “Y-10(CHRL-SP)” with an 80 kA breaker		APS (100%)
b2666.10	Replace Yukon 138 kV breaker “Y-12(1-1BUS)” with an 80 kA breaker		APS (100%)
b2666.11	Replace Yukon 138 kV breaker “Y-14(4-1BUS)” with an 80 kA breaker		APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2666.12	Replace Yukon 138 kV breaker “Y-2(1B-BETHE)” with an 80 kA breaker		APS (100%)
b2666.13	Replace Yukon 138 kV breaker “Y-21(SHEPJ)” with an 80 kA breaker		APS (100%)
b2666.14	Replace Yukon 138 kV breaker “Y-22(SHEPHJT)” with an 80 kA breaker		APS (100%)
b2672	Change CT Ratio at Seneca Caverns from 120/1 to 160/1 and adjust relay settings accordingly		APS (100%)
b2688.3	Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and adjust CT ratios		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)
b2689.3	Upgrade terminal equipment at structure 27A		APS (100%)
b2696	Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations. New rating of line will be 353 MVA summer normal/422 MVA emergency		APS (100%)
b2700	Remove existing Black Oak SPS		APS (100%)
b2743.6	Reconfigure the Ringgold 230 kV substation to double bus double breaker scheme		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.6.1	Replace the two Ringgold 230/138 kV transformers	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2743.7	Rebuild/Reconductor the Ringgold – Catoctin 138 kV circuit and upgrade terminal equipment on both ends	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2747.1	Relocate the FirstEnergy Pratts 138 kV terminal CVTs at Gordonsville substation to allow for the installation of a new motor operated switch being installed by Dominion	APS (100%)
b2763	Replace the breaker risers and wave trap at Bredinville 138 kV substation on the Cabrey Junction 138 kV terminal	APS (100%)
b2764	Upgrade Fairview 138 kV breaker risers and disconnect leads; Replace 500 CU breaker risers and 556 ACSR disconnect leads with 795 ACSR	APS (100%)
b2964.1	Replace terminal equipment at Pruntytown and Glen Falls 138 kV station	APS (100%)
b2964.2	Reconductor approximately 8.3 miles of the McAlpin - White Hall Junction 138 kV circuit	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2965	Reconductor the Charleroi – Allenport 138 kV line with 954 ACSR conductor. Replace breaker risers at Charleroi and Allenport	DL (100%)
b2966	Reconductor the Yukon – Smithton – Shepler Hill Jct 138 kV line with 795 ACSS conductor. Replace Line Disconnect Switch at Yukon	APS (100%)
b2966.1	Reconductor the Yukon - Smithton - Shepler Hill Jct 138 kV line and replace terminal equipment as necessary to achieve required rating	APS (100%)
b2967	Convert the existing 6 wire Butler - Shanor Manor - Krendale 138 kV line into two separate 138 kV lines. New lines will be Butler - Keisters and Butler - Shanor Manor - Krendale 138 kV	APS (100%)
b2970	Ringgold – Catoclin Solution	APS (100%)
b2970.1	Install two new 230 kV positions at Ringgold for 230/138 kV transformers	APS (100%)
b2970.2	Install new 230 kV position for Ringgold – Catoclin 230 kV line	APS (100%)
b2970.3	Install one new 230 kV breaker at Catoclin substation	APS (100%)
b2970.4	Install new 230/138 kV transformer at Catoclin substation. Convert Ringgold – Catoclin 138 kV line to 230 kV operation	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
<u>b2970.5</u>	<u>Convert Garfield 138/12.5 kV substation to 230/12.5 kV</u>	<u>APS (100%)</u>
b2996	Construct a new 500/138 kV substation as a 4-breaker ring bus with expansion plans for double-breaker-double-bus on the 500 kV bus and breaker-and-a-half on the 138 kV bus to provide EHV source to the Marcellus shale load growth area. Projected load growth of additional 160 MVA to current plan of 280 MVA, for a total load of 440 MVA served from Waldo Run substation. Replace primary relaying and carrier sets on Belmont and Harrison 500 kV Remote End substations. Construct additional 3-breaker string at Waldo Run 138 kV bus. Relocate the Sherwood #2 line terminal to the new string. Construct two single circuit Flint Run - Waldo Run 138 kV lines using 795 ACSR (approximately 3 miles). After terminal relocation on new 3-breaker string at Waldo Run, terminate new Flint Run 138 kV lines onto the two open terminals	APS (100%)
b3005	Reconductor 3.1 mile 556 ACSR portion of Cabot to Butler 138 kV with 556 ACSS and upgrade terminal equipment. 3.1 miles of line will be reconducted for this project. The total length of the line is 7.75 miles	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3006	Replace four Yukon 500/138 kV transformers with three transformers with higher rating and reconfigure 500 kV bus	APS (52.84%) / DL (47.16%)
b3007.1	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - AP portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Social Hall, meters, relays, bus conductor, a wave trap, circuit breaker and disconnects will be replaced	APS (100%)
b3010	Replace terminal equipment at Keystone and Cabot 500 kV buses. At Keystone, bus tubing and conductor, a wave trap, and meter will be replaced. At Cabot, a wave trap and bus conductor will be replaced	APS (100%)
b3011.1	Construct new Route 51 substation and connect 10 138 kV lines to new substation	DL (100%)
b3011.2	Upgrade terminal equipment at Yukon to increase rating on Yukon to Charleroi #2 138 kV line (New Yukon to Route 51 #4 138 kV line)	DL (100%)
b3011.3	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #1 138 kV line	DL (100%)
b3011.4	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #2 138 kV line	DL (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b3011.5	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #3 138 kV line		DL (100%)
b3011.6	Upgrade remote end relays for Yukon – Allenport – Iron Bridge 138 kV line		DL (100%)
b3012.1	Construct new ties from FirstEnergy's new substation to Duquesne's new substation – AP portion. The estimated line length is approximately 4.7 miles, however, this length is subject to change based on the final route of the line. Approximately 1.7 miles could potentially be constructed by using the existing double circuit towers on the Wycoff tap. The line is planned to use 2-954 ACSS conductors per phase <u>two new 138 kV ties with the single structure from APS's new substation to Duquesne's new substation. The estimated line length is approximately 4.7 miles. The line is planned to use multiple ACSS conductors per phase</u>		<u>ATSI (38.21%) / DL (40061.79%)</u>
<u>b3012.3</u>	<u>Construct a new Elrama – Route 51 138 kV No.3 line: reconductor 4.7 miles of the existing line, and construct 1.5 miles of a new line to the reconducted portion. Install a new line terminal at APS Route 51 substation</u>		<u>DL (100%)</u>

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b3013	Reconductor Vasco Tap to Edgewater Tap 138 kV line. 4.4 miles. The new conductor will be 336 ACSS replacing the existing 336 ACSR conductor		APS (100%)
b3015.6	Reconductor Elrama to Mitchell 138 kV line – AP portion. 4.2 miles total. 2x 795 ACSS/TW 20/7		DL (100%)
b3028	Upgrade substation disconnect leads at William 138 kV substation		APS (100%)
b3051.1	Ronceverte cap bank and terminal upgrades		APS (100%)
b3052	Install a 138 kV capacitor (29.7 MVAR effective) at West Winchester 138 kV		APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3068	Reconductor the Yukon – Westraver 138 kV line (2.8 miles), replace the line drops and relays at Yukon 138 kV and replace switches at Westraver 138 kV bus		APS (100%)
b3069	Reconductor the Westraver – Route 51 138 kV line (5.63 miles) and replace line switches at Westraver 138 kV bus		APS (100%)
b3070	Reconductor the Yukon – Route 51 #1 138 kV line (8 miles), replace the line drops, relays and line disconnect switch at Yukon 138 kV bus		APS (100%)
b3071	Reconductor the Yukon – Route 51 #2 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3072	Reconductor the Yukon – Route 51 #3 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3074	Reconductor the 138 kV bus at Armstrong substation		APS (100%)
b3075	Replace the 500/138 kV transformer breaker and reconductor 138 kV bus at Cabot substation		APS (100%)
b3076	Reconductor the Edgewater – Loyalhanna 138 kV line (0.67 mile)		APS (100%)
b3079	Replace the Wylie Ridge 500/345 kV transformer #7		ATSI (72.30%) / DL (27.70%)
b3083	Reconductor the 138 kV bus at Butler and reconductor the 138 kV bus and replace line trap at Karns City		APS (100%)

SCHEDULE 12 – APPENDIX A

(15) Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2141.1	Remove Byron SPS upon completion of Byron - Wayne 345 kV	ComEd (100%)
b2365	Replace 138 kV bus tie 1-2 circuit breaker, station conductor, relays, and a wave trap at TSS 55 Hegewisch substation	ComEd (100%)
b2366	Reconductor 1.4 miles of 138 kV line 0112, Kickapoo Creek - LaSalle County 138kV line	ComEd (100%)
b2415	Install a 138 kV Red Blue bus tie with underground cable and a line 15913 CB at Highland Park	ComEd (100%)
b2416	Reconductor 0.125 miles of the East Frankfort - Mokena 138 kV line L6604	ComEd (100%)
b2417	Replace Ridgeland 138 kV bus tie CB and underground cable at TSS 192 Ridgeland 138 kV substation	ComEd (100%)
b2418	Reconductor 7.5 miles of Waukegan - Gurnee 138 kV line L1607	ComEd (100%)
b2419	Reconductor 0.33 miles of 138 kV underground cable on the Sawyer - Crawford 138 kV Blue line (L1324)	ComEd (100%)
b2465	Replace the Skokie 138 kV breaker '88 L8809' with a 63 kA breaker	ComEd (100%)
b2466	Replace the Skokie 138 kV breaker '88 L8810' with 63kA breaker	ComEd (100%)
b2467	Replace the Skokie 138 kV breaker '88 L11416' with 63 kA breaker	ComEd (100%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2468	Replace the Skokie 138 kV breaker '88 L8803' with 63kA breaker		ComEd (100%)
b2469	Replace the Des Plaines 138 kV breaker '46 11702' with 63 kA breaker		ComEd (100%)
b2561	Install a new 345 kV circuit breaker 5-7 at Elwood substation		ComEd (100%)
b2562	Remove 2.0 miles of wood poles on 138 kV line 17105, erect new steel structures, and install new 1113 kcmil ACSR conductor from Roscoe Bert to Harlem		ComEd (100%)
b2613	Replace relays at Mazon substation		ComEd (100%)
b2692.1	Replace station equipment at Nelson, ESS H-471 and Quad Cities		AEC (0.18%) / AEP (18.69%) / APS (5.87%) / ATSI (7.86%) / BGE (3.32%) / ComEd (38.23%) / Dayton (2.76%) / DEOK (4.13%) / DL (2.23%) / Dominion (5.15%) / DPL (1.97%) / EKPC (1.36%) / JCPL (0.52%) / MetED (0.04%) / Neptune (0.04%) / PECO (1.08%) / PENELEC (1.25%) / PEPCO (3.56%) / PPL (0.45%) / PSEG (1.17%) / RECO (0.14%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2692.2	Upgrade conductor ratings of Cordova – Nelson, Quad Cities – ESS H-471 and ESS H-471 – Nelson 345 kV lines and mitigating sag limitations	AEC (0.18%) / AEP (18.69%) / APS (5.87%) / ATSI (7.86%) / BGE (3.32%) / ComEd (38.23%) / Dayton (2.76%) / DEOK (4.13%) / DL (2.23%) / Dominion (5.15%) / DPL (1.97%) / EKPC (1.36%) / JCPL (0.52%) / MetED (0.04%) / Neptune (0.04%) / PECO (1.08%) / PENELEC (1.25%) / PEPCO (3.56%) / PPL (0.45%) / PSEG (1.17%) / RECO (0.14%)
b2693	Replace L7815 B phase line trap at Wayne substation	ComEd (100%)
b2699.1	Replace 5 Powerton 345 kV CB's with 2 cycle IPO breakers, install one new 345 kV CB; swap line 0302 and line 0303 bus positions; reconfigure Powerton 345 kV bus as single ring configuration	ComEd (100%)
b2699.2	Remove SPS logic at Powerton that trips generators or sectionalizes bus under normal conditions; minimal SPS logic will remain	ComEd (100%)
b2721	Goodings Grove – Balance Station Load (swap bus positions for 345 kV lines 1312 & 11620 and 345 kV lines 11604 & 11622) and replace 138 kV bus tie 2-3	ComEd (100%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2728	Mitigate sag limitations on Loretto – Wilton Center 345 kV Line and replace station conductor at Wilton Center		ATSI (3.43%) / AEP (3.34%) / ComEd (92.02%) / DLCO (1.21%)
b2732.1	Cut-in of line 93505 Tazewell – Kendall 345 kV line into Dresden		ComEd (100%)
b2732.2	Raise towers to remove the sag limitations on Pontiac – Loretto 345 kV line		ComEd (100%)
b2930	Upgrade capacity on E. Frankfort – University Park 345 kV		ComEd (100%)
b2931	Upgrade substation equipment at Pontiac Midpoint station to increase capacity on Pontiac – Brokaw 345 kV line		ComEd (100%)
b2941	Build an indoor new Elk Grove 138 kV GIS substation at the point where Rolling Meadows & Schaumburg tap off from the main lines, between Landmeier and Busse. The four 345 kV circuits in the ROW will be diverted into Gas Insulated Bus (GIB) and go through the basement of the building to provide clearance for the above ground portion of the building		ComEd (100%)
b2959	Install a new 138 kV circuit 18702 from Schauff Road to Rock Falls and install a fourth breaker and a half run at Schauff Road		ComEd (100%)
b2995	Remove Davis Creek RAS		ComEd (100%)
b2997	Remove University Park North RAS		ComEd (100%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2998	Install a 120 MVAR 345 kV shunt inductor at Powerton (the 345 kV yard already contains an empty bus position on the ring we only need a switching breaker for the inductor)		ComEd (100%)
b2999	Rebuild the 12.36 mile Schauff Road to Nelson tap 138 kV line L15508		ComEd (100%)
b3049	Replace 345 kV breaker at Joliet substation		ComEd (100%)
<u>b3111</u>	<u>Install high-speed backup clearing scheme on the E. Frankfort – Matteson 138 kV line (L6603)</u>		<u>ComEd (100%)</u>

SCHEDULE 12 – APPENDIX A

(16) The Dayton Power and Light Company

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2540	Increase rating of Shelby-E. Sidney-Quincy-Logan 138kV line to 224 MVA by replace/raise three pole swing out structure; push/pull/retension conductors on two spans; lower eight spans of single phase		Dayton (100%)
b2541	As needed in PJM Operations connect two 30 MVAR mobile shunts to Eldean and Sidney 69 kV buses; Block LTCs for Eldean 138/69 kV and Sidney 138/69kV transformers after loss of Shelby-Sidney 138kV line		Dayton (100%)
b2879.1	Replace wavetrap at the Stuart 345 kV substation		Dayton (100%)
<u>b3108.1</u>	<u>Install 100 MVAR reactor at Miami 138 kV substation</u>		<u>Dayton (100%)</u>
<u>b3108.2</u>	<u>Install 100 MVAR reactor at Sugarcreek 138 kV substation</u>		<u>Dayton (100%)</u>
<u>b3108.3</u>	<u>Install 100 MVAR reactor at Hutchings 138 kV substation</u>		<u>Dayton (100%)</u>

SCHEDULE 12 – APPENDIX A

- (17) **AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)**

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b1570.4	<u>Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer</u>		<u>AEP (100%)</u>
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station		<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: ATSI (24.65%) / Dayton (8.85%) / DEOK (19.91%) / Dominion (41.38%) / EKPC (5.21%)</p>

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1797.1	Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: ATSI (5.74%) / Dayton (1.97%) / DEOK (4.40%) / Dominion (9.97%) / EKPC (1.12%) / PEPSCO (76.80%)</p>
b2055	Upgrade relay at Brues station	AEP (100%)
b2122.3	Upgrade terminal equipment at Howard on the Howard - Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)	AEP (100%)
b2122.4	Perform a sag study on the Howard - Brookside 138 kV line	AEP (100%)
b2229	Install a 300 MVAR reactor at Dequine 345 kV	AEP (100%)

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2230	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2231	Install 765 kV reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line	AEP (100%)
b2232	Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line	AEP (100%)
b2233	Change transformer tap settings for the Baker 765/345 kV transformer	AEP (100%)
b2252	Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	AEP (100%)

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2253	Install an 86.4 MVAR capacitor bank at Gorsuch 138 kV station in Ohio		AEP (100%)
b2254	Rebuild approximately 4.9 miles of Corner - Degussa 138 kV line in Ohio		AEP (100%)
b2255	Rebuild approximately 2.8 miles of Maliszewski - Polaris 138 kV line in Ohio		AEP (100%)
b2256	Upgrade approximately 36 miles of 138 kV through path facilities between Harrison 138 kV station and Ross 138 kV station in Ohio		AEP (100%)
b2257	Rebuild the Pokagon - Corey 69 kV line as a double circuit 138 kV line with one side at 69 kV and the other side as an express circuit between Pokagon and Corey stations		AEP (100%)
b2258	Rebuild 1.41 miles of #2 CU 46 kV line between Tams Mountain - Slab Fork to 138 kV standards. The line will be strung with 1033 ACSR		AEP (100%)
b2259	Install a new 138/69 kV transformer at George Washington 138/69 kV substation to provide support to the 69 kV system in the area		AEP (100%)
b2286	Rebuild 4.7 miles of Muskingum River - Wolf Creek 138 kV line and remove the 138/138 kV transformer at Wolf Creek Station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2287	Loop in the Meadow Lake - Olive 345 kV circuit into Reynolds 765/345 kV station		AEP (100%)
b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholasville and Marcellus 34.5 kV stations at this new station		AEP (100%)
b2344.2	Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station		AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA’s Marcellus station		AEP (100%)
b2344.4	From REA’s Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)		AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)		AEP (100%)
b2344.6	Retire AEP’s Marcellus 34.5/12 kV and Nicholasville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line		AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)		AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations		AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV		AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades		AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures		AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit		AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit		AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'	AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2394	Replace the Sporn 345 kV breaker 'CC1'		AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio		AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station		AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor		AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station		Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)
			DFAX Allocation: AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408 2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2-138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2502.1	Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway-Brookside, Holloway-Harmon #1 and #2, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station		AEP (100%)
b2502.2	Convert Freebyrd 69 kV to 138 kV		AEP (100%)
b2502.3	Rebuild/convert Freebyrd-South Cadiz 69 kV circuit to 138 kV		AEP (100%)
b2502.4	Upgrade South Cadiz to 138 kV breaker and a half		AEP (100%)
b2530	Replace the Sporn 138 kV breaker 'G1' with 80kA breaker		AEP (100%)
b2531	Replace the Sporn 138 kV breaker 'D' with 80kA breaker		AEP (100%)
b2532	Replace the Sporn 138 kV breaker 'O1' with 80kA breaker		AEP (100%)
b2533	Replace the Sporn 138 kV breaker 'P2' with 80kA breaker		AEP (100%)
b2534	Replace the Sporn 138 kV breaker 'U' with 80kA breaker		AEP (100%)
b2535	Replace the Sporn 138 kV breaker 'O' with 80 kA breaker		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2536	Replace the Sporn 138 kV breaker 'O2' with 80 kA breaker		AEP (100%)
b2537	Replace the Robinson Park 138 kV breakers A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, and F1 with 63 kA breakers		AEP (100%)
b2555	Reconductor 0.5 miles Tiltonsville – Windsor 138 kV and string the vacant side of the 4.5 mile section using 556 ACSR in a six wire configuration		AEP (100%)
b2556	Install two 138 kV prop structures to increase the maximum operating temperature of the Clinch River- Clinch Field 138 kV line		AEP (100%)
b2581	Temporary operating procedure for delay of upgrade b1464. Open the Corner 138 kV circuit breaker 86 for an overload of the Corner – Washington MP 138 kV line. The tower contingency loss of Belmont – Trissler 138 kV and Belmont – Edgelawn 138 kV should be added to Operational contingency		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.		AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit		AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch		AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor		AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2597	Rebuild approximately 1 mi. section of Dragoon-Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon-Dodge Tap branch		AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline-Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.		AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap		AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV		AEP (100%)
b2601	Fremont Station Improvements		AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker		AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker		AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker		AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1		AEP (100%)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at Fremont Station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2602.1	Install 138 kV breaker E2 at North Proctorville	AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations	AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington	AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah	AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville	AEP (100%)
b2603	Boone Area Improvements	AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)	AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit	AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646” OPGW Static wires	AEP (100%)
b2604	Bellefonte Transformer Addition	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap stations		AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation		AEP (100%)
b2607	Pine Gap Relay Limit Increase		AEP (100%)
b2608	Richlands Relay Upgrade		AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build		AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV		AEP (100%)
b2611	Skin Fork Area Improvements		AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components		AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line		AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort-Tanners Creek 345 kV line)		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker		AEP (100%)
b2645	Ohio Central 138 kV Loop		AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2		AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor		AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto		AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)		AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.2	Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford – Jacksons Ferry 765 kV line	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2697.1	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature. 6 potential line crossings to be addressed.	AEP (100%)
b2697.2	Replace terminal equipment at AEP's Danville and East Danville substations to improve thermal capacity of Danville – East Danville 138 kV circuit	AEP (100%)

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line		AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2-28.8 MVAR capacitor banks		AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW		AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit		AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station		AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA breakers		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards		AEP (100%)
b2733	Replace South Canton 138 kV breakers ‘L’ and ‘L2’ with 80 kA rated breakers		AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station		AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR		AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection		AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but initial configuration will constitute a 3 breaker ring bus		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2753.3	Connect two 138 kV 6-wired circuits from “Point A” (currently de-energized and owned by FirstEnergy) in circuit positions previously designated Burger #1 & Burger #2 138 kV. Install interconnection settlement metering on both circuits exiting Holloway		AEP (100%)
b2753.6	Build double circuit 138 kV line from Dilles Bottom to “Point A”. Tie each new AEP circuit in with a 6-wired line at Point A. This will create a Dilles Bottom – Holloway 138 kV circuit and a George Washington – Holloway 138 kV circuit		AEP (100%)
b2753.7	Retire line sections (Dilles Bottom – Bellaire and Moundsville – Dilles Bottom 69 kV lines) south of FirstEnergy 138 kV line corridor, near “Point A”. Tie George Washington – Moundsville 69 kV circuit to George Washington – West Bellaire 69 kV circuit		AEP (100%)
b2753.8	Rebuild existing 69 kV line as double circuit from George Washington – Dilles Bottom 138 kV. One circuit will cut into Dilles Bottom 138 kV initially and the other will go past with future plans to cut in		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooton 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		AEP (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville 138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively		AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington		AEP (100%)
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct. - Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)		AEP (100%)
b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T-Line from the 69 kV through-path		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)		AEP (100%)
b2790	Install a 3 MVAR, 34.5 kV cap bank at Caldwell substation		AEP (100%)
b2791	Rebuild Tiffin – Howard, new transformer at Chatfield		AEP (100%)
b2791.1	Rebuild portions of the East Tiffin - Howard 69 kV line from East Tiffin to West Rockaway Switch (0.8 miles) using 795 ACSR Drake conductor (129 MVA rating, 50% loading)		AEP (100%)
b2791.2	Rebuild Tiffin - Howard 69 kV line from St. Stephen's Switch to Hinesville (14.7 miles) using 795 ACSR Drake conductor (90 MVA rating, non-conductor limited, 38% loading)		AEP (100%)
b2791.3	New 138/69 kV transformer with 138/69 kV protection at Chatfield		AEP (100%)
b2791.4	New 138/69 kV protection at existing Chatfield transformer		AEP (100%)
b2792	Replace the Elliott transformer with a 130 MVA unit, reconductor 0.42 miles of the Elliott – Ohio University 69 kV line with 556 ACSR to match the rest of the line conductor (102 MVA rating, 73% loading) and rebuild 4 miles of the Clark Street – Strouds R		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2793	Energize the spare Fremont Center 138/69 kV 130 MVA transformer #3. Reduces overloaded facilities to 46% loading		AEP (100%)
b2794	Construct new 138/69/34 kV station and 1-34 kV circuit (designed for 69 kV) from new station to Decliff station, approximately 4 miles, with 556 ACSR conductor (51 MVA rating)		AEP (100%)
b2795	Install a 34.5 kV 4.8 MVAR capacitor bank at Killbuck 34.5 kV station		AEP (100%)
b2796	Rebuild the Malvern - Oneida Switch 69 kV line section with 795 ACSR (1.8 miles, 125 MVA rating, 55% loading)		AEP (100%)
b2797	Rebuild the Ohio Central - Conesville 69 kV line section (11.8 miles) with 795 ACSR conductor (128 MVA rating, 57% loading). Replace the 50 MVA Ohio Central 138/69 kV XFMR with a 90 MVA unit		AEP (100%)
b2798	Install a 14.4 MVAR capacitor bank at West Hicksville station. Replace ground switch/MOAB at West Hicksville with a circuit switcher		AEP (100%)
b2799	Rebuild Valley - Almena, Almena - Hartford, Riverside - South Haven 69 kV lines. New line exit at Valley Station. New transformers at Almena and Hartford		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2799.1	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSR conductor (360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station	AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker	AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley	AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA breaker		AEP (100%)
b2818	Replace West Huntington 138 kV breaker 'F' with a 40 kA breaker		AEP (100%)
b2819	Replace Madison 138 kV breaker 'V' with a 63 kA breaker		AEP (100%)
b2820	Replace Sterling 138 kV breaker 'G' with a 40 kA breaker		AEP (100%)
b2821	Replace Morse 138 kV breakers '103', '104', '105', and '106' with 63 kA breakers		AEP (100%)
b2822	Replace Clinton 138 kV breakers '105' and '107' with 63 kA breakers		AEP (100%)
b2826.1	Install 300 MVAR reactor at Ohio Central 345 kV substation		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation	AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)	DFAX Allocation: Dayton (34.34%) / DEOK (56.45%) / EKPC (9.21%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit	AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor	DFAX Allocation: Dayton (100%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit	AEP (100%)
b2872	Replace the South Canton 138 kV breaker ‘K2’ with a 80 kA breaker	AEP (100%)
b2873	Replace the South Canton 138 kV breaker “M” with a 80 kA breaker	AEP (100%)
b2874	Replace the South Canton 138 kV breaker “M2” with a 80 kA breaker	AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers	AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2881	Rebuild ~1.7 miles of the Dunn Hollow – London 46 kV line section utilizing 795 26/7 ACSR conductor (58 MVA rating, non-conductor limited)	AEP (100%)
b2882	Rebuild Reusens - Peakland Switch 69 kV line. Replace Peakland Switch	AEP (100%)
b2882.1	Rebuild the Reusens - Peakland Switch 69 kV line (approximately 0.8 miles) utilizing 795 ACSR conductor (86 MVA rating, non-conductor limited)	AEP (100%)
b2882.2	Replace existing Peakland S.S with new 3 way switch phase over phase structure	AEP (100%)
b2883	Rebuild the Craneco – Pardee – Three Forks – Skin Fork 46 kV line section (approximately 7.2 miles) utilizing 795 26/7 ACSR conductor (108 MVA rating)	AEP (100%)
b2884	Install a second transformer at Nagel station, comprised of 3 single phase 250 MVA 500/138 kV transformers. Presently, TVA operates their end of the Boone Dam – Holston 138 kV interconnection as normally open preemptively for the loss of the existing Nagel	AEP (100%)
b2885	New delivery point for City of Jackson	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2885.1	Install a new Ironman Switch to serve a new delivery point requested by the City of Jackson for a load increase request	AEP (100%)
b2885.2	Install a new 138/69 kV station (Rhodes) to serve as a third source to the area to help relieve overloads caused by the customer load increase	AEP (100%)
b2885.3	Replace Coalton Switch with a new three breaker ring bus (Heppner)	AEP (100%)
b2886	Install 90 MVA 138/69 kV transformer, new transformer high and low side 3000 A 40 kA CBs, and a 138 kV 40 kA bus tie breaker at West End Fostoria	AEP (100%)
b2887	Add 2-138 kV CB's and relocate 2-138 kV circuit exits to different bays at Morse Road. Eliminate 3 terminal line by terminating Genoa - Morse circuit at Morse Road	AEP (100%)
b2888	Retire Poston substation. Install new Lemaster substation	AEP (100%)
b2888.1	Remove and retire the Poston 138 kV station	AEP (100%)
b2888.2	Install a new greenfield station, Lemaster 138 kV Station, in the clear	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston - Trimble 69 kV line		AEP (100%)
b2889	Expand Cliffview station		AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)		AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)		AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby		AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2890.1	Rebuild 23.55 miles of the East Cambridge – Smyrna 34.5 kV circuit with 795 ACSR conductor (128 MVA rating) and convert to 69 kV		AEP (100%)
b2890.2	East Cambridge: Install a 2000 A 69 kV 40 kA circuit breaker for the East Cambridge – Smyrna 69 kV circuit		AEP (100%)
b2890.3	Old Washington: Install 69 kV 2000 A two way phase over phase switch		AEP (100%)
b2890.4	Install 69 kV 2000 A two way phase over phase switch		AEP (100%)
b2891	Rebuild the Midland Switch to East Findlay 34.5 kV line (3.31 miles) with 795 ACSR (63 MVA rating) to match other conductor in the area		AEP (100%)
b2892	Install new 138/12 kV transformer with high side circuit switcher at Leon and a new 138 kV line exit towards Ripley. Establish 138 kV at the Ripley station with a new 138/69 kV 130 MVA transformer and move the distribution load to 138 kV service		AEP (100%)
b2936.1	Rebuild approximately 6.7 miles of 69 kV line between Mottville and Pigeon River using 795 ACSR conductor (129 MVA rating). New construction will be designed to 138 kV standards but operated at 69 kV		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2936.2	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker	AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor	AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature	AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances	AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station	AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station	AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit	AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker “JM” with 63 kA breaker and associated substation works including switches, bus leads, control cable and new DICM	AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR ‘Curlew’ conductor and steel poles	AEP (100%)
b3000	Replace South Canton 138 kV breaker ‘N’ with an 80kA breaker	AEP (100%)
b3001	Replace South Canton 138 kV breaker ‘N1’ with an 80kA breaker	AEP (100%)
b3002	Replace South Canton 138 kV breaker ‘N2’ with an 80kA breaker	AEP (100%)
b3036	Rebuild 15.4 miles of double circuit North Delphos – Rockhill 138 kV line	AEP (100%)
b3037	Upgrades at the Natrium substation	AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section	AEP (100%)
b3039	Line swaps at Muskingum 138 kV station	AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section (~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville	AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network	AEP (100%)
b3040.5	Retire Mill Run station	AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station	AEP (100%)
b3051.2	Adjust CT tap ratio at Roncerverte 138 kV	AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV	AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str's 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str's 1–11 (0.5 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3086.3	Rebuild West Melrose – Whirlpool 34 kV line Str’s 55–80 (1 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.4	North Findlay station: Install a 138 kV 3000A 63kA line breaker and low side 34.5 kV 2000A 40kA breaker, high side 138 kV circuit switcher on T1	AEP (100%)
b3086.5	Ebersole station: Install second 90 MVA 138/69/34 kV transformer. Install two low side (69 kV) 2000A 40kA breakers for T1 and T2	AEP (100%)
b3087.1	Construct a new greenfield station to the west (approx. 1.5 miles) of the existing Fords Branch Station in the new Kentucky Enterprise Industrial Park. This station will consist of six 3000A 40kA 138 kV breakers laid out in a ring arrangement, two 30 MVA 138/34.5 kV transformers, and two 30 MVA 138/12 kV transformers. The existing Fords Branch Station will be retired	AEP (100%)
b3087.2	Construct approximately 5 miles of new double circuit 138 kV line in order to loop the new Kewanee station into the existing Beaver Creek – Cedar Creek 138 kV circuit	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3087.3	Remote end work will be required at Cedar Creek Station	AEP (100%)
b3095	Rebuild Lakin – Racine Tap 69 kV line section (9.2 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
<u>b3099</u>	<u>Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station</u>	<u>AEP (100%)</u>
<u>b3100</u>	<u>Replace the 138 kV MOAB switcher “YY” with a new 138 kV circuit switcher on the high side of Chemical transformer No.6</u>	<u>AEP (100%)</u>
<u>b3101</u>	<u>Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson – Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)</u>	<u>AEP (100%)</u>
<u>b3102</u>	<u>Replace existing 50 MVA 138/69 kV transformers #1 and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers</u>	<u>AEP (100%)</u>

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

<u>b3103.1</u>	<u>Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers</u>		<u>AEP (100%)</u>
<u>b3103.2</u>	<u>Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards</u>		<u>AEP (100%)</u>
<u>b3103.3</u>	<u>Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line</u>		<u>AEP (100%)</u>
<u>b3103.4</u>	<u>Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit</u>		<u>AEP (100%)</u>
<u>b3103.5</u>	<u>Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers “A”, “B”, and “G.” Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV breakers. Install a new 138/69 kV transformer</u>		<u>AEP (100%)</u>

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

<u>b3103.6</u>	<u>Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station</u>		<u>AEP (100%)</u>
<u>b3103.7</u>	<u>Build a new 69 kV line from Armstrong Cork – Jay station</u>		<u>AEP (100%)</u>
<u>b3103.8</u>	<u>Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations</u>		<u>AEP (100%)</u>
<u>b3104</u>	<u>Perform a sag study on the Polaris – Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA</u>		<u>AEP (100%)</u>
<u>b3105</u>	<u>Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations</u>		<u>AEP (100%)</u>
<u>b3106</u>	<u>Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild</u>		<u>AEP (100%)</u>
<u>b3109</u>	<u>Rebuild 5.2 miles Bethel – Sawmill 138 kV line including ADSS</u>		<u>AEP (100%)</u>

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

<u>b3112</u>	<u>Construct a single circuit 138 kV line (approx. 3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station</u>		<u>AEP (100%)</u>
<u>b3116</u>	<u>Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment</u>		<u>AEP (100%)</u>
<u>b3118.1</u>	<u>Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers</u>		<u>AEP (100%)</u>
<u>b3118.2</u>	<u>Perform 138 kV remote end work at Grangston station</u>		<u>AEP (100%)</u>
<u>b3118.3</u>	<u>Perform 138 kV remote end work at Bellefonte station</u>		<u>AEP (100%)</u>
<u>b3118.4</u>	<u>Relocate the Chadwick – Leach 69 kV circuit within Chadwick station</u>		<u>AEP (100%)</u>

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
<u>b3118.5</u>	<u>Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus</u>		<u>AEP (100%)</u>
<u>b3118.6</u>	<u>Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to construability aspects</u>		<u>AEP (100%)</u>
<u>b3118.7</u>	<u>Reconductor Chadwick – Leach and Chadwick – England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconducted circuits would maintain acceptable clearances</u>		<u>AEP (100%)</u>
<u>b3118.8</u>	<u>Replace the 20 kA 69 kV circuit breaker ‘F’ at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station</u>		<u>AEP (100%)</u>
<u>b3118.9</u>	<u>Rebuild 336 ACSR portion of Leach – Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor</u>		<u>AEP (100%)</u>
<u>b3118.10</u>	<u>Replace 69 kV line risers (towards Chadwick) at Leach station</u>		<u>AEP (100%)</u>

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

<u>b3208</u>	<u>Retire approximately 38 miles of the 44 mile Clifford – Scottsville 46 kV circuit. Build new 138 kV “in and out” to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls – Riverville (approx. 10 miles) and Riverville – Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)</u>		<u>AEP (100%)</u>
<u>b3209</u>	<u>Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR</u>		<u>AEP (100%)</u>

SCHEDULE 12 – APPENDIX A

(18) Duquesne Light Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2175.1	200 MVAR shunt reactor at Brunot Island 345 kV	DL (100%)
b2175.2	200 MVAR shunt reactor on future Brunot Island – Carson 345 kV circuit	DL (100%)
b2198	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-40 COLLIER'	DL (100%)
b2199	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-41 COLLIER'	DL (100%)
b2200	Revise the reclosing for the Crescent 138 kV breaker 'Z-29 Beaver'	DL (100%)
b2201	Revise the reclosing for the Crescent 138 kV breaker 'Z-82 VALLEY'	DL (100%)
b2202	Revise the reclosing for the Crescent 138 kV breaker 'Z-21 NORTH'	DL (100%)
b2203	Revise the reclosing for the Elrama 138 kV breaker 'Z18-USX CLAI'	DL (100%)
b2204	Revise the reclosing for the Elrama 138 kV breaker 'Z13-WEST MIF'	DL (100%)
b2205	Revise the reclosing for the Elrama 138 kV breaker 'Z15-DRAVOSBU'	DL (100%)
b2206	Revise the reclosing for the Woodville 138 kV breaker 'Z-106 PINEY'	DL (100%)
b2207	Revise the reclosing for the Woodville 138 kV breaker 'Z-64 COLLIER'	DL (100%)
b2208	Revise the reclosing for the Beaver Valley 138 kV breaker 'Z-28 CRESCEN'	DL (100%)

Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2209	Revise the reclosing for the Cheswick 138 kV breaker 'Z-51 WILMERD'	DL (100%)
b2280	Replace the USAP 138kV breaker 'XFMR'	DL (100%)
b2303	Revise the reclosing to the Dravosburg 138kV breaker 'Z73 West Mifflin' from 5 sec to 15 sec	DL (100%)
b2563	Operate with the Crescent 345/138 kV #3 autotransformer in-service by replacing 8 overdutied 138 kV breakers at Crescent, 3 138 kV breakers at Beaver Valley, install #1 section 345 kV breaker for 331 circuit at Crescent	DL (100%)
b2632	Replace the Oakland 138 kV 'Z-101 Arsenal' breaker	DL (100%)
b2639	Replace the Crescent 138 kV 'NO3 – 4 138' breaker with a 63kA breaker	DL (100%)
b2640	Replace the Crescent 138 kV 'Z-143 SWCKLY' breaker with a 63kA breaker	DL (100%)
b2641	Replace the Crescent 138 kV 'Z-24 MONTOUR' breaker with a 63kA breaker	DL (100%)
b2642	Replace the Crescent 138 kV 'Z-28 BEAVER' breaker with a 63kA breaker	DL (100%)
b2689.1	Reconductor approximately 7 miles of the Woodville – Peters (Z-117) 138 kV circuit	AEC (1.00%) / APS (66.39%) / BGE (4.62%) / DOM (8.84%) / DPL (5.85%) / Neptune (0.12%) / PECO (3.40%) / PEPCO (6.32%) / PSEG (3.46%)

Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2689.2	Reconfigure West Mifflin-USS Clairton (Z-15) 138 kV circuit to establish Dravosburg-USS Clairton (Z-14) 138 kV circuit and West Mifflin-Wilson (Z-15) 138 kV circuit	AEC (1.00%) / APS (66.39%) / BGE (4.62%) / DOM (8.84%) / DPL (5.85%) / Neptune (0.12%) / PECO (3.40%) / PEPCO (6.32%) / PSEG (3.46%)
<u>b3011.7</u>	<u>Replace the line terminal equipment and line breaker #85 at Dravosburg 138 kV substation in the Elwyn Z-70 line position/bay, with the breaker duty as 63kA</u>	<u>DL (100%)</u>
b3012.2	Construct <u>two</u> new ties from <u>a new</u> FirstEnergy's <u>new</u> substation to <u>a new</u> Duquesne's <u>new</u> substation <u>by using two separate structures</u> – DL Duquesne portion	<u>ATSI (38.21%) / DL (40061.79%)</u>
<u>b3012.4</u>	<u>Establish the new tie line in place of the existing Elrama – Mitchell 138 kV line</u>	<u>DL (100%)</u>
b3015.1	Construct new Elrama 138 kV substation and connect 7 138 kV lines to new substation	DL (100%)
b3015.2	Reconductor Elrama to Wilson 138 kV line. 4.8 miles	DL (100%)
b3015.3	Reconductor Dravosburg to West Mifflin 138 kV line. 3 miles	DL (100%)
b3015.4	Run new conductor on existing tower to establish the new Dravosburg – Elrama (Z-75) circuit. 10 miles	DL (100%)

Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3015.5	Reconductor Elrama to Mitchell 138 kV line – DL portion. 4.2 miles total. 2x795 ACSS/TW 20/7	DL (100%)
b3015.7	Reconductor Wilson to West Mifflin 138 kV line. 2 miles. 795 ACSS/TW 20/7	DL (100%)
b3061	Reconductor the West Mifflin – Dravosburg (Z-73) and Dravosburg – Elrama (Z-75) 138 kV lines	DL (100%)
b3062	Install 138 kV tie breaker at West Mifflin	DL (100%)
b3063	Reconductor the Wilson – Dravosburg (Z-72) 138 kV line (approx. 5 miles)	DL (100%)
b3064	Expand Elrama 138 kV substation to loop in existing US Steel Clariton – Piney Fork 138 kV line	DL (100%)
<u>b3064.2</u>	<u>Replace the West Mifflin 138 kV breakers “Z-94”, “Z-74”, “Z-14”, and “Z-13” with 63 kA breakers</u>	<u>DL (100%)</u>
b3065	Install 138 kV tie breaker at Wilson	DL (100%)
b3084	Reconductor the Oakland – Panther Hollow 138 kV line (approx. 1 mile)	DL (100%)

SCHEDULE 12 – APPENDIX A

(20) Virginia Electric and Power Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1698.7	Replace Loudoun 230 kV breaker '203052' with 63kA rating	Dominion (100%)
b1696.1	Replace the Idylwood 230 kV '25112' breaker with 50kA breaker	Dominion (100%)
b1696.2	Replace the Idylwood 230 kV '209712' breaker with 50kA breaker	Dominion (100%)
b1793.1	Remove the Carolina 22 SPS to include relay logic changes, minor control wiring, relay resets and SCADA programming upon completion of project	Dominion (100%)
b2281	Additional Temporary SPS at Bath County	Dominion (100%)
b2350	Reconductor 211 feet of 545.5 ACAR conductor on 59 Line Elmont - Greenwood DP 115 kV to achieve a summer emergency rating of 906 amps or greater	Dominion (100%)
b2358	Install a 230 kV 54 MVAR capacitor bank on the 2016 line at Harmony Village Substation	Dominion (100%)
b2359	Wreck and rebuild approximately 1.3 miles of existing 230 kV line between Cochran Mill - X4-039 Switching Station	Dominion (100%)
b2360	Build a new 39 mile 230 kV transmission line from Dooms - Lexington on existing right-of-way	Dominion (100%)
b2361	Construct 230 kV OH line along existing Line #2035 corridor, approx. 2.4 miles from Idylwood - Dulles Toll Road (DTR) and 2.1 miles on new right-of-way along DTR to new Scott's Run Substation	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2368	Replace the Brambleton 230 kV breaker '209502' with 63kA breaker	Dominion (100%)
b2369	Replace the Brambleton 230 kV breaker '213702' with 63kA breaker	Dominion (100%)
b2370	Replace the Brambleton 230 kV breaker 'H302' with 63kA breaker	Dominion (100%)
b2373	Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line	Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)
		DFAX Allocation: Dominion (100%)
b2397	Replace the Beaumeade 230 kV breaker '2079T2116' with 63kA	Dominion (100%)
b2398	Replace the Beaumeade 230 kV breaker '2079T2130' with 63kA	Dominion (100%)
b2399	Replace the Beaumeade 230 kV breaker '208192' with 63kA	Dominion (100%)
b2400	Replace the Beaumeade 230 kV breaker '209592' with 63kA	Dominion (100%)
b2401	Replace the Beaumeade 230 kV breaker '211692' with 63kA	Dominion (100%)
b2402	Replace the Beaumeade 230 kV breaker '227T2130' with 63kA	Dominion (100%)
b2403	Replace the Beaumeade 230 kV breaker '274T2130' with 63kA	Dominion (100%)

The Annual Revenue Requirement for all Virginia Electric and Power Company projects in this Section 20 shall be as specified in Attachment 7 to Appendix A of Attachment H-16A and under the procedures detailed in Attachment H-16B.

*Neptune Regional Transmission System, LLC

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2404	Replace the Beaumeade 230 kV breaker '227T2095' with 63kA	Dominion (100%)
b2405	Replace the Pleasant view 230 kV breaker '203T274' with 63kA	Dominion (100%)
b2443	Construct new underground 230 kV line from Glebe to Station C, rebuild Glebe Substation, construct 230 kV high side bus at Station C with option to install 800 MVA PAR	Dominion (97.11%) / ME (0.18%) / PEPCO (2.71%)
b2443.1	Replace the Idylwood 230 kV breaker '203512' with 50kA	Dominion (100%)
b2443.2	Replace the Ox 230 kV breaker '206342' with 63kA breaker	Dominion (100%)
b2443.3	Glebe – Station C PAR	DFAX Allocation: Dominion (22.57%) / PEPCO (77.43%)
b2443.6	Install a second 500/230 kV transformer at Possum Point substation and replace bus work and associated equipment as needed	Dominion (100%)
b2443.7	Replace 19 63kA 230 kV breakers with 19 80kA 230 kV breakers	Dominion (100%)
b2457	Replace 24 115 kV wood h-frames with 230 kV Dominion pole H-frame structures on the Clubhouse – Purdy 115 kV line	Dominion (100%)
b2458.1	Replace 12 wood H-frame structures with steel H-frame structures and install shunts on all conductor splices on Carolina – Woodland 115 kV	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2458.2	Upgrade all line switches and substation components at Carolina 115 kV to meet or exceed new conductor rating of 174 MVA	Dominion (100%)
b2458.3	Replace 14 wood H-frame structures on Carolina – Woodland 115 kV	Dominion (100%)
b2458.4	Replace 2.5 miles of static wire on Carolina – Woodland 115 kV	Dominion (100%)
b2458.5	Replace 4.5 miles of conductor between Carolina 115 kV and Jackson DP 115 kV with min. 300 MVA summer STE rating; Replace 8 wood H-frame structures located between Carolina and Jackson DP with steel H-frames	Dominion (100%)
b2460.1	Replace Hanover 230 kV substation line switches with 3000A switches	Dominion (100%)
b2460.2	Replace wave traps at Four River 230 kV and Elmont 230 kV substations with 3000A wave traps	Dominion (100%)
b2461	Wreck and rebuild existing Remington CT – Warrenton 230 kV (approx. 12 miles) as a double-circuit 230 kV line	Dominion (100%)
b2461.1	Construct a new 230 kV line approximately 6 miles from NOVEC's Wheeler Substation a new 230 kV switching station in Vint Hill area	Dominion (100%)
b2461.2	Convert NOVEC's Gainesville – Wheeler line (approximately 6 miles) to 230 kV	Dominion (100%)
b2461.3	Complete a Vint Hill – Wheeler – Loudoun 230 kV networked line	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2471	Replace Midlothian 500 kV breaker 563T576 and motor operated switches with 3 breaker 500 kV ring bus. Terminate Lines # 563 Carson – Midlothian, #576 Midlothian –North Anna, Transformer #2 in new ring	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: Dominion (100%)</p>
b2504	Rebuild 115 kV Line #32 from Halifax-South Boston (6 miles) for min. of 240 MVA and transfer Welco tap to Line #32. Moving Welco to Line #32 requires disabling auto-sectionalizing scheme	Dominion (100%)
b2505	Install structures in river to remove the 115 kV #65 line (Whitestone-Harmony Village 115 kV) from bridge and improve reliability of the line	Dominion (100%)
b2542	Replace the Loudoun 500 kV ‘H2T502’ breaker with a 50kA breaker	Dominion (100%)
b2543	Replace the Loudoun 500 kV ‘H2T584’ breaker with a 50kA breaker	Dominion (100%)
b2565	Reconductor wave trap at Carver Substation with a 2000A wave trap	Dominion (100%)
b2566	Reconductor 1.14 miles of existing line between ACCA and Hermitage and upgrade associated terminal equipment	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2582	Rebuild the Elmont – Cunningham 500 kV line	Dominion (100%)
b2583	Install 500 kV breaker at Ox Substation to remove Ox Tx#1 from H1T561 breaker failure outage.	Dominion (100%)
b2584	Relocate the Bremo load (transformer #5) to #2028 (Bremo-Charlottesville 230 kV) line and Cartersville distribution station to #2027 (Bremo-Midlothian 230 kV) line	Dominion (100%)
b2585	Reconductor 7.63 miles of existing line between Cranes and Stafford, upgrade associated line switches at Stafford	DFAX Allocation: PEPCO (100%)
b2620	Wreck and rebuild the Chesapeake – Deep Creek – Bowers Hill – Hodges Ferry 115 kV line; minimum rating 239 MVA normal/emergency, 275 MVA load dump rating	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2622	Rebuild Line #47 between Kings Dominion 115 kV and Fredericksburg 115 kV to current standards with summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2623	Rebuild Line #4 between Bremo and Structure 8474 (4.5 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2624	Rebuild 115 kV Lines #18 and #145 between Possum Point Generating Station and NOVEC’s Smoketown DP (approx. 8.35 miles) to current 230 kV standards with a normal continuous summer rating of 524 MVA at 115 kV	Dominion (100%)
b2625	Rebuild 115 kV Line #48 between Thole Street and Structure 48/71 to current standard. The remaining line to Sewells Point is 2007 vintage. Rebuild 115 kV Line #107 line, Sewells Point to Oakwood, between structure 107/17 and 107/56 to current standard.	Dominion (100%)
b2626	Rebuild 115 kV Line #34 between Skiffes Creek and Yorktown and the double circuit portion of 115 kV Line #61 to current standards with a summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2627	Rebuild 115 kV Line #1 between Crewe 115 kV and Fort Pickett DP 115 kV (12.2 miles) to current standards with summer emergency rating of 261 MVA at 115 kV	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2628	Rebuild 115 kV Line #82 Everetts – Voice of America (20.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2629	Rebuild the 115 kV Lines #27 and #67 lines from Greenwich 115 kV to Burton 115 kV Structure 27/280 to current standard with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2630	Install circuit switchers on Gravel Neck Power Station GSU units #4 and #5. Install two 230 kV CCVT's on Lines #2407 and #2408 for loss of source sensing	Dominion (100%)
b2636	Install three 230 kV bus breakers and 230 kV, 100 MVAR Variable Shunt Reactor at Dahlgren to provide line protection during maintenance, remove the operational hazard and provide voltage reduction during light load conditions	Dominion (100%)
b2647	Rebuild Boydton Plank Rd – Kerr Dam 115 kV Line #38 (8.3 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2648	Rebuild Carolina – Kerr Dam 115 kV Line #90 (38.7 miles) to current standards with summer emergency rating of 353 MVA 115 kV.	Dominion (100%)
b2649	Rebuild Clubhouse – Carolina 115 kV Line #130 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2649.1	Rebuild of 1.7 mile tap to Metcalf and Belfield DP (MEC) due to poor condition. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2649.2	Rebuild of 4.1 mile tap to Brinks DP (MEC) due to wood poles built in 1962. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR and 393.6 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2650	Rebuild Twittys Creek – Pamplin 115 kV Line #154 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2651	Rebuild Buggs Island – Plywood 115 kV Line #127 (25.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV. The line should be rebuilt for 230 kV and operated at 115 kV.	Dominion (100%)
b2652	Rebuild Greatbridge – Hickory 115 kV Line #16 and Greatbridge – Chesapeake E.C. to current standard with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2653.1	Build 20 mile 115 kV line from Pantego to Trowbridge with summer emergency rating of 353 MVA.	Dominion (100%)
b2653.2	Install 115 kV four-breaker ring bus at Pantego	Dominion (100%)
b2653.3	Install 115 kV breaker at Trowbridge	Dominion (100%)
b2654.1	Build 15 mile 115 kV line from Scotland Neck to S Justice Branch with summer emergency rating of 353 MVA. New line will be routed to allow HEMC to convert Dawson's Crossroads RP from 34.5 kV to 115 kV.	Dominion (100%)
b2654.2	Install 115 kV three-breaker ring bus at S Justice Branch	Dominion (100%)
b2654.3	Install 115 kV breaker at Scotland Neck	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2665	Rebuild the Cunningham – Dooks 500 kV line	Dominion (100%)
b2686	Pratts Area Improvement	Dominion (100%)
b2686.1	Build a 230 kV line from Remington Substation to Gordonsville Substation utilizing existing ROW	Dominion (100%)
b2686.2	Install a 3rd 230/115 kV transformer at Gordonsville Substation	Dominion (100%)
b2686.3	Upgrade Line 2088 between Gordonsville Substation and Louisa CT Station	Dominion (100%)
<u>b2686.4</u>	<u>Replace the Remington CT 230 kV breaker “2114T2155” with a 63 kA breaker</u>	<u>Dominion (100%)</u>
b2686.11	Upgrading sections of the Gordonsville – Somerset 115 kV circuit	Dominion (100%)
b2686.12	Upgrading sections of the Somerset – Doubleday 115 kV circuit	Dominion (100%)
b2686.13	Upgrading sections of the Orange – Somerset 115 kV circuit	Dominion (100%)
b2686.14	Upgrading sections of the Mitchell – Mt. Run 115 kV circuit	Dominion (100%)

*Neptune Regional Transmission System, LLC

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
b2717.1	De-energize Davis – Rosslyn #179 and #180 69 kV lines		Dominion (100%)
b2717.2	Remove splicing and stop joints in manholes		Dominion (100%)
b2717.3	Evacuate and dispose of insulating fluid from various reservoirs and cables		Dominion (100%)
b2717.4	Remove all cable along the approx. 2.5 mile route, swab and cap-off conduits for future use, leave existing communication fiber in place		Dominion (100%)
b2719.1	Expand Perth substation and add a 115 kV four breaker ring		Dominion (100%)
b2719.2	Extend the Hickory Grove DP tap 0.28 miles to Perth and terminate it at Perth		Dominion (100%)
b2719.3	Split Line #31 at Perth and terminate it into the new ring bus with 2 breakers separating each of the line terminals to prevent a breaker failure from taking out both 115 kV lines		Dominion (100%)
b2720	Replace the Loudoun 500 kV 'H1T569' breakers with 50kA breaker		Dominion (100%)
b2729	Optimal Capacitors Configuration: New 175 MVAR capacitor at Brambleton, new 175 MVAR capacitor at Ashburn, new 300 MVAR capacitor at Shelhorn, new 150 MVAR capacitor at Liberty		AEC (1.97%) / BGE (14.46%) / Dominion (35.33%) / DPL (3.78%) / JCPL (3.33%) / ME (2.53%) / Neptune (0.63%) / PECO (6.30%) / PEPCO (20.36%) / PPL (3.97%) / PSEG (7.34%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2744	Rebuild the Carson – Rogers Rd 500 kV circuit	Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%) DFAX Allocation: Dominion (100%)
b2745	Rebuild 21.32 miles of existing line between Chesterfield – Lakeside 230 kV	Dominion (100%)
b2746.1	Rebuild Line #137 Ridge Rd – Kerr Dam 115 kV, 8.0 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.2	Rebuild Line #1009 Ridge Rd – Chase City 115 kV, 9.5 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.3	Install a second 4.8 MVAR capacitor bank on the 13.8 kV bus of each transformer at Ridge Rd	Dominion (100%)
b2747	Install a Motor Operated Switch and SCADA control between Dominion's Gordonsville 115 kV bus and FirstEnergy's 115 kV line	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2757	Install a +/-125 MVAR Statcom at Colington 230 kV	Dominion (100%)
b2758	Rebuild Line #549 Doods – Valley 500kV	Dominion (100%)
b2759	Rebuild Line #550 Mt. Storm – Valley 500kV	Dominion (100%)
b2800	The 7 mile section from Dozier to Thompsons Corner of line #120 will be rebuilt to current standards using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Line is proposed to be rebuilt on single circuit steel monopole structure	Dominion (100%)
b2801	Lines #76 and #79 will be rebuilt to current standard using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Proposed structure for rebuild is double circuit steel monopole structure	Dominion (100%)
b2802	Rebuild Line #171 from Chase City – Boynton Plank Road tap by removing end-of-life facilities and installing 9.4 miles of new conductor. The conductor used will be at current standards with a summer emergency rating of 393 MVA at 115kV	Dominion (100%)
b2815	Build a new Pinewood 115kV switching station at the tap serving North Doswell DP with a 115kV four breaker ring bus	Dominion (100%)
b2842	Update the nameplate for Mount Storm 500 kV "57272" to be 50kA breaker	Dominion (100%)
b2843	Replace the Mount Storm 500 kV "G2TY" with 50kA breaker	Dominion (100%)
b2844	Replace the Mount Storm 500 kV "G2TZ" with 50kA breaker	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2845	Update the nameplate for Mount Storm 500 kV "G3TSX1" to be 50kA breaker	Dominion (100%)
b2846	Update the nameplate for Mount Storm 500 kV "SX172" to be 50kA breaker	Dominion (100%)
b2847	Update the nameplate for Mount Storm 500 kV "Y72" to be 50kA breaker	Dominion (100%)
b2848	Replace the Mount Storm 500 kV "Z72" with 50kA breaker	Dominion (100%)
b2871	Rebuild 230 kV line #247 from Swamp to Suffolk (31 miles) to current standards with a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2876	Rebuild line #101 from Mackeys – Creswell 115 kV, 14 miles, with double circuit structures. Install one circuit with provisions for a second circuit. The conductor used will be at current standards with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2877	Rebuild line #112 from Fudge Hollow – Lowmoor 138 kV (5.16 miles) to current standards with a summer emergency rating of 314 MVA at 138 kV	Dominion (100%)
b2899	Rebuild 230 kV line #231 to current standard with a summer emergency rating of 1046 MVA. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2900	Build a new 230/115 kV switching station connecting to 230 kV network line #2014 (Earleys – Everetts). Provide a 115 kV source from the new station to serve Windsor DP	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2922	Rebuild 8 of 11 miles of 230 kV lines #211 and #228 to current standard with a summer emergency rating of 1046 MVA for rebuilt section. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2928	Rebuild four structures of 500 kV line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the line #567 line rating from 1954 MVA to 2600 MVA	Dominion (100%)
b2929	Rebuild 230 kV line #2144 from Winfall to Swamp (4.3 miles) to current standards with a standard conductor (bundled 636 ACSR) having a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2960	Replace fixed series capacitors on 500 kV Line #547 at Lexington and on 500 kV Line #548 at Valley	Dominion (100%)
b2961	Rebuild approximately 3 miles of Line #205 & Line #2003 from Chesterfield to Locks & Poe respectively	Dominion (100%)
b2962	Split Line #227 (Brambleton – Beaumeade 230 kV) and terminate into existing Belmont substation	Dominion (100%)
b2962.1	Replace the Beaumeade 230 kV breaker “274T2081” with 63kA breaker	Dominion (100%)
b2962.2	Replace the NIVO 230 kV breaker “2116T2130” with 63kA breaker	Dominion (100%)
b2963	Reconductor the Woodbridge to Occoquan 230 kV line segment of Line #2001 with 1047 MVA conductor and replace line terminal equipment at Possum Point, Woodbridge, and Occoquan	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2978	Install 2-125 MVAR STATCOMs at Rawlings and 1-125 MVAR STATCOM at Clover 500 kV substations	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: Dominion (100%)</p>
b2980	Rebuild 115 kV Line #43 between Staunton and Harrisonburg (22.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2981	Rebuild 115 kV Line #29 segment between Fredericksburg and Aquia Harbor to current 230 kV standards (operating at 115 kV) utilizing steel H-frame structures with 2-636 ACSR to provide a normal continuous summer rating of 524 MVA at 115 kV (1047 MVA at 230 kV)	Dominion (100%)

*Neptune Regional Transmission System, LLC

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2989	Install a second 230/115 kV Transformer (224 MVA) approximately 1 mile north of Bremo and tie 230 kV Line #2028 (Bremo – Charlottesville) and 115 kV Line #91 (Bremo - Sherwood) together. A three breaker 230 kV ring bus will split Line #2028 into two lines and Line #91 will also be split into two lines with a new three breaker 115 kV ring bus. Install a temporary 230/115 kV transformer at Bremo substation for the interim until the new substation is complete	Dominion (100%)
b2990	Chesterfield to Basin 230 kV line – Replace 0.14 miles of 1109 ACAR with a conductor which will increase the line rating to approximately 706 MVA	Dominion (100%)
b2991	Chaparral to Locks 230 kV line – Replace breaker lead	Dominion (100%)
b2994	Acquire land and build a new switching station (Skippers) at the tap serving Brink DP with a 115 kV four breaker ring to split Line #130 and terminate the end points	Dominion (100%)
b3018	Rebuild Line #49 between New Road and Middleburg substations with single circuit steel structures to current 115 kV standards with a minimum summer emergency rating of 261 MVA	Dominion (100%)
b3019	Rebuild 500 kV Line #552 Bristers to Chancellor – 21.6 miles long	Dominion (100%)
b3019.1	Update the nameplate for Morrisville 500 kV breaker “H1T594” to be 50kA	Dominion (100%)
b3019.2	Update the nameplate for Morrisville 500 kV breaker “H1T545” to be 50kA	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3020	Rebuild 500 kV Line #574 Ladysmith to Elmont – 26.2 miles long	Dominion (100%)
b3021	Rebuild 500 kV Line #581 Ladysmith to Chancellor – 15.2 miles long	Dominion (100%)
b3026	Reconductor Line #274 (Pleasant View – Ashburn – Beaumeade 230 kV) with a minimum rating of 1200 MVA. Also upgrade terminal equipment	Dominion (100%)
b3027.1	Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith substation	Dominion (100%)
b3027.2	Reconductor 230 kV Line #2089 between Ladysmith and Ladysmith CT substations to increase the line rating from 1047 MVA to 1225 MVA	Dominion (100%)
b3027.3	Replace the Ladysmith 500 kV breaker "H1T581" with 50kA breaker	Dominion (100%)
b3027.4	Update the nameplate for Ladysmith 500 kV breaker "H1T575" to be 50kA breaker	Dominion (100%)
b3027.5	Update the nameplate for Ladysmith 500 kV breaker "568T574" (will be renumbered as "H2T568") to be 50kA breaker	Dominion (100%)
b3055	Install spare 230/69 kV transformer at Davis substation	Dominion (100%)
b3056	Partial rebuild 230 kV Line #2113 Waller to Lightfoot	Dominion (100%)
b3057	Rebuild 230 kV Lines #2154 and #19 Waller to Skiffes Creek	Dominion (100%)
b3058	Partial rebuild of 230 kV Lines #265, #200 and #2051	Dominion (100%)
b3059	Rebuild 230 kV Line #2173 Loudoun to Ellick	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b3060	Rebuild 4.6 mile Elklick – Bull Run 230 kV Line #295 and the portion (3.85 miles) of the Clifton – Walney 230 kV Line #265 which shares structures with Line #295		Dominion (100%)
b3088	Rebuild 4.75 mile section of Line #26 between Lexington and Rockbridge with a minimum summer emergency rating of 261 MVA		Dominion (100%)
b3089	Rebuild 230 kV Line #224 between Lanexa and Northern Neck utilizing double circuit structures to current 230 kV standards. Only one circuit is to be installed on the structures with this project with a minimum summer emergency rating of 1047 MVA		Dominion (100%)
b3090	Convert the overhead portion (approx. 1500 feet) of 230 kV Lines #248 & #2023 to underground and convert Glebe substation to gas insulated substation		Dominion (100%)
<u>b3096</u>	<u>Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA</u>		<u>Dominion (100%)</u>
<u>b3097</u>	<u>Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA</u>		<u>Dominion (100%)</u>
<u>b3098</u>	<u>Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115 kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA</u>		<u>Dominion (100%)</u>

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

<u>b3110.1</u>	<u>Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation</u>		<u>Dominion (100%)</u>
<u>b3110.2</u>	<u>Replace the Bull Run 230 kV breakers “200T244” and “200T295” with 50 kA breakers</u>		<u>Dominion (100%)</u>
<u>b3113</u>	<u>Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings</u>		<u>Dominion (100%)</u>
<u>b3114</u>	<u>Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change</u>		<u>Dominion (100%)</u>

Attachment C

Schedule 12 – Appendix A of the
PJM Open Access Transmission Tariff

(Clean Format)

SCHEDULE 12 – APPENDIX A

(5) Mid-Atlantic Interstate Transmission, LLC for the Metropolitan Edison Company Zone

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2006.1.1	Loop the 2026 (TMI – Hosensack 500 kV) line in to the Lauschtown	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: PPL (100%)</p>
b2006.2.1	Upgrade relay at South Reading on the 1072 230 V line	ME (100%)
b2006.4	Replace the South Reading 69 kV '81342' breaker with 40kA breaker	ME (100%)
b2006.5	Replace the South Reading 69 kV '82842' breaker with 40kA breaker	ME (100%)
b2452	Install 2nd Hunterstown 230/115 kV transformer	APS (8.30%) / BGE (14.70%) / DEOK (0.48%) / Dominion (36.92%) / ME (23.85%) / PEPCO (15.75%)

**Mid-Atlantic Interstate Transmission, LLC for the Metropolitan Edison Company Zone
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2452.1	Reconductor Hunterstown - Oxford 115 kV line		APS (8.30%) / BGE (14.70%) / DEOK (0.48%) / Dominion (36.92%) / ME (23.85%) / PEPCO (15.75%)
b2452.3	Replace the Hunterstown 115 kV breaker '96192' with 40 kA		ME (100%)
b2588	Install a 36.6 MVAR 115 kV capacitor at North Bangor substation		ME (100%)
b2637	Convert Middletown Junction 230 kV substation to nine bay double breaker configuration.		ME (100%)
b2644	Install a 28.8 MVAR 115 kV capacitor at the Mountain substation		ME (100%)
b2688.1	Lincoln Substation: Upgrade the bus conductor and replace CTs.		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)
b2688.2	Germantown Substation: Replace 138/115 kV transformer with a 135/180/224 MVA bank. Replace Lincoln 115 kV breaker, install new 138 kV breaker, upgrade bus conductor and adjust/replace CTs.		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)

Mid-Atlantic Interstate Transmission, LLC for the Metropolitan Edison Company Zone (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.4	Upgrade terminal equipment at Hunterstown 500 kV on the Conemaugh – Hunterstown 500 kV circuit	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2752.4	Upgrade terminal equipment and required relay communication at TMI 500 kV: on the Beach Bottom – TMI 500 kV circuit	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2749	Replace relay at West Boyertown 69 kV station on the West Boyertown – North Boyertown 69 kV circuit	ME (100%)
b2765	Upgrade bus conductor at Gardners 115 kv substation; Upgrade bus conductor and adjust CT ratios at Carlisle Pike 115 kV	ME (100%)
b2814	Install a 3rd 230/69 kV 224 MVA Transformer at Lyons and install new terminal equipment for existing Lyons - East Penn(865) 69 kV Line	ME (100%)
b2950	Upgrade limiting 115 kV switches on the 115 kV side of the 230/115 kV Northwood substation and adjust setting on limiting ZR relay	ME (100%)
b3115	Provide new station service to control building from 230 kV bus (served from plant facilities presently)	ME (100%)

SCHEDULE 12 – APPENDIX A

(14) Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2117	Reconductor 0.33 miles of the Parkersburg - Belpre line and upgrade Parkersburg terminal equipment	APS (100%)
b2118	Add 44 MVAR Cap at New Martinsville	APS (100%)
b2120	Six-Wire Lake Lynn - Lardin 138 kV circuits	APS (100%)
b2142	Replace Weirton 138 kV breaker “Wylie Ridge 210” with 63 kA breaker	APS (100%)
b2143	Replace Weirton 138 kV breaker “Wylie Ridge 216” with 63 kA breaker	APS (100%)
b2174.8	Replace relays at Mitchell substation	APS (100%)
b2174.9	Replace primary relay at Piney Fork substation	APS (100%)
b2174.10	Perform relay setting changes at Bethel Park substation	APS (100%)
b2213	Armstrong Substation: Relocate 138 kV controls from the generating station building to new control building	APS (100%)
b2214	Albright Substation: Install a new control building in the switchyard and relocate controls and SCADA equipment from the generating station building the new control center	APS (100%)
b2215	Rivesville Switching Station: Relocate controls and SCADA equipment from the generating station building to new control building	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2216	Willow Island: Install a new 138 kV cross bus at Belmont Substation and reconnect and reconfigure the 138 kV lines to facilitate removal of the equipment at Willow Island switching station	APS (100%)
b2235	130 MVAR reactor at Monocacy 230 kV	APS (100%)
b2260	Install a 32.4 MVAR capacitor at Bartonville	APS (100%)
b2261	Install a 33 MVAR capacitor at Damascus	APS (100%)
b2267	Replace 1000 Cu substation conductor and 1200 amp wave trap at Marlowe	APS (100%)
b2268	Reconductor 6.8 miles of 138kV 336 ACSR with 336 ACSS from Double Toll Gate to Riverton	APS (100%)
b2299	Reconductor from Collins Ferry - West Run 138 kV with 556 ACSS	APS (100%)
b2300	Reconductor from Lake Lynn - West Run 138 kV	APS (100%)
b2341	Install 39.6 MVAR Capacitor at Shaffers Corner 138 kV Substation	APS (100%)
b2342	Construct a new 138 kV switching station (Shuman Hill substation), which is next the Mobley 138 kV substation and install a 31.7 MVAR capacitor	APS (100%)
b2343	Install a 31.7 MVAR capacitor at West Union 138 kV substation	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2362	Install a 250 MVAR SVC at Squab Hollow 230 kV	APS (100%)
b2362.1	Install a 230 kV breaker at Squab Hollow 230 kV substation	APS (100%)
b2363	Convert the Shingletown 230 kV bus into a 6 breaker ring bus	APS (100%)
b2364	Install a new 230/138 kV transformer at Squab Hollow 230 kV substation. Loop the Forest - Elko 230 kV line into Squab Hollow. Loop the Brookville - Elko 138 kV line into Squab Hollow	APS (100%)
b2412	Install a 44 MVAR 138 kV capacitor at the Hempfield 138 kV substation	APS (100%)
b2433.1	Install breaker and a half 138 kV substation (Waldo Run) with 4 breakers to accommodate service to MarkWest Sherwood Facility including metering which is cut into Glen Falls Lamberton 138 kV line	APS (100%)
b2433.2	Install a 70 MVAR SVC at the new WaldoRun 138 kV substation	APS (100%)
b2433.3	Install two 31.7 MVAR capacitors at the new WaldoRun 138 kV substation	APS (100%)
b2424	Replace the Weirton 138 kV breaker 'WYLIE RID210' with 63 kA breakers	APS (100%)
b2425	Replace the Weirton 138 kV breaker 'WYLIE RID216' with 63 kA breakers	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2426	Replace the Oak Grove 138 kV breaker 'OG1' with 63 kA breakers	APS (100%)
b2427	Replace the Oak Grove 138 kV breaker 'OG2' with 63 kA breakers	APS (100%)
b2428	Replace the Oak Grove 138 kV breaker 'OG3' with 63 kA breakers	APS (100%)
b2429	Replace the Oak Grove 138 kV breaker 'OG4' with 63 kA breakers	APS (100%)
b2430	Replace the Oak Grove 138 kV breaker 'OG5' with 63 kA breakers	APS (100%)
b2431	Replace the Oak Grove 138 kV breaker 'OG6' with 63 kA breakers	APS (100%)
b2432	Replace the Ridgeley 138 kV breaker 'RC1' with a 40 kA rated breaker	APS (100%)
b2440	Replace the Cabot 138kV breaker 'C9-KISKI VLY' with 63kA	APS (100%)
b2472	Replace the Ringgold 138 kV breaker 'RCM1' with 40kA breakers	APS (100%)
b2473	Replace the Ringgold 138 kV breaker '#4 XMFR' with 40kA breakers	APS (100%)
b2475	Construct a new line between Oak Mound 138 kV substation and Waldo Run 138 kV substation	APS (100%)
b2545.1	Construct a new 138 kV substation (Shuman Hill substation) connected to the Fairview –Willow Island (84) 138 kV line	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2545.2	Install a ring bus station with five active positions and two 52.8 MVAR capacitors with 0.941 mH reactors	APS (100%)
b2545.3	Install a +90/-30 MVAR SVC protected by a 138 kV breaker	APS (100%)
b2545.4	Remove the 31.7 MVAR capacitor bank at Mobley 138 kV	APS (100%)
b2546	Install a 51.8 MVAR (rated) 138 kV capacitor at Nyswaner 138 kV substation	APS (100%)
b2547.1	Construct a new 138 kV six breaker ring bus Hillman substation	APS (100%)
b2547.2	Loop Smith- Imperial 138 kV line into the new Hillman substation	APS (100%)
b2547.3	Install +125/-75 MVAR SVC at Hillman substation	APS (100%)
b2547.4	Install two 31.7 MVAR 138 kV capacitors	APS (100%)
b2548	Eliminate clearance de-rate on Wylie Ridge – Smith 138 kV line and upgrade terminals at Smith 138 kV, new line ratings 294 MVA (Rate A)/350 MVA (Rate B)	APS (100%)
b2612.1	Relocate All Dam 6 138 kV line and the 138 kV line to AE units 1&2	APS (100%)
b2612.2	Install 138 kV, 3000A bus-tie breaker in the open bus-tie position next to the Shaffers corner 138 kV line	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2612.3	Install a 6-pole manual switch, foundation, control cable, and all associated facilities		APS (100%)
b2666	Yukon 138 kV Breaker Replacement		APS (100%)
b2666.1	Replace Yukon 138 kV breaker “Y-11(CHARL1)” with an 80 kA breaker		APS (100%)
b2666.2	Replace Yukon 138 kV breaker “Y-13(BETHEL)” with an 80 kA breaker		APS (100%)
b2666.3	Replace Yukon 138 kV breaker “Y-18(CHARL2)” with an 80 kA breaker		APS (100%)
b2666.4	Replace Yukon 138 kV breaker “Y-19(CHARL2)” with an 80 kA breaker		APS (100%)
b2666.5	Replace Yukon 138 kV breaker “Y-4(4B-2BUS)” with an 80 kA breaker		APS (100%)
b2666.6	Replace Yukon 138 kV breaker “Y-5(LAYTON)” with an 80 kA breaker		APS (100%)
b2666.7	Replace Yukon 138 kV breaker “Y-8(HUNTING)” with an 80 kA breaker		APS (100%)
b2666.8	Replace Yukon 138 kV breaker “Y-9(SPRINGD)” with an 80 kA breaker		APS (100%)
b2666.9	Replace Yukon 138 kV breaker “Y-10(CHRL-SP)” with an 80 kA breaker		APS (100%)
b2666.10	Replace Yukon 138 kV breaker “Y-12(1-1BUS)” with an 80 kA breaker		APS (100%)
b2666.11	Replace Yukon 138 kV breaker “Y-14(4-1BUS)” with an 80 kA breaker		APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2666.12	Replace Yukon 138 kV breaker “Y-2(1B-BETHE)” with an 80 kA breaker		APS (100%)
b2666.13	Replace Yukon 138 kV breaker “Y-21(SHEPJ)” with an 80 kA breaker		APS (100%)
b2666.14	Replace Yukon 138 kV breaker “Y-22(SHEPHJT)” with an 80 kA breaker		APS (100%)
b2672	Change CT Ratio at Seneca Caverns from 120/1 to 160/1 and adjust relay settings accordingly		APS (100%)
b2688.3	Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and adjust CT ratios		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)
b2689.3	Upgrade terminal equipment at structure 27A		APS (100%)
b2696	Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations. New rating of line will be 353 MVA summer normal/422 MVA emergency		APS (100%)
b2700	Remove existing Black Oak SPS		APS (100%)
b2743.6	Reconfigure the Ringgold 230 kV substation to double bus double breaker scheme		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.6.1	Replace the two Ringgold 230/138 kV transformers	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2743.7	Rebuild/Reconductor the Ringgold – Catoctin 138 kV circuit and upgrade terminal equipment on both ends	AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2747.1	Relocate the FirstEnergy Pratts 138 kV terminal CVTs at Gordonsville substation to allow for the installation of a new motor operated switch being installed by Dominion	APS (100%)
b2763	Replace the breaker risers and wave trap at Bredinville 138 kV substation on the Cabrey Junction 138 kV terminal	APS (100%)
b2764	Upgrade Fairview 138 kV breaker risers and disconnect leads; Replace 500 CU breaker risers and 556 ACSR disconnect leads with 795 ACSR	APS (100%)
b2964.1	Replace terminal equipment at Pruntytown and Glen Falls 138 kV station	APS (100%)
b2964.2	Reconductor approximately 8.3 miles of the McAlpin - White Hall Junction 138 kV circuit	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2965	Reconductor the Charleroi – Allenport 138 kV line with 954 ACSR conductor. Replace breaker risers at Charleroi and Allenport	DL (100%)
b2966	Reconductor the Yukon – Smithton – Shepler Hill Jct 138 kV line with 795 ACSS conductor. Replace Line Disconnect Switch at Yukon	APS (100%)
b2966.1	Reconductor the Yukon - Smithton - Shepler Hill Jct 138 kV line and replace terminal equipment as necessary to achieve required rating	APS (100%)
b2967	Convert the existing 6 wire Butler - Shanor Manor - Krendale 138 kV line into two separate 138 kV lines. New lines will be Butler - Keisters and Butler - Shanor Manor - Krendale 138 kV	APS (100%)
b2970	Ringgold – Catocin Solution	APS (100%)
b2970.1	Install two new 230 kV positions at Ringgold for 230/138 kV transformers	APS (100%)
b2970.2	Install new 230 kV position for Ringgold – Catocin 230 kV line	APS (100%)
b2970.3	Install one new 230 kV breaker at Catocin substation	APS (100%)
b2970.4	Install new 230/138 kV transformer at Catocin substation. Convert Ringgold – Catocin 138 kV line to 230 kV operation	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2970.5	Convert Garfield 138/12.5 kV substation to 230/12.5 kV	APS (100%)
b2996	Construct a new 500/138 kV substation as a 4-breaker ring bus with expansion plans for double-breaker-double-bus on the 500 kV bus and breaker-and-a-half on the 138 kV bus to provide EHV source to the Marcellus shale load growth area. Projected load growth of additional 160 MVA to current plan of 280 MVA, for a total load of 440 MVA served from Waldo Run substation. Replace primary relaying and carrier sets on Belmont and Harrison 500 kV Remote End substations. Construct additional 3-breaker string at Waldo Run 138 kV bus. Relocate the Sherwood #2 line terminal to the new string. Construct two single circuit Flint Run - Waldo Run 138 kV lines using 795 ACSR (approximately 3 miles). After terminal relocation on new 3-breaker string at Waldo Run, terminate new Flint Run 138 kV lines onto the two open terminals	APS (100%)
b3005	Reconductor 3.1 mile 556 ACSR portion of Cabot to Butler 138 kV with 556 ACSS and upgrade terminal equipment. 3.1 miles of line will be reconducted for this project. The total length of the line is 7.75 miles	APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3006	Replace four Yukon 500/138 kV transformers with three transformers with higher rating and reconfigure 500 kV bus	APS (52.84%) / DL (47.16%)
b3007.1	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - AP portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Social Hall, meters, relays, bus conductor, a wave trap, circuit breaker and disconnects will be replaced	APS (100%)
b3010	Replace terminal equipment at Keystone and Cabot 500 kV buses. At Keystone, bus tubing and conductor, a wave trap, and meter will be replaced. At Cabot, a wave trap and bus conductor will be replaced	APS (100%)
b3011.1	Construct new Route 51 substation and connect 10 138 kV lines to new substation	DL (100%)
b3011.2	Upgrade terminal equipment at Yukon to increase rating on Yukon to Charleroi #2 138 kV line (New Yukon to Route 51 #4 138 kV line)	DL (100%)
b3011.3	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #1 138 kV line	DL (100%)
b3011.4	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #2 138 kV line	DL (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b3011.5	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #3 138 kV line		DL (100%)
b3011.6	Upgrade remote end relays for Yukon – Allenport – Iron Bridge 138 kV line		DL (100%)
b3012.1	Construct two new 138 kV ties with the single structure from APS’s new substation to Duquesne’s new substation. The estimated line length is approximately 4.7 miles. The line is planned to use multiple ACSS conductors per phase		ATSI (38.21%) / DL (61.79%)
b3012.3	Construct a new Elrama – Route 51 138 kV No.3 line: reconductor 4.7 miles of the existing line, and construct 1.5 miles of a new line to the reconducted portion. Install a new line terminal at APS Route 51 substation		DL (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b3013	Reconductor Vasco Tap to Edgewater Tap 138 kV line. 4.4 miles. The new conductor will be 336 ACSS replacing the existing 336 ACSR conductor		APS (100%)
b3015.6	Reconductor Elrama to Mitchell 138 kV line – AP portion. 4.2 miles total. 2x 795 ACSS/TW 20/7		DL (100%)
b3028	Upgrade substation disconnect leads at William 138 kV substation		APS (100%)
b3051.1	Ronceverte cap bank and terminal upgrades		APS (100%)
b3052	Install a 138 kV capacitor (29.7 MVAR effective) at West Winchester 138 kV		APS (100%)

Monongahela Power Company, The Potomac Edison Company, and West Penn Power Company, all doing business as Allegheny Power (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3068	Reconductor the Yukon – Westraver 138 kV line (2.8 miles), replace the line drops and relays at Yukon 138 kV and replace switches at Westraver 138 kV bus		APS (100%)
b3069	Reconductor the Westraver – Route 51 138 kV line (5.63 miles) and replace line switches at Westraver 138 kV bus		APS (100%)
b3070	Reconductor the Yukon – Route 51 #1 138 kV line (8 miles), replace the line drops, relays and line disconnect switch at Yukon 138 kV bus		APS (100%)
b3071	Reconductor the Yukon – Route 51 #2 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3072	Reconductor the Yukon – Route 51 #3 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3074	Reconductor the 138 kV bus at Armstrong substation		APS (100%)
b3075	Replace the 500/138 kV transformer breaker and reconductor 138 kV bus at Cabot substation		APS (100%)
b3076	Reconductor the Edgewater – Loyalhanna 138 kV line (0.67 mile)		APS (100%)
b3079	Replace the Wylie Ridge 500/345 kV transformer #7		ATSI (72.30%) / DL (27.70%)
b3083	Reconductor the 138 kV bus at Butler and reconductor the 138 kV bus and replace line trap at Karns City		APS (100%)

SCHEDULE 12 – APPENDIX A

(15) Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2141.1	Remove Byron SPS upon completion of Byron - Wayne 345 kV	ComEd (100%)
b2365	Replace 138 kV bus tie 1-2 circuit breaker, station conductor, relays, and a wave trap at TSS 55 Hegewisch substation	ComEd (100%)
b2366	Reconductor 1.4 miles of 138 kV line 0112, Kickapoo Creek - LaSalle County 138kV line	ComEd (100%)
b2415	Install a 138 kV Red Blue bus tie with underground cable and a line 15913 CB at Highland Park	ComEd (100%)
b2416	Reconductor 0.125 miles of the East Frankfort - Mokena 138 kV line L6604	ComEd (100%)
b2417	Replace Ridgeland 138 kV bus tie CB and underground cable at TSS 192 Ridgeland 138 kV substation	ComEd (100%)
b2418	Reconductor 7.5 miles of Waukegan - Gurnee 138 kV line L1607	ComEd (100%)
b2419	Reconductor 0.33 miles of 138 kV underground cable on the Sawyer - Crawford 138 kV Blue line (L1324)	ComEd (100%)
b2465	Replace the Skokie 138 kV breaker '88 L8809' with a 63 kA breaker	ComEd (100%)
b2466	Replace the Skokie 138 kV breaker '88 L8810' with 63kA breaker	ComEd (100%)
b2467	Replace the Skokie 138 kV breaker '88 L11416' with 63 kA breaker	ComEd (100%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2468	Replace the Skokie 138 kV breaker '88 L8803' with 63kA breaker		ComEd (100%)
b2469	Replace the Des Plaines 138 kV breaker '46 11702' with 63 kA breaker		ComEd (100%)
b2561	Install a new 345 kV circuit breaker 5-7 at Elwood substation		ComEd (100%)
b2562	Remove 2.0 miles of wood poles on 138 kV line 17105, erect new steel structures, and install new 1113 kcmil ACSR conductor from Roscoe Bert to Harlem		ComEd (100%)
b2613	Replace relays at Mazon substation		ComEd (100%)
b2692.1	Replace station equipment at Nelson, ESS H-471 and Quad Cities		AEC (0.18%) / AEP (18.69%) / APS (5.87%) / ATSI (7.86%) / BGE (3.32%) / ComEd (38.23%) / Dayton (2.76%) / DEOK (4.13%) / DL (2.23%) / Dominion (5.15%) / DPL (1.97%) / EKPC (1.36%) / JCPL (0.52%) / MetED (0.04%) / Neptune (0.04%) / PECO (1.08%) / PENELEC (1.25%) / PEPCO (3.56%) / PPL (0.45%) / PSEG (1.17%) / RECO (0.14%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2692.2	Upgrade conductor ratings of Cordova – Nelson, Quad Cities – ESS H-471 and ESS H-471 – Nelson 345 kV lines and mitigating sag limitations	AEC (0.18%) / AEP (18.69%) / APS (5.87%) / ATSI (7.86%) / BGE (3.32%) / ComEd (38.23%) / Dayton (2.76%) / DEOK (4.13%) / DL (2.23%) / Dominion (5.15%) / DPL (1.97%) / EKPC (1.36%) / JCPL (0.52%) / MetED (0.04%) / Neptune (0.04%) / PECO (1.08%) / PENELEC (1.25%) / PEPCO (3.56%) / PPL (0.45%) / PSEG (1.17%) / RECO (0.14%)
b2693	Replace L7815 B phase line trap at Wayne substation	ComEd (100%)
b2699.1	Replace 5 Powerton 345 kV CB's with 2 cycle IPO breakers, install one new 345 kV CB; swap line 0302 and line 0303 bus positions; reconfigure Powerton 345 kV bus as single ring configuration	ComEd (100%)
b2699.2	Remove SPS logic at Powerton that trips generators or sectionalizes bus under normal conditions; minimal SPS logic will remain	ComEd (100%)
b2721	Goodings Grove – Balance Station Load (swap bus positions for 345 kV lines 1312 & 11620 and 345 kV lines 11604 & 11622) and replace 138 kV bus tie 2-3	ComEd (100%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2728	Mitigate sag limitations on Loretto – Wilton Center 345 kV Line and replace station conductor at Wilton Center		ATSI (3.43%) / AEP (3.34%) / ComEd (92.02%) / DLCO (1.21%)
b2732.1	Cut-in of line 93505 Tazewell – Kendall 345 kV line into Dresden		ComEd (100%)
b2732.2	Raise towers to remove the sag limitations on Pontiac – Loretto 345 kV line		ComEd (100%)
b2930	Upgrade capacity on E. Frankfort – University Park 345 kV		ComEd (100%)
b2931	Upgrade substation equipment at Pontiac Midpoint station to increase capacity on Pontiac – Brokaw 345 kV line		ComEd (100%)
b2941	Build an indoor new Elk Grove 138 kV GIS substation at the point where Rolling Meadows & Schaumburg tap off from the main lines, between Landmeier and Busse. The four 345 kV circuits in the ROW will be diverted into Gas Insulated Bus (GIB) and go through the basement of the building to provide clearance for the above ground portion of the building		ComEd (100%)
b2959	Install a new 138 kV circuit 18702 from Schauff Road to Rock Falls and install a fourth breaker and a half run at Schauff Road		ComEd (100%)
b2995	Remove Davis Creek RAS		ComEd (100%)
b2997	Remove University Park North RAS		ComEd (100%)

**Commonwealth Edison Company and Commonwealth Edison Company of Indiana, Inc.
(cont.)**

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2998	Install a 120 MVAR 345 kV shunt inductor at Powerton (the 345 kV yard already contains an empty bus position on the ring we only need a switching breaker for the inductor)		ComEd (100%)
b2999	Rebuild the 12.36 mile Schauff Road to Nelson tap 138 kV line L15508		ComEd (100%)
b3049	Replace 345 kV breaker at Joliet substation		ComEd (100%)
b3111	Install high-speed backup clearing scheme on the E. Frankfort – Matteson 138 kV line (L6603)		ComEd (100%)

SCHEDULE 12 – APPENDIX A

(16) The Dayton Power and Light Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2540	Increase rating of Shelby-E. Sidney-Quincy-Logan 138kV line to 224 MVA by replace/raise three pole swing out structure; push/pull/retension conductors on two spans; lower eight spans of single phase	Dayton (100%)
b2541	As needed in PJM Operations connect two 30 MVAR mobile shunts to Eldean and Sidney 69 kV buses; Block LTCs for Eldean 138/69 kV and Sidney 138/69kV transformers after loss of Shelby-Sidney 138kV line	Dayton (100%)
b2879.1	Replace wavetrap at the Stuart 345 kV substation	Dayton (100%)
b3108.1	Install 100 MVAR reactor at Miami 138 kV substation	Dayton (100%)
b3108.2	Install 100 MVAR reactor at Sugarcreek 138 kV substation	Dayton (100%)
b3108.3	Install 100 MVAR reactor at Hutchings 138 kV substation	Dayton (100%)

SCHEDULE 12 – APPENDIX A

- (17) **AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company)**

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer	AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: ATSI (24.65%) / Dayton (8.85%) / DEOK (19.91%) / Dominion (41.38%) / EKPC (5.21%)</p>

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1797.1	Reconductor the AEP portion of the Cloverdale - Lexington 500 kV line with 2-1780 ACSS	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: ATSI (5.74%) / Dayton (1.97%) / DEOK (4.40%) / Dominion (9.97%) / EKPC (1.12%) / PEPSCO (76.80%)</p>
b2055	Upgrade relay at Brues station	AEP (100%)
b2122.3	Upgrade terminal equipment at Howard on the Howard - Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)	AEP (100%)
b2122.4	Perform a sag study on the Howard - Brookside 138 kV line	AEP (100%)
b2229	Install a 300 MVAR reactor at Dequine 345 kV	AEP (100%)

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2230	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2231	Install 765 kV reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line	AEP (100%)
b2232	Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line	AEP (100%)
b2233	Change transformer tap settings for the Baker 765/345 kV transformer	AEP (100%)
b2252	Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	AEP (100%)

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2253	Install an 86.4 MVAR capacitor bank at Gorsuch 138 kV station in Ohio		AEP (100%)
b2254	Rebuild approximately 4.9 miles of Corner - Degussa 138 kV line in Ohio		AEP (100%)
b2255	Rebuild approximately 2.8 miles of Maliszewski - Polaris 138 kV line in Ohio		AEP (100%)
b2256	Upgrade approximately 36 miles of 138 kV through path facilities between Harrison 138 kV station and Ross 138 kV station in Ohio		AEP (100%)
b2257	Rebuild the Pokagon - Corey 69 kV line as a double circuit 138 kV line with one side at 69 kV and the other side as an express circuit between Pokagon and Corey stations		AEP (100%)
b2258	Rebuild 1.41 miles of #2 CU 46 kV line between Tams Mountain - Slab Fork to 138 kV standards. The line will be strung with 1033 ACSR		AEP (100%)
b2259	Install a new 138/69 kV transformer at George Washington 138/69 kV substation to provide support to the 69 kV system in the area		AEP (100%)
b2286	Rebuild 4.7 miles of Muskingum River - Wolf Creek 138 kV line and remove the 138/138 kV transformer at Wolf Creek Station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2287	Loop in the Meadow Lake - Olive 345 kV circuit into Reynolds 765/345 kV station		AEP (100%)
b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholasville and Marcellus 34.5 kV stations at this new station		AEP (100%)
b2344.2	Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station		AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA’s Marcellus station		AEP (100%)
b2344.4	From REA’s Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)		AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)		AEP (100%)
b2344.6	Retire AEP’s Marcellus 34.5/12 kV and Nicholasville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line		AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)		AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations		AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV		AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades		AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures		AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit		AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit		AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'	AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2394	Replace the Sporn 345 kV breaker 'CC1'	AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio	AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station	AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor	AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station	Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)
		DFAX Allocation: AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408 2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2-138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2502.1	Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway-Brookside, Holloway-Harmon #1 and #2, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station		AEP (100%)
b2502.2	Convert Freebyrd 69 kV to 138 kV		AEP (100%)
b2502.3	Rebuild/convert Freebyrd-South Cadiz 69 kV circuit to 138 kV		AEP (100%)
b2502.4	Upgrade South Cadiz to 138 kV breaker and a half		AEP (100%)
b2530	Replace the Sporn 138 kV breaker 'G1' with 80kA breaker		AEP (100%)
b2531	Replace the Sporn 138 kV breaker 'D' with 80kA breaker		AEP (100%)
b2532	Replace the Sporn 138 kV breaker 'O1' with 80kA breaker		AEP (100%)
b2533	Replace the Sporn 138 kV breaker 'P2' with 80kA breaker		AEP (100%)
b2534	Replace the Sporn 138 kV breaker 'U' with 80kA breaker		AEP (100%)
b2535	Replace the Sporn 138 kV breaker 'O' with 80 kA breaker		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2536	Replace the Sporn 138 kV breaker 'O2' with 80 kA breaker		AEP (100%)
b2537	Replace the Robinson Park 138 kV breakers A1, A2, B1, B2, C1, C2, D1, D2, E1, E2, and F1 with 63 kA breakers		AEP (100%)
b2555	Reconductor 0.5 miles Tiltonsville – Windsor 138 kV and string the vacant side of the 4.5 mile section using 556 ACSR in a six wire configuration		AEP (100%)
b2556	Install two 138 kV prop structures to increase the maximum operating temperature of the Clinch River- Clinch Field 138 kV line		AEP (100%)
b2581	Temporary operating procedure for delay of upgrade b1464. Open the Corner 138 kV circuit breaker 86 for an overload of the Corner – Washington MP 138 kV line. The tower contingency loss of Belmont – Trissler 138 kV and Belmont – Edgelawn 138 kV should be added to Operational contingency		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.		AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit		AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch		AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor		AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards		AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2597	Rebuild approximately 1 mi. section of Dragoon-Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon-Dodge Tap branch		AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline-Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.		AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap		AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV		AEP (100%)
b2601	Fremont Station Improvements		AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker		AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker		AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker		AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1		AEP (100%)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at Fremont Station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2602.1	Install 138 kV breaker E2 at North Proctorville	AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations	AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington	AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah	AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville	AEP (100%)
b2603	Boone Area Improvements	AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)	AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit	AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646” OPGW Static wires	AEP (100%)
b2604	Bellefonte Transformer Addition	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap stations		AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation		AEP (100%)
b2607	Pine Gap Relay Limit Increase		AEP (100%)
b2608	Richlands Relay Upgrade		AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build		AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV		AEP (100%)
b2611	Skin Fork Area Improvements		AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components		AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line		AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort-Tanners Creek 345 kV line)		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker		AEP (100%)
b2645	Ohio Central 138 kV Loop		AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2		AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor		AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto		AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)		AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2687.2	Install a 300 MVAR shunt line reactor on the Broadford end of the Broadford – Jacksons Ferry 765 kV line	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPSCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: AEP (100%)</p>
b2697.1	Mitigate violations identified by sag study to operate Fieldale-Thornton-Franklin 138 kV overhead line conductor at its max. operating temperature. 6 potential line crossings to be addressed.	AEP (100%)
b2697.2	Replace terminal equipment at AEP's Danville and East Danville substations to improve thermal capacity of Danville – East Danville 138 kV circuit	AEP (100%)

*Neptune Regional Transmission System, LLC

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line		AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2-28.8 MVAR capacitor banks		AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW		AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit		AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station		AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA breakers		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards		AEP (100%)
b2733	Replace South Canton 138 kV breakers ‘L’ and ‘L2’ with 80 kA rated breakers		AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station		AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR		AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection		AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but initial configuration will constitute a 3 breaker ring bus		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2753.3	Connect two 138 kV 6-wired circuits from “Point A” (currently de-energized and owned by FirstEnergy) in circuit positions previously designated Burger #1 & Burger #2 138 kV. Install interconnection settlement metering on both circuits exiting Holloway		AEP (100%)
b2753.6	Build double circuit 138 kV line from Dilles Bottom to “Point A”. Tie each new AEP circuit in with a 6-wired line at Point A. This will create a Dilles Bottom – Holloway 138 kV circuit and a George Washington – Holloway 138 kV circuit		AEP (100%)
b2753.7	Retire line sections (Dilles Bottom – Bellaire and Moundsville – Dilles Bottom 69 kV lines) south of FirstEnergy 138 kV line corridor, near “Point A”. Tie George Washington – Moundsville 69 kV circuit to George Washington – West Bellaire 69 kV circuit		AEP (100%)
b2753.8	Rebuild existing 69 kV line as double circuit from George Washington – Dilles Bottom 138 kV. One circuit will cut into Dilles Bottom 138 kV initially and the other will go past with future plans to cut in		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooton 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		AEP (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville 138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively		AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington		AEP (100%)
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct. - Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)		AEP (100%)
b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T-Line from the 69 kV through-path		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)		AEP (100%)
b2790	Install a 3 MVAR, 34.5 kV cap bank at Caldwell substation		AEP (100%)
b2791	Rebuild Tiffin – Howard, new transformer at Chatfield		AEP (100%)
b2791.1	Rebuild portions of the East Tiffin - Howard 69 kV line from East Tiffin to West Rockaway Switch (0.8 miles) using 795 ACSR Drake conductor (129 MVA rating, 50% loading)		AEP (100%)
b2791.2	Rebuild Tiffin - Howard 69 kV line from St. Stephen's Switch to Hinesville (14.7 miles) using 795 ACSR Drake conductor (90 MVA rating, non-conductor limited, 38% loading)		AEP (100%)
b2791.3	New 138/69 kV transformer with 138/69 kV protection at Chatfield		AEP (100%)
b2791.4	New 138/69 kV protection at existing Chatfield transformer		AEP (100%)
b2792	Replace the Elliott transformer with a 130 MVA unit, reconductor 0.42 miles of the Elliott – Ohio University 69 kV line with 556 ACSR to match the rest of the line conductor (102 MVA rating, 73% loading) and rebuild 4 miles of the Clark Street – Strouds R		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2793	Energize the spare Fremont Center 138/69 kV 130 MVA transformer #3. Reduces overloaded facilities to 46% loading	AEP (100%)
b2794	Construct new 138/69/34 kV station and 1-34 kV circuit (designed for 69 kV) from new station to Decliff station, approximately 4 miles, with 556 ACSR conductor (51 MVA rating)	AEP (100%)
b2795	Install a 34.5 kV 4.8 MVAR capacitor bank at Killbuck 34.5 kV station	AEP (100%)
b2796	Rebuild the Malvern - Oneida Switch 69 kV line section with 795 ACSR (1.8 miles, 125 MVA rating, 55% loading)	AEP (100%)
b2797	Rebuild the Ohio Central - Conesville 69 kV line section (11.8 miles) with 795 ACSR conductor (128 MVA rating, 57% loading). Replace the 50 MVA Ohio Central 138/69 kV XFMR with a 90 MVA unit	AEP (100%)
b2798	Install a 14.4 MVAR capacitor bank at West Hicksville station. Replace ground switch/MOAB at West Hicksville with a circuit switcher	AEP (100%)
b2799	Rebuild Valley - Almena, Almena - Hartford, Riverside - South Haven 69 kV lines. New line exit at Valley Station. New transformers at Almena and Hartford	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2799.1	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSR conductor (360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station	AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)	AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker	AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley	AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA breaker		AEP (100%)
b2818	Replace West Huntington 138 kV breaker 'F' with a 40 kA breaker		AEP (100%)
b2819	Replace Madison 138 kV breaker 'V' with a 63 kA breaker		AEP (100%)
b2820	Replace Sterling 138 kV breaker 'G' with a 40 kA breaker		AEP (100%)
b2821	Replace Morse 138 kV breakers '103', '104', '105', and '106' with 63 kA breakers		AEP (100%)
b2822	Replace Clinton 138 kV breakers '105' and '107' with 63 kA breakers		AEP (100%)
b2826.1	Install 300 MVAR reactor at Ohio Central 345 kV substation		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation		AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)		DFAX Allocation: Dayton (34.34%) / DEOK (56.45%) / EKPC (9.21%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit		AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor		DFAX Allocation: Dayton (100%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit		AEP (100%)
b2872	Replace the South Canton 138 kV breaker ‘K2’ with a 80 kA breaker		AEP (100%)
b2873	Replace the South Canton 138 kV breaker “M” with a 80 kA breaker		AEP (100%)
b2874	Replace the South Canton 138 kV breaker “M2” with a 80 kA breaker		AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers		AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2881	Rebuild ~1.7 miles of the Dunn Hollow – London 46 kV line section utilizing 795 26/7 ACSR conductor (58 MVA rating, non-conductor limited)	AEP (100%)
b2882	Rebuild Reusens - Peakland Switch 69 kV line. Replace Peakland Switch	AEP (100%)
b2882.1	Rebuild the Reusens - Peakland Switch 69 kV line (approximately 0.8 miles) utilizing 795 ACSR conductor (86 MVA rating, non-conductor limited)	AEP (100%)
b2882.2	Replace existing Peakland S.S with new 3 way switch phase over phase structure	AEP (100%)
b2883	Rebuild the Craneco – Pardee – Three Forks – Skin Fork 46 kV line section (approximately 7.2 miles) utilizing 795 26/7 ACSR conductor (108 MVA rating)	AEP (100%)
b2884	Install a second transformer at Nagel station, comprised of 3 single phase 250 MVA 500/138 kV transformers. Presently, TVA operates their end of the Boone Dam – Holston 138 kV interconnection as normally open preemptively for the loss of the existing Nagel	AEP (100%)
b2885	New delivery point for City of Jackson	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2885.1	Install a new Ironman Switch to serve a new delivery point requested by the City of Jackson for a load increase request		AEP (100%)
b2885.2	Install a new 138/69 kV station (Rhodes) to serve as a third source to the area to help relieve overloads caused by the customer load increase		AEP (100%)
b2885.3	Replace Coalton Switch with a new three breaker ring bus (Heppner)		AEP (100%)
b2886	Install 90 MVA 138/69 kV transformer, new transformer high and low side 3000 A 40 kA CBs, and a 138 kV 40 kA bus tie breaker at West End Fostoria		AEP (100%)
b2887	Add 2-138 kV CB's and relocate 2-138 kV circuit exits to different bays at Morse Road. Eliminate 3 terminal line by terminating Genoa - Morse circuit at Morse Road		AEP (100%)
b2888	Retire Poston substation. Install new Lemaster substation		AEP (100%)
b2888.1	Remove and retire the Poston 138 kV station		AEP (100%)
b2888.2	Install a new greenfield station, Lemaster 138 kV Station, in the clear		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston - Trimble 69 kV line	AEP (100%)
b2889	Expand Cliffview station	AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)	AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)	AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby	AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2890.1	Rebuild 23.55 miles of the East Cambridge – Smyrna 34.5 kV circuit with 795 ACSR conductor (128 MVA rating) and convert to 69 kV		AEP (100%)
b2890.2	East Cambridge: Install a 2000 A 69 kV 40 kA circuit breaker for the East Cambridge – Smyrna 69 kV circuit		AEP (100%)
b2890.3	Old Washington: Install 69 kV 2000 A two way phase over phase switch		AEP (100%)
b2890.4	Install 69 kV 2000 A two way phase over phase switch		AEP (100%)
b2891	Rebuild the Midland Switch to East Findlay 34.5 kV line (3.31 miles) with 795 ACSR (63 MVA rating) to match other conductor in the area		AEP (100%)
b2892	Install new 138/12 kV transformer with high side circuit switcher at Leon and a new 138 kV line exit towards Ripley. Establish 138 kV at the Ripley station with a new 138/69 kV 130 MVA transformer and move the distribution load to 138 kV service		AEP (100%)
b2936.1	Rebuild approximately 6.7 miles of 69 kV line between Mottville and Pigeon River using 795 ACSR conductor (129 MVA rating). New construction will be designed to 138 kV standards but operated at 69 kV		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2936.2	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker		AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor		AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature		AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances		AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station		AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station		AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit		AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker “JM” with 63 kA breaker and associated substation works including switches, bus leads, control cable and new DICM		AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR ‘Curlew’ conductor and steel poles		AEP (100%)
b3000	Replace South Canton 138 kV breaker ‘N’ with an 80kA breaker		AEP (100%)
b3001	Replace South Canton 138 kV breaker ‘N1’ with an 80kA breaker		AEP (100%)
b3002	Replace South Canton 138 kV breaker ‘N2’ with an 80kA breaker		AEP (100%)
b3036	Rebuild 15.4 miles of double circuit North Delphos – Rockhill 138 kV line		AEP (100%)
b3037	Upgrades at the Natrium substation		AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section		AEP (100%)
b3039	Line swaps at Muskingum 138 kV station		AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section (~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor	AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville	AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network	AEP (100%)
b3040.5	Retire Mill Run station	AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station	AEP (100%)
b3051.2	Adjust CT tap ratio at Ronceverte 138 kV	AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV	AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str's 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor	AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str's 1–11 (0.5 mile), utilizing 795 26/7 ACSR conductor	AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3086.3	Rebuild West Melrose – Whirlpool 34 kV line Str's 55–80 (1 mile), utilizing 795 26/7 ACSR conductor		AEP (100%)
b3086.4	North Findlay station: Install a 138 kV 3000A 63kA line breaker and low side 34.5 kV 2000A 40kA breaker, high side 138 kV circuit switcher on T1		AEP (100%)
b3086.5	Ebersole station: Install second 90 MVA 138/69/34 kV transformer. Install two low side (69 kV) 2000A 40kA breakers for T1 and T2		AEP (100%)
b3087.1	Construct a new greenfield station to the west (approx. 1.5 miles) of the existing Fords Branch Station in the new Kentucky Enterprise Industrial Park. This station will consist of six 3000A 40kA 138 kV breakers laid out in a ring arrangement, two 30 MVA 138/34.5 kV transformers, and two 30 MVA 138/12 kV transformers. The existing Fords Branch Station will be retired		AEP (100%)
b3087.2	Construct approximately 5 miles of new double circuit 138 kV line in order to loop the new Kewanee station into the existing Beaver Creek – Cedar Creek 138 kV circuit		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3087.3	Remote end work will be required at Cedar Creek Station		AEP (100%)
b3095	Rebuild Lakin – Racine Tap 69 kV line section (9.2 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor		AEP (100%)
b3099	Install a 138 kV 3000A 40 kA circuit switcher on the high side of the existing 138/34.5 kV transformer No.5 at Holston station		AEP (100%)
b3100	Replace the 138 kV MOAB switcher “YY” with a new 138 kV circuit switcher on the high side of Chemical transformer No.6		AEP (100%)
b3101	Rebuild the 1/0 Cu. conductor sections (approx. 1.5 miles) of the Fort Robinson – Moccasin Gap 69 kV line section (approx. 5 miles) utilizing 556 ACSR conductor and upgrade existing relay trip limit (WN/WE: 63 MVA, line limited by remaining conductor sections)		AEP (100%)
b3102	Replace existing 50 MVA 138/69 kV transformers #1 and #2 (both 1957 vintage) at Fremont station with new 130 MVA 138/69 kV transformers		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3103.1	Install a 138/69 kV transformer at Royerton station. Install a 69 kV bus with one 69 kV breaker toward Bosman station. Rebuild the 138 kV portion into a ring bus configuration built for future breaker and a half with four 138 kV breakers		AEP (100%)
b3103.2	Rebuild the Bosman/Strawboard station in the clear across the road to move it out of the flood plain and bring it up to 69 kV standards		AEP (100%)
b3103.3	Retire 138 kV breaker L at Delaware station and re-purpose 138 kV breaker M for the Jay line		AEP (100%)
b3103.4	Retire all 34.5 kV equipment at Hartford City station. Re-purpose breaker M for the Bosman line 69 kV exit		AEP (100%)
b3103.5	Rebuild the 138 kV portion of Jay station as a 6 breaker, breaker and a half station re-using the existing breakers "A", "B", and "G." Rebuild the 69 kV portion of this station as a 6 breaker ring bus re-using the 2 existing 69 kV breakers. Install a new 138/69 kV transformer		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3103.6	Rebuild the 69 kV Hartford City – Armstrong Cork line but instead of terminating it into Armstrong Cork, terminate it into Jay station		AEP (100%)
b3103.7	Build a new 69 kV line from Armstrong Cork – Jay station		AEP (100%)
b3103.8	Rebuild the 34.5 kV Delaware – Bosman line as the 69 kV Royerton – Strawboard line. Retire the line section from Royerton to Delaware stations		AEP (100%)
b3104	Perform a sag study on the Polaris – Westerville 138 kV line (approx. 3.6 miles) to increase the summer emergency rating to 310 MVA		AEP (100%)
b3105	Rebuild the Delaware – Hyatt 138 kV line (approx. 4.3 miles) along with replacing conductors at both Hyatt and Delaware substations		AEP (100%)
b3106	Perform a sag study (6.8 miles of line) to increase the SE rating to 310 MVA. Note that results from the sag study could cover a wide range of outcomes, from no work required to a complete rebuild		AEP (100%)
b3109	Rebuild 5.2 miles Bethel – Sawmill 138 kV line including ADSS		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3112	Construct a single circuit 138 kV line (approx. 3.5 miles) from Amlin to Dublin using 1033 ACSR Curlew (296 MVA SN), convert Dublin station into a ring configuration, and re-terminating the Britton UG cable to Dublin station		AEP (100%)
b3116	Replace existing Mullens 138/46 kV 30 MVA transformer No.4 and associated protective equipment with a new 138/46 kV 90 MVA transformer and associated protective equipment		AEP (100%)
b3118.1	Expand existing Chadwick station and install a second 138/69 kV transformer at a new 138 kV bus tied into the Bellefonte – Grangston 138 kV circuit. The 69 kV bus will be reconfigured into a ring bus arrangement to tie the new transformer into the existing 69 kV via installation of four 3000A 63 kA 69 kV circuit breakers		AEP (100%)
b3118.2	Perform 138 kV remote end work at Grangston station		AEP (100%)
b3118.3	Perform 138 kV remote end work at Bellefonte station		AEP (100%)
b3118.4	Relocate the Chadwick – Leach 69 kV circuit within Chadwick station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b3118.5	Terminate the Bellefonte – Grangston 138 kV circuit to the Chadwick 138 kV bus		AEP (100%)
b3118.6	Chadwick – Tri-State #2 138 kV circuit will be reconfigured within the station to terminate into the newly established 138 kV bus #2 at Chadwick due to constructability aspects		AEP (100%)
b3118.7	Reconductor Chadwick – Leach and Chadwick – England Hill 69 kV lines with 795 ACSS conductor. Perform a LiDAR survey and a sag study to confirm that the reconducted circuits would maintain acceptable clearances		AEP (100%)
b3118.8	Replace the 20 kA 69 kV circuit breaker ‘F’ at South Neal station with a new 3000A 40 kA 69 kV circuit breaker. Replace line risers towards Leach station		AEP (100%)
b3118.9	Rebuild 336 ACSR portion of Leach – Miller S.S 69 kV line section (approx. 0.3 mile) with 795 ACSS conductor		AEP (100%)
b3118.10	Replace 69 kV line risers (towards Chadwick) at Leach station		AEP (100%)

AEP Service Corporation on behalf of its Affiliate Companies (AEP Indiana Michigan Transmission Company, AEP Kentucky Transmission Company, AEP Ohio Transmission Company, AEP West Virginia Transmission Company, Appalachian Power Company, Indiana Michigan Power Company, Kentucky Power Company, Kingsport Power Company, Ohio Power Company and Wheeling Power Company) (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3208	Retire approximately 38 miles of the 44 mile Clifford – Scottsville 46 kV circuit. Build new 138 kV “in and out” to two new distribution stations to serve the load formerly served by Phoenix, Shipman, Schuyler (AEP), and Rockfish stations. Construct new 138 kV lines from Joshua Falls – Riverville (approx. 10 miles) and Riverville – Gladstone (approx. 5 miles). Install required station upgrades at Joshua Falls, Riverville and Gladstone stations to accommodate the new 138 kV circuits. Rebuild Reusen – Monroe 69 kV (approx. 4 miles)	AEP (100%)
b3209	Rebuild the 10.5 mile Berne – South Decatur 69 kV line using 556 ACSR	AEP (100%)

SCHEDULE 12 – APPENDIX A

(18) Duquesne Light Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2175.1	200 MVAR shunt reactor at Brunot Island 345 kV	DL (100%)
b2175.2	200 MVAR shunt reactor on future Brunot Island – Carson 345 kV circuit	DL (100%)
b2198	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-40 COLLIER'	DL (100%)
b2199	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-41 COLLIER'	DL (100%)
b2200	Revise the reclosing for the Crescent 138 kV breaker 'Z-29 Beaver'	DL (100%)
b2201	Revise the reclosing for the Crescent 138 kV breaker 'Z-82 VALLEY'	DL (100%)
b2202	Revise the reclosing for the Crescent 138 kV breaker 'Z-21 NORTH'	DL (100%)
b2203	Revise the reclosing for the Elrama 138 kV breaker 'Z18-USX CLAI'	DL (100%)
b2204	Revise the reclosing for the Elrama 138 kV breaker 'Z13-WEST MIF'	DL (100%)
b2205	Revise the reclosing for the Elrama 138 kV breaker 'Z15-DRAVOSBU'	DL (100%)
b2206	Revise the reclosing for the Woodville 138 kV breaker 'Z-106 PINEY'	DL (100%)
b2207	Revise the reclosing for the Woodville 138 kV breaker 'Z-64 COLLIER'	DL (100%)
b2208	Revise the reclosing for the Beaver Valley 138 kV breaker 'Z-28 CRESCEN'	DL (100%)

Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2209	Revise the reclosing for the Cheswick 138 kV breaker 'Z-51 WILMERD'	DL (100%)
b2280	Replace the USAP 138kV breaker 'XFMR'	DL (100%)
b2303	Revise the reclosing to the Dravosburg 138kV breaker 'Z73 West Mifflin' from 5 sec to 15 sec	DL (100%)
b2563	Operate with the Crescent 345/138 kV #3 autotransformer in-service by replacing 8 overdutied 138 kV breakers at Crescent, 3 138 kV breakers at Beaver Valley, install #1 section 345 kV breaker for 331 circuit at Crescent	DL (100%)
b2632	Replace the Oakland 138 kV 'Z-101 Arsenal' breaker	DL (100%)
b2639	Replace the Crescent 138 kV 'NO3 – 4 138' breaker with a 63kA breaker	DL (100%)
b2640	Replace the Crescent 138 kV 'Z-143 SWCKLY' breaker with a 63kA breaker	DL (100%)
b2641	Replace the Crescent 138 kV 'Z-24 MONTOUR' breaker with a 63kA breaker	DL (100%)
b2642	Replace the Crescent 138 kV 'Z-28 BEAVER' breaker with a 63kA breaker	DL (100%)
b2689.1	Reconductor approximately 7 miles of the Woodville – Peters (Z-117) 138 kV circuit	AEC (1.00%) / APS (66.39%) / BGE (4.62%) / DOM (8.84%) / DPL (5.85%) / Neptune (0.12%) / PECO (3.40%) / PEPCO (6.32%) / PSEG (3.46%)

Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2689.2 Reconfigure West Mifflin-USS Clairton (Z-15) 138 kV circuit to establish Dravosburg-USS Clairton (Z-14) 138 kV circuit and West Mifflin-Wilson (Z-15) 138 kV circuit		AEC (1.00%) / APS (66.39%) / BGE (4.62%) / DOM (8.84%) / DPL (5.85%) / Neptune (0.12%) / PECO (3.40%) / PEPCO (6.32%) / PSEG (3.46%)
b3011.7 Replace the line terminal equipment and line breaker #85 at Dravosburg 138 kV substation in the Elwyn Z-70 line position/bay, with the breaker duty as 63kA		DL (100%)
b3012.2 Construct two new ties from a new FirstEnergy substation to a new Duquesne substation by using two separate structures – Duquesne portion		ATSI (38.21%) / DL (61.79%)
b3012.4 Establish the new tie line in place of the existing Elrama – Mitchell 138 kV line		DL (100%)
b3015.1 Construct new Elrama 138 kV substation and connect 7 138 kV lines to new substation		DL (100%)
b3015.2 Reconductor Elrama to Wilson 138 kV line. 4.8 miles		DL (100%)
b3015.3 Reconductor Dravosburg to West Mifflin 138 kV line. 3 miles		DL (100%)
b3015.4 Run new conductor on existing tower to establish the new Dravosburg – Elrama (Z-75) circuit. 10 miles		DL (100%)

Duquesne Light Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3015.5	Reconductor Elrama to Mitchell 138 kV line – DL portion. 4.2 miles total. 2x795 ACSS/TW 20/7	DL (100%)
b3015.7	Reconductor Wilson to West Mifflin 138 kV line. 2 miles. 795 ACSS/TW 20/7	DL (100%)
b3061	Reconductor the West Mifflin – Dravosburg (Z-73) and Dravosburg – Elrama (Z-75) 138 kV lines	DL (100%)
b3062	Install 138 kV tie breaker at West Mifflin	DL (100%)
b3063	Reconductor the Wilson – Dravosburg (Z-72) 138 kV line (approx. 5 miles)	DL (100%)
b3064	Expand Elrama 138 kV substation to loop in existing US Steel Clariton – Piney Fork 138 kV line	DL (100%)
b3064.2	Replace the West Mifflin 138 kV breakers “Z-94”, “Z-74”, “Z-14”, and “Z-13” with 63 kA breakers	DL (100%)
b3065	Install 138 kV tie breaker at Wilson	DL (100%)
b3084	Reconductor the Oakland – Panther Hollow 138 kV line (approx. 1 mile)	DL (100%)

SCHEDULE 12 – APPENDIX A

(20) Virginia Electric and Power Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b1698.7	Replace Loudoun 230 kV breaker '203052' with 63kA rating	Dominion (100%)
b1696.1	Replace the Idylwood 230 kV '25112' breaker with 50kA breaker	Dominion (100%)
b1696.2	Replace the Idylwood 230 kV '209712' breaker with 50kA breaker	Dominion (100%)
b1793.1	Remove the Carolina 22 SPS to include relay logic changes, minor control wiring, relay resets and SCADA programming upon completion of project	Dominion (100%)
b2281	Additional Temporary SPS at Bath County	Dominion (100%)
b2350	Reconductor 211 feet of 545.5 ACAR conductor on 59 Line Elmont - Greenwood DP 115 kV to achieve a summer emergency rating of 906 amps or greater	Dominion (100%)
b2358	Install a 230 kV 54 MVAR capacitor bank on the 2016 line at Harmony Village Substation	Dominion (100%)
b2359	Wreck and rebuild approximately 1.3 miles of existing 230 kV line between Cochran Mill - X4-039 Switching Station	Dominion (100%)
b2360	Build a new 39 mile 230 kV transmission line from Dooms - Lexington on existing right-of-way	Dominion (100%)
b2361	Construct 230 kV OH line along existing Line #2035 corridor, approx. 2.4 miles from Idylwood - Dulles Toll Road (DTR) and 2.1 miles on new right-of-way along DTR to new Scott's Run Substation	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2368	Replace the Brambleton 230 kV breaker '209502' with 63kA breaker	Dominion (100%)
b2369	Replace the Brambleton 230 kV breaker '213702' with 63kA breaker	Dominion (100%)
b2370	Replace the Brambleton 230 kV breaker 'H302' with 63kA breaker	Dominion (100%)
b2373	Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line	Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)
		DFAX Allocation: Dominion (100%)
b2397	Replace the Beaumeade 230 kV breaker '2079T2116' with 63kA	Dominion (100%)
b2398	Replace the Beaumeade 230 kV breaker '2079T2130' with 63kA	Dominion (100%)
b2399	Replace the Beaumeade 230 kV breaker '208192' with 63kA	Dominion (100%)
b2400	Replace the Beaumeade 230 kV breaker '209592' with 63kA	Dominion (100%)
b2401	Replace the Beaumeade 230 kV breaker '211692' with 63kA	Dominion (100%)
b2402	Replace the Beaumeade 230 kV breaker '227T2130' with 63kA	Dominion (100%)
b2403	Replace the Beaumeade 230 kV breaker '274T2130' with 63kA	Dominion (100%)

The Annual Revenue Requirement for all Virginia Electric and Power Company projects in this Section 20 shall be as specified in Attachment 7 to Appendix A of Attachment H-16A and under the procedures detailed in Attachment H-16B.

*Neptune Regional Transmission System, LLC

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2404	Replace the Beaumeade 230 kV breaker '227T2095' with 63kA	Dominion (100%)
b2405	Replace the Pleasant view 230 kV breaker '203T274' with 63kA	Dominion (100%)
b2443	Construct new underground 230 kV line from Glebe to Station C, rebuild Glebe Substation, construct 230 kV high side bus at Station C with option to install 800 MVA PAR	Dominion (97.11%) / ME (0.18%) / PEPCO (2.71%)
b2443.1	Replace the Idylwood 230 kV breaker '203512' with 50kA	Dominion (100%)
b2443.2	Replace the Ox 230 kV breaker '206342' with 63kA breaker	Dominion (100%)
b2443.3	Glebe – Station C PAR	DFAX Allocation: Dominion (22.57%) / PEPCO (77.43%)
b2443.6	Install a second 500/230 kV transformer at Possum Point substation and replace bus work and associated equipment as needed	Dominion (100%)
b2443.7	Replace 19 63kA 230 kV breakers with 19 80kA 230 kV breakers	Dominion (100%)
b2457	Replace 24 115 kV wood h-frames with 230 kV Dominion pole H-frame structures on the Clubhouse – Purdy 115 kV line	Dominion (100%)
b2458.1	Replace 12 wood H-frame structures with steel H-frame structures and install shunts on all conductor splices on Carolina – Woodland 115 kV	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2458.2	Upgrade all line switches and substation components at Carolina 115 kV to meet or exceed new conductor rating of 174 MVA	Dominion (100%)
b2458.3	Replace 14 wood H-frame structures on Carolina – Woodland 115 kV	Dominion (100%)
b2458.4	Replace 2.5 miles of static wire on Carolina – Woodland 115 kV	Dominion (100%)
b2458.5	Replace 4.5 miles of conductor between Carolina 115 kV and Jackson DP 115 kV with min. 300 MVA summer STE rating; Replace 8 wood H-frame structures located between Carolina and Jackson DP with steel H-frames	Dominion (100%)
b2460.1	Replace Hanover 230 kV substation line switches with 3000A switches	Dominion (100%)
b2460.2	Replace wave traps at Four River 230 kV and Elmont 230 kV substations with 3000A wave traps	Dominion (100%)
b2461	Wreck and rebuild existing Remington CT – Warrenton 230 kV (approx. 12 miles) as a double-circuit 230 kV line	Dominion (100%)
b2461.1	Construct a new 230 kV line approximately 6 miles from NOVEC's Wheeler Substation a new 230 kV switching station in Vint Hill area	Dominion (100%)
b2461.2	Convert NOVEC's Gainesville – Wheeler line (approximately 6 miles) to 230 kV	Dominion (100%)
b2461.3	Complete a Vint Hill – Wheeler – Loudoun 230 kV networked line	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2471	Replace Midlothian 500 kV breaker 563T576 and motor operated switches with 3 breaker 500 kV ring bus. Terminate Lines # 563 Carson – Midlothian, #576 Midlothian –North Anna, Transformer #2 in new ring	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: Dominion (100%)</p>
b2504	Rebuild 115 kV Line #32 from Halifax-South Boston (6 miles) for min. of 240 MVA and transfer Welco tap to Line #32. Moving Welco to Line #32 requires disabling auto-sectionalizing scheme	Dominion (100%)
b2505	Install structures in river to remove the 115 kV #65 line (Whitestone-Harmony Village 115 kV) from bridge and improve reliability of the line	Dominion (100%)
b2542	Replace the Loudoun 500 kV ‘H2T502’ breaker with a 50kA breaker	Dominion (100%)
b2543	Replace the Loudoun 500 kV ‘H2T584’ breaker with a 50kA breaker	Dominion (100%)
b2565	Reconductor wave trap at Carver Substation with a 2000A wave trap	Dominion (100%)
b2566	Reconductor 1.14 miles of existing line between ACCA and Hermitage and upgrade associated terminal equipment	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2582	Rebuild the Elmont – Cunningham 500 kV line	Dominion (100%)
b2583	Install 500 kV breaker at Ox Substation to remove Ox Tx#1 from H1T561 breaker failure outage.	Dominion (100%)
b2584	Relocate the Bremo load (transformer #5) to #2028 (Bremo-Charlottesville 230 kV) line and Cartersville distribution station to #2027 (Bremo-Midlothian 230 kV) line	Dominion (100%)
b2585	Reconductor 7.63 miles of existing line between Cranes and Stafford, upgrade associated line switches at Stafford	DFAX Allocation: PEPCO (100%)
b2620	Wreck and rebuild the Chesapeake – Deep Creek – Bowers Hill – Hodges Ferry 115 kV line; minimum rating 239 MVA normal/emergency, 275 MVA load dump rating	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2622	Rebuild Line #47 between Kings Dominion 115 kV and Fredericksburg 115 kV to current standards with summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2623	Rebuild Line #4 between Bremo and Structure 8474 (4.5 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2624	Rebuild 115 kV Lines #18 and #145 between Possum Point Generating Station and NOVEC's Smoketown DP (approx. 8.35 miles) to current 230 kV standards with a normal continuous summer rating of 524 MVA at 115 kV	Dominion (100%)
b2625	Rebuild 115 kV Line #48 between Thole Street and Structure 48/71 to current standard. The remaining line to Sewells Point is 2007 vintage. Rebuild 115 kV Line #107 line, Sewells Point to Oakwood, between structure 107/17 and 107/56 to current standard.	Dominion (100%)
b2626	Rebuild 115 kV Line #34 between Skiffes Creek and Yorktown and the double circuit portion of 115 kV Line #61 to current standards with a summer emergency rating of 353 MVA at 115 kV	Dominion (100%)
b2627	Rebuild 115 kV Line #1 between Crewe 115 kV and Fort Pickett DP 115 kV (12.2 miles) to current standards with summer emergency rating of 261 MVA at 115 kV	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2628	Rebuild 115 kV Line #82 Everetts – Voice of America (20.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2629	Rebuild the 115 kV Lines #27 and #67 lines from Greenwich 115 kV to Burton 115 kV Structure 27/280 to current standard with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2630	Install circuit switchers on Gravel Neck Power Station GSU units #4 and #5. Install two 230 kV CCVT's on Lines #2407 and #2408 for loss of source sensing	Dominion (100%)
b2636	Install three 230 kV bus breakers and 230 kV, 100 MVAR Variable Shunt Reactor at Dahlgren to provide line protection during maintenance, remove the operational hazard and provide voltage reduction during light load conditions	Dominion (100%)
b2647	Rebuild Boydton Plank Rd – Kerr Dam 115 kV Line #38 (8.3 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2648	Rebuild Carolina – Kerr Dam 115 kV Line #90 (38.7 miles) to current standards with summer emergency rating of 353 MVA 115 kV.	Dominion (100%)
b2649	Rebuild Clubhouse – Carolina 115 kV Line #130 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2649.1	Rebuild of 1.7 mile tap to Metcalf and Belfield DP (MEC) due to poor condition. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2649.2	Rebuild of 4.1 mile tap to Brinks DP (MEC) due to wood poles built in 1962. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR and 393.6 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor	Dominion (100%)
b2650	Rebuild Twittys Creek – Pamplin 115 kV Line #154 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2651	Rebuild Buggs Island – Plywood 115 kV Line #127 (25.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV. The line should be rebuilt for 230 kV and operated at 115 kV.	Dominion (100%)
b2652	Rebuild Greatbridge – Hickory 115 kV Line #16 and Greatbridge – Chesapeake E.C. to current standard with summer emergency rating of 353 MVA at 115 kV.	Dominion (100%)
b2653.1	Build 20 mile 115 kV line from Pantego to Trowbridge with summer emergency rating of 353 MVA.	Dominion (100%)
b2653.2	Install 115 kV four-breaker ring bus at Pantego	Dominion (100%)
b2653.3	Install 115 kV breaker at Trowbridge	Dominion (100%)
b2654.1	Build 15 mile 115 kV line from Scotland Neck to S Justice Branch with summer emergency rating of 353 MVA. New line will be routed to allow HEMC to convert Dawson's Crossroads RP from 34.5 kV to 115 kV.	Dominion (100%)
b2654.2	Install 115 kV three-breaker ring bus at S Justice Branch	Dominion (100%)
b2654.3	Install 115 kV breaker at Scotland Neck	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2665	Rebuild the Cunningham – Dooks 500 kV line	Dominion (100%)
b2686	Pratts Area Improvement	Dominion (100%)
b2686.1	Build a 230 kV line from Remington Substation to Gordonsville Substation utilizing existing ROW	Dominion (100%)
b2686.2	Install a 3rd 230/115 kV transformer at Gordonsville Substation	Dominion (100%)
b2686.3	Upgrade Line 2088 between Gordonsville Substation and Louisa CT Station	Dominion (100%)
b2686.4	Replace the Remington CT 230 kV breaker “2114T2155” with a 63 kA breaker	Dominion (100%)
b2686.11	Upgrading sections of the Gordonsville – Somerset 115 kV circuit	Dominion (100%)
b2686.12	Upgrading sections of the Somerset – Doubleday 115 kV circuit	Dominion (100%)
b2686.13	Upgrading sections of the Orange – Somerset 115 kV circuit	Dominion (100%)
b2686.14	Upgrading sections of the Mitchell – Mt. Run 115 kV circuit	Dominion (100%)

*Neptune Regional Transmission System, LLC

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
b2717.1	De-energize Davis – Rosslyn #179 and #180 69 kV lines		Dominion (100%)
b2717.2	Remove splicing and stop joints in manholes		Dominion (100%)
b2717.3	Evacuate and dispose of insulating fluid from various reservoirs and cables		Dominion (100%)
b2717.4	Remove all cable along the approx. 2.5 mile route, swab and cap-off conduits for future use, leave existing communication fiber in place		Dominion (100%)
b2719.1	Expand Perth substation and add a 115 kV four breaker ring		Dominion (100%)
b2719.2	Extend the Hickory Grove DP tap 0.28 miles to Perth and terminate it at Perth		Dominion (100%)
b2719.3	Split Line #31 at Perth and terminate it into the new ring bus with 2 breakers separating each of the line terminals to prevent a breaker failure from taking out both 115 kV lines		Dominion (100%)
b2720	Replace the Loudoun 500 kV 'H1T569' breakers with 50kA breaker		Dominion (100%)
b2729	Optimal Capacitors Configuration: New 175 MVAR capacitor at Brambleton, new 175 MVAR capacitor at Ashburn, new 300 MVAR capacitor at Shelhorn, new 150 MVAR capacitor at Liberty		AEC (1.97%) / BGE (14.46%) / Dominion (35.33%) / DPL (3.78%) / JCPL (3.33%) / ME (2.53%) / Neptune (0.63%) / PECO (6.30%) / PEPCO (20.36%) / PPL (3.97%) / PSEG (7.34%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2744	Rebuild the Carson – Rogers Rd 500 kV circuit	Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%) DFAX Allocation: Dominion (100%)
b2745	Rebuild 21.32 miles of existing line between Chesterfield – Lakeside 230 kV	Dominion (100%)
b2746.1	Rebuild Line #137 Ridge Rd – Kerr Dam 115 kV, 8.0 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.2	Rebuild Line #1009 Ridge Rd – Chase City 115 kV, 9.5 miles, for 346 MVA summer emergency rating	Dominion (100%)
b2746.3	Install a second 4.8 MVAR capacitor bank on the 13.8 kV bus of each transformer at Ridge Rd	Dominion (100%)
b2747	Install a Motor Operated Switch and SCADA control between Dominion's Gordonsville 115 kV bus and FirstEnergy's 115 kV line	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2757	Install a +/-125 MVAR Statcom at Colington 230 kV	Dominion (100%)
b2758	Rebuild Line #549 Doods – Valley 500kV	Dominion (100%)
b2759	Rebuild Line #550 Mt. Storm – Valley 500kV	Dominion (100%)
b2800	The 7 mile section from Dozier to Thompsons Corner of line #120 will be rebuilt to current standards using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Line is proposed to be rebuilt on single circuit steel monopole structure	Dominion (100%)
b2801	Lines #76 and #79 will be rebuilt to current standard using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Proposed structure for rebuild is double circuit steel monopole structure	Dominion (100%)
b2802	Rebuild Line #171 from Chase City – Boynton Plank Road tap by removing end-of-life facilities and installing 9.4 miles of new conductor. The conductor used will be at current standards with a summer emergency rating of 393 MVA at 115kV	Dominion (100%)
b2815	Build a new Pinewood 115kV switching station at the tap serving North Doswell DP with a 115kV four breaker ring bus	Dominion (100%)
b2842	Update the nameplate for Mount Storm 500 kV "57272" to be 50kA breaker	Dominion (100%)
b2843	Replace the Mount Storm 500 kV "G2TY" with 50kA breaker	Dominion (100%)
b2844	Replace the Mount Storm 500 kV "G2TZ" with 50kA breaker	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2845	Update the nameplate for Mount Storm 500 kV "G3TSX1" to be 50kA breaker	Dominion (100%)
b2846	Update the nameplate for Mount Storm 500 kV "SX172" to be 50kA breaker	Dominion (100%)
b2847	Update the nameplate for Mount Storm 500 kV "Y72" to be 50kA breaker	Dominion (100%)
b2848	Replace the Mount Storm 500 kV "Z72" with 50kA breaker	Dominion (100%)
b2871	Rebuild 230 kV line #247 from Swamp to Suffolk (31 miles) to current standards with a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2876	Rebuild line #101 from Mackeys – Creswell 115 kV, 14 miles, with double circuit structures. Install one circuit with provisions for a second circuit. The conductor used will be at current standards with a summer emergency rating of 262 MVA at 115 kV	Dominion (100%)
b2877	Rebuild line #112 from Fudge Hollow – Lowmoor 138 kV (5.16 miles) to current standards with a summer emergency rating of 314 MVA at 138 kV	Dominion (100%)
b2899	Rebuild 230 kV line #231 to current standard with a summer emergency rating of 1046 MVA. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2900	Build a new 230/115 kV switching station connecting to 230 kV network line #2014 (Earleys – Everetts). Provide a 115 kV source from the new station to serve Windsor DP	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2922	Rebuild 8 of 11 miles of 230 kV lines #211 and #228 to current standard with a summer emergency rating of 1046 MVA for rebuilt section. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2928	Rebuild four structures of 500 kV line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the line #567 line rating from 1954 MVA to 2600 MVA	Dominion (100%)
b2929	Rebuild 230 kV line #2144 from Winfall to Swamp (4.3 miles) to current standards with a standard conductor (bundled 636 ACSR) having a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2960	Replace fixed series capacitors on 500 kV Line #547 at Lexington and on 500 kV Line #548 at Valley	Dominion (100%)
b2961	Rebuild approximately 3 miles of Line #205 & Line #2003 from Chesterfield to Locks & Poe respectively	Dominion (100%)
b2962	Split Line #227 (Brambleton – Beaumeade 230 kV) and terminate into existing Belmont substation	Dominion (100%)
b2962.1	Replace the Beaumeade 230 kV breaker “274T2081” with 63kA breaker	Dominion (100%)
b2962.2	Replace the NIVO 230 kV breaker “2116T2130” with 63kA breaker	Dominion (100%)
b2963	Reconductor the Woodbridge to Occoquan 230 kV line segment of Line #2001 with 1047 MVA conductor and replace line terminal equipment at Possum Point, Woodbridge, and Occoquan	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2978	Install 2-125 MVAR STATCOMs at Rawlings and 1-125 MVAR STATCOM at Clover 500 kV substations	<p>Load-Ratio Share Allocation: AEC (1.61%) / AEP (14.10%) / APS (5.79%) / ATSI (7.95%) / BGE (4.11%) / ComEd (13.24%) / Dayton (2.07%) / DEOK (3.22%) / DL (1.73%) / DPL (2.48%) / Dominion (13.17%) / EKPC (2.13%) / JCPL (3.71%) / ME (1.88%) / NEPTUNE* (0.42%) / PECO (5.34%) / PENELEC (1.86%) / PEPCO (3.98%) / PPL (4.76%) / PSEG (6.19%) / RE (0.26%)</p> <p>DFAX Allocation: Dominion (100%)</p>
b2980	Rebuild 115 kV Line #43 between Staunton and Harrisonburg (22.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV	Dominion (100%)
b2981	Rebuild 115 kV Line #29 segment between Fredericksburg and Aquia Harbor to current 230 kV standards (operating at 115 kV) utilizing steel H-frame structures with 2-636 ACSR to provide a normal continuous summer rating of 524 MVA at 115 kV (1047 MVA at 230 kV)	Dominion (100%)

*Neptune Regional Transmission System, LLC

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2989	Install a second 230/115 kV Transformer (224 MVA) approximately 1 mile north of Bremono and tie 230 kV Line #2028 (Bremono – Charlottesville) and 115 kV Line #91 (Bremono - Sherwood) together. A three breaker 230 kV ring bus will split Line #2028 into two lines and Line #91 will also be split into two lines with a new three breaker 115 kV ring bus. Install a temporary 230/115 kV transformer at Bremono substation for the interim until the new substation is complete	Dominion (100%)
b2990	Chesterfield to Basin 230 kV line – Replace 0.14 miles of 1109 ACAR with a conductor which will increase the line rating to approximately 706 MVA	Dominion (100%)
b2991	Chaparral to Locks 230 kV line – Replace breaker lead	Dominion (100%)
b2994	Acquire land and build a new switching station (Skippers) at the tap serving Brink DP with a 115 kV four breaker ring to split Line #130 and terminate the end points	Dominion (100%)
b3018	Rebuild Line #49 between New Road and Middleburg substations with single circuit steel structures to current 115 kV standards with a minimum summer emergency rating of 261 MVA	Dominion (100%)
b3019	Rebuild 500 kV Line #552 Bristers to Chancellor – 21.6 miles long	Dominion (100%)
b3019.1	Update the nameplate for Morrisville 500 kV breaker “H1T594” to be 50kA	Dominion (100%)
b3019.2	Update the nameplate for Morrisville 500 kV breaker “H1T545” to be 50kA	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3020	Rebuild 500 kV Line #574 Ladysmith to Elmont – 26.2 miles long	Dominion (100%)
b3021	Rebuild 500 kV Line #581 Ladysmith to Chancellor – 15.2 miles long	Dominion (100%)
b3026	Reconductor Line #274 (Pleasant View – Ashburn – Beaumeade 230 kV) with a minimum rating of 1200 MVA. Also upgrade terminal equipment	Dominion (100%)
b3027.1	Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith substation	Dominion (100%)
b3027.2	Reconductor 230 kV Line #2089 between Ladysmith and Ladysmith CT substations to increase the line rating from 1047 MVA to 1225 MVA	Dominion (100%)
b3027.3	Replace the Ladysmith 500 kV breaker "H1T581" with 50kA breaker	Dominion (100%)
b3027.4	Update the nameplate for Ladysmith 500 kV breaker "H1T575" to be 50kA breaker	Dominion (100%)
b3027.5	Update the nameplate for Ladysmith 500 kV breaker "568T574" (will be renumbered as "H2T568") to be 50kA breaker	Dominion (100%)
b3055	Install spare 230/69 kV transformer at Davis substation	Dominion (100%)
b3056	Partial rebuild 230 kV Line #2113 Waller to Lightfoot	Dominion (100%)
b3057	Rebuild 230 kV Lines #2154 and #19 Waller to Skiffes Creek	Dominion (100%)
b3058	Partial rebuild of 230 kV Lines #265, #200 and #2051	Dominion (100%)
b3059	Rebuild 230 kV Line #2173 Loudoun to Ellick	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3060	Rebuild 4.6 mile Elklick – Bull Run 230 kV Line #295 and the portion (3.85 miles) of the Clifton – Walney 230 kV Line #265 which shares structures with Line #295	Dominion (100%)
b3088	Rebuild 4.75 mile section of Line #26 between Lexington and Rockbridge with a minimum summer emergency rating of 261 MVA	Dominion (100%)
b3089	Rebuild 230 kV Line #224 between Lanexa and Northern Neck utilizing double circuit structures to current 230 kV standards. Only one circuit is to be installed on the structures with this project with a minimum summer emergency rating of 1047 MVA	Dominion (100%)
b3090	Convert the overhead portion (approx. 1500 feet) of 230 kV Lines #248 & #2023 to underground and convert Glebe substation to gas insulated substation	Dominion (100%)
b3096	Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA	Dominion (100%)
b3097	Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA	Dominion (100%)
b3098	Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115 kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA	Dominion (100%)

Virginia Electric and Power Company (cont.)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3110.1	Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation	Dominion (100%)
b3110.2	Replace the Bull Run 230 kV breakers “200T244” and “200T295” with 50 kA breakers	Dominion (100%)
b3113	Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings	Dominion (100%)
b3114	Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change	Dominion (100%)