

PJM Interconnection, L.L.C. 2750 Monroe Blvd. Audubon, PA 19403

Alejandro Bautista Counsel T: (610) 635-3447 | F: (610) 666-8211 alejandro.bautista@pjm.com

March 12, 2021

Honorable Kimberly D. Bose, Secretary Federal Energy Regulatory Commission 888 First Street, N.E., Room 1A Washington, D.C. 20426

Re: PJM Interconnection, L.L.C., Docket No. ER21-1364-000

[30-Day Comment Period Requested]

Dear Secretary Bose:

In accordance with PJM Open Access Transmission Tariff ("Tariff"), Schedule 12¹ and Amended and Restated Operating Agreement of PJM Interconnection, L.L.C. ("Operating Agreement"), Schedule 6, section 1.6, and pursuant to section 205 of the Federal Power Act,² PJM Interconnection, L.L.C. ("PJM") hereby submits amendments to Tariff, Schedule 12-Appendix A to incorporate cost responsibility assignments for 69 baseline upgrades in the recent update to the Regional Transmission Expansion Plan ("RTEP") approved by the PJM Board of Managers ("PJM Board") on February 10, 2021.³ PJM requests that the revised Tariff sections become effective on June 10, 2021, 90 days after the date of this filing.

¹ All capitalized terms that are not otherwise defined herein have the meaning as defined in the Tariff, Operating Agreement, and Reliability Assurance Agreement among Load Serving Entities in the PJM Region.

² 16 U.S.C. § 824d.

³ The 69 baseline upgrades approved by the PJM Board on February 10, 2021 with estimated costs totaling \$327.79 million include the following: (i) 66 new transmission system enhancements and expansions with an estimated cost of \$299.23 million; and (ii) three baseline upgrades, b2779.6, b2779.7 and b3213.1, that are scope changes to existing baseline projects b2779 and b3213 with an estimated cost of \$28.56 million.

I. DESCRIPTION OF FILING

A. Tariff, Schedule 12 Requirements to Designate Cost Responsibility Assignments

Pursuant to Tariff, Schedule 12, PJM is required to designate in Tariff, Schedule 12-Appendix A, cost responsibility assignments for all transmission enhancements and expansions included in the RTEP after February 1, 2013.⁴ Similarly, Tariff, Schedule 12 requires that within 30 days of the PJM Board's approval of each RTEP, or addition to the RTEP, PJM shall designate in Tariff, Schedule 12-Appendix A, and in a report filed with the Federal Energy Regulatory Commission ("Commission"), the "Responsible Customers"⁵ that will be subject to charges related to transmission enhancements and expansions included in the RTEP.⁶ Tariff, Schedule 12 further provides that customers designated to be responsible for assignments of costs that PJM files with the Commission shall have 30 days from the date of such filing to submit comments regarding the proposed cost responsibility assignments.⁷

Accordingly, PJM hereby submits amendments to Tariff, Schedule 12-Appendix A to include the new cost responsibility assignments for RTEP upgrades approved by the PJM Board on February 10, 2021. The revised Tariff sections containing new language, including new cost

⁴ *PJM Interconnection, L.L.C.*, 142 FERC ¶ 61,214 at PP 411, 448 (2013) (accepting revisions to Tariff, Schedule 12 modifying the cost allocation methodologies for transmission projects included in the RTEP, effective February 1, 2013).

⁵ Responsible Customers include "the customers using Point-to-Point Transmission Service and/or Network Integration Transmission Service and Merchant Transmission Facility owners that will be subject to each such Transmission Enhancement Charge." *See* Tariff, Schedule 12, section (b)(viii).

⁶ *Id.*; *see also* Operating Agreement, Schedule 6, section 1.6.

⁷ See Tariff, Schedule 12, section (b)(viii).

responsibility assignments, are reflected in redline and clean format in Attachments B and C, respectively, to this filing.⁸

1. Assignment of Cost Responsibility for Regional Facilities

The new transmission enhancements or expansions included in this most recent update to the RTEP approved by the PJM Board on February 10, 2021 are not Regional Facilities or Necessary Lower Voltage Facilities.⁹ Thus, PJM does not include any cost responsibility assignments for such facilities in Tariff, Schedule 12-Appendix A with this filing.

- 2. Assignments of Cost Responsibility for Lower Voltage Facilities Needed for Reliability
 - a. Cost Responsibility Assignments that Address Transmission Enhancements Costing More than \$5 Million and Require DFAX Analysis

Consistent with Tariff, Schedule 12, PJM submits amendments to the Tariff, Schedule 12-

Appendix A to include the cost responsibility assignments for transmission enhancements or expansions that are Lower Voltage Facilities.¹⁰ Twenty-five (25) enhancements or expansions¹¹ included in this filing, approved by the PJM Board on February 10, 2021, are Lower Voltage

⁸ The revised Tariff sections do not include any proposed rates or charges for recovery of any system upgrade costs. In accordance with Tariff, Schedule 12, recovery of the costs of such facilities that the RTEP requires Transmission Owners to construct, own and/or finance is governed by the Transmission Owners' established rates.

⁹ As defined in PJM Tariff, Schedule 12, section (b)(i), Regional Facilities include transmission enhancements and expansions that, among other things, will operate at or above 500 kV or will be double-circuit 345 kV facilities; and Necessary Lower Voltage Facilities include transmission enhancements and expansions that operate below 500 kV, or 345 kV in the case of double-circuit 345 kV facilities, that must be constructed or strengthened to support new Regional Facilities.

¹⁰ See Tariff, Schedule 12, section (b)(ii)(A) ("If the Lower Voltage Facility is a Reliability Project, [PJM] shall use the DFAX analysis described in section (b)(iii) of this Schedule 12"). As defined in PJM Tariff, Schedule 12, section (b)(ii), Lower Voltage Facilities include transmission enhancements and expansions that are not Regional Facilities and are not Necessary Lower Voltage Facilities.

¹¹ The Lower Voltage Facilities include the following: b2779.6, b2779.7, b3123, b3246.1, b3246.2, b3246.3, b3246.4, b3246.5, b3273.1, b3273.2, b3273.3, b3273.4, b3274, b3276.1, b3276.2, b3276.3, b3303.1, b3303.2, b3304, b3304.1, b3304.2, b3304.3, b3304.4, b3306, and b3312.

Facilities required to address reliability needs for which PJM applied the solution-based DFAX analysis described in Tariff, Schedule 12, section (b)(iii).

b. Cost Responsibility Assignments that Address Transmission Enhancements Costing Less than \$5 Million

Tariff, Schedule 12, section (b)(vi) provides that, notwithstanding Tariff, Schedule 12, sections (b)(i), (b)(ii), (b)(iv) and (b)(v), cost responsibility for an enhancement or expansion for which the good faith estimate of the cost of such enhancement or expansion included for the first time in the RTEP does not equal or exceed \$5 million shall be assigned to the zone where the enhancement or expansion is to be located. Consistent with Tariff, Schedule 12, section (b)(vi), PJM proposes revisions to Tariff, Schedule 12-Appendix A to include cost responsibility assignments for thirty-four (34) enhancements or expansions needed for reliability.¹² Therefore, consistent with Tariff, Schedule 12, section (b)(vi), cost responsibility for such enhancements or expansions shall be allocated 100 percent to the zone of the Transmission Owner where the enhancements or expansions are to be located.

c. Cost Responsibility Assignments that Address Spare Parts, Replacement Equipment and Circuit Breakers

Tariff, Schedule 12, section (b)(iv)(C) provides that cost responsibility for circuit breakers and associated equipment independently included in the RTEP and not a part of the design specifications of a transmission element of a Required Transmission Enhancement shall be assigned to the zone of the owner of the circuit breakers and associated equipment, if the owner of the circuit breakers and associated equipment is a Transmission Owner listed in Tariff,

¹² The enhancements and expansions allocated pursuant to Tariff, Schedule 12, section (b)(vi) include the following: b3222, b3224, b3226, b3228, b3230, b3233, b3234, b3235, b3236, b3237, b3240, b3241, b3243, b3248, b3253, b3255, b3256, b3257, b3258, b3259, b3265, b3266, b3267, b3275.1, b3275.2, b3275.3, b3275.4, b3275.5, b3275.6, b3275.7, b3300, b3301, b3302, and b3305.

Attachment J. PJM proposes revisions to Tariff, Schedule 12-Appendix A to include cost responsibility assignment for six (6) enhancements needed to address standalone circuit breakers and associated equipment.¹³ Therefore, consistent with Tariff, Schedule 12, section (b)(iv)(C), cost responsibility for such enhancements shall be allocated 100 percent to the zone of the Transmission Owner of the circuit breaker and associated equipment.

d. Cost Responsibility Assignments for Transmission Enhancements that Address Reliability Violations on Transmission Facilities Operating At or Below 200 kV

Tariff, Schedule 12, section (b)(xvi), provides that solutions for reliability violations on a facility operating at or below 200 kV not included in a competitive proposal window pursuant to Operating Agreement, Schedule 6, section 1.5.8(c) will be allocated 100 percent to the zone in which the transmission facilities are located.¹⁴ Consistent with Tariff, Schedule 12, section (b)(xvi), PJM proposes revisions to Tariff, Schedule 12-Appendix A to include cost responsibility assignments for four (4) reliability enhancements to address reliability violations on transmission facilities operating at or below 200 kV that were not included in a competitive proposal window.¹⁵ Therefore, consistent with Tariff, Schedule 12, section (b)(xvi), cost responsibility for such enhancements shall be allocated 100 percent to the zone in which the facilities are to be located.

¹³ The enhancements and expansions allocated pursuant to Tariff, Schedule 12, section (b)(iv) include the following: b3213.1, b3231, b3232, b3238, b3239, and b3277.

¹⁴ *PJM Interconnection, L.L.C.*, 158 FERC ¶ 61,124 (2017) (accepting Tariff, Schedule 12, section (b)(xvi) cost allocation methodology, effective August 26, 2016, to assign costs of projects exempted from a proposal window pursuant to Operating Agreement, Schedule 6, section 1.5.8(n) 100 percent to the zone in which the transmission facilities will be located).

¹⁵ The baseline upgrades addressing reliability violations on transmission facilities operating at or below 200 kV not included in a competitive proposal window include the following: b3227, b3242, b3244, and b3245.

B. Cost Responsibility Assignment Summary

For informational purposes, PJM also includes as Attachment A to this filing a Cost Responsibility Assignment Summary for the enhancements or expansions approved by the PJM Board on February 10, 2021. In addition to specifying the cost responsibility assignments for the enhancements or expansions, the summary sheets provide the criteria violation and test, a description of the upgrade, in-service date, estimated upgrade costs, and the entity designated with construction responsibility for each enhancement or expansion.

II. COMMENT PERIOD

Tariff, Schedule 12, section (b)(viii) provides that customers designated to be responsible for assignments of cost responsibility shall have 30 days from the date of such filing to seek review regarding the proposed cost responsibility assignments. Consistent with this provision, PJM requests that the comment date for this filing be set 30 days from the date of this filing, April 11, 2021.¹⁶ To accommodate such a comment date, PJM requests an effective date of June 10, 2021 (90 days from the date of this filing) for all revised Tariff sections submitted in this docket.¹⁷

III. DOCUMENTS ENCLOSED

PJM encloses the following:

- 1. This transmittal letter;
- 2. Attachment A Cost Responsibility Assignment Summary Sheets;

¹⁶ Because April 11, 2021 falls on a Sunday, comments would be due on Monday, April 12, 2021. *See* 18 C.F.R. § 385.2007 (a)(2) (2020).

¹⁷ See, e.g., PJM Interconnection, L.L.C., Errata Notice of Extending Comment Period, Docket Nos. ER06-456-018, *et al.* (Dec. 2, 2008) (granting extension of time for filing protests or comments to accommodate Tariff, Schedule 12 of the PJM Tariff); *PJM Interconnection, L.L.C.*, Errata Notice Extending Comment Date, Docket No. ER08-229-000 (Nov. 30, 2007) (same); *PJM Interconnection, L.L.C.*, Notice Extending Comment Date, Docket No. ER07-1186-000 (July 31, 2007) (same).

- 3. Attachment B Revised Tariff, Schedule 12-Appendix A (in redlined form); and
- 4. Attachment C Revised Tariff, Schedule 12-Appendix A (in clean form).

IV. CORRESPONDENCE AND COMMUNICATIONS

Correspondence and communications with respect to this filing should be sent to the

following persons:

Craig Glazer Vice President – Federal Government Policy PJM Interconnection, L.L.C. 1200 G Street, N.W., Suite 600 Washington, D.C. 20005 Ph: (202) 423-4743 Fax: (202) 393-7741 craig.glazer@pjm.com

Pauline Foley Associate General Counsel PJM Interconnection, L.L.C. 2750 Monroe Blvd. Audubon, PA 19403 Ph: (610) 666-8248 Fax: (610) 666-8211 pauline.foley@pim.com Alejandro Bautista Counsel PJM Interconnection, L.L.C. 2750 Monroe Blvd. Audubon, PA 19403 Ph: (610) 635-3447 Fax: (610) 666-8211 alejandro.bautista@pjm.com

V. SERVICE

PJM has served a copy of this filing on all PJM Members on all state utility regulatory commissions in the PJM Region by posting this filing electronically. In accordance with the Commission's regulations,¹⁸ PJM will post a copy of this filing to the FERC filings section of its internet site, located at the following link: <u>http://www.pjm.com/documents/ferc-manuals/fercfilings.aspx</u> with a specific link to the newly-filed document, and will send an e-mail on the same date as this filing to all PJM Members and all state utility regulatory commissions in

¹⁸ See 18 C.F.R. §§ 35.2(e) and 385.2010(f)(3) (2020).

Kimberly D. Bose, Secretary March 12, 2021 Page 8

the PJM Region¹⁹ alerting them that this filing has been made by PJM and is available by following such link. If the document is not immediately available by using the referenced link, the document will be available through the referenced link within 24 hours of the filing. Also, a copy of this filing will be available on the FERC's eLibrary website located at the following link: <u>http://www.ferc.gov/docs-filing/elibrary.asp</u> in accordance with the Commission's regulations and Order No. 714.

Respectfully submitted,

Craig Glazer Vice President – Federal Government Policy PJM Interconnection, L.L.C. 1200 G Street, N.W., Suite 600 Washington, D.C. 20005 Ph: (202) 423-4743 Fax: (202) 393-7741 craig.glazer@pjm.com

Pauline Foley Associate General Counsel PJM Interconnection, L.L.C. 2750 Monroe Blvd. Audubon, PA 19403 Ph: (610) 666-8248 Fax: (610) 666-8211 pauline.foley@pjm.com By: /s/ Alejandro Bautista

Alejandro Bautista Counsel PJM Interconnection, L.L.C. 2750 Monroe Blvd. Audubon, PA 19403 Ph: (610) 635-3447 Fax: (610) 666-8211 alejandro.bautista@pjm.com

¹⁹ PJM already maintains, updates and regularly uses e-mail lists for all PJM Members and affected state commissions.

Attachment A

Cost Responsibility Assignment Summary Sheets

Baseline Upgrade b2779.6

- Overview of Reliability Problem
 - o Criteria Violation: Greater than 300 MW consequential load loss
 - Contingency: Loss of South Butler Collingwood 345 kV
 - Criteria test: Load Loss Limit (PJM Criteria)
- Overview of Reliability Solution
 - Description of Upgrade: Construct a 345 kV ring bus at Dunton Lake to serve Steel Dynamics, Inc. (SDI) load at 345 kV via two (2) circuits
 - o Required Upgrade In-Service Date: November 15, 2021
 - Estimated Upgrade Cost: \$ 23.40 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP. The upgrade benefits load entirely within the zone receiving the allocation. The distribution factor would be based on an interface entirely within the zone. Therefore no distribution factor table is provided

Baseline Upgrade b2779.7

- Overview of Reliability Problem
 - Criteria Violation: Greater than 300 MW consequential load loss
 - Contingency: Loss of the South Butler Collingwood 345 kV
 - Criteria test: Load Loss Limit (PJM Criteria)
- Overview of Reliability Solution
 - Description of Upgrade: Retire Collingwood 345 kV station
 - Required Upgrade In-Service Date: December 15, 2021
 - Estimated Upgrade Cost: \$ 1.40 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP. The upgrade benefits load entirely within the zone receiving the allocation. The distribution factor would be based on an interface entirely within the zone. Therefore no distribution factor table is provided

- Overview of Reliability Problem
 - Criteria Violation: N/A
 - Contingency: N/A
 - Criteria test: Sammis 1,2,3 and 4 deactivations
- Overview of Reliability Solution
 - Description of Upgrade: At Sammis 345 kV station: Install a new control building in the switchyard, construct a new station access road, install new switchyard power supply to separate from existing generating station power service, separate all communications circuits, and separate all protection and controls schemes
 - Required Upgrade In-Service Date: June 01, 2022
 - Estimated Upgrade Cost: \$ 15.30 M
 - Construction Responsibility: ATSI
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to ATSI. The upgrade benefits load entirely within the zone receiving the allocation. The distribution factor would be based on an interface entirely within the zone. Therefore no distribution factor table is provided

Baseline Upgrade b3213.1

- Overview of Reliability Problem
 - Criteria Violation: Over duty breaker
 - Contingency: N/A
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the eight (8) Chickahominy 230 kV breakers with 63 kA breakers:
 "SC122", "205022", "209122", 210222-2", "28722", "H222", "21922" and "287T2129"
 - Required Upgrade In-Service Date: June 01, 2023
 - Estimated Upgrade Cost: \$ 3.76 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Post contingency voltage violation on the 69 kV system along the Limestone – Lock Haven – Renovo path
 - Contingency: Multiple
 - Criteria test: PPL FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install one (1) 7.2 MVAR fixed cap bank on the Lock Haven Reno 69 kV line and one (1) 7.2 MVAR fixed cap bank on the Lock Haven – Flemington 69 kV line near the Flemington 69/12 kV substation
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.90 M
 - Construction Responsibility: PPL
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to PPL

- Overview of Reliability Problem
 - o Criteria Violation: Overload of the Mt. Pleasant Middletown Tap 138 kV line
 - o Contingency: Tower outage of both the Keeney Steele 230 kV lines
 - o Criteria test: Winter Generator Deliverability and Winter N-1 Thermal Overload
- Overview of Reliability Solution
 - Description of Upgrade: Replace a disconnect switch and reconductor a short span of the Mt. Pleasant – Middletown tap 138 kV line
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.42 M
 - Construction Responsibility: DPL
- Cost Allocation
 - \circ $\,$ $\,$ The cost for this baseline upgrade is allocated 100% to DPL $\,$

- Overview of Reliability Problem
 - Criteria Violation: Post contingency voltage violation at the Peermont and Swainton 69 kV stations
 - Contingency: Multiple
 - Criteria test: Summer N-1 Voltage Magnitude and Voltage Drop
- Overview of Reliability Solution
 - o Description of Upgrade: Add 10 MVAR 69 kV capacitor bank at Swainton substation
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 2.90 M
 - Construction Responsibility: AEC
- Cost Allocation
 - \circ ~ The cost for this baseline upgrade is allocated 100% to AEC ~

- Overview of Reliability Problem
 - Criteria Violation: Overload of the Corson Court 69 kV line for several N-1-1 outages including the Corson – Middle 138 kV line and Corson – England 138 kV line
 - Contingency: Multiple N-1-1 contingencies
 - Criteria test: Summer N-1-1 Thermal
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the Corson Court 69 kV line to achieve ratings equivalent to 795 ACSR conductor or better
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 13.20 M
 - Construction Responsibility: AEC
- Cost Allocation
 - $\circ~$ The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to AEC

- Overview of Reliability Problem
 - Criteria Violation: The Westport to Center 115 kV circuit overloaded
 - Contingency: Loss of the Brandon Shore to Riverside 230 kV circuits #2344 and #2345
 - o Criteria test: Generation Deliverability and Winter baseline
- Overview of Reliability Solution
 - Description of Upgrade: Replace two (2) relays at Center substation to increase ratings on the Westport to Center 110552 115 kV circuit
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.03 M
 - Construction Responsibility: BGE
- Cost Allocation
 - \circ $\,$ $\,$ The cost for this baseline upgrade is allocated 100% to BGE $\,$

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Multiple voltage magnitude violations in the RTEP 2025 summer N-1-1 analysis
 - Contingency: Loss of the Dutch Fork 138 kV capacitor followed by the Enon 138 kV capacitor
 - Criteria test: APS FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: At Enon substation install a second 138 kV, 28.8 MVAR nameplate, capacitor and the associated 138 kV capacitor switcher
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.80 M
 - Construction Responsibility: APS
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to APS

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Huntingdon 46 kV breaker No. 2 is overdutied
 - Contingency: N/A
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the existing No. 2 cap bank breaker at Huntingdon substation with a new breaker with higher interrupting capability
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.80 M
 - Construction Responsibility: PENELEC
- Cost Allocation
 - $_{\odot}$ $\,$ The cost for this baseline upgrade is allocated 100% to PENELEC $\,$

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Three Altoona 46 kV breakers are overdutied
 - Contingency: N/A
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the existing Williamsburg, ALH (Hollidaysburg) and bus section breaker at the Altoona substation with a new breaker with higher interrupting capability
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.70 M
 - Construction Responsibility: PENELEC
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to PENELEC

- Overview of Reliability Problem
 - Criteria Violation: Post contingency high voltage violations along the Rockwood Mayersdale North 115 kV line
 - Contingency: Multiple contingencies
 - Criteria test: Light load Voltage
- Overview of Reliability Solution
 - Description of Upgrade: Install one (1) 34 MVAR 115 kV shunt reactor and breaker. Install one (1) 115 kV circuit breaker to expand the substation to a 4-breaker ring bus
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 4.90 M
 - Construction Responsibility: PENELEC
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to PENELEC

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation High Voltages, based on ATSI TO Criteria, observed for voltage magnitude analysis of the Light Load case in the area of Pine 138 kV
 - Contingency: Multiple
 - Criteria test: ATSI FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Extend both the east and west 138 kV buses at Pine substation, and install one (1) 138 kV breaker, associated disconnect switches, and one (1) 100 MVAR reactor
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 3.80 M
 - Construction Responsibility: ATSI
- Cost Allocation
 - \circ $\,$ The cost for this baseline upgrade is allocated 100% to ATSI

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation High Voltage, based on ATSI TO Criteria, observed for voltage magnitude analysis of the Light Load case at Tangy 138 kV
 - Contingency: The loss of the Gavin Flatlick 765 kV line
 - o Criteria test: ATSI FERC FORM 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Extend 138 kV bus work to the west of Tangy substation for the addition of the 100 MVAR reactor bay and one (1) 138 kV 40 kA circuit breaker
 - \circ $\;$ Required Upgrade In-Service Date: June 01, 2025 $\;$
 - Estimated Upgrade Cost: \$ 3.70 M
 - Construction Responsibility: ATSI
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to ATSI

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation High Voltage, based on ATSI TO Criteria, observed for voltage magnitude analysis of the Light Load case around Broadview, Tech and Morefiel 138 kV buses
 - Contingency: The loss of the Edgewood Urbana 69 kV line
 - Criteria test: ATSI FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Extend the Broadview 138 kV bus by adding two (2) new breakers and associated equipment and install a 75 MVAR reactor
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 4.50 M
 - Construction Responsibility: ATSI
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to ATSI

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Post contingency voltage violation on the 46 kV system along the Hill Valley – Mount Union – Mapleton path Outline Multiple
 - Contingency: Multiple
 - Criteria test: First Energy FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install two (2) 46 kV 6.12 MVAR capacitors effective at Mt. Union
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 4.00 M
 - Construction Responsibility: PENELEC
- Cost Allocation
 - \circ $\,$ $\,$ The cost for this baseline upgrade is allocated 100% to PENELEC $\,$

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Seven (7) existing 40 kA
 Whippany 34.5 kV breakers (X76, B37 (O769), D4, F6, P142, 320BY77 and A157) are overdutied
 - Contingency: N/A
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace seven (7) overdutied 34.5 kV breakers with 50 kA rated equipment at the Whippany substation
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 8.67 M
 - Construction Responsibility: JCPL
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to JCPL

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Fourteen (14) existing 40 kA
 Freneau 34.5 kV breakers (M139A, M139B, C211, B29, V100, W101, Z104, O15, S45, F32, E31, BK1A, BK1B, BK2A and BK2B) are overdutied
 - Contingency: N/A
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace fourteen (14) overdutied 34.5 kV breakers with 63 kA rated equipment
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 5.70 M
 - Construction Responsibility: JCPL
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to JCPL

- Overview of Reliability Problem
 - Criteria Violation: Thermal violation on the Cherry Run Morgan 138 kV line
 - Contingency: Stuck breaker of the BDL3 or BDL4 500 kV breakers at Bedington substation
 - o Criteria test: Winter Generator Deliverability
- Overview of Reliability Solution
 - Description of Upgrade: Upgrade Cherry Run and Morgan terminals to make the transmission line the limiting component
 - o Required Upgrade In-Service Date: December 01, 2025
 - Estimated Upgrade Cost: \$ 0.23 M
 - Construction Responsibility: APS
- Cost Allocation
 - $_{\odot}$ $\,$ The cost for this baseline upgrade is allocated 100% to APS $\,$

- Overview of Reliability Problem
 - Criteria Violation: Low voltage violation at multiple substations
 - Contingency: Bus contingency at Junction 138 kV substation
 - Criteria test: N-1 and N-1-1 Summer Voltage Magnitude/Drop; APS Form 715 Criteria: Voltage Magnitude/Drop
- Overview of Reliability Solution
 - Description of Upgrade: Install 138 kV, 36 MVAR capacitor and a 5 uF reactor protected by a 138 kV capacitor switcher. Install a breaker on the 138 kV Junction terminal. Install a 138 kV 3.5 uF reactor on the existing Hardy 138 kV capacitor
 - \circ $\;$ Required Upgrade In-Service Date: June 01, 2025 $\;$
 - Estimated Upgrade Cost: \$ 2.85 M
 - Construction Responsibility: APS
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to APS

- Overview of Reliability Problem
 - o Criteria Violation: Low voltage violation at multiple 138 kV substations
 - Contingency: N-1-1 contingency on the Bartonville Meadowbrook and Feagans Mill -Millville 138 kV lines
 - Criteria test: N-1-1 Summer Voltage Magnitude; APS Form 715 Criteria: Voltage Magnitude/Drop
- Overview of Reliability Solution
 - Description of Upgrade: Reconfigure Stonewall 138 kV substation from its current configuration to a six-breaker, breaker-and-a-half layout and add two (2) 36 MVAR capacitors with capacitor switchers
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 13.30 M
 - Construction Responsibility: APS
- Cost Allocation
 - The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to APS

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Overload of the Bass Spy Run1 34.5 kV line
 - Contingency: Multiple N-1-1 contingencies
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - o Description of Upgrade: Replace risers at the Bass 34.5 kV station
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - \circ $\,$ $\,$ The cost for this baseline upgrade is allocated 100% to AEP $\,$

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Overload of the Harlan Robinson Park 69 kV line
 - Contingency: N-1-1 contingency pair of the loss of Sowers South Hicksville Lockwood 138 kV line with South Hicksville 138/69 kV transformer and the loss of the Auburn – Joist – Butler 69 kV line
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild approximately 9 miles of the Robinson Park Harlan 69 kV line
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 20.90 M
 - Construction Responsibility: AEP
- Cost Allocation
 - $\circ~$ The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: Post contingency voltage drop violation on the Williams 115 kV substation
 - Contingency: Line fault stuck breaker contingency loss of the Williams Tiffany Laurel Lake – Westover 115 kV circuit
 - o Criteria test: Winter Baseline Voltage Drop
- Overview of Reliability Solution
 - Description of Upgrade: Construct a new breaker-and-a-half substation near Tiffany substation. All transmission assets and lines will be relocated to the new substation. The two (2) distribution transformers will be fed via two (2) dedicated 115 kV feeds to the existing Tiffany substation
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 23.20 M
 - Construction Responsibility: PENELEC
- Cost Allocation
 - The driver for this upgrade is less than 200 kV. The cost for this baseline upgrade is allocated 100% to PENELEC

Baseline Upgrade b3246.1

- Overview of Reliability Problem
 - Criteria Violation: Multiple load drop violations in the Manassas area greater than 300 MW
 - Contingency: Multiple
 - Criteria test: N-1-1 Load Drop
- Overview of Reliability Solution
 - Description of Upgrade: Convert 115 kV Line #172 Liberty Lomar and 115 kV Line #197 Cannon Branch Lomar to 230 kV to provide a new 230 kV source between Cannon Branch and Liberty. The majority of 115 kV Line #172 Liberty Lomar and Line #197 Cannon Branch Lomar is adequate for 230 kV operation. Rebuild 0.36 mile segment between the Lomar and Cannon Branch junction. Lines will have a summer rating of 1047MVA/1047MVA (SN/SE)
 - o Required Upgrade In-Service Date: June 01, 2023
 - Estimated Upgrade Cost: \$ 10.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3246.1 through b3246.5 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3246.2

- Overview of Reliability Problem
 - Criteria Violation: Multiple load drop violations in the Manassas area greater than 300 MW
 - Contingency: Multiple
 - Criteria test: N-1-1 Load Drop
- Overview of Reliability Solution
 - Description of Upgrade: Perform substation work for the 115 kV to 230 kV line conversion at Liberty, Wellington, Godwin, Pioneer, Sandlot and Cannon Branch
 - Required Upgrade In-Service Date: June 01, 2023
 - Estimated Upgrade Cost: \$ 21.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3246.1 through b3246.5 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion
- Overview of Reliability Problem
 - Criteria Violation: Multiple load drop violations in the Manassas area greater than 300 MW
 - Contingency: Multiple
 - Criteria test: N-1-1 Load Drop
- Overview of Reliability Solution
 - Description of Upgrade: Extend 230 kV Line #2011 Cannon Branch Clifton to Winters Branch by removing the existing Line #2011 termination at Cannon Branch and extending the line to Brickyard creating 230 kV Line #2011 Brickyard - Clifton. Extend a new 230 kV line between Brickyard and Winters Branch with a summer rating of 1572MVA/1572MVA (SN/SE)
 - Required Upgrade In-Service Date: June 01, 2023
 - Estimated Upgrade Cost: \$ 10.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3246.1 through b3246.5 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: Multiple load drop violations in the Manassas area greater than 300 MW
 - Contingency: Multiple
 - Criteria test: N-1-1 Load Drop
- Overview of Reliability Solution
 - Description of Upgrade: Perform substation work at Cannon Branch, Brickyard and Winters Branch for the 230 kV Line #2011 Cannon Branch – Clifton extension
 - $\circ \quad \mbox{Required Upgrade In-Service Date: June 01, 2023}$
 - Estimated Upgrade Cost: \$ 4.00 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3246.1 through b3246.5 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: Multiple load drop violations in the Manassas area greater than 300 MW
 - Contingency: Multiple
 - Criteria test: N-1-1 Load Drop
- Overview of Reliability Solution
 - Description of Upgrade: Replace the Gainesville 230 kV 40 kA breaker "216192" with a 50 kA breaker
 - o Required Upgrade In-Service Date: June 01, 2023
 - Estimated Upgrade Cost: \$ 0.50 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3246.1 through b3246.5 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Voltage drop violation at Wolf Lake, Albion, Philips, Brimfield, North Kendallville and Kendallville 69 kV buses
 - Contingency: Multiple N-1-1 contingency pairs
 Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install a low side 69 kV circuit breaker at the Albion 138/69 kV transformer #1
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.40 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Voltage magnitude and voltage drop violations at Mill Street, Sugar Hill, Friendship, Central Portsmouth, Cornerstone Station, Ruhlman, Rosemount, Sciotoville, Millbrook Park, Oertels Corners, Siloam, South Shore 69 kV buses and South Lucasville 138 kV bus
 - Contingency: Multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install a 3000A 40 kA 138 kV breaker on the high side of 138/69 kV transformer #5 at the Millbrook Park station. The transformer and associated bus protection will be upgraded accordingly
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.63 M
 - Construction Responsibility: AEP
- Cost Allocation
 - o The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Sand Hill Cricket 138 kV line cannot be dispatched below normal rating after the loss of Sand Hill – Warton Hill #1 138 kV line in N-1-1 test
 - Contingency: Loss of the Sand Hill Warton Hill #1 138 kV line
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Upgrade 795 AAC risers at the Sand Hill 138 kV station towards Cricket Switch with 1272 AAC
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.04 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation One of the Tidd Wheeling Steel 138 kV lines #1 and #2 cannot be dispatched below normal rating after the loss of the other line in N-1-1 test
 - Contingency: Loss of the Tidd Wheeling Steel 138 kV lines #1 or #2
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Upgrade 500 MCM Cu risers at Tidd 138 kV station towards Wheeling Steel; replace with 1272 AAC conductor
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.07 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Overload of the Twin Branch 1 Twin Branch 2 34.5 kV circuit
 - Contingency: Multiple N-1 contingencies and N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace two spans of 336.4 26/7 ACSR on the Twin Branch AM General #2 34.5 kV circuit
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.14 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Overload of the Easton North Canton 69 kV line and voltage drop violations at Belden Village and Wayview 69 kV buses
 - Contingency: N-1-1 contingency pair of the loss of West Canton Promway Wayview 138 kV line and the loss of Wagnenhals 138/69/23 kV transformer and the Canton Center – Wagenhals – June Road 138 kV line, LTV Steel – Wagenhals – North East Canton 138 KV line and West Louisville – Georgetown 69 kV line
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Install a 3000A 63 kA 138 kV breaker on the high side of 138/69 kV transformer #2 at Wagenhals station. The transformer and associated bus protection will be upgraded accordingly
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.10 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Voltage drop violations at BILLIAR, North Fredericksburg, Shreve, Big Prairie, PAINTVSS, Drake Valley and LOUDNVL 69 kV buses
 - Contingency: Fault on the South Millersburg West Millersburg Wooster East Wooster 138 kV line with stuck breaker at Wooster 138 kV bus
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: At West Millersburg station, replace the 138 kV MOAB on the West Millersburg – Wooster 138 kV line with a 3000A 40 kA breaker
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.68 M
 - Construction Responsibility: AEP
- Cost Allocation
 - $_{\odot}$ $\,$ The cost for this baseline upgrade is allocated 100% to AEP $\,$

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Arsenal Riazzi (Z-101) 138 kV line exceeds its normal rating as a result of a N-2 failure of underground cables (Z-47 and Z-48) in a common trench
 - o Contingency: N-2 failure of underground cables (Z-47 and Z-48) in a common trench
 - Criteria test: TO Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Implement slow circulation on existing underground 138 kV high pressure fluid filled (HPFF) cable between the Arsenal and Riazzi substations
 - \circ Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 2.40 M
 - Construction Responsibility: DL
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to DL

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Clay Village Clay Village T - 69 KV line section is overloaded
 - o Contingency: Loss of the Ghent Owen County Tap 138 kV line
 - Criteria test: EKPC 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Upgrade the metering CT associated with the Clay Village – Clay Village T 69 kV line section to increase the line ratings
 - Required Upgrade In-Service Date: December 01, 2021
 - Estimated Upgrade Cost: \$ 0.03 M
 - Construction Responsibility: EKPC
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to EKPC

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation Low voltage at the Brodhead 69 kV distribution substation
 - o Contingency: Loss of the Brodhead Three Link 69 kV line
 - Criteria test: EKPC 715 Criteria
 - Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 4/0 ACSR Norwood Shopville 69 kV line section using 556 ACSR/TW
 - o Required Upgrade In-Service Date: December 01, 2021
 - Estimated Upgrade Cost: \$ 3.79 M
 - Construction Responsibility: EKPC
- Cost Allocation
 - \circ $\,$ $\,$ The cost for this baseline upgrade is allocated 100% to EKPC $\,$

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Ottawa Leipsic Deshler Tap 69 kV line, East Leipsic – North Leipsic 69 kV line, East Leipsic 138/69 kV transformer, Cairo – East Lima 69 kV line, and McComb OP – New Liberty 34.5 kV line are overloaded
 - o Contingency: A tower contingency and multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild and convert the existing 17.6 miles East Leipsic New Liberty 34.5 kV circuit to 138 kV using 795 ACSR
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 31.35 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3273.1 through b3273.4 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Ottawa Leipsic Deshler Tap 69 kV line, East Leipsic – North Leipsic 69 kV line, East Leipsic 138/69 kV transformer, Cairo – East Lima 69 kV line, and McComb OP – New Liberty 34.5 kV line are overloaded
 - o Contingency: A tower contingency and multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Convert the existing 34.5 kV equipment to 138 kV and expand the existing McComb station to the north and east to allow for new equipment to be installed. Install two (2) new 138 kV box bays to allow for line positions and two (2) new 138/12 kV transformers
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.87 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3273.1 through b3273.4 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Ottawa Leipsic Deshler Tap 69 kV line, East Leipsic – North Leipsic 69 kV line, East Leipsic 138/69 kV transformer, Cairo – East Lima 69 kV line, and McComb OP – New Liberty 34.5 kV line are overloaded
 - o Contingency: A tower contingency and multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Expand the existing East Leipsic 138 kV station to the north to allow for another 138 kV line exit to be installed. The new line exit will involve installing a new 138 kV circuit breaker, disconnect switches and the addition of a new dead end structure along with the extension of the existing 138 kV bus work
 - \circ Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.30 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3273.1 through b3273.4 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Ottawa Leipsic Deshler Tap 69 kV line, East Leipsic – North Leipsic 69 kV line, East Leipsic 138/69 kV transformer, Cairo – East Lima 69 kV line, and McComb OP – New Liberty 34.5 kV line are overloaded
 - o Contingency: A tower contingency and multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC FORM 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Add one (1) 138 kV circuit breaker and disconnect switches in order to add an additional line position at New Liberty 138 kV station. Install line relaying potential devices and retire the 34.5 kV breaker 'F'
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.90 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3273.1 through b3273.4 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The West Newcomerstown Kimbolton – Salt Fork 69 kV line are overloaded
 - Contingency: N-1-1 contingency pair of the loss of the West Cambridge East New Concord – PHILO 138 kV line, West Cambridge 138/69 kV transformer and West Cambridge – Cassell JSS 69 kV line, and the loss of the West Byesville – Derwent 69 kV line
 - o Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild approximately 8.9 miles of 69 kV line between Newcomerstown and Salt Fork Switch with 556 ACSR conductor
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 15.89 M
 - Construction Responsibility: AEP
- Cost Allocation
 - No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the Kammer Station Cresaps Switch 69 kV line, approximately 0.5 mile
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.93 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs.
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the Cresaps Switch McElroy Station 69 kV, approximately 0.67 mile
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.25 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs.
 - O Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace a single span of 4/0 ACSR from Moundsville -Natrium structure 93L to Carbon Tap switch 69 kV located between the Colombia Carbon and Conner Run stations. Remainder of the line is 336 ACSR
 - \circ Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.01 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs.
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild from Colombia Carbon to Columbia Carbon Tap structure 93N 69 kV, approximately 0.72 mile. The remainder of the line between Colombia Carbon Tap structure 93N and Natrium station is 336 ACSR and will remain
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.08 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs.
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace the Cresaps 69 kV 3-Way Phase-Over-Phase switch and structure with a new 1200A 3-Way switch and steel pole
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.71 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs.
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace 477 MCM Alum bus and risers at McElroy 69 kV station
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.33 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The Conner RN Columbia Natrium 69 kV line and Kammer – Cresaps – McElroy 69 kV line are overloaded
 - Contingency: A tower contingency and multiple N-1-1 contingency pairs.
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Replace Natrium 138 kV bus existing between CB-BT1 and along the 138 kV Main Bus # 1 dropping to CBH1 from the 500 MCM conductors to a 1272 KCM AAC conductor. Replace the dead end clamp and strain insulators
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.29 M
 - Construction Responsibility: AEP
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Lancaster Lancaster 69 kV line and Lancaster – South Lancaster 69 kV line, Ralston – Lancaster Junction 69 kV line are overloaded
 - Contingency: Multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 2/0 Copper section of the Lancaster South Lancaster 69 kV line, approximately 2.9 miles of the 3.2 miles total length with 556 ACSR conductor. The remaining section has a 336 ACSR conductor
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 5.37 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3276.1, b3276.2 and b3276.3 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Lancaster Lancaster 69 kV line and Lancaster – South Lancaster 69 kV line, Ralston – Lancaster Junction 69 kV line are overloaded
 - Contingency: Multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 1/0 Copper section of the line between Lancaster Junction and Ralston station 69 kV, approximately 2.3 miles of the 3.1 miles total length
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 4.58 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3276.1, b3276.2 and b3276.3 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The East Lancaster Lancaster 69 kV line and Lancaster – South Lancaster 69 kV line, Ralston – Lancaster Junction 69 kV line are overloaded
 - Contingency: Multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild the 2/0 Copper portion of the line between East Lancaster Tap and Lancaster 69 kV, approximately 0.81 mile
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.20 M
 - Construction Responsibility: AEP
- Cost Allocation
 - Baseline upgrades b3276.1, b3276.2 and b3276.3 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

- Overview of Reliability Problem
 - Criteria Violation: Breaker Over Duty
 - Contingency: N/A
 - Criteria test: Short Circuit
- Overview of Reliability Solution
 - Description of Upgrade: Replace the existing East Akron 138 kV breaker 'B-22' with 3000A continuous, 40 kA momentary current interrupting rating circuit breaker
 - Required Upgrade In-Service Date: June 01, 2021
 - Estimated Upgrade Cost: \$ 0.55 M
 - Construction Responsibility: ATSI
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to ATSI

- Overview of Reliability Problem
 - Criteria Violation: Overload of 230 kV Line #2172
 - Contingency: Multiple contingencies
 - o Criteria test: N-1 thermal, Generation Deliverability, N-1-1 thermal, TO Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Reconductor 230 kV Line #2172 from Brambleton to Evergreen Mills along with upgrading the line leads at Brambleton to achieve a summer emergency rating of 1574 MVA
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 2.32 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: Overload of 230 kV Line #2210
 - Contingency: Multiple contingencies
 - o Criteria test: N-1 thermal, Generation Deliverability, N-1-1 thermal, TO Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Reconductor 230 kV Line #2210 from Brambleton to Evergreen Mills along with upgrading the line leads at Brambleton to achieve a summer emergency rating of 1574 MVA
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 2.26 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: Overload of 230 kV Line #2213
 - \circ $\,$ Contingency: Loss of 230 kV Line #227 and 230 kV Line #274 $\,$
 - Criteria test: N-1-1 thermal summer
- Overview of Reliability Solution
 - Description of Upgrade: Reconductor 230 kV Line #2213 from Cabin Run to Yardley Ridge along with upgrading the line leads at Yardley to achieve a summer emergency rating of 1574 MVA
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 1.75 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: 300 MW load loss
 - Contingency: Loss of 230 kV Line #2149 and 230 kV Line #9167
 - Criteria test: N-1-1 300 MW load loss summer and winter
- Overview of Reliability Solution
 - Description of Upgrade: Extend a new single circuit 230 kV Line #9250 from Farmwell substation to Nimbus substation
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 5.65 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3303.1 and b3303.2 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - o Criteria Violation: 300 MW load loss
 - Contingency: Loss of 230 kV Line #2149 and 230 kV Line #9167
 - Criteria test: N-1-1 300 MW load loss summer and winter
- Overview of Reliability Solution
 - o Description of Upgrade: Remove Beaumeade 230 kV Line #2152 line switch
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 0.05 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3303.1 and b3303.2 constitute a single reliability project. No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: 300 MW load loss
 - Contingency: Multiple
 - o Criteria test: Common mode and N-1-1 300 MW load loss winter
- Overview of Reliability Solution
 - o Description of Upgrade: Midlothian area improvements for 300 MW load drop relief
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 6.22 M
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3304, b3304.1 through b3304.4 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

- Overview of Reliability Problem
 - Criteria Violation: 300 MW load loss
 - Contingency: Multiple
 - o Criteria test: Common mode & N-1-1 300 MW load loss winter
- Overview of Reliability Solution
 - o Description of Upgrade: Cut 230 kV Line #2066 at Trabue junction
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: N/A
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3304, b3304.1 through b3304.4 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion
Baseline Upgrade b3304.2

- Overview of Reliability Problem
 - Criteria Violation: 300 MW load loss
 - Contingency: Multiple
 - o Criteria test: Common mode & N-1-1 300 MW load loss winter
- Overview of Reliability Solution
 - Description of Upgrade: Reconductor idle 230 kV Line #242 (radial from Midlothian to Trabue junction) to allow a minimum summer rating of 1047 MVA and connect to the section of 230 kV Line #2066 between Trabue junction and Winterpock, re-number 230 kV Line #242 structures to Line #2066
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: N/A
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3304, b3304.1 through b3304.4 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3304.3

- Overview of Reliability Problem
 - Criteria Violation: 300 MW load loss
 - Contingency: Multiple
 - o Criteria test: Common mode & N-1-1 300 MW load loss winter
- Overview of Reliability Solution
 - Description of Upgrade: Use the section of idle 115 kV Line #153, between Midlothian and Trabue junction to connect to the section of (former) 230 kV Line #2066 between Trabue junction and Trabue to create new Midlothian – Trabue lines with new line numbers #2218 and #2219
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: N/A
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3304, b3304.1 through b3304.4 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3304.4

- Overview of Reliability Problem
 - Criteria Violation: 300 MW load loss
 - Contingency: Multiple
 - o Criteria test: Common mode & N-1-1 300 MW load loss winter
- Overview of Reliability Solution
 - Description of Upgrade: Create new line terminations at Midlothian for the new Midlothian – Trabue 230 kV lines
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: N/A
 - Construction Responsibility: Dominion
- Cost Allocation
 - Baseline upgrades b3304, b3304.1 through b3304.4 constitute a single reliability project. Only Dominion zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to Dominion

Baseline Upgrade b3305

- Overview of Reliability Problem
 - Criteria Violation: The Constitution to Concord 115 kV circuits #110567 and #110568 are overloaded
 - \circ Contingency: Tower line outage loss of the Brandon Shore to Riverside 230 kV Line #2344 and #2345
 - o Criteria test: Summer Generator Deliverability
- Overview of Reliability Solution
 - o Description of Upgrade: Replace Pumphrey 230/115 kV transformer
 - Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 4.69 M
 - Construction Responsibility: BGE
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to BGE

Baseline Upgrade b3306

- Overview of Reliability Problem
 - Criteria Violation: Post contingency high voltage violation on the Pierce Brook 345 kV substation
 - Contingency: Loss of the Pierce Brook Five Mile 345 kV circuit plus Pierce Brook shunt reactor, and Pierce Brook – Five Mile 345 kV circuit plus Lewis Run - Pierce Brook 230 kV circuits
 - Criteria test: Summer and Winter N-1-1
- Overview of Reliability Solution
 - Description of Upgrade: Install a second 125 MVAR 345 kV shunt reactor and associated equipment at Pierce Brook substation. Install a 345 kV breaker on the high side of the 345/230 kV transformer #1
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 8.08 M
 - Construction Responsibility: PENELEC
- Cost Allocation
 - The cost for this baseline upgrade is allocated 100% to PENELEC. The upgrade benefits load entirely within the zone. The distribution factor would be based on an interface entirely within the zone receiving the allocation. Therefore no distribution factor table is provided.

Baseline Upgrade b3312

- Overview of Reliability Problem
 - Criteria Violation: FERC Form 715 Criteria Violation The West Mount Vernon 138/69 kV transformer, North Mount Vernon-Mount Vernon 69 kV line, South Mount Vernon-North Mount Vernon 69 kV line and West Mount Vernon-Pittsburg 69 kV line are overloaded
 - Contingency: Multiple N-1-1 contingency pairs
 - Criteria test: AEP FERC Form 715 Criteria
- Overview of Reliability Solution
 - Description of Upgrade: Rebuild approximately 4 miles of existing 69 kV line between West Mount Vernon and Mount Vernon stations. Replace the existing 138/69 kV transformer at West Mount Vernon with a larger 90 MVA unit along with existing 69 kV breaker 'C'
 - o Required Upgrade In-Service Date: June 01, 2025
 - Estimated Upgrade Cost: \$ 12.93 M
 - Construction Responsibility: AEP
- Cost Allocation
 - No transmission zone has greater than 1% distribution factor. The cost for this baseline upgrade is allocated 100% to AEP

Attachment B

Schedule 12 – Appendix A of the PJM Open Access Transmission Tariff

(Marked / Redline Format)

SCHEDULE 12 – APPENDIX A

(1) Atlantic City Electric Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
------------------------------------	----------------------------	-------------------------

b2123	Upgrade the 69 kV bus at Laurel	AEC (100%)
b2226	Upgrade the Tackahoe to Mill 69 kV circuit	AEC (100%)
b2227	50 MVAR shunt reactor at Mickleton 230 kV and relocate Mickleton #1 230 69 kV transformer	AEC (100%)
b2228	+150/-100 MVAR SVC at Cedar 230 kV	AEC (100%)
b2296	Replace the Mickleton 230kV breaker PCB U with 63kA breaker	AEC (100%)
b2297	Replace the Mickleton 230kV breaker PCB V with 63kA breaker	AEC (100%)
b2305	Rebuild and reconductor 1.2 miles of the US Silica to US Silica #1 69 kV circuit	AEC (100%)
b2306	Rebuild and reconductor 1.67 miles of the US Silica #1 to W1-089 TAP 69 kV circuit	AEC (100%)
b2351	Reconductor section A of Corson - Sea Isle - Swainton 69 kV line	AEC (100%)
b2353	Upgrade the overcurrent protective relaying at Middle T3 and T4 138/69 kV transformers	AEC (100%)
b2354	Install second 230/69 kV transformer and 230 kV circuit breaker at Churchtown substation	AEC (100%)

Atlantic City Electric Company (cont.)

		1	
b2354.1	Replace Churchtown 69kV breaker 'D'		AEC (100%)
b2476	Install new Dennis 230/69 kV transformer		AEC (100%)
b2477	Upgrade 138 kV and 69 kV breakers at Corson substation		AEC (100%)
b2478	Reconductor 2.74 miles of Sherman - Lincoln 138 kV line and associated substation upgrades		AEC (100%)
b2479	New Orchard - Cardiff 230 kV line (remove, rebuild and reconfigure existing 138 kV line) and associated substation upgrades		AEC (100%)
b2480.1	New Upper Pittsgrove - Lewis 138 kV line and associated substation upgrades		AEC (100%)
b2480.2	Relocate Monroe to Deepwater Tap 138 kV to Landis 138 kV and associated substation upgrades		AEC (100%)
b2480.3	New Landis - Lewis 138 kV line and associated substation upgrades		AEC (100%)
b2481	New Cardiff - Lewis #2 138 kV line and associated substation upgrades		AEC (100%)
b2489	Install a 100 MVAR capacitor at BL England		AEC (100%)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)

Atlantic City Electric Company (cont.)

1		
b2538	Replace the Mickleton 230kV 'MK' breaker with 63kA breaker	AEC (100%)
b2553	Replace Middle T3 138/69 kV transformer with 225 MVA nameplate	AEC (100%)
b2723.1	Replace the Mickleton 69 kV 'PCB A' breaker with 63kA breaker	AEC (100%)
b2723.2	Replace the Mickleton 69 kV 'PCB B' breaker with 63kA breaker	AEC (100%)
b2723.3	Replace the Mickleton 69 kV 'PCB C' breaker with 63kA breaker	AEC (100%)
b2723.4	Replace the Mickleton 69 kV 'PCB Q' breaker with 63kA breaker	AEC (100%)
b2839	Replace the Sickler 69 kV 'H' breaker with 63kA breaker	AEC (100%)
b2840	Replace the Sickler 69 kV 'M' breaker with 63kA breaker	AEC (100%)
b2841	Replace the Sickler 69 kV 'A' breaker with 63kA breaker	AEC (100%)
b2945.1	Rebuild the BL England – Middle Tap 138 kV line to 2000A on double circuited steel poles and new foundations	AEC (100%)
b2945.2	Reconductor BL England – Merion 138 kV (1.9 miles) line	AEC (100%)
b2945.3	Reconductor Merion – Corson 138 kV (8 miles) line	AEC (100%)

Atlantic City Electric Company (cont.)

		 (»)
b3135	Install back-up relay on the 138 kV bus at Corson substation	AEC (100%)
<u>b3226</u>	Add 10 MVAR 69 kV capacitor bank at Swainton substation	<u>AEC (100%)</u>
<u>b3227</u>	<u>Rebuild the Corson – Court</u> <u>69 kV line to achieve ratings</u> <u>equivalent to 795 ACSR</u> <u>conductor or better</u>	<u>AEC (100%)</u>

SCHEDULE 12 – APPENDIX A

(2) Baltimore Gas and Electric Company

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Install a 115 kV tie		
	breaker at Wagner to		
b2219	create a separation from		BGE (100%)
	line 110535 and		
	transformer 110-2		
h2220	Install four 115 kV		PCE (1000%)
02220	breakers at Chestnut Hill		BGE (100%)
	Install an SPS to trip		
L0001	approximately 19 MW		DCE $(1000/)$
02221	load at Green St. and		BGE (100%)
	Concord		
	Install a 230/115kV		
	transformer at Raphael		
	Rd and construct		
	approximately 3 miles of		
b2307	115kV line from Raphael		BGE (100%)
	Rd. to Joppatowne.		
	Construct a 115kV three		
	breaker ring at		
	Joppatowne		
	Build approximately 3		
	miles of 115kV		
	underground line from		
	Bestgate tap to Waugh		
b2308	Chapel. Create two		BGE (100%)
	breaker bay at Waugh		
	Chapel to accommodate		
	the new underground		
	circuit		
	Build a new Camp Small		
b2396	115 kV station and install		BGE (100%)
	30 MVAR capacitor		

Baltimore Gas and Electric Company (cont.)

Required 1		Annual Revenue Requirement	responsible Customer(s)
h2396 1	Install a tie breaker at Mays Chapel 115 kV		BGE (100%)
02370.1	substation		DGE (100%)
	Upgrade the Riverside		
	115kV substation strain		
	bus conductors on		
	circuits 115012 and		
b2567	115011 with double		BGE (100%)
	bundled 1272 ACSR to		
	achieve ratings of		
	491/577 MVA SN/SE on		
	both transformer leads		
	Reconductor Northwest –		
	Northwest #2 115kV		
b2568	110574 substation tie		BGE (100%)
02000	circuit with 2167 ACSR		
	to achieve ratings of		
	400/462 MVA SN/SE		
	Conastone 230 kV		
	substation tie-in work		AEP(6.46%) / APS(8.74%) / DCE(10.740%) / CCE(10.740%) / CCE(10.740%) / CCE(10.740%) / CCE(10.740%) / CCE(10.74%)
	(install a new circuit		BGE (19.74%) / ComEd (2.16%)
b2752.6	breaker at Conastone		/ Dayton (0.59%) / DEOK
	230 kV and upgrade any		(1.02%) / DL $(0.01%)$ /
	required terminal		Dominion (39.95%) / EKPC
	equipment to terminate		(0.45%) / PEPCO (20.88%)
	the new circuit)		AED(6.460/)/ADS(9.740/)/
	Reconductor/Rebuild the		AEP (0.40%) / APS (8.74%) / BCE (10.74%) / ComEd (2.16%)
	two Conastone –		(19.74%) / Collied (2.10%)
b2752.7	Northwest 230 kV lines		(1.02%)/DL(0.01%)/
	and upgrade terminal		(1.02%) / DL (0.01%) / Dominion (30.05%) / EKPC
	equipment on both ends		(0.45%) / PEPCO (20.88%)
	Replace the Conastone		
1.0750.0	230 kV '2322 B5'		
b2752.8	breaker with a 63kA		BGE (100%)
	breaker		

Baltimore Gas and Electric Company (cont.)

		*	
b2752.9	Replace the Conastone 230 kV '2322 B6' breaker with a 63kA breaker		BGE (100%)
b2766.1	Upgrade substation equipment at Conastone 500 kV to increase facility rating to 2826 MVA normal and 3525 MVA emergency		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEC (3.52%) / APS (9.95%) / ATSI (10.68%) / BGE (6.92%) / DPL (16.32%) / JCPL (11.32%) / NEPTUNE* (1.22%) / PENELEC (2.30%) / PEPCO (12.59%) / PSEG (24.22%) / RE (0.96%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

Baltimore Gas and Electric Company (cont.)

Required I	Talishiission Enhancements 7	Annual Revenue Requirementer	nt Responsible Customer(s)
b2816	Re-connect the Crane – Windy Edge 110591 & 110592 115 kV circuits into the Northeast Substation with the addition of a new 115 kV 3-breaker bay		BGE (100%)
b2992.1	Reconductor the Conastone to Graceton 230 kV 2323 & 2324 circuits. Replace 7 disconnect switches at Conastone substation		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.2	Add Bundle conductor on the Graceton – Bagley – Raphael Road 2305 & 2313 230 kV circuits		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.3	Replacing short segment of substation conductor on the Windy Edge to Glenarm 110512 115 kV circuit		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.4	Reconductor the Raphael Road – Northeast 2315 & 2337 230 kV circuits		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
<u>b3228</u>	Replace two (2) relays atCenter substation toincrease ratings on theWestport to Center110552 115 kV circuit		<u>BGE (100%)</u>
<u>b3305</u>	Replace Pumphrey 230/115 kV transformer		<u>BGE (100%)</u>

SCHEDULE 12 – APPENDIX A

(3) Delmarva Power & Light Company

Required II		inual Revenue Requirement	Responsible Customer(s)
b2288	Build a new 138 kV line from Piney Grove – Wattsville		DPL (100%)
b2395	Reconductor the Harmony – Chapel St 138 kV circuit		DPL (100%)
b2569	Replace Terminal equipment at Silverside 69 kV substation		DPL (100%)
b2633.7	Implement high speed relaying utilizing OPGW on Red Lion – Hope Creek 500 kV line		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEC (0.01%) / DPL (99.98%) / JCPL (0.01%)
b2633.10	Interconnect the new Silver Run 230 kV substation with existing Red Lion – Cartanza and Red Lion – Cedar Creek 230 kV lines		AEC (8.01%) / BGE (1.94%) / DPL (12.99%) / JCPL (13.85%) / ME (5.88%) / NEPTUNE* (3.45%) / PECO (17.62%) / PPL (14.85%) / PSEG (20.79%) / RE (0.62%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

Delmarva Power & Light Company (cont.)

Required II		nuui revenue requirement	
b2695	Rebuild Worcester – Ocean Pine 69 kV ckt. 1 to 1400A capability summer		DPL (100%)
b2946	Convert existing Preston 69 kV substation to DPL's current design standard of a 3-breaker ring bus		DPL (100%)
b2947.1	Upgrade terminal equipment at DPL's Naamans substation (Darley - Naamans 69 kV)		DPL (100%)
b2947.2	Reconductor 0.11 mile section of Darley - Naamans 69 kV circuit		DPL (100%)
b2948	Upgrade terminal equipment at DPL's Silverside Road substation (Dupont Edge Moor – Silver R. 69 kV)		DPL (100%)
b2987	Install a 30 MVAR capacitor bank at DPL's Cool Springs 69 kV substation. The capacitor bank would be installed in two separate 15 MVAR stages allowing DPL operational flexibility		DPL (100%)
b3143.1	Reconductor the Silverside Road – Darley 69 kV circuit		DPL (100%)
b3143.2	Reconductor the Darley – Naamans 69 kV circuit		DPL (100%)
b3143.3	Replace three (3) existing 1200 A disconnect switches with 2000 A disconnect switches and install three (3) new 2000 A disconnect switches at Silverside 69 kV station		DPL (100%)

Delmarva Power & Light Company (cont.)

Required Tr	ansmission Enhancements Ani	nual Revenue Requirement	Responsible Customer(s)
	Replace two (2) 1200 A		
	disconnect switches with		
	2000 A disconnect		
	switches. Replace existing		
	954 ACSR and 500 SDCU		
	stranded bus with two (2)		
h21424	954 ACSR stranded bus.		DDI (1000%)
03145.4	Reconfigure four (4) CTs		DFL (100%)
	from 1200 A to 2000 A		
	and install two (2) new		
	2000 A disconnect		
	switches and two (2) new		
	954 ACSR stranded bus at		
	Naamans 69 kV station		
	Replace four (4) 1200 A		
	disconnect switches with		
	2000 A disconnect		
	switches. Replace existing		
	954 ACSR and 1272		
	MCM AL stranded bus		
	with two (2) 954 ACSR		
	stranded bus. Reconfigure		
b3143.5	eight (8) CTs from 1200 A		DPL (100%)
	to 2000 A and install four		
	(4) new 2000 A (310 MVA		
	SE / 351 MVA WE)		
	disconnect switches and		
	two (2) new 954 ACSR		
	(331 MVA SE / 369 MVA		
	WE) stranded bus at		
	Darley 69 kV station		
	Rebuild approx. 12 miles		
b3155	of Wye Mills –		DPL (100%)
	Stevensville line		
	Replace a disconnect		
	switch and reconductor a		
<u>b3224</u>	short span of the Mt.		<u>DPL (100%)</u>
	<u>Pleasant – Middletown tap</u>		
	<u>138 kV line</u>		

SCHEDULE 12 – APPENDIX A

(4) Jersey Central Power & Light Company

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2234	260 MVAR reactor at West Wharton 230 kV		JCPL (100%)
b2270	Advance Raritan River - Replace G1047E breaker at the 230kV Substation		JCPL (100%)
b2271	Advance Raritan River - Replace G1047F breaker at the 230kV Substation		JCPL (100%)
b2272	Advance Raritan River - Replace T1034E breaker at the 230kV Substation		JCPL (100%)
b2273	Advance Raritan River - Replace T1034F breaker at the 230kV Substation		JCPL (100%)
b2274	Advance Raritan River - Replace I1023E breaker at the 230kV Substation		JCPL (100%)
b2275	Advance Raritan River - Replace I1023F breaker at the 230kV Substation		JCPL (100%)
b2289	Freneau Substation - upgrade 2.5 inch pipe to bundled 1590 ACSR conductor at the K1025 230 kV Line Terminal		JCPL (100%)
b2292	Replace the Whippany 230 kV breaker B1 (CAP) with 63kA breaker		JCPL (100%)
b2357	Replace the East Windsor 230 kV breaker 'E1' with 63kA breaker		JCPL (100%)

Required Tra	Insmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
	Replace transformer		
b2495	leads on the Glen		ICDI (1000%)
	Gardner 230/34.5 kV #1		JCFL (100%)
	transformer		
	Replace Franklin		
b2/06	115/34.5 kV transformer		ICDI (100%)
02490	#2 with 90 MVA		JCI L (100%)
	transformer		
	Reconductor 0.9 miles of		
	the Captive Plastics to		
b2497	Morris Park 34.5 kV		JCPL (100%)
	circuit (397ACSR) with		
	556 ACSR		
	Extend 5.8 miles of 34.5		
	kV circuit from North		
	Branch substation to		
b2498	Lebanon substation with		JCPL (100%)
	397 ACSR and install		
	34.5 kV breaker at		
	Lebanon substation		
	Upgrade terminal		
	equipment at Monroe on		
b2500	the Englishtown to		JCPL (100%)
	Monroe (H34) 34.5 kV		
	circuit		
	Upgrade limiting		
h2570	terminal facilities at		ICDI (1000/)
02370	Feneau, Parlin, and		JCFL (100%)
	Williams substations		
	Upgrade the limiting		
b2571	terminal facilities at both		ICDI (1000/)
	Jackson and North		JCPL (100%)
	Hanover		
	Upgrade the V74 34.5 kV		
h2596	transmission line		$\mathbf{ICDI} (1000/)$
02586	between Allenhurst and		JCPL (100%)
	Elberon Substations		

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)
Required Tra	nsmission Enhancements	Annual Revenue Requirement Responsible Customer(s) Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) /
b2633.6	relaying utilizing OPGW on Deans – East Windsor 500 kV	EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (0.01%) / DPL (99.98%) / JCPL (0.01%)
b2633.6.1	Implement high speed relaying utilizing OPGW on East Windsor - New Freedom 500 kV	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (0.01%) / DPL (99.98%) / JCPL (0.01%)

Required Tra	Institussion Enhancements An	nual Revenue Requirement	Responsible Customer(s)
b2676	Install one (1) 72 MVAR fast switched capacitor at the Englishtown 230 kV substation		JCPL (100%)
b2708	Replace the Oceanview 230/34.5 kV transformer #1		JCPL (100%)
b2709	Replace the Deep Run 230/34.5 kV transformer #1		JCPL (100%)
b2754.2	Install 5 miles of optical ground wire (OPGW) between Gilbert and Springfield 230 kV substations		JCPL (100%)
b2754.3	Install 7 miles of all- dielectric self-supporting (ADSS) fiber optic cable between Morris Park and Northwood 230 kV substations		JCPL (100%)
b2754.6	Upgrade relaying at Morris Park 230 kV		JCPL (100%)
b2754.7	Upgrade relaying at Gilbert 230 kV		JCPL (100%)
b2809	Install a bypass switch at Mount Pleasant 34.5 kV substation to allow the Mount Pleasant substation load to be removed from the N14 line and transfer to O769 line		JCPL (100%)
b3023	Replace West Wharton 115 kV breakers 'G943A' and 'G943B' with 40kA breakers		JCPL (100%)
b3042	Replace substation conductor at Raritan River 230 kV substation on the Kilmer line terminal		JCPL (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Ind	Instrussion Enhancements Ann	uai Kevenue Kequitement	Responsible Customer(s)
	Construct seven new 34.5		
	kV circuits on existing pole		
	lines (total of 53.5 miles),		
b3130	rebuild/reconductor two		ICPI (100%)
03130	34.5 kV circuits (total of		JCI L (100%)
	5.5 miles) and install a		
	second 115/34.5 kV		
	transformer (Werner)		
	Construct a new 34.5 kV		
h2120.1	circuit from Oceanview to		ICDI (1000%)
03130.1	Allenhurst 34.5 kV (4		JCFL (100%)
	miles)		
	Construct a new 34.5 kV		
h2120.2	circuit from Atlantic to		$\mathbf{ICDI} (1000\%)$
03130.2	Red Bank 34.5 kV (12		JCPL (100%)
	miles)		
	Construct a new 34.5 kV		
h2120.2	circuit from Freneau to		ICDI (100%)
03130.3	Taylor Lane 34.5 kV (6.5		JCFL (100%)
	miles)		
	Construct a new 34.5 kV		
b3130.4	circuit from Keyport to		JCPL (100%)
	Belford 34.5 kV (6 miles)		
	Construct a new 34.5 kV		
b3130.5	circuit from Red Bank to		JCPL (100%)
	Belford 34.5 kV (5 miles)		
	Construct a new 34.5 kV		
b3130.6	circuit from Werner to		JCPL (100%)
	Clark Street (7 miles)		
	Construct a new 34.5 kV		
b3130.7	circuit from Atlantic to		JCPL (100%)
	Freneau (13 miles)		
	Rebuild/reconductor the		
1.2120.9	Atlantic – Camp Woods		\mathbf{ICDI} (1000/)
03130.8	Switch Point (3.5 miles)		JCPL (100%)
	34.5 kV circuit		
	Rebuild/reconductor the		
b3130.9	Allenhurst – Elberon (2		JCPL (100%)
	miles) 34.5 kV circuit		
	Install 2nd 115/34.5 kV		
b3130.10	transformer at Werner		JCPL (100%)
	substation		

Required Tra	ansmission Enhancements	Ann	ual Revenue Requirement	Responsible Customer(s)
<u>b3238</u>	Replace seven (7) overdutied 34.5 kV breakers with 50 kA ra equipment at the Whipp substation	<u>ited</u> bany		JCPL (100%)
<u>b3239</u>	Replace fourteen (14 overdutied 34.5 kV breakers with 63 kA ra equipment	<u>l)</u> nted		JCPL (100%)

SCHEDULE 12 – APPENDIX A

(7) Mid-Atlantic Interstate Transmission, LLC for the Pennsylvania Electric Company Zone

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2212	Shawville Substation: Relocate 230 kV and 115 kV controls from the generating station building to new control building		PENELEC (100%)
b2293	Replace the Erie South 115 kV breaker 'Buffalo Rd' with 40kA breaker		PENELEC (100%)
b2294	Replace the Johnstown 115 kV breaker 'Bon Aire' with 40kA breaker		PENELEC (100%)
b2302	Replace the Erie South 115 kV breaker 'French #2' with 40kA breaker		PENELEC (100%)
b2304	Replace the substation conductor and switch at South Troy 115 kV substation		PENELEC (100%)
b2371	Install 75 MVAR capacitor at the Erie East 230 kV substation		PENELEC (100%)
b2441	Install +250/-100 MVAR SVC at the Erie South 230 kV station		PENELEC (100%)
b2442	Install three 230 kV breakers on the 230 kV side of the Lewistown #1, #2 and #3 transformers		PENELEC (100%)
b2450	Construct a new 115 kV line from Central City West to Bedford North		PENELEC (100%)
b2463	Rebuild and reconductor 115 kV line from East Towanda to S. Troy and upgrade terminal equipment at East Towanda, Tennessee Gas and South Troy		PENELEC (100%)

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Construct Warren 230 kV		
b2494	ring bus and install a		DENELEC (100%)
	second Warren 230/115		$\mathbf{I} = \mathbf{I} = $
	kV transformer		
	Reconductor the North		
	Meshoppen – Oxbow-		
b25521	Lackawanna 230 kV		PENELEC (99.00%) / PPL
02332.1	circuit and upgrade		(1.00%)
	terminal equipment		
	(MAIT portion)		
	Replace the Warren 115		
b2573	kV 'B12' breaker with a		PENELEC (100%)
	40kA breaker		
	Reconfigure Pierce Brook		
	345 kV station to a ring		
b2587	bus and install a 125		PENELEC (100%)
	MVAR shunt reactor at		
	the station		
	Replace relays at East		
b2621	Towanda and East Sayre		PENELEC (100%)
	115 KV substations		
	(158/191 MVA SIN/SE)		
	Replace wave trap, bus		
h2677	Hillton 115 kV substation		DENELEC (100%)
02077	Poplace relays at Prospect		FENELEC (100%)
	and Cooper substations		
	Convert the East Towarda		
	115 kV substation to		
b2678	breaker and half		PENELEC (100%)
	configuration		
	Install a 115 kV Venango		
b2679	Jct. line breaker at		PENELEC (100%)
02017	Edinboro South		
b2680	Install a 115 kV breaker		
	on Hooversville #1 115/23		PENELEC (100%)
	kV transformer		
	Install a 115 kV breaker		
b2681	on the Eclipse $#2\ 115/34.5$		PENELEC (100%)
02001	kV transformer		2 (20070)
	L		

		1 (/
b2682	Install two 21.6 MVAR capacitors at the Shade Gap 115 kV substation	PENELEC (100%)
b2683	Install a 36 MVAR 115 kV capacitor and associated equipment at Morgan Street substation	PENELEC (100%)
b2684	Install a 36 MVAR 115 kV capacitor at Central City West substation	PENELEC (100%)
b2685	Install a second 115 kV 3000A bus tie breaker at Hooversville substation	PENELEC (100%)
b2735	Replace the Warren 115 kV 'NO. 2 XFMR' breaker with 40kA breaker	PENELEC (100%)
b2736	Replace the Warren 115 kV 'Warren #1' breaker with 40kA breaker	PENELEC (100%)
b2737	Replace the Warren 115 kV 'A TX #1' breaker with 40kA breaker	PENELEC (100%)
b2738	Replace the Warren 115 kV 'A TX #2' breaker with 40kA breaker	PENELEC (100%)
b2739	Replace the Warren 115 kV 'Warren #2' breaker with 40kA breaker	PENELEC (100%)
b2740	Revise the reclosing of the Hooversville 115 kV 'Ralphton' breaker	PENELEC (100%)
b2741	Revise the reclosing of the Hooversville 115 kV 'Statler Hill' breaker	PENELEC (100%)

Required 1		inual Revenue Requirement	Responsible Customer(s)
			AEP (6.46%) / APS (8.74%) /
	Tie in new Rice substation		BGE (19.74%) / ComEd
b2743.2	to Conemaugh –		(2.16%) / Dayton $(0.59%)$ /
02710.2	Hunterstown 500 kV		DEOK (1.02%) / DL (0.01%)
	Hunterstown 500 k v		/ Dominion (39.95%) / EKPC
			(0.45%) / PEPCO (20.88%)
	Upgrade terminal		AEP (6.46%) / APS (8.74%) /
	equipment at Conemaugh		BGE (19.74%) / ComEd
h2743 3	500 kV on the Conemaugh		(2.16%) / Dayton (0.59%) /
02743.3	- Hunterstown 500 kV		DEOK (1.02%) / DL (0.01%)
	circuit		/ Dominion (39.95%) / EKPC
	circuit		(0.45%) / PEPCO (20.88%)
	Install two 28 MVAR		
b2748	capacitors at Tiffany 115		PENELEC (100%)
	kV substation		
	Construct a new 345 kV		
	breaker string with three		
	(3) 345 kV breakers at		
b2767	Homer City and move the		PENELEC (100%)
	North autotransformer		
	connection to this new		
	breaker string		
	Reconductor 3.7 miles of		
	the Bethlehem – Leretto 46		
b2803	kV circuit and replace		PENELEC (100%)
	terminal equipment at		
	Summit 46 kV		
	Install a new relay and		
	replace 4/0 CU bus		
h2801	conductor at Huntingdon		DENELEC (100%)
02004	46 kV station, on the		FENELEC (100%)
	Huntingdon – C tap 46 kV		
	circuit		
	Install a new relay and		
b2805	replace 4/0 CU & 250 CU		
	substation conductor at		
	Hollidaysburg 46 kV		PENELEC (100%)
	station, on the		
	Hollidaysburg – HCR Tap		
	46 kV circuit		

Required T	ransmission Enhancements An	nual Revenue Requirement	Responsible Customer(s)
b2806	Install a new relay and replace meter at the Raystown 46 kV substation, on the Raystown – Smithfield 46 kV circuit		PENELEC (100%)
b2807	Replace the CHPV and CRS relay, and adjust the IAC overcurrent relay trip setting; or replace the relay at Eldorado 46 kV substation, on the Eldorado – Gallitzin 46 kV circuit		PENELEC (100%)
b2808	Adjust the JBC overcurrent relay trip setting at Raystown 46 kV, and replace relay and 4/0 CU bus conductor at Huntingdon 46 kV substations, on the Raystown – Huntingdon 46 kV circuit		PENELEC (100%)
b2865	Replace Seward 115 kV breaker "Jackson Road" with 63kA breaker		PENELEC (100%)
b2866	Replace Seward 115 kV breaker "Conemaugh N." with 63kA breaker		PENELEC (100%)
b2867	Replace Seward 115 kV breaker "Conemaugh S." with 63kA breaker		PENELEC (100%)
b2868	Replace Seward 115 kV breaker "No.8 Xfmr" with 63kA breaker		PENELEC (100%)
b2944	Install two 345 kV 80 MVAR shunt reactors at Mainesburg station		PENELEC (100%)

b2951	Seward, Blairsville East, Shelocta work	PENELEC (100%)
b2951.1	Upgrade Florence 115 kV line terminal equipment at Seward SS	PENELEC (100%)
b2951.2	Replace Blairsville East / Seward 115 kV line tuner, coax, line relaying and carrier set at Shelocta SS	PENELEC (100%)
b2951.3	Replace Seward / Shelocta 115 kV line CVT, tuner, coax, and line relaying at Blairsville East SS	PENELEC (100%)
b2952	Replace the North Meshoppen #3 230/115 kV transformer eliminating the old reactor and installing two breakers to complete a 230 kV ring bus at North Meshoppen	PENELEC (100%)
b2953	Replace the Keystone 500 kV breaker "NO. 14 Cabot" with 50kA breaker	PENELEC (100%)
b2954	Replace the Keystone 500 kV breaker "NO. 16 Cabot" with 50kA breaker	PENELEC (100%)
b2984	Reconfigure the bus at Glory and install a 50.4 MVAR 115 kV capacitor	PENELEC (100%)
b3007.2	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - PENELEC portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Blairsville East, the wave trap and breaker disconnects will be replaced	PENELEC (100%)

Required T	ransmission Enhancements Annu	ual Revenue Requirement	Responsible Customer(s)
	Upgrade Blairsville East		
	138/115 kV transformer		
	terminals. This project is an		
	upgrade to the tap of the		
b3008	Seward – Shelocta 115 kV		PENELEC (100%)
	line into Blairsville		
	substation. The project will		
	replace the circuit breaker		
	and adjust relay settings		
	Upgrade Blairsville East 115		
h3000	kV terminal equipment.		PENELEC (100%)
03009	Replace 115 kV circuit		FENELEC (100%)
	breaker and disconnects		
	Replace the existing Shelocta		
b3014	230/115 kV transformer and		PENELEC (100%)
	construct a 230 kV ring bus		
	Upgrade terminal equipment		
	at Corry East 115 kV to		
b3016	increase rating of Four Mile		PENELEC (100%)
	to Corry East 115 kV line.		
	Replace bus conductor		
	Rebuild Glade to Warren 230		
	kV line with hi-temp		
	conductor and substation		
b3017.1	terminal upgrades. 11.53		PENELEC (100%)
	miles. New conductor will be		
	1033 ACSS. Existing		
	conductor is 1033 ACSR		
h2017 2	Glade substation terminal		
	upgrades. Replace bus		PENELEC (100%)
03017.2	conductor, wave traps, and		1 EI(EEEC (100%)
	relaying		
b3017.3	Warren substation terminal		
	upgrades. Replace bus		PENELEC (100%)
	conductor, wave traps, and		TENELLEC (100%)
	relaying		
	Replace Saxton 115 kV		
b3022	breaker 'BUS TIE' with a		PENELEC (100%)
	40kA breaker		

Upgrade terminal equipment at Corry East 115 kV to increase rating of Warren to Corry East 115 kV line. Replace bus conductorPENELEC (100%)Install one 115 kV 36 b3043MVAR capacitor at West Fall 115 kV substationPENELEC (100%)Replace the Blairsville East 138/115 kV transformer and as breaker disconnects and bus conductorPENELEC (100%)Reconductor the Franklin b3077Reconductor the Franklin (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)	Required T	ransmission Enhancements Ann	ual Revenue Requirement	Responsible Customer(s)
at Corry East 115 kV to increase rating of Warren to Corry East 115 kV line. Replace bus conductorPENELEC (100%)MVAR capacitor at West Fall 115 kV substationPENELEC (100%)Replace the Blairsville East 138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)B3073Reconductor the Franklin (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)		Upgrade terminal equipment		
b3024increase rating of Warren to Corry East 115 kV line. Replace bus conductorPENELEC (100%)Install one 115 kV 36Install one 115 kV 36b3043MVAR capacitor at West Fall 115 kV substationPENELEC (100%)Replace the Blairsville East 138/115 kV transformer and as breaker disconnects and bus conductorPENELEC (100%)B3073Reconductor the Franklin (6.78 miles)PENELEC (100%)B3073Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)		at Corry East 115 kV to		
Corry East 115 kV line. Replace bus conductorReplace bus conductorInstall one 115 kV 36Install one 115 kV 36b3043MVAR capacitor at West Fall 115 kV substationPENELEC (100%)Replace the Blairsville East 138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)Reconductor the Franklin b3077PENELEC (100%)B3077Pike B – Wayne 115 kV line (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)	b3024	increase rating of Warren to		PENELEC (100%)
Replace bus conductorInstall one 115 kV 36b3043MVAR capacitor at WestFall 115 kV substationReplace the Blairsville East138/115 kV transformer andb3073associated equipment such as breaker disconnects and bus conductorReconductor the Franklinb3077Pike B – Wayne 115 kV line (6.78 miles)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.b3078relays Morgan Street. Reconductor the 138 kV bus		Corry East 115 kV line.		
Install one 115 kV 36PENELEC (100%)b3043MVAR capacitor at West Fall 115 kV substationPENELEC (100%)Replace the Blairsville East 138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)B3073Reconductor the Franklin (6.78 miles)PENELEC (100%)B3073Reconductor the I38 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)B3078Reconductor the 138 kV busPENELEC (100%)		Replace bus conductor		
b3043MVAR capacitor at West Fall 115 kV substationPENELEC (100%)Replace the Blairsville East 138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)Base Reconductor the Franklin (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)Base Reconductor the 138 kV bus And replace the line trap, Reconductor the 138 kV busPENELEC (100%)		Install one 115 kV 36		
Fall 115 kV substationReplace the Blairsville East 138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)80073Reconductor the Franklin (6.78 miles)PENELEC (100%)80074Reconductor the Franklin (6.78 miles)PENELEC (100%)80075Reconductor the I38 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)80078Reconductor the 138 kV busPENELEC (100%)	b3043	MVAR capacitor at West		PENELEC (100%)
Replace the Blairsville East 138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)Base Reconductor the Franklin b3077Reconductor the Franklin (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street. Reconductor the 138 kV busPENELEC (100%)		Fall 115 kV substation		
b3073138/115 kV transformer and associated equipment such as breaker disconnects and bus conductorPENELEC (100%)Base and the second se		Replace the Blairsville East		
b3073associated equipment such as breaker disconnects and bus conductorPENELEC (100%)BaselineBeconductor the Franklin Pike B – Wayne 115 kV line (6.78 miles)PENELEC (100%)BaselineReconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)BaselinePENELEC (100%)PENELEC (100%)		138/115 kV transformer and		
as breaker disconnects and bus conductor as breaker disconnects and bus conductor Reconductor the Franklin b3077 Reconductor the Franklin (6.78 miles) Reconductor the 138 kV bus and replace the line trap, relays Morgan Street. PENELEC (100%) Barbon Street. PENELEC (100%)	b3073	associated equipment such		PENELEC (100%)
bus conductor Bus conductor the Franklin b3077 Reconductor the Franklin b3077 Pike B – Wayne 115 kV line (6.78 miles) PENELEC (100%) Reconductor the 138 kV bus and replace the line trap, b3078 relays Morgan Street. Reconductor the 138 kV bus PENELEC (100%)		as breaker disconnects and		
Reconductor the FranklinPENELEC (100%)b3077Pike B – Wayne 115 kV line (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)b3078relays Morgan Street. Reconductor the 138 kV busPENELEC (100%)		bus conductor		
b3077Pike B – Wayne 115 kV line (6.78 miles)PENELEC (100%)Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)Beconductor the 138 kV busPENELEC (100%)		Reconductor the Franklin		
(6.78 miles) Reconductor the 138 kV bus and replace the line trap, relays Morgan Street. B3078 Reconductor the 138 kV bus	b3077	Pike B – Wayne 115 kV line		PENELEC (100%)
Reconductor the 138 kV bus and replace the line trap, relays Morgan Street.PENELEC (100%)Reconductor the 138 kV busPENELEC (100%)		(6.78 miles)		
b3078 relays Morgan Street. Reconductor the 138 kV bus		Reconductor the 138 kV bus		
b3078 relays Morgan Street. Reconductor the 138 kV bus		and replace the line trap.		
Reconductor the 138 kV bus	b3078	relays Morgan Street		PENELEC (100%)
	00070	Reconductor the 138 kV bus		
at Venango Junction		at Venango Junction		
Construct 4-breaker 115 kV		Construct 4-breaker 115 kV		
b3082 ring bus at Geneva PENELEC (100%)	b3082	ring bus at Geneva		PENELEC (100%)
Rebuild 20 miles of the East		Rebuild 20 miles of the East		
b3137 Towanda – North PENELEC (100%)	b3137	Towanda – North		PENELEC (100%)
Meshoppen 115 kV line	00107	Meshoppen 115 kV line		
Upgrade bus conductor and		Upgrade bus conductor and		
relay papels of the Jackson		relay panels of the Jackson		
b3144 PENELEC (100%)	b3144	Road – Nanty Glo 46 kV		PENELEC (100%)
SJN line		SIN line		
Upgrade line relaying and		Upgrade line relaying and		
substation conductor on the		substation conductor on the		
b3144.1 46 kV Nanty Glo line exit at PENELEC (100%)	b3144.1	46 kV Nanty Glo line exit at		PENELEC (100%)
Jackson Road substation		Jackson Road substation		
Upgrade line relaying and		Upgrade line relaying and		
substation conductor on the	b3144.2	substation conductor on the		
b3144.2 46 kV Jackson Road line PENELEC (100%)		46 kV Jackson Road line		PENELEC (100%)
exit at Nanty Glo substation		exit at Nanty Glo substation		
Install one (1) 13 2 MVAR	b3154	Install one (1) 13 2 MVAR		
b3154 46 kV capacitor at the PENELEC (100%)		46 kV capacitor at the		PENELEC (100%)
Logan substation		Logan substation		

Required T	ransmission Enhancements Ann	ual Revenue Requirement	Responsible Customer(s)
<u>b3231</u>	Replace the existing No. 2 cap bank breaker at Huntingdon substation with a new breaker with higher		PENELEC (100%)
	interrupting capability		
<u>b3232</u>	<u>Williamsburg, ALH</u> (Hollidaysburg) and bus section breaker at the Altoona substation with a new breaker with higher interrupting capability		<u>PENELEC (100%)</u>
<u>b3233</u>	Install one (1) 34 MVAR 115 kV shunt reactor and breaker. Install one (1) 115 kV circuit breaker to expand the substation to a 4-breaker ring bus		<u>PENELEC (100%)</u>
<u>b3237</u>	Install two (2) 46 kV 6.12 MVAR capacitors effective at Mt. Union		PENELEC (100%)
<u>b3245</u>	Construct a new breaker- and-a-half substation near Tiffany substation. All transmission assets and lines will be relocated to the new substation. The two (2) distribution transformers will be fed via two (2) dedicated 115 kV feeds to the existing Tiffany substation		<u>PENELEC (100%)</u>
<u>b3306</u>	Install a second 125 MVAR 345 kV shunt reactor and associated equipment at Pierce Brook substation. Install a 345 kV breaker on the high side of the 345/230 kV transformer #1		<u>PENELEC (100%)</u>

SCHEDULE 12 – APPENDIX A

(9) **PPL Electric Utilities Corporation**

Required Transmission Enhancements		Annual Revenue Requirer	ment Responsible Customer(s)
b1813.12	Replace the Blooming Grove 230 kV breaker 'Peckville'		PPL (100%)
b2223	Rebuild and reconductor 2.6 miles of the Sunbury - Dauphin 69 kV circuit		PPL (100%)
b2224	Add a 2nd 150 MVA 230/69 kV transformer at Springfield		PPL (100%)
b2237	150 MVAR shunt reactor at Alburtis 500 kV		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: PPL (100%)
b2238	100 MVAR shunt reactor at Elimsport 230 kV		PPL (100%)

* Neptune Regional Transmission System, LLC

PPL Electric Utilities Corporation (cont.)

Required	Transmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
b2269	Rebuild approximately 23.7 miles of the Susquehanna - Jenkins 230kV circuit. This replaces a temporary SPS that is already planned to mitigate the violation until this solution is implemented		PPL (100%)
b2282	Rebuild the Siegfried- Frackville 230 kV line		PPL (100%)
b2406.1	Rebuild Stanton- Providence 69 kV 2&3 9.5 miles with 795 SCSR		PPL (100%)
b2406.2	Reconductor 7 miles of the Lackawanna - Providence 69 kV #1 and #2 with 795 ACSR		PPL (100%)
b2406.3	Rebuild SUB2 Tap 1 (Lackawanna - Scranton 1) 69 kV 1.5 miles 556 ACSR		PPL (100%)
b2406.4	Rebuild SUB2 Tap 2 (Lackawanna - Scranton 1) 69 kV 1.6 miles 556 ACSR		PPL (100%)
b2406.5	Create Providence - Scranton 69 kV #1 and #2, 3.5 miles with 795 ACSR		PPL (100%)
b2406.6	Rebuild Providence 69 kV switchyard		PPL (100%)
b2406.7	Install 2 - 10.8 MVAR capacitors at EYNO 69 kV		PPL (100%)
b2406.8	Rebuild Stanton 230 kV yard		PPL (100%)

PPL Electric Utilities Corporation (cont.)

nequirea		Timuai ne venue negune	
b2446	Replace wave trap and protective relays at Montour		PPL (100%)
b2447	Replace wave trap and protective relays at Montour		PPL (100%)
b2448	Install a 2nd Sunbury 900MVA 500-230kV transformer and associated equipment		PPL (100%)
b2552.2	Reconductor the North Meshoppen - Oxbow – Lackawanna 230 kV circuit and upgrade terminal equipment (PPL portion)		PENELEC (98.84%) / PPL (1.16%)
b2574	Replace the Sunbury 230 kV 'MONTOUR NORT' breaker with a 63kA breaker		PPL (100%)
b2690	Reconductor two spans of the Graceton – Safe Harbor 230 kV transmission line. Includes termination point upgrades		PPL (100%)
b2691	Reconductor three spans limiting Brunner Island – Yorkana 230 kV line, add 2 breakers to Brunner Island switchyard, upgrade associated terminal equipment		PPL (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)
PPL Electric Utilities Corporation (cont.)

Required '	Transmission Enhancements	cements Annual Revenue Requirement Responsible Customer(s)		
		Load-Ratio Share Allocation:		
		AEC (1.71%) / AEP (14.04%) /		
		APS (5.61%) / ATSI (8.10%) /		
		BGE (4.36%) / ComEd (13.14%)		
		/ Dayton (2.15%) / DEOK		
		(3.23%) / DL (1.73%) / DPL		
	Add a 200 MVAD abunt	(2.65%) / Dominion (13.03%) /		
h2716	Adu a 200 M v AK shuht	EKPC (1.77%) / JCPL (3.84%) /		
02710	500 kV substation	ME (1.93%) / NEPTUNE*		
	JOO KV SUDStation	(0.45%) / OVEC (0.07%) /		
		PECO (5.29%) / PENELEC		
		(1.89%) / PEPCO (3.82%) / PPL		
		(4.72%) / PSEG (6.21%) / RE		
		(0.26%)		
		DFAX Allocation:		
		PPL (100%)		
	Install 7 miles of optical			
	ground wire (OPGW)			
b2754.1	between Gilbert and	PPL (100%)		
	Springfield 230 kV			
	substations			
	Use ~ 40 route miles of			
	existing fibers on PPL			
b2754.4	230 kV system to	PPL (100%)		
	establish direct fiber			
	circuits			
b2754 5	Upgrade relaying at	PPI (100%)		
02754.5	Martins Creek 230 kV			
b2756	Install 2% reactors at	PPI (100%)		
02750	Martins Creek 230 kV			
	Expand existing			
b2813	Lycoming 69 kV yard to	PPI (100%)		
02813	double bus double			
	breaker arrangement			

PPL Electric Utilities Corporation (cont.)

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)		
			Load	-Ratio Share Allocation:
			AEC	(1.71%) / AEP (14.04%) /
			APS	(5.61%) / ATSI (8.10%) /
			BGE ((4.36%) / ComEd (13.14%)
			/ D	Dayton (2.15%) / DEOK
			(3.2	3%) / DL (1.73%) / DPL
	Reconfigure/Expand the		(2.65	%) / Dominion (13.03%) /
1 202 4	Lackawanna 500 kV		EKPC	C (1.77%) / JCPL (3.84%) /
b2824	substation by adding a		ME	E (1.93%) / NEPTUNE*
	third bay with three		(0.4	45%) / OVEC (0.07%) /
	breakers		PEC	CO (5.29%) / PENELEC
			(1.89%	%) / PEPCO (3.82%) / PPL
			(4.72	2%) / PSEG (6.21%) / RE
				(0.26%)
				DFAX Allocation:
				PPL (100%)
	Build a new 230/69 kV			
	substation by tapping the			
	Montour – Susquehanna			
b2838	230 kV double circuits			PPL (100%)
	and Berwick – Hunlock			
	& Berwick – Colombia			
	69 kV circuits			
	Replace Martins Creek			
b2979	230 kV circuit breakers			PPL (100%)
	with 80 kA rating			
	Replace terminal			
	equipment (bus			
h2221	conductor) on the 230 kV			DDI (1000%)
03221	side of the Steel City			11L (100%)
	500/230 kV Transformer			
	#1			
	Install one (1) 7.2 MVAR			
	fixed cap bank on the			
	Lock Haven – Reno 69			
	kV line and one (1) 7.2			
<u>b3222</u>	MVAR fixed cap bank			<u>PPL (100%)</u>
	on the Lock Haven –			
	Flemington 69 kV line			
	near the Flemington			
	69/12 kV substation			

SCHEDULE 12 – APPENDIX A

Required Tra	nsmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
	Reconductor 0.33 miles of		
	the Parkersburg - Belpre		
b2117	line and upgrade		APS (100%)
	Parkersburg terminal		
	equipment		
h2118	Add 44 MVAR Cap at New	,	ADS(1000%)
02118	Martinsville		AFS (100%)
b2120	Six-Wire Lake Lynn -		APS(100%)
02120	Lardin 138 kV circuits		AI 5 (10070)
	Replace Weirton 138 kV		
b2142	breaker "Wylie Ridge 210"		APS (100%)
	with 63 kA breaker		
	Replace Weirton 138 kV		
b2143	breaker "Wylie Ridge 216"		APS (100%)
	with 63 kA breaker		
b2174.8	Replace relays at Mitchell		APS(100%)
02174.0	substation		110(100/0)
b2174.9	Replace primary relay at		APS(100%)
02171.9	Piney Fork substation		110 (10070)
	Perform relay setting		
b2174.10	changes at Bethel Park		APS (100%)
	substation		
	Armstrong Substation:		
	Relocate 138 kV controls		
b2213	from the generating station		APS (100%)
	building to new control		
	building		
	Albright Substation: Install		
	a new control building in		
	the switchyard and relocate		
b2214	controls and SCADA		APS (100%)
	equipment from the		
	generating station building		
	the new control center		
	Rivesville Switching		
	Station: Relocate controls		
b2215	and SCADA equipment		APS (100%)
	from the generating station		110 (10070)
	building to new control		
	building		

Required Tr	ansmission Enhancements A	Annual Revenue Requirement	Responsible Customer(s)
	Willow Island: Install a new		
	138 kV cross bus at		
	Belmont Substation and		
h2216	reconnect and reconfigure		ADS(1000%)
02210	the 138 kV lines to facilitate		AFS (100%)
	removal of the equipment at		
	Willow Island switching		
	station		
h2235	130 MVAR reactor at		APS(100%)
02233	Monocacy 230 kV		AFS (100%)
h2260	Install a 32.4 MVAR		ADS(1000%)
02200	capacitor at Bartonville		AFS (100%)
h2261	Install a 33 MVAR		ADS(1000%)
02201	capacitor at Damascus		AFS (100%)
	Replace 1000 Cu substation		
b2267	conductor and 1200 amp		APS (100%)
	wave trap at Marlowe		
	Reconductor 6.8 miles of		
h2268	138kV 336 ACSR with 336		APS(100%)
02208	ACSS from Double Toll		AFS (100%)
	Gate to Riverton		
	Reconductor from Collins		
b2299	Ferry - West Run 138 kV		APS (100%)
	with 556 ACSS		
h2200	Reconductor from Lake		ADS(1000%)
02300	Lynn - West Run 138 kV		AFS (100%)
	Install 39.6 MVAR		
b2341	Capacitor at Shaffers Corner		APS (100%)
	138 kV Substation		
	Construct a new 138 kV		
	switching station (Shuman		
h7217	Hill substation), which is		ADS(1000%)
02342	next the Mobley 138 kV		AFS (100%)
	substation and install a 31.7		
	MVAR capacitor		
	Install a 31.7 MVAR		
b2343	capacitor at West Union 138		APS (100%)
	kV substation		

Required Tr	ansmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
h2262	Install a 250 MVAR SVC at		ADS(1000())
02502	Squab Hollow 230 kV		APS (100%)
	Install a 230 kV breaker at		
b2362.1	Squab Hollow 230 kV		APS (100%)
	substation		
	Convert the Shingletown		
b2363	230 kV bus into a 6 breaker		APS (100%)
	ring bus		
	Install a new 230/138 kV		
	transformer at Squab		
	Hollow 230 kV substation.		
h2261	Loop the Forest - Elko 230		ADS(1000/)
02304	kV line into Squab Hollow.		AFS (100%)
	Loop the Brookville - Elko		
	138 kV line into Squab		
	Hollow		
	Install a 44 MVAR 138 kV		
b2412	capacitor at the Hempfield		APS (100%)
	138 kV substation		
	Install breaker and a half		
	138 kV substation (Waldo		
	Run) with 4 breakers to		
b2/33 1	accommodate service to		APS(100%)
02433.1	MarkWest Sherwood		AI 5 (100%)
	Facility including metering		
	which is cut into Glen Falls		
	Lamberton 138 kV line		
	Install a 70 MVAR SVC at		
b2433.2	the new WaldoRun 138 kV		APS (100%)
	substation		
	Install two 31.7 MVAR		
b24333	capacitors at the new		APS(100%)
02433.3	WaldoRun 138 kV		M S (100%)
	substation		
	Replace the Weirton 138 kV		
b2424	breaker 'WYLIE RID210'		APS (100%)
	with 63 kA breakers		
	Replace the Weirton 138 kV		
b2425	breaker 'WYLIE RID216'		APS (100%)
	with 63 kA breakers		

Required Tr	ansmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
	Replace the Oak Grove 138		
b2426	kV breaker 'OG1' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2427	kV breaker 'OG2' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2428	kV breaker 'OG3' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2429	kV breaker 'OG4' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2430	kV breaker 'OG5' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2431	kV breaker 'OG6' with 63		APS (100%)
	kA breakers		
	Replace the Ridgeley 138		
b2432	kV breaker 'RC1' with a 40		APS (100%)
	kA rated breaker		
	Replace the Cabot 138kV		
b2440	breaker 'C9-KISKI VLY'		APS (100%)
	with 63kA		
	Replace the Ringgold 138		
b2472	kV breaker 'RCM1' with		APS (100%)
	40kA breakers		
	Replace the Ringgold 138		
b2473	kV breaker '#4 XMFR' with		APS (100%)
	40kA breakers		
	Construct a new line		
b2475	between Oak Mound 138		APS (100%)
02175	kV substation and Waldo		111 B (10070)
	Run 138 kV substation		
	Construct a new 138 kV		
	substation (Shuman Hill		
b2545.1	substation) connected to the		APS (100%)
	Fairview – Willow Island		
	(84) 138 kV line		

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2545.2	Install a ring bus station with five active positions and two 52.8 MVAR capacitors with 0.941 mH reactors		APS (100%)
b2545.3	Install a +90/-30 MVAR SVC protected by a 138 kV breaker	7	APS (100%)
b2545.4	Remove the 31.7 MVAR capacitor bank at Mobley 138 kV		APS (100%)
b2546	Install a 51.8 MVAR (rated 138 kV capacitor at Nyswaner 138 kV substation)	APS (100%)
b2547.1	Construct a new 138 kV six breaker ring bus Hillman substation	ζ	APS (100%)
b2547.2	Loop Smith- Imperial 138 kV line into the new Hillman substation		APS (100%)
b2547.3	Install +125/-75 MVAR SVC at Hillman substation		APS (100%)
b2547.4	Install two 31.7 MVAR 138 kV capacitors	3	APS (100%)
b2548	Eliminate clearance de-rate on Wylie Ridge – Smith 133 kV line and upgrade terminals at Smith 138 kV, new line ratings 294 MVA (Rate A)/350 MVA (Rate B	2 8)	APS (100%)
b2612.1	Relocate All Dam 6 138 kV line and the 138 kV line to AE units 1&2	T	APS (100%)
b2612.2	Install 138 kV, 3000A bus- tie breaker in the open bus- tie position next to the Shaffers corner 138 kV line		APS (100%)

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Install a 6-pole manual		
b26123	switch, foundation, control		APS(100%)
02012.3	cable, and all associated		M S (10070)
	facilities		
b2666	Yukon 138 kV Breaker		APS (100%)
02000	Replacement		111 D (10070)
	Replace Yukon 138 kV		
b2666.1	breaker "Y-11(CHARL1)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.2	breaker "Y-13(BETHEL)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.3	breaker "Y-18(CHARL2)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.4	breaker "Y-19(CHARL2)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.5	breaker "Y-4(4B-2BUS)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.6	breaker "Y-5(LAYTON)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.7	breaker "Y-8(HUNTING)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.8	breaker "Y-9(SPRINGD)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.9	breaker "Y-10(CHRL-SP)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.10	breaker "Y-12(1-1BUS)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.11	breaker "Y-14(4-1BUS)"		APS (100%)
	with an 80 kA breaker		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
b2666.12	Replace Yukon 138 kV breaker "Y-2(1B-BETHE)" with an 80 kA breaker		APS (100%)
b2666.13	Replace Yukon 138 kV breaker "Y-21(SHEPJ)" with an 80 kA breaker		APS (100%)
b2666.14	Replace Yukon 138 kV breaker "Y-22(SHEPHJT)" with an 80 kA breaker		APS (100%)
b2672	Change CT Ratio at Seneca Caverns from 120/1 to 160/1 and adjust relay settings accordingly		APS (100%)
b2688.3	Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and adjust CT ratios		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)
b2689.3	Upgrade terminal equipment at structure 27A		APS (100%)
b2696	Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations. New rating of line will be 353 MVA summer normal/422 MVA emergency		APS (100%)
b2700	Remove existing Black Oak SPS		APS (100%)
b2743.6	Reconfigure the Ringgold 230 kV substation to double bus double breaker scheme		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.6.1	Replace the two Ringgold 230/138 kV transformers		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2743.7	Rebuild/Reconductor the Ringgold – Catoctin 138 kV circuit and upgrade terminal equipment on both ends		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2747.1	Relocate the FirstEnergy Pratts 138 kV terminal CVTs at Gordonsville substation to allow for the installation of a new motor operated switch being installed by Dominion		APS (100%)
b2763	Replace the breaker risers and wave trap at Bredinville 138 kV substation on the Cabrey Junction 138 kV terminal		APS (100%)
b2764	Upgrade Fairview 138 kV breaker risers and disconnect leads; Replace 500 CU breaker risers and 556 ACSR disconnect leads with 795 ACSR		APS (100%)
b2964.1	Replace terminal equipment at Pruntytown and Glen Falls 138 kV station		APS (100%)
b2964.2	Reconductor approximately 8.3 miles of the McAlpin - White Hall Junction 138 kV circuit		APS (100%)

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Reconductor the Charleroi –		
	Allenport 138 kV line with		
b2965	954 ACSR conductor.		DL (100%)
	Replace breaker risers at		
	Charleroi and Allenport		
	Reconductor the Yukon –		
	Smithton – Shepler Hill Jct		
b2966	138 kV line with 795 ACSS		APS (100%)
	conductor. Replace Line		
	Disconnect Switch at Yukon		
	Reconductor the Yukon -		
	Smithton - Shepler Hill Jct		
b2966 1	138 kV line and replace		APS (100%)
02900.1	terminal equipment as		111 5 (10070)
	necessary to achieve		
	required rating		
	Convert the existing 6 wire		
	Butler - Shanor Manor -		
	Krendale 138 kV line into		
b2967	two separate 138 kV lines.		APS (100%)
	New lines will be Butler -		
	Keisters and Butler - Shanor		
	Manor - Krendale 138 kV		
b2970	Ringgold – Catoctin		APS (100%)
02970	Solution		1115 (10070)
	Install two new 230 kV		
b2970.1	positions at Ringgold for		APS (100%)
	230/138 kV transformers		
	Install new 230 kV position		
b2970.2	for Ringgold – Catoctin 230		APS (100%)
	kV line		
	Install one new 230 kV		
b2970.3	breaker at Catoctin		APS (100%)
	substation		
	Install new 230/138 kV		
	transformer at Catoctin		
b2970.4	substation. Convert		APS (100%)
	Ringgold – Catoctin 138 kV		
	line to 230 kV operation		

Required Tr	ansmission Enhancements Annu	al Revenue Requirement	Responsible Customer(s)
h2070 5	Convert Garfield 138/12.5 kV		ADS(100%)
02970.3	substation to 230/12.5 kV		AFS (100%)
h2006	Construct new Flint Run 500/138		See sub-IDs for cost
02990	kV substation		allocations
	Construct a new 500/138 kV		
	substation as a 4-breaker ring bus		
	with expansion plans for double-		
	breaker-double-bus on the 500		
	kV bus and breaker-and-a-half on		
	the 138 kV bus to provide EHV		
	source to the Marcellus shale		
	load growth area. Projected load		
	growth of additional 160 MVA to		
	current plan of 280 MVA, for a		
	total load of 440 MVA served		
120061	from Waldo Run substation.		
02996.1	Construct additional 3-breaker		APS (100%)
	string at Waldo Run 138 kV bus.		
	Relocate the Sherwood #2 line		
	terminal to the new string.		
	Construct two single circuit Flint		
	Run - Waldo Run 138 kV lines		
	using 795 ACSR (approximately		
	3 miles). After terminal		
	relocation on new 3-breaker		
	string at Waldo Run, terminate		
	new Flint Run 138 kV lines onto		
	the two open terminals		
	Loop the Belmont – Harrison 500		
	kV line into and out of the new		
	Flint Run 500 kV substation (less		
b2996.2	than 1 mile). Replace primary		APS (100%)
	relaying and carrier sets on		
	Belmont and Harrison 500 kV		
	remote end substations		
	Upgrade two (2) existing 138 kV		
10006.2	breakers (Rider 50 and #1/4		
b2996.3	transformer breaker) at Glen Falls		APS (100%)
	with 63 kA 3000A units		

Required T	ransmission Enhancements An	nual Revenue Requirement	Responsible Customer(s)
b3005	Reconductor 3.1 mile 556 ACSR portion of Cabot to Butler 138 kV with 556 ACSS and upgrade terminal equipment. 3.1 miles of line will be reconductored for this project. The total length of the line is 7.75 miles		APS (100%)
b3006	Replace four Yukon 500/138 kV transformers with three transformers with higher rating and reconfigure 500 kV bus		APS (73.55%) / DL (26.45%)
b3007.1	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - AP portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Social Hall, meters, relays, bus conductor, a wave trap, circuit breaker and disconnects will be replaced		APS (100%)
b3010	Replace terminal equipment at Keystone and Cabot 500 kV buses. At Keystone, bus tubing and conductor, a wave trap, and meter will be replaced. At Cabot, a wave trap and bus conductor will be replaced		APS (100%)
b3011.1	Construct new Route 51 substation and connect 10 138 kV lines to new substation		DL (100%)
b3011.2	Upgrade terminal equipment at Yukon to increase rating on Yukon to Charleroi #2 138 kV line (New Yukon to Route 51 #4 138 kV line)		DL (100%)

		•••••••(*)
b3011.3	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #1 138 kV line	DL (100%)
b3011.4	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #2 138 kV line	DL (100%)
b3011.5	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #3 138 kV line	DL (100%)
b3011.6	Upgrade remote end relays for Yukon – Allenport – Iron Bridge 138 kV line	DL (100%)
b3012.1	Construct two new 138 kV ties with the single structure from APS's new substation to Duquesne's new substation. The estimated line length is approximately 4.7 miles. The line is planned to use multiple ACSS conductors per phase	ATSI (38.21%) / DL (61.79%)
b3012.3	Construct a new Elrama – Route 51 138 kV No.3 line: reconductor 4.7 miles of the existing line, and construct 1.5 miles of a new line to the reconductored portion. Install a new line terminal at APS Route 51 substation	DL (100%)

Required IIa		ne venue negunement	Responsible Customer(s)
b3013	Reconductor Vasco Tap to Edgewater Tap 138 kV line. 4.4 miles. The new conductor will be 336 ACSS replacing the existing 336 ACSR conductor		APS (100%)
b3015.6	Reconductor Elrama to Mitchell 138 kV line – AP portion. 4.2 miles total. 2x 795 ACSS/TW 20/7		DL (100%)
b3015.8	Upgrade terminal equipment at Mitchell for Mitchell – Elrama 138 kV line		APS (100%)
b3028	Upgrade substation disconnect leads at William 138 kV substation		APS (100%)
b3051.1	Ronceverte cap bank and terminal upgrades		APS (100%)
b3052	Install a 138 kV capacitor (29.7 MVAR effective) at West Winchester 138 kV		APS (100%)
b3064.3	Upgrade line relaying at Piney Fork and Bethel Park for Piney For – Elrama 138 kV line and Bethel Park – Elrama 138 kV		APS (100%)

b3068	Reconductor the Yukon – Westraver 138 kV line (2.8 miles), replace the line drops and relays at Yukon 138 kV	APS (100%)
	Westraver 138 kV bus	
b3069	Reconductor the Westraver – Route 51 138 kV line (5.63 miles) and replace line switches at Westraver 138 kV bus	APS (100%)
b3070	Reconductor the Yukon – Route 51 #1 138 kV line (8 miles), replace the line drops, relays and line disconnect switch at Yukon 138 kV bus	APS (100%)
b3071	Reconductor the Yukon – Route 51 #2 138 kV line (8 miles) and replace relays at Yukon 138 kV bus	APS (100%)
b3072	Reconductor the Yukon – Route 51 #3 138 kV line (8 miles) and replace relays at Yukon 138 kV bus	APS (100%)
b3074	Reconductor the 138 kV bus at Armstrong substation	APS (100%)
b3075	Replace the 500/138 kV transformer breaker and reconductor 138 kV bus at Cabot substation	APS (100%)
b3076	Reconductor the Edgewater – Loyalhanna 138 kV line (0.67 mile)	APS (100%)
b3079	Replace the Wylie Ridge 500/345 kV transformer #7	ATSI (72.30%) / DL (27.70%)
b3083	Reconductor the 138 kV bus at Butler and reconductor the 138 kV bus and replace line trap at Karns City	APS (100%)

b3128	Relocate 34.5 kV lines from generating station roof R. Paul Smith 138 kV station	APS (100%)
<u>b3230</u>	At Enon substation install a second 138 kV, 28.8 MVAR nameplate, capacitor and the associated 138 kV capacitor switcher	<u>APS (100%)</u>
<u>b3240</u>	<u>Upgrade Cherry Run and</u> <u>Morgan terminals to make</u> <u>the transmission line the</u> <u>limiting component</u>	<u>APS (100%)</u>
<u>b3241</u>	Install 138 kV, 36 MVAR capacitor and a 5 uF reactor protected by a 138 kV capacitor switcher. Install a breaker on the 138 kV Junction terminal. Install a 138 kV 3.5 uF reactor on the existing Hardy 138 kV capacitor	<u>APS (100%)</u>
<u>b3242</u>	Reconfigure Stonewall 138kV substation from itscurrent configuration to asix-breaker, breaker-and-a-half layout and add two (2)36 MVAR capacitors withcapacitor switchers	<u>APS (100%)</u>

SCHEDULE 12 – APPENDIX A

(17) American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company

Required II		au revenue requiement	
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer		AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tra	Institussion Enhancements Anin	lai Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%) /
			APS (5.61%) / ATSI (8.10%) /
			BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
			(13.03%) / EKPC (1.77%) /
	Reconductor the AEP		JCPL (3.84%) / ME (1.93%) /
b1707 1	portion of the Cloverdale -		NEPTUNE* (0.45%) / OVEC
01/9/.1	Lexington 500 kV line with		(0.07%) / PECO (5.29%) /
	2-1780 ACSS		PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			AEP (0.79%) / APS (53.70%) /
			Dayton (0.15%) / DEOK
			(0.40%) / Dominion (1.13%) /
			EKPC (0.23%) / PEPCO
			(43.60%)
h2055	Upgrade relay at Brues		A EP (100%)
02035	station		MLI (10070)
	Upgrade terminal		
	equipment at Howard on		
b2122.3	the Howard - Brookside		AEP (100%)
	138 kV line to achieve		
	ratings of 252/291 (SN/SE)		
	Perform a sag study on the		
b2122.4	Howard - Brookside 138		AEP (100%)
	kV line		
b2229	Install a 300 MVAR		A EP (100%)
	reactor at Dequine 345 kV		ALI (10070)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

		Load-Ratio Share Allocation:
		AEC (1.71%) / AEP (14.04%) /
		APS (5.61%) / ATSI (8.10%) /
		BGE (4.36%) / ComEd
		(13.14%) / Dayton (2.15%) /
Replace existing 150		DEOK (3.23%) / DL (1.73%) /
MVAP reactor at Amos 765		DPL (2.65%) / Dominion
kV substation on Amos N		(13.03%) / EKPC (1.77%) /
Proctorville Hanging Pock		JCPL (3.84%) / ME (1.93%) /
with 300 MVAP reactor		NEPTUNE* (0.45%) / OVEC
with 500 W VAR reactor		(0.07%) / PECO (5.29%) /
		PENELEC (1.89%) / PEPCO
		(3.82%) / PPL (4.72%) / PSEG
		(6.21%) / RE (0.26%)
		DFAX Allocation:
		AEP (100%)
Install 765 kV reactor		
breaker at Dumont 765 kV	mont 765 kV	A ED (100%)
substation on the Dumont -		ALI (100%)
Wilton Center line		
Install 765 kV reactor		
breaker at Marysville 765		
kV substation on the		AEP (100%)
Marysville - Maliszewski		
line		
Change transformer tap		
settings for the Baker		AEP (100%)
765/345 kV transformer		
Loop the North Muskingum		
- Crooksville 138 kV line		
into AEP's Philo 138 kV		$\mathbf{AED}(10004)$
station which lies		ALF(100%)
approximately 0.4 miles		
from the line		
	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line Change transformer tap settings for the Baker 765/345 kV transformer Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line Install 765 kV reactor breaker at Marysville 765 kV substation on the Baker 765/345 kV transformer Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

	Install an 86.4 MVAR	
b2253	capacitor bank at Gorsuch	AEP (100%)
	138 kV station in Ohio	
	Rebuild approximately 4.9	
b2254	miles of Corner - Degussa	AEP (100%)
	138 kV line in Ohio	
	Rebuild approximately 2.8	
b2255	miles of Maliszewski -	AEP (100%)
	Polaris 138 kV line in Ohio	
	Upgrade approximately 36	
	miles of 138 kV through	
b2256	path facilities between	AEP (100%)
	Harrison 138 kV station and	
	Ross 138 kV station in Ohio	
	Rebuild the Pokagon -	
	Corey 69 kV line as a	
	double circuit 138 kV line	
b2257	with one side at 69 kV and	AEP (100%)
	the other side as an express	
	circuit between Pokagon	
	and Corey stations	
	Rebuild 1.41 miles of #2	
	CU 46 kV line between	
1-2259	Tams Mountain - Slab Fork	AED (1000/)
02238	to 138 kV standards. The	AEP (100%)
	line will be strung with	
	1033 ACSR	
	Install a new 138/69 kV	
	transformer at George	
b2259	Washington 138/69 kV	AED (1000/)
	substation to provide	AEP (100%)
	support to the 69 kV system	
	in the area	

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tra	ansmission Enhancements Annu	ual Revenue Requirement	Responsible Customer(s)
	Rebuild 4.7 miles of		
	Muskingum River - Wolf		
67786	Creek 138 kV line and		A ED (1000/)
02280	remove the 138/138 kV		AEP (100%)
	transformer at Wolf Creek		
	Station		
	Loop in the Meadow Lake -		
1-2207	Olive 345 kV circuit into		A E D (1000/)
02287	Reynolds 765/345 kV		AEP (100%)

station

b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholsville and Marcellus 34.5 kV stations at this new	AEP (100%)
b2344.2	station Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station	AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA's Marcellus station	AEP (100%)
b2344.4	From REA's Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)	AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)	AEP (100%)
b2344.6	Retire AEP's Marcellus 34.5/12 kV and Nicholsville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line	AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)	AEP (100%)
b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)	AEP (100%)

b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations	AEP (100%)
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV	AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades	AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures	AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit	AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit	AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit	AEP (100%)

b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'	AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'	AEP (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2394	Replace the Sporn 345 kV breaker 'CC1'	AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio	AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station	AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor	AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEP (100%)

		*	
b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408 2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2- 138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

	······································	
	Construct new 138 kV	
	switching station	
	Nottingnam tapping 6-138	
	KV FE circuits (Holloway-	
L2502 1	Brookside, Holloway-	A = D (1000/)
02502.1	Harmon #1 and #2,	AEP (100%)
	Holloway-Reeds,	
	Holloway-New Stacy,	
	Holloway-Cloverdale). Exit	
	a 138 KV circuit from new	
	station to Freedyrd station	
b2502.2	Convert Freebyrd 69 kV to	AEP (100%)
	138 KV	· · · ·
1.0500.0	Rebuild/convert Freebyrd-	
62502.3	South Cadiz 69 KV circuit	AEP (100%)
	to 138 KV	
b2502.4	Upgrade South Cadiz to 138	AEP (100%)
	kV breaker and a half	
1	Replace the Sporn 138 kV	
b2530	breaker 'G1' with 80kA	AEP (100%)
	breaker	
1.0.5.0.1	Replace the Sporn 138 kV	
b2531	breaker 'D' with 80kA	AEP (100%)
	breaker	
1.0.7.0.0	Replace the Sporn 138 kV	
b2532	breaker 'O1' with 80kA	AEP (100%)
	breaker	
	Replace the Sporn 138 kV	
b2533	breaker 'P2' with 80kA	AEP (100%)
	breaker	
	Replace the Sporn 138 kV	
b2534	breaker 'U' with 80kA	AEP (100%)
	breaker	
	Replace the Sporn 138 kV	
b2535	breaker 'O' with 80 kA	AEP (100%)
	breaker	

	Replace the Sporn 138 kV	
b2536	breaker 'O2' with 80 kA	AEP (100%)
	breaker	
	Replace the Robinson Park	
	138 kV breakers A1, A2,	
b2537	B1, B2, C1, C2, D1, D2,	AEP (100%)
	E1, E2, and F1 with 63 kA	
	breakers	
	Reconductor 0.5 miles	
	Tiltonsville – Windsor 138	
h2555	kV and string the vacant	A = D(1000/)
02333	side of the 4.5 mile section	AEP (100%)
	using 556 ACSR in a six	
	wire configuration	
	Install two 138 kV prop	
	structures to increase the	
h2556	maximum operating	A = D (1000/)
02330	temperature of the Clinch	AEP (100%)
	River- Clinch Field 138 kV	
	line	
	Temporary operating	
	procedure for delay of	
	upgrade b1464. Open the	
	Corner 138 kV circuit	
	breaker 86 for an overload	
b2581	of the Corner – Washington	A ED (1000/2)
	MP 138 kV line. The tower	ALF (100%)
	contingency loss of	
	Belmont – Trissler 138 kV	
	and Belmont – Edgelawn	
	138 kV should be added to	
	Operational contingency	

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.	AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit	AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch	AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor	AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards	AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards	AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana	AEP (100%)

b2597	Rebuild approximately 1 mi. section of Dragoon- Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon- Dodge Tap branch	AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline- Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.	AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap	AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV	AEP (100%)
b2601	Fremont Station Improvements	AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker	AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker	AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker	AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1	AEP (100%)

Required II		an nevenue negunement	Responsible Customer(s)
b2601.5	Install two (2) circuit switchers on high side of transformers # 2 and 3 at Fremont Station		AEP (100%)
b2602.1	Install 138 kV breaker E2 at North Proctorville		AEP (100%)
b2602.2	Construct 2.5 Miles of 138 kV 1033 ACSR from East Huntington to Darrah 138 kV substations		AEP (100%)
b2602.3	Install breaker on new line exit at Darrah towards East Huntington		AEP (100%)
b2602.4	Install 138 kV breaker on new line at East Huntington towards Darrah		AEP (100%)
b2602.5	Install 138 kV breaker at East Huntington towards North Proctorville		AEP (100%)
b2603	Boone Area Improvements		AEP (100%)
b2603.1	Purchase approximately a 200X300 station site near Slaughter Creek 46 kV station (Wilbur Station)		AEP (100%)
b2603.2	Install 3 138 kV circuit breakers, Cabin Creek to Hernshaw 138 kV circuit		AEP (100%)
b2603.3	Construct 1 mi. of double circuit 138 kV line on Wilbur – Boone 46 kV line with 1590 ACSS 54/19 conductor @ 482 Degree design temp. and 1-159 12/7 ACSR and one 86 Sq.MM. 0.646" OPGW Static wires		AEP (100%)
b2604	Bellefonte Transformer Addition		AEP (100%)

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundsville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap	AEP (100%)
	stations	
b2606	Hammondsville from 23 kV to 69 kV operation	AEP (100%)
b2607	Pine Gap Relay Limit Increase	AEP (100%)
b2608	Richlands Relay Upgrade	AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build	AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV	AEP (100%)
b2611	Skin Fork Area Improvements	AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components	AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line	AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort- Tanners Creek 345 kV line)	AEP (100%)

		^	· · · · · · · · · · · · · · · · · · ·
b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker		AEP (100%)
b2645	Ohio Central 138 kV Loop		AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2		AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor		AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto		AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)		AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits		AEP (100%)

Required Tr	ansmission Enhancements Annu	al Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%) /
			APS (5.61%) / ATSI (8.10%) /
			BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
	Install a 300 MVAP shunt		DEOK (3.23%) / DL (1.73%) /
	line reactor on the		DPL (2.65%) / Dominion
h2687.2	Broadford and of the		(13.03%) / EKPC (1.77%) /
02007.2	Broadford Jacksons Ferry		JCPL (3.84%) / ME (1.93%) /
	765 kV line		NEPTUNE* (0.45%) / OVEC
	703 KV IIIC		(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			AEP (100%)
	Mitigate violations		
	identified by sag study to		
	operate Fieldale-Thornton-		
b2697.1	Franklin 138 kV overhead		AEP (100%)
020711	line conductor at its max.		
	operating temperature. 6		
	potential line crossings to		
	be addressed.		
	Replace terminal equipment		
	at AEP's Danville and East		
b2697.2	Danville substations to		AEP (100%)
	improve thermal capacity of		
	Danville – East Danville		
	138 kV circuit		
Required Tr	ansmission Enhancements Annua	al Revenue Requirement	Responsible Customer(s)
-------------	------------------------------------------------------------	------------------------	-------------------------
	Replace relays at AEP's Cloverdale and Jackson's		
b2698	Ferry substations to improve the thermal capacity of		AEP (100%)
	Cloverdale – Jackson's Ferry 765 kV line		
	Construct Herlan station as breaker and a half		
b2701.1	configuration with 9-138 kV		AEP (100%)
	CB's on 4 strings and with 2- 28.8 MVAR capacitor banks		
	Construct new 138 kV line		
	from Herlan station to Blue		
b2701.2	Racer station. Estimated		AEP (100%)
	ACSS/TW Yukon and		
	OPGW		
2501.2	Install 1-138 kV CB at Blue		
2701.3	Racer to terminate new Herlan circuit		AEP (100%)
	Rebuild/upgrade line		
b2714	between Glencoe and Willow Grove Switch 69 kV		AEP (100%)
	Build approximately 11.5		
	miles of 34.5 kV line with		
b2715	556.5 ACSR 26/7 Dove		AEP (100%)
	from Flushing station to		
	Smyrna station		
	Replace the South Canton		
b2727	138 kV breakers K' , J' , (11) and (12) with 80kA		AEP (100%)
	breakers		

· 175 · · · · · · 1 5 . 11 0 \sim

		(»)
b2731	Convert the Sunnyside – East Sparta – Malvern 23 kV sub-transmission network to 69 kV. The lines are already built to 69 kV standards	AEP (100%)
b2733	Replace South Canton 138 kV breakers 'L' and 'L2' with 80 kA rated breakers	AEP (100%)
b2750.1	Retire Betsy Layne 138/69/43 kV station and replace it with the greenfield Stanville station about a half mile north of the existing Betsy Layne station	AEP (100%)
b2750.2	Relocate the Betsy Layne capacitor bank to the Stanville 69 kV bus and increase the size to 14.4 MVAR	AEP (100%)
b2753.1	Replace existing George Washington station 138 kV yard with GIS 138 kV breaker and a half yard in existing station footprint. Install 138 kV revenue metering for new IPP connection	AEP (100%)
b2753.2	Replace Dilles Bottom 69/4 kV Distribution station as breaker and a half 138 kV yard design including AEP Distribution facilities but initial configuration will constitute a 3 breaker ring bus	AEP (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tr	ansmission Enhancements Annua	al Revenue Requirement	Responsible Customer(s)
	Connect two 138 kV 6-wired		
	circuits from "Point A"		
	(currently de-energized and		
	owned by FirstEnergy) in		
h2752 2	circuit positions previously		A ED (1000%)
02755.5	designated Burger #1 &		ALF (100%)
	Burger #2 138 kV. Install		
	interconnection settlement		
	metering on both circuits		
	exiting Holloway		
	Build double circuit 138 kV		
	line from Dilles Bottom to		
	"Point A". Tie each new		
	AEP circuit in with a 6-wired		
b2753.6	line at Point A. This will		AEP (100%)
	create a Dilles Bottom –		
	Holloway 138 kV circuit and		
	a George Washington –		
	Holloway 138 kV circuit		
	Retire line sections (Dilles		
	Bottom – Bellaire and		
	Moundsville – Dilles Bottom		
	69 kV lines) south of		
h2752 7	FirstEnergy 138 kV line		A = D(1000/)
02755.7	corridor, near "Point A". Tie		ALF (100%)
	George Washington –		
	Moundsville 69 kV circuit to		
	George Washington – West		
	Bellaire 69 kV circuit		
	Rebuild existing 69 kV line		
	as double circuit from		
	George Washington – Dilles		
b2753.8	Bottom 138 kV. One circuit		A = D(1000/)
	will cut into Dilles Bottom		AEP (100%)
	138 kV initially and the other		
	will go past with future plans		
	to cut in		

Required Tr	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line		AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer		AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line		AEP (100%)
b2761.3	Rebuild the Hazard – Wooton 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)		AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line		AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2		AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1		<i>EKPC</i> (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville138 kV line		AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station		AEP (100%)

Required Tr	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
	Construct a new 345/138 kV		
b2779.3	SDI Wilmington Station		
	which will be sourced from		AEP (100%)
	Collingwood 345 kV and		
	serve the SDI load at 345 kV		
	and 138 kV, respectively		
	Loop 138 kV circuits in-out		
	of the new SDI Wilmington		
	138 kV station resulting in a		
	direct circuit to Auburn 138		
1.0770.4	kV and an indirect circuit to		
62779.4	Auburn and Rob Park via		AEP (100%)
	Dunton Lake, and a circuit to		
	Campbell Road; Reconductor		
	138 kV line section between		
	Dunton Lake – SDI		
	Wilmington		
b2779.5	Expand Auburn 138 kV bus		AEP (100%)
	Construct a 345 kV ring bus		
h2770 6	at Dunton Lake to serve Steel		A = D (1000/)
<u>02779.0</u>	Dynamics, Inc. (SDI) load at		<u>AEP (100%)</u>
	345 kV via two (2) circuits		
b2770.7	Retire Collingwood 345 kV		A E P (100%)
02119.1	station		<u>ALF (100%)</u>
	Reconductor 0.53 miles (14		
	spans) of the Kaiser Jct Air		
	Force Jct. Sw section of the		
b2787	Kaiser - Heath 69 kV		AFP (100%)
02707	circuit/line with 336 ACSR to		ALI (10070)
	match the rest of the circuit		
	(73 MVA rating, 78%		
	loading)		

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2788	Install a new 3-way 69 kV line switch to provide service to AEP's Barnesville distribution station. Remove a portion of the #1 copper T- Line from the 69 kV through- path	AEP (100%)
b2789	Rebuild the Brues - Glendale Heights 69 kV line section (5 miles) with 795 ACSR (128 MVA rating, 43% loading)	AEP (100%)

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
	Install a 3 MVAR, 34.5 kV		
b2790	cap bank at Caldwell		AEP (100%)
	substation		
b2701	Rebuild Tiffin – Howard, new		A ED (100%)
02791	transformer at Chatfield		ALF (100%)
	Rebuild portions of the East		
	Tiffin - Howard 69 kV line		
	from East Tiffin to West		
b2791.1	Rockaway Switch (0.8 miles)		AEP (100%)
	using 795 ACSR Drake		
	conductor (129 MVA rating,		
	50% loading)		
	Rebuild Tiffin - Howard 69		
	kV line from St. Stephen's		
	Switch to Hinesville (14.7		
b2791.2	miles) using 795 ACSR		AEP (100%)
	Drake conductor (90 MVA		
	rating, non-conductor limited,		
	38% loading)		
	New 138/69 kV transformer		
b2791.3	with 138/69 kV protection at		AEP (100%)
	Chatfield		
b2791 /	New 138/69 kV protection at		$\Delta FP(100\%)$
02771.4	existing Chatfield transformer		MLI (100%)
	Replace the Elliott		
	transformer with a 130 MVA		
	unit, reconductor 0.42 miles		
	of the Elliott – Ohio		
h2702	University 69 kV line with		A FP (100%)
62792	556 ACSR to match the rest		ALI (100%)
	of the line conductor (102		
	MVA rating, 73% loading)		
	and rebuild 4 miles of the		
	Clark Street – Strouds R		

Required Tra	ansmission Enhancements	Annual Revenue Requirer	ment Responsible Customer(s)
	Energize the spare Fremont		
	Center 138/69 kV 130 MVA		
b2793	transformer #3. Reduces		AEP (100%)
	overloaded facilities to 46%		
	loading		
	Construct new 138/69/34 kV		
	station and 1-34 kV circuit		
	(designed for 69 kV) from new		
b2794	station to Decliff station,		AEP (100%)
	approximately 4 miles, with		
	556 ACSR conductor (51		
	MVA rating)		
	Install a 34.5 kV 4.8 MVAR		
b2795	capacitor bank at Killbuck		AEP (100%)
	34.5 kV station		
	Rebuild the Malvern - Oneida		
1.2706	Switch 69 kV line section with		AED (1000/)
02796	795 ACSR (1.8 miles, 125		AEP (100%)
	MVA rating, 55% loading)		
	Rebuild the Ohio Central -		
	Conesville 69 kV line section		
	(11.8 miles) with 795 ACSR		
b2797	conductor (128 MVA rating,		AEP (100%)
	57% loading). Replace the 50		
	MVA Ohio Central 138/69 kV		
	XFMR with a 90 MVA unit		
	Install a 14.4 MVAR capacitor		
	bank at West Hicksville		
h2709	station. Replace ground		A = D (1000/)
02798	switch/MOAB at West		AEP (100%)
	Hicksville with a circuit		
	switcher		
	Rebuild Valley - Almena,		
	Almena - Hartford, Riverside -		
b2799	South Haven 69 kV lines.		A = D (1000/)
	New line exit at Valley		AEP(100%)
	Station. New transformers at		
	Almena and Hartford		

Required Tr	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSP conductor		
b2799.1	(360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station		AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)		AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)		AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker		AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley		AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker		AEP (100%)

Required Transmission Enhancements		Annual Revenue Requir	ement Responsible Customer(s)
b2817	Replace Delaware 138 kV breaker 'P' with a 40 kA		AEP (100%)
	breaker		· · · ·
	Replace West Huntington 138		
b2818	kV breaker 'F' with a 40 kA		AEP (100%)
	breaker		
	Replace Madison 138 kV		
b2819	breaker 'V' with a 63 kA		AEP (100%)
	breaker		
	Replace Sterling 138 kV		
b2820	breaker 'G' with a 40 kA		AEP (100%)
	breaker		
	Replace Morse 138 kV		
h2821	breakers '103', '104', '105',	AEP (100%)	AEP(100%)
02021	and '106' with 63 kA		AEI (100%)
	breakers		
	Replace Clinton 138 kV		
b2822	breakers '105' and '107' with		AEP (100%)
	63 kA breakers		
	Install 300 MVAR reactor at		
b2826.1	Ohio Central 345 kV		AEP (100%)
	substation		

b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation	AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)	DFAX Allocation: Dayton (61.71%) / DEOK (37.68%) / OVEC (0.61%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit	AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor	DFAX Allocation: AEP (80.83%) / Dayton (18.73%) / OVEC (0.44%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit	AEP (100%)
b2872	Replace the South Canton 138 kV breaker 'K2' with a 80 kA breaker	AEP (100%)
b2873	Replace the South Canton 138 kV breaker "M" with a 80 kA breaker	AEP (100%)
b2874	Replace the South Canton 138 kV breaker "M2" with a 80 kA breaker	AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers	AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)	AEP (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tr	ansmission Enhancements	Annual Revenue Require	ment Responsible Customer(s)
	Rebuild ~1.7 miles of the		
	Dunn Hollow – London 46		
h2881	kV line section utilizing 795		AED (100%)
02001	26/7 ACSR conductor (58		ALF (100%)
	MVA rating, non-conductor		
	limited)		
	Rebuild Reusens - Peakland		
b2882	Switch 69 kV line. Replace		AEP (100%)
	Peakland Switch		
	Rebuild the Reusens -		
	Peakland Switch 69 kV line		
1.0000 1	(approximately 0.8 miles)		A ED (1000/)
02882.1	utilizing 795 ACSR		AEP (100%)
	conductor (86 MVA rating,		
	non-conductor limited)		
	Replace existing Peakland S.S		
b2882.2	with new 3 way switch phase		AEP (100%)
	over phase structure		
	Rebuild the Craneco – Pardee		
	– Three Forks – Skin Fork 46		
62002	kV line section		A E D (1000/)
02885	(approximately 7.2 miles)		AEP (100%)
	utilizing 795 26/7 ACSR		
	conductor (108 MVA rating)		
	Install a second transformer at		
	Nagel station, comprised of 3		
	single phase 250 MVA		
	500/138 kV transformers.		
h7881	Presently, TVA operates their		A ED (100%)
02004	end of the Boone Dam –		ALF (100%)
	Holston 138 kV		
	interconnection as normally		
	open preemptively for the loss		
	of the existing Nagel		
h2885	New delivery point for City		AEP (100%)
02003	of Jackson		ALI (10070)

Required Tr	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Install a new Ironman Switch		
	to serve a new delivery point		
b2885.1	requested by the City of		AEP (100%)
	Jackson for a load increase		
	request		
	Install a new 138/69 kV		
	station (Rhodes) to serve as a		
b2885.2	third source to the area to help		AEP (100%)
	relieve overloads caused by		
	the customer load increase		
	Replace Coalton Switch with		
b2885.3	a new three breaker ring bus		AEP (100%)
	(Heppner)		
	Install 90 MVA 138/69 kV		
	transformer, new transformer		
h7886	high and low side 3000 A 40		A E D (1000%)
02000	kA CBs, and a 138 kV 40 kA		ALF (100%)
	bus tie breaker at West End		
	Fostoria		
	Add 2-138 kV CB's and		
	relocate 2-138 kV circuit exits		
h2887	to different bays at Morse		A E D (1000%)
02007	Road. Eliminate 3 terminal		AEI (100%)
	line by terminating Genoa -		
	Morse circuit at Morse Road		
	Retire Poston substation.		
b2888	Install new Lemaster		AEP (100%)
	substation		
h2888 1	Remove and retire the Poston		A E P (100%)
02000.1	138 kV station		AEF (100%)
	Install a new greenfield		
b2888.2	station, Lemaster 138 kV		AEP (100%)
	Station, in the clear		

Required Tr	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Relocate the Trimble 69 kV		
	AEP Ohio radial delivery		
	point to 138 kV, to be served		
h7888 3	off of the Poston – Strouds		A E D (1000%)
02000.3	Run – Crooksville 138 kV		ALF (100%)
	circuit via a new three-way		
	switch. Retire the Poston -		
	Trimble 69 kV line		
b2889	Expand Cliffview station		AEP (100%)
	Cliffview Station: Establish		
	138 kV bus. Install two		
h2000 1	138/69 kV XFRs (130 MVA),		A ED (1000/)
02009.1	six 138 kV CBs (40 kA 3000		ALF (100%)
	A) and four 69 kV CBs (40		
	kA 3000 A)		
	Byllesby – Wythe 69 kV:		
h2889.2	Retire all 13.77 miles (1/0		$\Delta FP(100\%)$
02007.2	CU) of this circuit (~4 miles		MLI (10070)
	currently in national forest)		
	Galax – Wythe 69 kV: Retire		
	13.53 miles ($1/0$ CU section)		
	of line from Lee Highway		
	down to Byllesby. This		
b28893	section is currently double		AEP (100%)
02007.5	circuited with Byllesby –		
	Wythe 69 kV. Terminate the		
	southern 3/0 ACSR section		
	into the newly opened		
	position at Byllesby		
	Cliffview Line: Tap the		
	existing Pipers Gap – Jubal		
	Early 138 kV line section.		
b2889.4	Construct double circuit		AEP (100%)
	in/out (~2 miles) to newly		
	established 138 kV bus,		
	utilizing 795 26/7 ACSR		
	conductor		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	ment Responsible Customer(s)
	Rebuild 23.55 miles of the		
	East Cambridge – Smyrna		
b2890.1	34.5 kV circuit with 795		AEP (100%)
	ACSR conductor (128 MVA		
	rating) and convert to 69 kV		
	East Cambridge: Install a		
	2000 A 69 kV 40 kA circuit		
b2890.2	breaker for the East		AEP (100%)
	Cambridge – Smyrna 69 kV		
	circuit		
	Old Washington: Install 69		
b2890.3	kV 2000 A two way phase		AEP (100%)
	over phase switch		
h2800 /	Install 69 kV 2000 A two way		A EP (100%)
02070.4	phase over phase switch		ALI (100%)
	Rebuild the Midland Switch		
	to East Findlay 34.5 kV line		
b2891	(3.31 miles) with 795 ACSR		AEP (100%)
	(63 MVA rating) to match		
	other conductor in the area		
	Install new 138/12 kV		
	transformer with high side		
	circuit switcher at Leon and a		
	new 138 kV line exit towards		
h2892	Ripley. Establish 138 kV at		AFP (100%)
02072	the Ripley station with a new		
	138/69 kV 130 MVA		
	transformer and move the		
	distribution load to 138 kV		
	service		
	Rebuild approximately 6.7		
	miles of 69 kV line between		
	Mottville and Pigeon River		
b2936.1	using 795 ACSR conductor		AEP (100%)
02/0011	(129 MVA rating). New		
	construction will be designed		
	to 138 kV standards but		
	operated at 69 kV		

Required Tr	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA		
b2936.2	breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker		AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor		AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature		AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances		AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station		AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station		AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit		AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
b2988	Replace the Twin Branch 345 kV breaker "JM" with 63 kA		
	substation works including switches, bus leads, control cable and new DICM		AEP (100%)
b2993	Rebuild the Torrey – South Gambrinus Switch – Gambrinus Road 69 kV line section (1.3 miles) with 1033 ACSR 'Curlew' conductor and steel poles		AEP (100%)
b3000	Replace South Canton 138 kV breaker 'N' with an 80kA breaker		AEP (100%)
b3001	Replace South Canton 138 kV breaker 'N1' with an 80kA breaker		AEP (100%)
b3002	Replace South Canton 138 kV breaker 'N2' with an 80kA breaker		AEP (100%)
b3036	Rebuild 15.6 miles of Haviland - North Delphos 138 kV line		AEP (100%)
b3037	Upgrades at the Natrium substation		AEP (100%)
b3038	Reconductor the Capitol Hill – Coco 138 kV line section		AEP (100%)
b3039	Line swaps at Muskingum 138 kV station		AEP (100%)
b3040.1	Rebuild Ravenswood – Racine tap 69 kV line section (~15 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Require	ment Responsible Customer(s)
	Rebuild existing Ripley – Ravenswood 69 kV circuit		
b3040.2	(~9 miles) to 69 kV standards,		AEP (100%)
	utilizing 795 26/7 ACSR		
	conductor		
	Install new 3-way phase over		
h2040.2	phase switch at Sarah Lane		A E D (1000/)
03040.3	station to replace the retired		AEF (100%)
	switch at Cottageville		
	Install new 138/12 kV 20		
	MVA transformer at Polymer		
b3040.4	station to transfer load from		AFP (100%)
05010.1	Mill Run station to help		(10070)
	address overload on the 69		
	kV network		
b3040.5	Retire Mill Run station		AEP (100%)
h2010 6	Install 28.8 MVAR cap bank		A E P (100%)
03040.0	at South Buffalo station		AEF (100%)
b3051.2	Adjust CT tap ratio at		AFP (100%)
05051.2	Ronceverte 138 kV		
	Reconductor Kammer –		
	George Washington 138 kV		
b3085	line (approx. 0.08 mile).		AEP (100%)
	Replace the wave trap at		
	Kammer 138 kV		
	Rebuild New Liberty –		
b3086.1	Findlay 34 kV line Str's $1-37$		AEP (100%)
	(1.5 miles), utilizing /95 26/7		
	ACSR conductor		
	Rebuild New Liberty – North		
b3086.2	Baltimore 34 KV line Str's 1-		AEP (100%)
	11 (0.5 mile), utilizing 795		
	26/ / ACSK conductor		

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
	Rebuild West Melrose –		
h3086 3	Whirlpool 34 kV line Str's		$\Delta ED(100\%)$
03000.3	55–80 (1 mile), utilizing 795		ALF (100%)
	26/7 ACSR conductor		
	North Findlay station: Install		
	a 138 kV 3000A 63kA line		
h2096 1	breaker and low side 34.5 kV		A = D (1000/)
03080.4	2000A 40kA breaker, high		AEP (100%)
	side 138 kV circuit switcher		
	on T1		
	Ebersole station: Install		
	second 90 MVA 138/69/34		
b3086.5	kV transformer. Install two		AEP (100%)
	low side (69 kV) 2000A		
	40kA breakers for T1 and T2		
	Construct a new greenfield		
	station to the west (approx.		
	1.5 miles) of the existing		
	Fords Branch Station in the		
	new Kentucky Enterprise		
	Industrial Park. This station		
	will consist of six 3000A		
b3087.1	40kA 138 kV breakers laid		AEP (100%)
	out in a ring arrangement, two		
	30 MVA 138/34.5 kV		
	transformers, and two 30		
	MVA 138/12 kV		
	transformers. The existing		
	Fords Branch Station will be		
	retired		
	Construct approximately 5		
	miles of new double circuit		
h2007 2	138 kV line in order to loop		$\mathbf{AED}(1000/)$
03087.2	the new Kewanee station into		AEP(100%)
	the existing Beaver Creek –		
	Cedar Creek 138 kV circuit		

Required Tr	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Remote end work will be		
b3087.3	required at Cedar Creek		AEP (100%)
	Station		
	Install 28.8 MVar switching		
b3087.4	shunt at the new Fords		AEP (100%)
	Branch substation		
	Rebuild Lakin – Racine Tap		
h2005	69 kV line section (9.2 miles)		A E D (1000%)
03093	to 69 kV standards, utilizing		AEF (100%)
	795 26/7 ACSR conductor		
	Install a 138 kV 3000A 40 kA		
	circuit switcher on the high		
b3099	side of the existing 138/34.5		AEP (100%)
	kV transformer No.5 at		
	Holston station		
	Replace the 138 kV MOAB		
	switcher "YY" with a new		
b3100	138 kV circuit switcher on the		AEP (100%)
	high side of Chemical		
	transformer No.6		
	Rebuild the 1/0 Cu. conductor		
	sections (approx. 1.5 miles) of		
	the Fort Robinson – Moccasin		
	Gap 69 kV line section		
h2101	(approx. 5 miles) utilizing		A = D (1000%)
03101	556 ACSR conductor and		AEF (100%)
	upgrade existing relay trip		
	limit (WN/WE: 63 MVA, line		
	limited by remaining		
	conductor sections)		
	Replace existing 50 MVA		
	138/69 kV transformers #1		
b3102	and #2 (both 1957 vintage) at		AEP (100%)
	Fremont station with new 130		
	MVA 138/69 kV transformers		

Required Tr	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Install a 138/69 kV		
	transformer at Royerton		
	station. Install a 69 kV bus		
	with one 69 kV breaker		
b3103.1	toward Bosman station.		AEP (100%)
05105.1	Rebuild the 138 kV portion		(100/0)
	into a ring bus configuration		
	built for future breaker and a		
	half with four 138 kV		
	breakers		
	Rebuild the		
	Bosman/Strawboard station in		
h2102.2	the clear across the road to		A E D (1000%)
03103.2	move it out of the flood plain		ALF (100%)
	and bring it up to 69 kV		
	standards		
	Retire 138 kV breaker L at		
h2102.2	Delaware station and re-		A E D (1000%)
03103.3	purpose 138 kV breaker M		ALF (100%)
	for the Jay line		
	Retire all 34.5 kV equipment		
b3103.4	at Hartford City station. Re-		A E D (1000%)
03103.4	purpose breaker M for the		ALF (100%)
	Bosman line 69 kV exit		
	Rebuild the 138 kV portion of		
	Jay station as a 6 breaker,		
	breaker and a half station re-		
	using the existing breakers		
h2102 5	"A", "B", and "G." Rebuild		A E D (1000/)
05105.5	the 69 kV portion of this		AEP (100%)
	station as a 6 breaker ring bus		
	re-using the 2 existing 69 kV		
	breakers. Install a new 138/69		
	kV transformer		

Required Tr	ansmission Enhancements	Annual Revenue Require	ment Responsible Customer(s)
	Rebuild the 69 kV Hartford		
	City – Armstrong Cork line		
b3103.6	but instead of terminating it		AEP (100%)
	into Armstrong Cork,		
	terminate it into Jay station		
b3103.7	Build a new 69 kV line from		AEP (100%)
05105.7	Armstrong Cork – Jay station		71L1 (10070)
	Rebuild the 34.5 kV		
	Delaware – Bosman line as		
h2102.9	the 69 kV Royerton –		A E D (1000/)
03103.8	Strawboard line. Retire the		ALF (100%)
	line section from Royerton to		
	Delaware stations		
	Perform a sag study on the		
	Polaris – Westerville 138 kV		
h2104	line (approx. 3.6 miles) to		AED (1000/)
03104	increase the summer		AEP (100%)
	emergency rating to 310		
	MVA		
	Rebuild the Delaware – Hyatt		
	138 kV line (approx. 4.3		
b3105	miles) along with replacing		AEP (100%)
	conductors at both Hyatt and		
	Delaware substations		
	Perform a sag study (6.8		
	miles of line) to increase the		
	SE rating to 310 MVA. Note		
b3106	that results from the sag study		AEP (100%)
	could cover a wide range of		
	outcomes, from no work		
	required to a complete rebuild		
	Rebuild 5.2 miles Bethel –		
b3109	Sawmill 138 kV line		AEP (100%)
	including ADSS		

Required Tra	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Construct a single circuit 138		
	kV line (approx. 3.5 miles)		
	from Amlin to Dublin using		
	1033 ACSR Curlew (296		
b3112	MVA SN), convert Dublin		AEP (100%)
	station into a ring		
	configuration, and re-		
	terminating the Britton UG		
	cable to Dublin station		
	Replace existing Mullens		
	138/46 kV 30 MVA		
	transformer No.4 and		
h2116	associated protective		A E D (1000/)
03110	equipment with a new 138/46		AEP (100%)
	kV 90 MVA transformer and		
	associated protective		
	equipment		
	Expand existing Chadwick		
	station and install a second		
	138/69 kV transformer at a		
	new 138 kV bus tied into the		
	Bellefonte – Grangston 138		
L2110 1	kV circuit. The 69 kV bus		A ED (1000/)
03118.1	will be reconfigured into a		AEP (100%)
	ring bus arrangement to tie		
	the new transformer into the		
	existing 69 kV via installation		
	of four 3000A 63 kA 69 kV		
	circuit breakers		
h2110.0	Perform 138 kV remote end		$\overline{\mathbf{AED}(1000/)}$
03118.2	work at Grangston station		AEP (100%)
1.2110.2	Perform 138 kV remote end		
03118.3	work at Bellefonte station		AEP (100%)
	Relocate the Chadwick –		
b3118.4	Leach 69 kV circuit within		AEP (100%)
00110.1	Chadwick station		× /

Required Tra	ansmission Enhancements	Annual Revenue Requirement	ment Responsible Customer(s)
	Terminate the Bellefonte –		
b3118.5	Grangston 138 kV circuit to		AEP (100%)
	the Chadwick 138 kV bus		
	Chadwick – Tri-State #2 138		
	kV circuit will be		
	reconfigured within the		
b3118.6	station to terminate into the		AEP (100%)
	newly established 138 kV bus		
	#2 at Chadwick due to		
	construability aspects		
	Reconductor Chadwick –		
	Leach and Chadwick		
	England Hill 69 kV lines with		
	795 ACSS conductor.		
b3118.7	Perform a LiDAR survey and		AEP (100%)
	a sag study to confirm that the		
	reconductored circuits would		
	maintain acceptable		
	clearances		
	Replace the 20 kA 69 kV		
	circuit breaker 'F' at South		
121100	Neal station with a new		AED (1000/)
03118.8	3000A 40 kA 69 kV circuit		AEP (100%)
	breaker. Replace line risers		
	towards Leach station		
	Rebuild 336 ACSR portion of		
h2119.0	Leach – Miller S.S 69 kV line		A = D (1000/)
03116.9	section (approx. 0.3 mile)		AEP (100%)
	with 795 ACSS conductor		
	Replace 69 kV line risers		
b3118.10	(towards Chadwick) at Leach		AEP (100%)
	station		
	Rebuild the Jay – Pennville		
	138 kV line as double circuit		
10110 1	138/69 kV. Build a new 9.8		AED (1000/)
03119.1	mile single circuit 69 kV line		AEP (100%)
	from near Pennville station to		
	North Portland station		

Required Tr	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Install three (3) 69 kV		
	breakers to create the "U"		
b3119.2	string and add a low side		AEP (100%)
	breaker on the Jay		
	transformer 2		
	Install two (2) 69 kV breakers		
b31103	at North Portland station to		A EP (100%)
03117.5	complete the ring and allow		ALI (100%)
	for the new line		
	At Conesville 138 kV station:		
	Remove line leads to		
	generating units, transfer		
h3129	plant AC service to existing		AFP (100%)
03127	station service feeds in		ALL (10070)
	Conesville 345/138 kV yard,		
	and separate and reconfigure		
	protection schemes		
	At East Lima and Haviland		
	138 kV stations, replace line		
b3131	relays and wavetrap on the		AEP (100%)
	East Lima – Haviland 138 kV		
	facility		
	Rebuild 3.11 miles of the		
b3132	LaPorte Junction – New		AEP (100%)
05152	Buffalo 69 kV line with 795		
	ACSR		
	Rebuild the Garden Creek –		
b3139	Whetstone 69 kV line		AEP (100%)
	(approx. 4 miles)		
	Rebuild the Whetstone –		
b3140	Knox Creek 69 kV line		AEP (100%)
	(approx. 3.1 miles)		
	Rebuild the Knox Creek –		
b3141	Coal Creek 69 kV line		AEP (100%)
	(approx. 2.9 miles)		

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
b3148.1	Rebuild the 46 kV Bradley – Scarbro line to 96 kV standards using 795 ACSR to achieve a minimum rate of 120 MVA. Rebuild the new line adjacent to the existing one leaving the old line in service until the work is completed		AEP (100%)
b3148.2	Bradley remote end station work, replace 46 kV bus, install new 12 MVAR capacitor bank		AEP (100%)
b3148.3	Replace the existing switch at Sun substation with a 2-way SCADA-controlled motor- operated air-breaker switch		AEP (100%)
b3148.4	Remote end work and associated equipment at Scarbro station		AEP (100%)
b3148.5	Retire Mt. Hope station and transfer load to existing Sun station		AEP (100%)
b3149	Rebuild the 2.3 mile Decatur – South Decatur 69 kV line using 556 ACSR		AEP (100%)
b3150	Rebuild Ferguson 69/12 kV station in the clear as the 138/12 kV Bear station and connect it to an approx. 1 mile double circuit 138 kV extension from the Aviation – Ellison Road 138 kV line to remove the load from the 69 kV line		AEP (100%)

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
	Rebuild the 30 mile Gateway		
b3151 1	– Wallen 34.5 kV circuit as		A ED (1000%)
03131.1	the 27 mile Gateway –		ALF (100%)
	Wallen 69 kV line		
	Retire approx. 3 miles of the		
b3151.2	Columbia – Whitley 34.5 kV		AEP (100%)
	line		
	At Gateway station, remove		
	all 34.5 kV equipment and		
b3151.3	install one (1) 69 kV circuit		AEP (100%)
	breaker for the new Whitley		
	line entrance		
	Rebuild Whitley as a 69 kV		
b3151.4	station with two (2) lines and		AEP (100%)
	one (1) bus tie circuit breaker	ļ	
	Replace the Union 34.5 kV		
b3151.5	switch with a 69 kV switch		AEP (100%)
	structure	ļ	
	Replace the Eel River 34.5		
b3151.6	kV switch with a 69 kV		AEP (100%)
	switch structure		
h31517	Install a 69 kV Bobay switch		AFP (100%)
03131./	at Woodland station		······································
	Replace the Carroll and		
	Churubusco 34.5 kV stations		
	with the 69 kV Snapper		
h3151.8	station. Snapper station will		AFP (100%)
00101.0	have two (2) line circuit		(10070)
	breakers, one (1) bus tie		
	circuit breaker and a 14.4		
	MVAR cap bank		
	Remove 34.5 kV circuit		
b3151.9	breaker "AD" at Wallen		AEP (100%)
	station		
	Rebuild the 2.5 miles of the		
b3151.10	Columbia – Gateway 69 kV		AEP (100%)
	line		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.11	Rebuild Columbia station in the clear as a 138/69 kV station with two (2) 138/69 kV transformers and 4- breaker ring buses on the high		AEP (100%)
	and low side. Station will reuse 69 kV breakers "J" & "K" and 138 kV breaker "D"		
b3151.12	Rebuild the 13 miles of the Columbia – Richland 69 kV line		AEP (100%)
b3151.13	Rebuild the 0.5 mile Whitley – Columbia City No.1 line as 69 kV		AEP (100%)
b3151.14	Rebuild the 0.5 mile Whitley – Columbia City No.2 line as 69 kV		AEP (100%)
b3151.15	Rebuild the 0.6 mile double circuit section of the Rob Park – South Hicksville / Rob Park – Diebold Road as 69 kV		AEP (100%)
b3160.1	Construct an approx. 2.4 miles double circuit 138 kV extension using 1033 ACSR (Aluminum Conductor Steel Reinforced) to connect Lake Head to the 138 kV network		AEP (100%)
b3160.2	Retire the approx.2.5 miles 34.5 kV Niles – Simplicity Tap line		AEP (100%)
b3160.3	Retire the approx.4.6 miles Lakehead 69 kV Tap		AEP (100%)

Required Tra	ansmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
b3160.4	Build new 138/69 kV drop down station to feed Lakehead with a 138 kV breaker, 138 kV switcher, 138/69 kV transformer and a 138 kV Motor-Operated Air Break		AEP (100%)
b3160.5	Rebuild the approx. 1.2 miles Buchanan South 69 kV Radial Tap using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.6	Rebuild the approx.8.4 miles 69 kV Pletcher – Buchanan Hydro line as the approx. 9 miles Pletcher – Buchanan South 69 kV line using 795 ACSR (Aluminum Conductor Steel Reinforced)		AEP (100%)
b3160.7	Install a PoP (Point-of- Presence) switch at Buchanan South station with 2 line MOABs (Motor-Operated Air Break)		AEP (100%)

Required 7	Fransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Retire approximately 38		
	miles of the 44 mile Clifford		
	 Scottsville 46 kV circuit. 		
	Build new 138 kV "in and		
	out" to two new distribution		
	stations to serve the load		
	formerly served by Phoenix,		
	Shipman, Schuyler (AEP),		
	and Rockfish stations.		
	Construct new 138 kV lines		
b3208	from Joshua Falls – Riverville		AEP (100%)
	(approx. 10 miles) and		
	Riverville – Gladstone		
	(approx. 5 miles). Install		
	required station upgrades at		
	Joshua Falls, Riverville and		
	Gladstone stations to		
	accommodate the new 138		
	kV circuits. Rebuild Reusen –		
	Monroe 69 kV (approx. 4		
	miles)		
	Rebuild the 10.5 mile Berne –		
b3209	South Decatur 69 kV line		AEP (100%)
	using 556 ACSR		
	Replace approx. 0.7 mile		
b3210	Beatty – Galloway 69 kV line		AEP (100%)
	with 4000 kcmil XLPE cable		
h2220	Install 14.4 MVAR capacitor		A E P (1000%)
03220	bank at Whitewood 138 kV		ALF(100%)

Required Transmission Enhancements		Annual Revenue Requi	rement Responsible Customer(s)
<u>b3243</u>	Replace risers at the Bass 34.5 kV station		<u>AEP (100%)</u>
<u>b3244</u>	Rebuild approximately 9 miles of the Robinson Park – Harlan 69 kV line		<u>AEP (100%)</u>
<u>b3248</u>	Install a low side 69 kV circuit breaker at the Albion 138/69 kV transformer #1		<u>AEP (100%)</u>

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Install a 3000A 40 kA 138 kV		
	breaker on the high side of		
	<u>138/69 kV transformer #5 at</u>		
<u>b3253</u>	the Millbrook Park station.		<u>AEP (100%)</u>
	The transformer and		
	associated bus protection will		
	be upgraded accordingly		
	Upgrade 795 AAC risers at		
h2255	the Sand Hill 138 kV station		AED(100%)
03233	towards Cricket Switch with		<u>AEF (100%)</u>
	<u>1272 AAC</u>		
	Upgrade 500 MCM Cu risers		
	at Tidd 138 kV station		
<u>b3256</u>	towards Wheeling Steel;		<u>AEP (100%)</u>
	replace with 1272 AAC		
	<u>conductor</u>		
	Replace two spans of 336.4		
h3257	26/7 ACSR on the Twin		AED(100%)
03231	Branch – AM General #2		<u>ALI (100%)</u>
	<u>34.5 kV circuit</u>		
	Install a 3000A 63 kA 138 kV		
	breaker on the high side of		
	<u>138/69 kV transformer #2 at</u>		
<u>b3258</u>	Wagenhals station. The		<u>AEP (100%)</u>
	transformer and associated		
	bus protection will be		
	upgraded accordingly		
	At West Millersburg station,		
	replace the 138 kV MOAB on		
<u>b3259</u>	<u>the West Millersburg –</u>		<u>AEP (100%)</u>
	Wooster 138 kV line with a		
	<u>3000A 40 kA breaker</u>		
	Upgrade circuit breaker "R1"		
	at Tanners Creek 345 kV.		
h3261	Install Transient Recovery		
05201	Voltage capacitor to increase		
	the rating from 50 kA to 63		
	kA		AEP (100%)

Required 7	Transmission Enhancements	Annual Revenue Requiremen	t Responsible Customer(s)
	At West New Philadelphia		
	station, add a high side 138		
h3269	kV breaker on the 138/69 kV		$\Delta FP(100\%)$
03207	Transformer #2 along with a		MEI (10070)
	138 kV breaker on the line		
	towards Newcomerstown		
	Install 1.7 miles of 795 ACSR		
	138 kV conductor along the		
	other side of Dragoon Tap		
	138 kV line, which is		
	currently double circuit tower		
	with one position open.		
	Additionally, install a second		
h2270	138/34.5 kV transformer at		A E D (1000/)
05270	Dragoon, install a high side		AEF (100%)
	circuit switcher on the current		
	transformer at the Dragoon		
	Station, and install two (2)		
	138 kV line breakers on the		
	Dragoon – Jackson 138 kV		
	and Dragoon – Twin Branch		
	138 kV lines		
	Replace Dragoon 34.5 kV		
b3270.1	breakers "B", "C", and "D"		AEP (100%)
	with 40 kA breakers		
	Install a 138 kV circuit		
	breaker at Fremont station on		
h3271	the line towards Fremont		AEP(100%)
03271	Center and install a 9.6		AEI (100%)
	MVAR 69 kV capacitor bank		
	at Bloom Road station		
	Install two 138 kV circuit		
h2272	switchers on the high side of		A E D (1000)
63272	138/34.5 kV Transformers #1		AEF(100%)
	and #2 at Rockhill station		

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)		
		Rebuild and convert the		
		existing 17.6 miles East		
	<u>b3273.1</u>	Leipsic – New Liberty 34.5		<u>AEP (100%)</u>
		kV circuit to 138 kV using		
		795 ACSR		
		Convert the existing 34.5		
		kV equipment to 138 kV		
		and expand the existing		
		McComb station to the		
		north and east to allow for		
	b3273.2	new equipment to be		AEP (100%)
		installed. Install two (2)		
		new 138 kV box bays to		
		allow for line positions and		
		two (2) new 138/12 kV		
		transformers		
		Expand the existing East		
		Leipsic 138 kV station to		
		the north to allow for		
		another 138 kV line exit to		
		be installed. The new line		
		exit will involve installing		
	b3273.3	a new 138 kV circuit		AEP (100%)
		breaker, disconnect		
		switches and the addition		
		of a new dead end structure		
		along with the extension of		
		the existing 138 kV bus		
		work		
		Add one (1) 138 kV circuit		
		breaker and disconnect		
		switches in order to add an		
<u>t</u>	1 0 0 7 0 4	additional line position at		
	<u>b32/3.4</u>	New Liberty 138 kV		<u>AEP (100%)</u>
		station. Install line relaying		
		potential devices and retire		
		the 34.5 kV breaker 'F'		

Required Tra	ansmission Enhancements	Annual Revenue Requiremen	nt Responsible Customer(s)
<u>b3274</u>	Rebuild approximately 8.9 miles of 69 kV line between Newcomerstown and Salt Fork Switch with 556 ACSR		<u>AEP (100%)</u>
<u>b3275.1</u>	<u>Rebuild the Kammer Station</u> <u>– Cresaps Switch 69 kV line,</u> <u>approximately 0.5 mile</u>		<u>AEP (100%)</u>
<u>b3275.2</u>	<u>Rebuild the Cresaps Switch –</u> <u>McElroy Station 69 kV,</u> <u>approximately 0.67 mile</u>		<u>AEP (100%)</u>
<u>b3275.3</u>	Replace a single span of 4/0ACSR from Moundsville -Natrium structure 93L toCarbon Tap switch 69 kVlocated between theColombia Carbon and ConnerRun stations. Remainder ofthe line is 336 ACSR		<u>AEP (100%)</u>
<u>b3275.4</u>	Rebuild from Colombia Carbon to Columbia Carbon Tap structure 93N 69 kV, approximately 0.72 mile. The remainder of the line between Colombia Carbon Tap structure 93N and Natrium station is 336 ACSR and will remain		<u>AEP (100%)</u>
<u>b3275.5</u>	Replace the Cresaps 69 kV 3- Way Phase-Over-Phase switch and structure with a new 1200A 3-Way switch and steel pole		<u>AEP (100%)</u>
<u>b3275.6</u>	Replace 477 MCM Alum bus and risers at McElroy 69 kV station		<u>AEP (100%)</u>

Required Tra	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Replace Natrium 138 kV bus		
	existing between CB-BT1		
	and along the 138 kV Main		
	Bus #1 dropping to CBH1		
<u>b3275.7</u>	from the 500 MCM		<u>AEP (100%)</u>
	conductors to a 1272 KCM		
	AAC conductor. Replace the		
	dead end clamp and strain		
	insulators		
	Rebuild the 2/0 Copper		
	section of the Lancaster -		
	South Lancaster 69 kV line,		
h2276 1	approximately 2.9 miles of		A E D (1000/)
03270.1	the 3.2 miles total length with		<u>AEP (100%)</u>
	556 ACSR conductor. The		
	remaining section has a 336		
	ACSR conductor		
	Rebuild the 1/0 Copper		
	section of the line between		
h2276.2	Lancaster Junction and		A ED (1000%)
03270.2	Ralston station 69 kV,		<u>ALI (100%)</u>
	approximately 2.3 miles of		
	the 3.1 miles total length		
	Rebuild the 2/0 Copper		
	portion of the line between		
<u>b3276.3</u>	East Lancaster Tap and		<u>AEP (100%)</u>
	Lancaster 69 kV,		
	approximately 0.81 mile		
	Rebuild approximately 4		
	miles of existing 69 kV line		
	between West Mount Vernon		
	and Mount Vernon stations.		
<u>b3312</u>	Replace the existing 138/69		<u>AEP (100%)</u>
	kV transformer at West		
	Mount Vernon with a larger		
	90 MVA unit along with		
	existing 69 kV breaker 'C'		
SCHEDULE 12 – APPENDIX A

(18) Duquesne Light Company

riequireu r		
b2175.1	200 MVAR shunt reactor at Brunot Island 345 kV	DL (100%)
b2175.2	200 MVAR shunt reactor on future Brunot Island – Carson 345 kV circuit	DL (100%)
b2198	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-40 COLLIER'	DL (100%)
b2199	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-41 COLLIER'	DL (100%)
b2200	Revise the reclosing for the Crescent 138 kV breaker 'Z- 29 Beaver'	DL (100%)
b2201	Revise the reclosing for the Crescent 138 kV breaker 'Z- 82 VALLEY'	DL (100%)
b2202	Revise the reclosing for the Crescent 138 kV breaker 'Z- 21 NORTH'	DL (100%)
b2203	Revise the reclosing for the Elrama 138 kV breaker 'Z18-USX CLAI'	DL (100%)
b2204	Revise the reclosing for the Elrama 138 kV breaker 'Z13-WEST MIF'	DL (100%)
b2205	Revise the reclosing for the Elrama 138 kV breaker 'Z15 -DRAVOSBU'	DL (100%)
b2206	Revise the reclosing for the Woodville 138 kV breaker 'Z-106 PINEY'	DL (100%)
b2207	Revise the reclosing for the Woodville 138 kV breaker 'Z-64 COLLIER'	DL (100%)
b2208	Revise the reclosing for the Beaver Valley 138 kV breaker 'Z-28 CRESCEN'	DL (100%)

1		1
1.0000	Revise the reclosing for the	
b2209	Cheswick 138 kV breaker	DL (100%)
	Z-51 WILMERD'	
h2280	Replace the USAP 138kV	$DI_{(100\%)}$
02280	breaker 'XFMR'	DE (100%)
	Revise the reclosing to the	
L2202	Dravosburg 138kV breaker	$DI_{(1000)}$
02303	'Z73 West Mifflin' from 5	DL (100%)
	sec to 15 sec	
	Operate with the Crescent	
	345/138 kV #3	
	autotransformer in-service	
	by replacing 8 overdutied	
b2563	138 kV breakers at	DL (100%)
	Crescent, 3 138 kV breakers	
	at Beaver Valley, install #1	
	section 345 kV breaker for	
	331 circuit at Crescent	
	Replace the Oakland 138	
b2632	kV '7-101 Arsenal' breaker	DL (100%)
	Replace the Crescent	
h2639	138 kV (NO3 - 4.138)	$DI_{(100\%)}$
02037	hreaker with a $63kA$ breaker	DE (100%)
	Replace the Crescent 138	
b2640	kV '7-143 SWCKI V'	$DI_{(100\%)}$
02040	breaker with a $63k\Delta$ breaker	DE (100%)
	Replace the Crescent	
	138 kV '7 24 MONTOUP'	
b2641	brooker with a 62kA	DL (100%)
	breaker	
	Banlaga the Crassont	
h2612	129 1 AV (7 29 DE AVED)	DL(1000)
02042	138 KV Z-28 BEAVER	DL (100%)
	breaker with a 65kA breaker	
		AEC (0.99%) APS
		(66.14%)/ BGE (4.60%)/
	Reconductor approximately	DOM (8.81%)/ DPL
b2689.1	/ miles of the Woodville –	(5.83%)/ ECP (0.34%)/
	Peters (Z-117) 138 kV	HTP (0.04%)/ Neptune
	circuit	(0.12%)/ PECO (3.39%)/
		PEPCO (6.29%)/ PSEG
		(3.45%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required T	ransmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
b2689.2	Reconfigure West Mifflin- USS Clairton (Z-15) 138 kV circuit to establish Dravosburg-USS Clairton (Z-14) 138 kV circuit and West Mifflin-Wilson (Z-15) 138 kV circuit		AEC (0.99%)/ APS (66.14%)/ BGE (4.60%)/ DOM (8.81%)/ DPL (5.83%)/ ECP (0.34%)/ HTP (0.04%)/ Neptune (0.12%)/ PECO (3.39%)/ PEPCO (6.29%)/ PSEG (3.45%)
b3011.7	Replace the line terminal equipment and line breaker #85 at Dravosburg 138 kV substation in the Elwyn Z- 70 line position/bay, with the breaker duty as 63kA		DL (100%)
b3011.8	Upgrade 138 kV breaker "Z-78 Logans" at Dravosburg		DL (100%)
b3012.2	Construct two new ties from a new FirstEnergy substation to a new Duquesne substation by using two separate structures – Duquesne portion		ATSI (38.21%) / DL (61.79%)
b3012.4	Establish the new tie line in place of the existing Elrama – Mitchell 138 kV line		DL (100%)
b3015.1	Construct new Elrama 138 kV substation and connect 7 138 kV lines to new substation		DL (100%)
b3015.2	Reconductor Elrama to Wilson 138 kV line. 4.8 miles		APS (100%)
b3015.3	Reconductor Dravosburg to West Mifflin 138 kV line. 3 miles		DL (100%)
b3015.4	Run new conductor on existing tower to establish the new Dravosburg – Elrama (Z-75) circuit. 10 miles		DL (100%)

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3015.5	Reconductor Elrama to Mitchell 138 kV line – DL portion. 4.2 miles total. 2x795 ACSS/TW 20/7		DL (100%)
b3015.7	Reconductor Wilson to West Mifflin 138 kV line. 2 miles. 795 ACSS/TW 20/7		DL (100%)
b3061	Reconductor the West Mifflin – Dravosburg (Z-73) and Dravosburg – Elrama (Z-75) 138 kV lines		DL (100%)
b3062	Install 138 kV tie breaker at West Mifflin		DL (100%)
b3063	Reconductor the Wilson – Dravosburg (Z-72) 138 kV line (approx. 5 miles)		DL (100%)
b3064	Expand Elrama 138 kV substation to loop in existing US Steel Clariton – Piney Fork 138 kV line		DL (100%)
b3064.2	Replace the West Mifflin 138 kV breakers "Z-94", "Z-74", "Z-14", and "Z-13" with 63 kA breakers		DL (100%)
b3065	Install 138 kV tie breaker at Wilson		DL (100%)
b3084	Reconductor the Oakland – Panther Hollow 138 kV line (approx. 1 mile)		DL (100%)
b3212	The Crescent 138 kV oil- type breaker "2-5 TIE" is found to be overdutied following a model review and correction to short circuit base case		DL (100%)
b3217	Reconductor Wilson - Mitchell 138 kV line - DL portion		DL (100%)

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
<u>b3265</u>	Implement slow circulation on existing underground 138 kV high pressure fluid filled (HPFF) cable between the Arsenal and Riazzi substations		<u>DL (100%)</u>

SCHEDULE 12 – APPENDIX A

Required T	ransmission Enhancements Annua	al Revenue Requirement	Responsible Customer(s)
b1698.7	Replace Loudoun 230 kV breaker '203052' with 63kA rating		Dominion (100%)
b1696.1	Replace the Idylwood 230 kV '25112' breaker with 50kA breaker		Dominion (100%)
b1696.2	Replace the Idylwood 230 kV '209712' breaker with 50kA breaker		Dominion (100%)
b1793.1	Remove the Carolina 22 SPS to include relay logic changes, minor control wiring, relay resets and SCADA programming upon completion of project		Dominion (100%)
b2281	Additional Temporary SPS at Bath County		Dominion (100%)
b2350	Reconductor 211 feet of 545.5 ACAR conductor on 59 Line Elmont - Greenwood DP 115 kV to achieve a summer emergency rating of 906 amps or greater		Dominion (100%)
b2358	Install a 230 kV 54 MVAR capacitor bank on the 2016 line at Harmony Village Substation		Dominion (100%)
b2359	Wreck and rebuild approximately 1.3 miles of existing 230 kV line between Cochran Mill - X4-039 Switching Station		Dominion (100%)
b2360	Build a new 39 mile 230 kV transmission line from Dooms - Lexington on existing right- of-way		Dominion (100%)
b2361	Construct 230 kV OH line along existing Line #2035 corridor, approx. 2.4 miles from Idylwood - Dulles Toll Road (DTR) and 2.1 miles on new right-of-way along DTR to new Scott's Run Substation		Dominion (100%)

b2368	Replace the Brambleton 230 kV breaker '209502' with 63kA breaker	Dominion (100%)
b2369	Replace the Brambleton 230 kV breaker '213702' with 63kA breaker	Dominion (100%)
b2370	Replace the Brambleton 230 kV breaker 'H302' with 63kA breaker	Dominion (100%)
b2373	Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: APS (25.51%) / Dominion (74.49%)
b2397	Replace the Beaumeade 230 kV breaker '2079T2116' with 63kA	Dominion (100%)
b2398	Replace the Beaumeade 230 kV breaker '2079T2130' with 63kA	Dominion (100%)
b2399	Replace the Beaumeade 230 kV breaker '208192' with 63kA	Dominion (100%)
b2400	Replace the Beaumeade 230 kV breaker '209592' with 63kA	Dominion (100%)
b2401	Replace the Beaumeade 230 kV breaker '211692' with 63kA	Dominion (100%)
b2402	Replace the Beaumeade 230 kV breaker '227T2130' with 63kA	Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

The Annual Revenue Requirement for all Virginia Electric and Power Company projects in this Section 20 shall be as specified in Attachment 7 to Appendix A of Attachment H-16A and under the procedures detailed in Attachment H-16B.

*Neptune Regional Transmission System, LLC

b2403	Replace the Beaumeade 230 kV breaker '274T2130' with 63kA	Dominion (100%)
b2404	Replace the Beaumeade 230 kV breaker '227T2095' with 63kA	Dominion (100%)
b2405	Replace the Pleasant view 230 kV breaker '203T274' with 63kA	Dominion (100%)
b2443	Construct new underground 230 kV line from Glebe to Station C, rebuild Glebe Substation, construct 230 kV high side bus at Station C with option to install 800 MVA PAR	Dominion (97.11%) / ME (0.18%) / PEPCO (2.71%)
b2443.1	Replace the Idylwood 230 kV breaker '203512' with 50kA	Dominion (100%)
b2443.2	Replace the Ox 230 kV breaker '206342' with 63kA breaker	Dominion (100%)
b2443.3	Glebe – Station C PAR	DFAX Allocation: Dominion (22.57%) / PEPCO (77.43%)
b2443.6	Install a second 500/230 kV transformer at Possum Point substation and replace bus work and associated equipment as needed	Dominion (100%)
b2443.7	Replace 19 63kA 230 kV breakers with 19 80kA 230 kV breakers	Dominion (100%)
b2457	Replace 24 115 kV wood h-frames with 230 kV Dominion pole H-frame structures on the Clubhouse – Purdy 115 kV line	Dominion (100%)
b2458.1	Replace 12 wood H-frame structures with steel H- frame structures and install shunts on all conductor splices on Carolina – Woodland 115 kV	Dominion (100%)

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2458.2	Upgrade all line switches and substation components at Carolina 115 kV to meet or exceed new conductor rating of 174 MVA		Dominion (100%)
b2458.3	Replace 14 wood H-frame structures on Carolina – Woodland 115 kV		Dominion (100%)
b2458.4	Replace 2.5 miles of static wire on Carolina – Woodland 115 kV	;	Dominion (100%)
b2458.5	Replace 4.5 miles of conductor between Carolina 115 kV and Jackson DP 115 kV with min. 300 MVA summer STE rating; Replace 8 wood H-frame structures located between Carolina and Jackson DP with steel H-frames		Dominion (100%)
b2460.1	Replace Hanover 230 kV substation line switches with 3000A switches		Dominion (100%)
b2460.2	Replace wave traps at Four River 230 kV and Elmont 230 kV substations with 3000A wave traps		Dominion (100%)
b2461	Wreck and rebuild existing Remington CT – Warrenton 230 kV (approx. 12 miles) as a double-circuit 230 kV line	,	Dominion (100%)
b2461.1	Construct a new 230 kV line approximately 6 miles from NOVEC's Wheeler Substation a new 230 kV switching station in Vint Hill area	5	Dominion (100%)
b2461.2	Convert NOVEC's Gainesville – Wheeler line (approximately 6 miles) to 230 kV		Dominion (100%)
b2461.3	Complete a Vint Hill – Wheeler – Loudoun 230 kV networked line		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required T	ransmission Enhancements Annua	al Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
	Replace Midlothian 500 kV		DEOK (3.23%) / DL (1.73%) /
	operated switches with 3		DPL (2.65%) / Dominion
10471	breaker 500 kV ring bus.		(13.03%) / EKPC (1.77%) /
b24/1	Terminate Lines # 563 Carson		JCPL (3.84%) / ME (1.93%) /
	– Midlothian, #576		NEPTUNE* (0.45%) / OVEC
	Midlothian –North Anna, Transformer #2 in new ring		(0.07%) / PECO (5.29%) /
	Transformer #2 in new ring		PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Rebuild 115 kV Line #32		
	from Halifax-South Boston (6		
b2504	and transfer Welco tap to Line		
02304	#32. Moving Welco to Line		Dominion (100%)
	#32 requires disabling auto-		
	sectionalizing scheme		
	Install structures in river to		
b2505	(Whitestone-Harmony Village		
02303	115 kV) from bridge and		Dominion (100%)
	improve reliability of the line		
1.05.40	Replace the Loudoun 500 kV		
62542	$H_2 I 502$ breaker with a $50k\Delta$ breaker		Dominion (100%)
	Replace the Loudoun 500 kV		
b2543	'H2T584' breaker with a		$\mathbf{D}_{\text{aminion}}$ (100%)
	50kA breaker		Dominion (100%)
10565	Reconductor wave trap at		
b2565	Carver Substation with a 2000 A wave trap		Dominion (100%)
	Reconductor 1.14 miles of		
h2566	existing line between ACCA		
02300	and Hermitage and upgrade		Dominion (100%)
	associated terminal equipment		

Required T	ransmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Debuild the Elmont		(13.03%) / EKPC (1.77%) /
b2582	Cunningham 500 kV line		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Install 500 kV breaker at		
	Ox Substation to remove		
b2583	Ox Tx#1 from H1T561		Dominion (100%)
	breaker failure outage.		
	Relocate the Bremo load		
	(transformer #5) to #2028 (Bremo Charlottesville		
h2584	230 kV line and		Dominion (100%)
02301	Cartersville distribution		
	station to #2027 (Bremo-		
	Midlothian 230 kV) line		
	Reconductor 7.63 miles of		
h2585	Cranes and Stafford		PEPCO(100%)
02303	upgrade associated line		1 EI CO (100%)
	switches at Stafford		
	Wreck and rebuild the		
	Chesapeake – Deep Creek		
	- Bowers Hill - Hodges Forry 115 kV line:		
b2620	minimum rating 239		Dominion (100%)
	MVA normal/emergency,		
	275 MVA load dump		
	rating		

Required I		inual Revenue Requirement	Responsible Customer(s)
b2622	Rebuild Line #47 between Kings Dominion 115 kV and Fredericksburg 115 kV to current standards with summer emergency rating of 353 MVA at 115 kV		Dominion (100%)
b2623	Rebuild Line #4 between Bremo and Structure 8474 (4.5 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV		Dominion (100%)
b2624	Rebuild 115 kV Lines #18 and #145 between Possum Point Generating Station and NOVEC's Smoketown DP (approx. 8.35 miles) to current 230 kV standards with a normal continuous summer rating of 524 MVA at 115 kV		Dominion (100%)
b2625	Rebuild 115 kV Line #48 between Thole Street and Structure 48/71 to current standard. The remaining line to Sewells Point is 2007 vintage. Rebuild 115 kV Line #107 line, Sewells Point to Oakwood, between structure 107/17 and 107/56 to current standard.		Dominion (100%)
b2626	Rebuild 115 kV Line #34 between Skiffes Creek and Yorktown and the double circuit portion of 115 kV Line #61 to current standards with a summer emergency rating of 353 MVA at 115 kV		Dominion (100%)
b2627	Rebuild 115 kV Line #1 between Crewe 115 kV and Fort Pickett DP 115 kV (12.2 miles) to current standards with summer emergency rating of 261 MVA at 115 kV		Dominion (100%)

rtequireu r		au ne (enae negunement	
b2628	Rebuild 115 kV Line #82 Everetts – Voice of America (20.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV		Dominion (100%)
b2629	Rebuild the 115 kV Lines #27 and #67 lines from Greenwich 115 kV to Burton 115 kV Structure 27/280 to current standard with a summer emergency rating of 262 MVA at 115 kV		Dominion (100%)
b2630	Install circuit switchers on Gravel Neck Power Station GSU units #4 and #5. Install two 230 kV CCVT's on Lines #2407 and #2408 for loss of source sensing		Dominion (100%)
b2636	Install three 230 kV bus breakers and 230 kV, 100 MVAR Variable Shunt Reactor at Dahlgren to provide line protection during maintenance, remove the operational hazard and provide voltage reduction during light load conditions		Dominion (100%)
b2647	Rebuild Boydton Plank Rd – Kerr Dam 115 kV Line #38 (8.3 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)
b2648	Rebuild Carolina – Kerr Dam 115 kV Line #90 (38.7 miles) to current standards with summer emergency rating of 353 MVA 115 kV.		Dominion (100%)
b2649	Rebuild Clubhouse – Carolina 115 kV Line #130 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)

Required I	ransmission Ennancements Ann	ual Revenue Requirement	Responsible Customer(s)
b2649.1	Rebuild of 1.7 mile tap to Metcalf and Belfield DP (MEC) due to poor condition. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor		Dominion (100%)
b2649.2	Rebuild of 4.1 mile tap to Brinks DP (MEC) due to wood poles built in 1962. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR and 393.6 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor		Dominion (100%)
b2650	Rebuild Twittys Creek – Pamplin 115 kV Line #154 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)

Required Tra	ansmission Enhancements Annu	al Revenue Requirement	Responsible Customer(s)
b2651	Rebuild Buggs Island – Plywood 115 kV Line #127 (25.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV. The line should be rebuilt for 230 kV and operated at 115 kV.		Dominion (100%)
b2652	Rebuild Greatbridge – Hickory 115 kV Line #16 and Greatbridge – Chesapeake E.C. to current standard with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)
b2653.1	Build 20 mile 115 kV line from Pantego to Trowbridge with summer emergency rating of 353 MVA.		Dominion (100%)
b2653.2	Install 115 kV four-breaker ring bus at Pantego		Dominion (100%)
b2653.3	Install 115 kV breaker at Trowbridge		Dominion (100%)
b2654.1	Build 15 mile 115 kV line from Scotland Neck to S Justice Branch with summer emergency rating of 353 MVA. New line will be routed to allow HEMC to convert Dawson's Crossroads RP from 34.5 kV to 115 kV.		Dominion (100%)
b2654.2	Install 115 kV three-breaker ring bus at S Justice Branch		Dominion (100%)
b2654.3	Install 115 kV breaker at Scotland Neck		Dominion (100%)
b2654.3	Install a 2nd 224 MVA 230/115 kV transformer at Hathaway		Dominion (100%)

Required Tra	ansmission Enhancements Annu	ual Revenue Requirement	Responsible Customer(s)
Required Tra	Rebuild the Cunningham – Dooms 500 kV line	al Revenue Requirement	Responsible Customer(s) Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: Dominion (100%)
b2686	Pratts Area Improvement		Dominion (100%)
b2686.1	Build a 230 kV line from Remington Substation to Gordonsville Substation utilizing existing ROW		Dominion (100%)
b2686.2	Install a 3rd 230/115 kV transformer at Gordonsville Substation		Dominion (100%)
b2686.3	Upgrade Line 2088 between Gordonsville Substation and Louisa CT Station		Dominion (100%)
b2686.4	Replace the Remington CT 230 kV breaker "2114T2155" with a 63 kA breaker		Dominion (100%)
b2686.11	Upgrading sections of the Gordonsville – Somerset 115 kV circuit		Dominion (100%)
b2686.12	Upgrading sections of the Somerset – Doubleday 115 kV circuit		Dominion (100%)
b2686.13	Upgrading sections of the Orange – Somerset 115 kV circuit		Dominion (100%)
b2686.14	Upgrading sections of the Mitchell – Mt. Run 115 kV circuit		Dominion (100%)

*Neptune Regional Transmission System, LLC

Required IT		Alliual Revenue Require	ment Responsible Customer(s)
b2717.1	De-energize Davis – Rosslyn #179 and #180 69 kV lines		Dominion (100%)
b2717.2	Remove splicing and stop joints in manholes		Dominion (100%)
b2717.3	Evacuate and dispose of insulating fluid from various reservoirs and cables		Dominion (100%)
b2717.4	Remove all cable along the approx. 2.5 mile route, swab and cap-off conduits for future use, leave existing communication fiber in place		Dominion (100%)
b2719.1	Expand Perth substation and add a 115 kV four breaker ring		Dominion (100%)
b2719.2	Extend the Hickory Grove DP tap 0.28 miles to Perth and terminate it at Perth		Dominion (100%)
b2719.3	Split Line #31 at Perth and terminate it into the new ring bus with 2 breakers separating each of the line terminals to prevent a breaker failure from taking out both 115 kV lines		Dominion (100%)
b2720	Replace the Loudoun 500 kV 'H1T569' breakers with 50kA breaker		Dominion (100%)
b2729	Optimal Capacitors Configuration: New 175 MVAR capacitor at Brambleton, new 175 MVAR capacitor at Ashburn, new 300 MVAR capacitor at Shelhorm, new 150 MVAR capacitor at Liberty		AEC (1.96%) / BGE (14.37%) / Dominion (35.11%) / DPL (3.76%) / ECP (0.29%) / HTP (0.34%) / JCPL (3.31%) / ME (2.51%) / Neptune (0.63%) / PECO (6.26%) / PEPCO (20.23%) / PPL (3.94%) / PSEG (7.29%)

Required Tra	ansmission Enhancements Annua	Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
1-2744	Rebuild the Carson – Rogers		(13.03%) / EKPC (1.77%) /
D2744	Rd 500 kV circuit		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
		DFAX Allocation:	
			Dominion (100%)
	Rebuild 21.32 miles of		
b2745	existing line between		Dominion (100%)
	230 kV		
	Rebuild Line #137 Ridge Rd		
b2746 1	– Kerr Dam 115 kV, 8.0		Dominion (100%)
02740.1	miles, for 346 MVA summer		Dominion (100%)
	emergency rating Rebuild Line #1009 Ridge Rd		
	- Chase City 115 kV 9.5		
b2746.2	miles, for 346 MVA summer		Dominion (100%)
	emergency rating		
	Install a second 4.8 MVAR		
b2746.3	capacitor bank on the 13.8 KV		Dominion (100%)
	Ridge Rd		
	Install a Motor Operated		
	Switch and SCADA control		
b2747	between Dominion's		Dominion (100%)
	FirstEnergy's 115 kV line		
	Thousand gy STIJKV IIIC		

b2757	Install a +/-125 MVAr Statcom at Colington 230 kV	Dominion (100%)
b2758	Rebuild Line #549 Dooms – Valley 500kV	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: Dominion (100%)
b2759	Rebuild Line #550 Mt. Storm – Valley 500kV	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: APS (87 50%) / ATSI (0.37%)
		APS (87.50%) / ATSI (0.37%)

Required Tra	ansmission Ennancements Annual	Revenue Requirement	Responsible Customer(s)
b2800	The 7 mile section from Dozier to Thompsons Corner of line #120 will be rebuilt to current standards using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Line is proposed to be rebuilt on single circuit steel monopole structure		Dominion (100%)
b2801	Lines #76 and #79 will be rebuilt to current standard using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Proposed structure for rebuild is double circuit steel monopole structure		Dominion (100%)
b2802	Rebuild Line #171 from Chase City – Boydton Plank Road tap by removing end- of-life facilities and installing 9.4 miles of new conductor. The conductor used will be at current standards with a summer emergency rating of 393 MVA at 115kV		Dominion (100%)
b2815	Build a new Pinewood 115kV switching station at the tap serving North Doswell DP with a 115kV four breaker ring bus		Dominion (100%)
b2842	Update the nameplate for Mount Storm 500 kV "57272" to be 50kA breaker		Dominion (100%)
b2843	Replace the Mount Storm 500 kV "G2TY" with 50kA breaker		Dominion (100%)
b2844	Replace the Mount Storm 500 kV "G2TZ" with 50kA breaker		Dominion (100%)

Required In	ansinission Ennancements Annua	i Kevenue Keyunemeni	Responsible Customer(s)
b2845	Update the nameplate for Mount Storm 500 kV "G3TSX1" to be 50kA breaker		Dominion (100%)
b2846	Update the nameplate for Mount Storm 500 kV "SX172" to be 50kA breaker		Dominion (100%)
b2847	Update the nameplate for Mount Storm 500 kV "Y72" to be 50kA breaker		Dominion (100%)
b2848	Replace the Mount Storm 500 kV "Z72" with 50kA breaker		Dominion (100%)
b2871	Rebuild 230 kV line #247 from Swamp to Suffolk (31 miles) to current standards with a summer emergency rating of 1047 MVA at 230 kV		Dominion (100%)
b2876	Rebuild line #101 from Mackeys – Creswell 115 kV, 14 miles, with double circuit structures. Install one circuit with provisions for a second circuit. The conductor used will be at current standards with a summer emergency rating of 262 MVA at 115 kV		Dominion (100%)
b2877	Rebuild line #112 from Fudge Hollow – Lowmoor 138 kV (5.16 miles) to current standards with a summer emergency rating of 314 MVA at 138 kV		Dominion (100%)
b2899	Rebuild 230 kV line #231 to current standard with a summer emergency rating of 1046 MVA. Proposed conductor is 2-636 ACSR		Dominion (100%)
b2900	Build a new 230/115 kV switching station connecting to 230 kV network line #2014 (Earleys – Everetts). Provide a 115 kV source from the new station to serve Windsor DP		Dominion (100%)

Required In	ansmission Ennancements Annua	Revenue Requirement	Responsible Customer(s)
b2922	Rebuild 8 of 11 miles of 230 kV lines #211 and #228 to current standard with a summer emergency rating of 1046 MVA for rebuilt section. Proposed conductor is 2-636 ACSR		Dominion (100%)
b2928	Rebuild four structures of 500 kV line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the line #567 line rating from 1954 MVA to 2600 MVA		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: Dominion (100%)
b2929	Rebuild 230 kV line #2144 from Winfall to Swamp (4.3 miles) to current standards with a standard conductor (bundled 636 ACSR) having a summer emergency rating of 1047 MVA at 230 kV		Dominion (100%)
b2960	Replace fixed series capacitors on 500 kV Line #547 at Lexington and on 500 kV Line #548 at Valley		See sub-IDs for cost allocations

Required Tra	Insmission Enhancements Annua	Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Replace fixed series		(13.03%) / EKPC (1.77%) /
b2960.1	capacitors on 500 kV Line		JCPL (3.84%) / ME (1.93%) /
	#547 at Lexington		NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			DEOK (5.63%) / Dominion
			(91.06%) / EKPC (3.31%)

Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Replace fixed series		(13.03%) / EKPC (1.77%) /
b2960.2	capacitors on 500 kV Line		JCPL (3.84%) / ME (1.93%) /
	#548 at Valley		NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			DEOK (17.57%) / Dominion
			(74.24%) / EKPC (8.19%)
	Rebuild approximately 3		
b2961	miles of Line #205 & Line		Dominion (100%)
	#2003 from Chesterneid to		
	Split Line #227 (Brambleton		
1-20/22	– Beaumeade 230 kV) and		Dominion (100%)
02962	terminate into existing		
	Belmont substation		
h2062 1	Replace the Beaumeade 230		$\mathbf{D}_{\text{aminion}}(1000/)$
02902.1	63kA breaker		Dominion (100%)
	Replace the NIVO 230 kV		
b2962.2	breaker "2116T2130" with		Dominion (100%)
	63kA breaker		
	Reconductor the Woodbridge		
	segment of Line #2001 with		
b2963	1047 MVA conductor and		Dominion (100%)
	replace line terminal		()
	equipment at Possum Point,		
	Woodbridge, and Occoquan		

Required Tr	ansmission Enhancements Ann	ual Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%) /
			APS (5.61%) / ATSI (8.10%) /
			BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
	Install 2 125 MMAD		DEOK (3.23%) / DL (1.73%) /
	Install 2-125 WIVAR		DPL (2.65%) / Dominion
12079	STATCOWS at Rawings		(13.03%) / EKPC (1.77%) /
02978	and 1-125 MVAR		JCPL (3.84%) / ME (1.93%) /
	STATCOM at Clover 500		NEPTUNE* (0.45%) / OVEC
	k v substations		(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Rebuild 115 kV Line #43		
	between Staunton and		
h2080	Harrisonburg (22.8 miles)		Dominion (100%)
02980	to current standards with a		Dominion (100%)
	summer emergency rating		
	of 261 MVA at 115 kV		
	Rebuild 115 kV Line #29		
	segment between		
	Fredericksburg and Aquia		
	Harbor to current 230 kV		
	standards (operating at 115		
b2981	kV) utilizing steel H-frame		Dominion (100%)
	structures with 2-636		
	ACSR to provide a normal		
	continuous summer rating		
	of 524 MVA at 115 kV		
	(1047 MVA at 230 kV)		

*Neptune Regional Transmission System, LLC

Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
b2989	Install a second 230/115 kV Transformer (224 MVA) approximately 1 mile north of Bremo and tie 230 kV Line #2028 (Bremo – Charlottesville) and 115 kV Line #91 (Bremo - Sherwood) together. A three breaker 230 kV ring bus will split Line #2028 into two lines and Line #91 will also be split into two lines with a new three breaker 115 kV ring bus. Install a temporary 230/115 kV transformer at Bremo substation for the interim until the new substation is complete		Dominion (100%)
b2990	Chesterfield to Basin 230 kV line – Replace 0.14 miles of 1109 ACAR with a conductor which will increase the line rating to approximately 706 MVA		Dominion (100%)
b2991	Chaparral to Locks 230 kV line – Replace breaker lead		Dominion (100%)
b2994	Acquire land and build a new switching station (Skippers) at the tap serving Brink DP with a 115 kV four breaker ring to split Line #130 and terminate the end points		Dominion (100%)
b3018	Rebuild Line #49 between New Road and Middleburg substations with single circuit steel structures to current 115 kV standards with a minimum summer emergency rating of 261 MVA		Dominion (100%)

Required Tra	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Rebuild 500 kV Line #552		(13.03%) / EKPC (1.77%) /
b3019	Bristers to Chancellor – 21.6		JCPL (3.84%) / ME (1.93%) /
	miles long		NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (89.20%) / PEPCO
			(10.80%)
1 2010 1	Update the nameplate for		D · · · (1000()
63019.1	$\begin{array}{c} \text{Morrisville 500 kv breaker} \\ \text{``H1T594'' to be 50kA} \end{array}$		Dominion (100%)
	Update the nameplate for		
b3019.2	Morrisville 500 kV breaker		Dominion (100%)
	"H1T545" to be 50kA		

Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)	
			Load-Ratio Share Allocation:	
		Revenue Requirement Image: state stat	AEC (1.71%) / AEP (14.04%)	
			/ APS (5.61%) / ATSI (8.10%)	
		 / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) 		
			(13.14%) / Dayton (2.15%) /	
			DEOK (3.23%) / DL (1.73%) /	
			DPL (2.65%) / Dominion	
			(13.03%) / EKPC (1.77%) /	
	Rebuild 500 kV Line #574		JCPL (3.84%) / ME (1.93%) /	
b3020	Ladysmith to Elmont – 26.2		NEPTUNE* (0.45%) / OVEC	
	miles long		(0.07%) / PECO (5.29%) /	
			PENELEC (1.89%) / PEPCO	
			(3.82%) / PPL (4.72%) / PSEG	
			(6.21%) / RE (0.26%)	
			DFAX Allocation:	
			APS (16.36%) / DEOK	
			(11.61%) / Dominion (51.27%)	
			/ EKPC (5.30%) / PEPCO	
			(15.46%)	
			Load-Ratio Share Allocation:	
			AEC (1.71%) / AEP (14.04%)	
			/ APS (5.61%) / ATSI (8.10%)	
			/ BGE (4.36%) / ComEd	
			Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion	
		(13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) /		
	D 1 115001371		DPL (2.65%) / Dominion	
h3021	Ladysmith to Chancellor	(<i>13.03</i> %) / EK	(13.03%) / EKPC (1.77%) /	
03021	15.2 miles long		JCPL (3.84%) / ME (1.93%) /	
			NEPTUNE* (0.45%) / OVEC	
			(0.07%) / PECO (5.29%) /	
			PENELEC (1.89%) / PEPCO	
			(3.82%) / PPL (4.72%) / PSEG	
			(6.21%) / RE (0.26%)	
			DFAX Allocation:	
			Dominion (100%)	
	Reconductor Line #274			
	(Fleasant view – Asnburn – Beaumeade 230 kV) with a			
b3026	minimum rating of 1200		Dominion (100%)	
	MVA. Also upgrade terminal			
	equipment			

reequirea m		rite (enac ricequirement	
b3027.1	Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith substation		Dominion (100%)
b3027.2	Reconductor 230 kV Line #2089 between Ladysmith and Ladysmith CT substations to increase the line rating from 1047 MVA to 1225 MVA		Dominion (100%)
b3027.3	Replace the Ladysmith 500 kV breaker "H1T581" with 50kA breaker		Dominion (100%)
b3027.4	Update the nameplate for Ladysmith 500 kV breaker "H1T575" to be 50kA breaker		Dominion (100%)
b3027.5	Update the nameplate for Ladysmith 500 kV breaker "568T574" (will be renumbered as "H2T568") to be 50kA breaker		Dominion (100%)
b3055	Install spare 230/69 kV transformer at Davis substation		Dominion (100%)
b3056	Partial rebuild 230 kV Line #2113 Waller to Lightfoot		Dominion (100%)
b3057	Rebuild 230 kV Lines #2154 and #19 Waller to Skiffes Creek		Dominion (100%)
b3058	Partial rebuild of 230 kV Lines #265, #200 and #2051		Dominion (100%)
b3059	Rebuild 230 kV Line #2173 Loudoun to Elklick		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Custom

Required Ir	ansmission Ennancements Annua	Revenue Requirement	Responsible Customer(s)
b3060	Rebuild 4.6 mile Elklick – Bull Run 230 kV Line #295 and the portion (3.85 miles) of the Clifton – Walney 230 kV Line #265 which shares structures with Line #295		Dominion (100%)
b3088	Rebuild 4.75 mile section of Line #26 between Lexington and Rockbridge with a minimum summer emergency rating of 261 MVA		Dominion (100%)
b3089	Rebuild 230 kV Line #224 between Lanexa and Northern Neck utilizing double circuit structures to current 230 kV standards. Only one circuit is to be installed on the structures with this project with a minimum summer emergency rating of 1047 MVA		Dominion (100%)
b3090	Convert the overhead portion (approx. 1500 feet) of 230 kV Lines #248 & #2023 to underground and convert Glebe substation to gas insulated substation		Dominion (100%)
b3096	Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA		Dominion (100%)
b3097	Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA		Dominion (100%)
b3098	Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115 kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA		Dominion (100%)

b3098.1	Rebuild Balcony Falls 115 kV substation	Dominion (100%)
b3110.1	Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation	Dominion (100%)
b3110.2	Replace the Bull Run 230 kV breakers "200T244" and "200T295" with 50 kA breakers	Dominion (100%)
b3110.3	Replace the Clifton 230 kV breakers "201182" and "XT2011" with 63 kA breakers	Dominion (100%)
b3113	Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings	Dominion (100%)
b3114	Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change	Dominion (100%)
b3121	Rebuild Clubhouse – Lakeview 230 kV Line #254 with single- circuit wood pole equivalent structures at the current 230 kV standard with a minimum rating of 1047 MVA	Dominion (100%)

Required Tra	ansmission Enhancements Annual	l Revenue Requirement	Responsible Customer(s)
b3122	Rebuild Hathaway – Rocky Mount (Duke Energy Progress) 230 kV Line #2181 and Line #2058 with double circuit steel structures using double circuit conductor at current 230 kV standards with a minimum rating of 1047 MVA		Dominion (100%)
b3161.1	Split Chesterfield-Plaza 115 kV Line No. 72 by rebuilding the Brown Boveri tap line as double circuit loop in-and-out of the Brown Boveri Breaker station		Dominion (100%)
b3161.2	Install a 115 kV breaker at the Brown Boveri Breaker station. Site expansion is required to accommodate the new layout		Dominion (100%)
b3162	Acquire land and build a new 230 kV switching station (Stevensburg) with a 224 MVA, 230/115 kV transformer. Gordonsville- Remington 230 kV Line No. 2199 will be cut and connected to the new station. Remington-Mt. Run 115 kV Line No.70 and Mt. Run-Oak Green 115 kV Line No. 2 will also be cut and connected to the new station		Dominion (100%)
b3211	Rebuild the 1.3 mile section of 500 kV Line No. 569 (Loudoun – Morrisville) with single-circuit 500 kV structures at the current 500 kV standard. This will increase the rating of the line to 3424 MVA		Dominion (100%)
b3213	Install 2nd Chickahominy 500/230 kV transformer		Dominion (100%)
<u>b3213.1</u>	Replace the eight (8) Chickahominy 230 kV breakers with 63 kA breakers: "SC122", "205022", "209122", 210222-2", "28722", "H222", "21922" and "287T2129"		Dominion (100%)

	ansinission Ennancements Annua	Revenue Requirement	Responsible Customer(s)
	Install a second 230 kV circuit with a minimum		
	summer emergency rating of		
	1047 MVA between Lanexa		
	and Northern Next		
	substations. The second		
b3223.1	circuit will utilize the vacant		Dominion (100%)
	arms on the double-circuit		
	structures that are being		
	installed on Line #224		
	(Lanexa – Northern Next) as		
	part of the End-of-Life		
	rebuild project (b3089)		
	Expand the Northern Neck		
h3223 2	terminal from a 230 kV, 4-		Dominion (100%)
03223.2	breaker ring bus to a 6-		Dominion (100%)
	breaker ring bus		
	Expand the Lanexa terminal		
h3223 3	from a 6-breaker ring bus to a		Dominion (100%)
03223.3	breaker-and-a-half		
	arrangement		
	$\frac{\text{Convert 115 kV Line #1/2}}{115 kV Line #1/2}$		
	Liberty – Lomar and 115 KV		
	Line #19/ Cannon Branch –		
	Lomar to 230 kV to provide a		
	new 230 KV source between		
	Cannon Branch and Liberty.		
	<u>#172 Liberty</u> Lomer and		
1-2246-1	$\frac{\#1/2 \text{ Liberty} - \text{Lomar and}}{\text{Line} \#107 \text{ Company Branch}}$		$\mathbf{D}_{\text{restrict}}$ (1000/)
<u>D3240.1</u>	Line #197 Cannon Branch –		Dominion (100%)
	Domarticon Pobuild 0.36 mile		
	operation. Rebuild 0.30 mile		
	and Cannon Branch junction		
	Lines will have a summer		
	rating of		
	$1047 MV \Delta / 1047 MV \Delta$		
	$\frac{104/101/104/104/101/14}{(SN/SF)}$		
	Perform substation work for		
	the 115 kV to 230 kV line		
b3246.2	conversion at Liberty.		Dominion (100%)
b3223.1 b3223.2 b3223.3 <u>b3246.1</u> <u>b3246.2</u>	Wellington, Godwin, Pioneer.		
	Sandlot and Cannon Branch		

Required Tr	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
<u>b3246.3</u>	Extend 230 kV Line #2011 Cannon Branch – Clifton to Winters Branch by removing the existing Line #2011 termination at Cannon Branch and extending the line to Brickyard creating 230 kV Line #2011 Brickyard - Clifton. Extend a new 230 kV line between Brickyard and Winters Branch with a summer rating of 1572MVA/1572MVA (SN/SE)		<u>Dominion (100%)</u>
<u>b3246.4</u>	Perform substation work at Cannon Branch, Brickyard and Winters Branch for the 230 kV Line #2011 Cannon Branch – Clifton extension		<u>Dominion (100%)</u>
<u>b3246.5</u>	<u>Replace the Gainesville 230</u> <u>kV 40 kA breaker "216192"</u> <u>with a 50 kA breaker</u>		<u>Dominion (100%)</u>
b3247	Replace 13 towers with galvanized steel towers on Doubs – Goose Creek 500 kV. Reconductor 3 mile section with three (3) 1351.5 ACSR 45/7. Upgrade line terminal equipment at Goose Creek substation to support the 500 kV line rebuild		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: Dominion (100%)
<u>b3300</u>	Reconductor 230 kV Line #2172 from Brambleton to Evergreen Mills along with upgrading the line leads at Brambleton to achieve a summer emergency rating of 1574 MVA		<u>Dominion (100%)</u>

<u>Required In</u>	ansmission chinancements Annua	I Kevenue Kequitement	Responsible Customer(s)
<u>b3301</u>	Reconductor 230 kV Line #2210 from Brambleton to Evergreen Mills along with upgrading the line leads at Brambleton to achieve a summer emergency rating of 1574 MVA		<u>Dominion (100%)</u>
<u>b3302</u>	Reconductor 230 kV Line #2213 from Cabin Run to Yardley Ridge along with upgrading the line leads at Yardley to achieve a summer emergency rating of 1574 MVA		<u>Dominion (100%)</u>
<u>b3303.1</u>	Extend a new single circuit 230 kV Line #9250 from Farmwell substation to Nimbus substation		<u>Dominion (100%)</u>
<u>b3303.2</u>	Remove Beaumeade 230 kV Line #2152 line switch		<u>Dominion (100%)</u>
<u>b3304</u>	Midlothian area improvements for 300 MW load drop relief		<u>Dominion (100%)</u>
<u>b3304.1</u>	Cut 230 kV Line #2066 at Trabue junction		Dominion (100%)
<u>b3304.2</u>	Reconductor idle 230 kV <u>Line #242 (radial from</u> <u>Midlothian to Trabue</u> junction) to allow a minimum summer rating of 1047 MVA and connect to the section of 230 kV Line #2066 between <u>Trabue junction and</u> <u>Winterpock, re-number 230</u> <u>kV Line #242 structures to</u> <u>Line #2066</u>		<u>Dominion (100%)</u>
<u>b3304.3</u>	Use the section of idle 115 <u>kV Line #153, between</u> <u>Midlothian and Trabue</u> <u>junction to connect to the</u> <u>section of (former) 230 kV</u> <u>Line #2066 between Trabue</u> <u>junction and Trabue to create</u> <u>new Midlothian – Trabue</u> <u>lines with new line numbers</u> <u>#2218 and #2219</u>		<u>Dominion (100%)</u>
<u>b3304.4</u>	<u>Create new line terminations</u> <u>at Midlothian for the new</u> <u>Midlothian – Trabue 230 kV</u> <u>lines</u>		Dominion (100%)

SCHEDULE 12 – APPENDIX A

(23) American Transmission Systems, Inc.

Required Transmission Enhancements		Annual Revenue Requirement	Responsible Customer(s)
b2019.2	Terminate Burger – Longview 138 kV, Burger – Brookside 138 kV, Burger – Cloverdale 138 kV #1, and Burger – Harmon 138 kV #2 into Holloway substation; Loop Burger – Harmon #1 138 kV and Burger – Knox 138 kV into Holloway substation		ATSI (100%)
b2019.3	Reconfigure Burger 138 kV substation to accommodate two 138 kV line exits and generation facilities		ATSI (100%)
b2019.4	Remove both Burger 138 kV substations (East and West 138 kV buses) and all 138 kV lines on the property		ATSI (100%)
b2019.5	Terminate and de- energize the 138 kV lines on the last structure before the Burger Plant property		ATSI (100%)
b2122.1	Reconductor the ATSI portion of the Howard – Brookside 138 kV line		ATSI (100%)
b2122.2	Upgrade terminal equipment at Brookside on the Howard – Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)		ATSI (100%)
b2188	Revise the reclosing for the Bluebell 138 kV breaker '301-B-94'		ATSI (100%)
b2192	Replace the Longview 138 kV breaker '651-B- 32'		ATSI (100%)
b2193	Replace the Lowellville 138 kV breaker '1-10-B 4'		ATSI (100%)
Required'	Fransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
-----------	-----------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------	-------------------------
b2195	Replace the Roberts 138 kV breaker '601-B-60'		ATSI (100%)
b2196	Replace the Sammis 138 kV breaker '780-B-76'		ATSI (100%)
b2262	New Castle Generating Station – Relocate 138kV, 69kV, and 23kV controls from the generating station building to new control building		ATSI (100%)
b2263	Niles Generation Station – Relocate 138kV and 23kV controls from the generation station building to new control building		ATSI (100%)
b2265	Ashtabula Generating Station – Relocate 138kV controls from the generating station building to new control building		ATSI (100%)
b2284	Increase the design operating temperature on the Cloverdale – Barberton 138kV line		ATSI (100%)
b2285	Increase the design operating temperature on the Cloverdale – Star 138kV line		ATSI (100%)
b2301	Reconductor 0.7 miles of 605 ACSR conductor on the Beaver Black River 138kV line		ATSI (100%)
b2301.1	Wave trap and line drop replacement at Beaver (312/380 MVA SN/SE)		ATSI (100%)
b2349	Replace the East Springfield 138kV breaker 211-B-63 with 40kA		ATSI (100%)
b2367	Replace the East Akron 138kV breaker 36-B-46 with 40kA		ATSI (100%)

		1 1	
b2413	Replace a relay at McDowell 138 kV substation		ATSI (100%)
b2434	Build a new London – Tangy 138 kV line		ATSI (100%)
b2435	Build a new East Springfield – London #2 138 kV line		Dayton (100%)
b2459	Install +260/-150 MVAR SVC at Lake Shore		ATSI (100%)
b2492	Replace the Beaver 138 kV breaker '426-B-2' with 63kA breaker		ATSI (100%)
b2493	Replace the Hoytdale 138kV breaker '83-B-30' with 63kA breaker		ATSI (100%)
b2557	At Avon substation, replace the existing 345/138 kV 448 MVA #92 transformer with a 560 MVA unit		ATSI (100%)
b2558	Close normally open switch A 13404 to create a Richland J Bus – Richland K Bus 138 kV line		ATSI (100%)
b2559	Reconductor the Black River – Lorain 138 kV line and upgrade Black River and Lorain substation terminal end equipment		ATSI (100%)
b2560	Construct a second 138 kV line between West Fremont and Hayes substation on open tower position of the West Fremont –Groton –Hayes 138 kV line		ATSI (100%)
b2616	Addition of 4th 345/138 kV transformer at Harding		ATSI (100%)

b2673	Rebuild the existing double circuit tower line section from Beaver substation to Brownhelm Jct. approx. 2.8 miles	ATSI (100%)
b2674	Rebuild the 6.6 miles of Evergreen to Ivanhoe 138 kV circuit with 477 ACSS conductor	ATSI (100%)
b2675	Install 26.4 MVAR capacitor and associated terminal equipment at Lincoln Park 138 kV substation	ATSI (100%)
b2725	Build new 345/138 kV Lake Avenue substation w/ breaker and a half high side (2 strings), 2-345/138 kV transformers and breaker and a half (2 strings) low side (138 kV). Substation will tie Avon – Beaver 345 kV #1/#2 and Black River – Johnson #1/#2 lines	ATSI (100%)
b2725.1	Replace the Murray 138 kV breaker '453-B-4' with 40kA breaker	ATSI (100%)
b2742	Replace the Hoytdale 138 kV '83-B-26' and '83-B- 30' breakers with 63kA breakers	ATSI (100%)
b2753.4	Double capacity for 6 wire "Burger-Cloverdale No. 2" 138 kV line and connect at Holloway and "Point A"	ATSI (100%)
b2753.5	Double capacity for 6 wire "Burger-Longview" 138 kV line and connect at Holloway and "Point A"	ATSI (100%)
b2778	Add 2nd 345/138 kV transformer at Chamberlin substation	ATSI (100%)
b2780	Replace Bruce Mansfield 345 kV breaker 'B57' with an 80 kA breaker, and associated gang-operated disconnect switches D56 and D58	ATSI (100%)

b2869	Replace the Crossland 138 kV breaker "B-16" with a 40kA breaker	ATSI (100%)
b2875	Relocate the Richland to Ridgeville 138 kV line from Richland J bus to K, extend the K bus and install a new breaker	ATSI (100%)
b2896	Rebuild/Reconductor the Black River – Lorain 138 kV circuit	ATSI (100%)
b2897	Reconductor the Avon – Lorain 138 kV section and upgrade line drop at Avon	ATSI (100%)
b2898	Reconductor the Beaver – Black River 138 kV with 954Kcmil ACSS conductor and upgrade terminal equipment on both stations	ATSI (100%)
b2942.1	Install a 100 MVAR 345 kV shunt reactor at Hayes substation	ATSI (100%)
b2942.2	Install a 200 MVAR 345 kV shunt reactor at Bayshore substation	ATSI (100%)
b2972	Reconductor limiting span of Lallendorf – Monroe 345 kV	MISO (11.00%) / AEP (5.38%) / APS (4.27%) / ATSI (66.48%) / Dayton (2.71%) / Dominion (5.31%) / DL (4.85%)
b3031	Transfer load off of the Leroy Center - Mayfield Q2 138 kV line by reconfiguring the Pawnee substation primary source, via the existing switches, from the Leroy Center - Mayfield Q2 138 kV line to the Leroy Center - Mayfield Q1 138 kV line	ATSI (100%)

Required	ransmission Ennancements	Annual Revenue Requiremen	a Responsible Customer(s)
b3032	Greenfield - NASA 138 kV terminal upgrades: NASA substation, Greenfield exit: Revise CT tap on breaker B22 and adjust line relay settings; Greenfield substation, NASA exit: Revise CT tap on breaker B1 and adjust line relay settings; replace 336.4 ACSR line drop with 1033.5 AL		ATSI (100%)
b3033	Ottawa – Lakeview 138 kV reconductor and substation upgrades		ATSI (100%)
b3034	Lakeview – Greenfield 138 kV reconductor and substation upgrades		ATSI (100%).
b3066	Reconductor the Cranberry – Jackson 138 kV line (2.1 miles), reconductor 138 kV bus at Cranberry bus and replace 138 kV line switches at Jackson bus		ATSI (100%)
b3067	Reconductor the Jackson – Maple 138 kV line (4.7 miles), replace line switches at Jackson 138 kV and replace the line traps and relays at Maple 138 kV bus		ATSI (100%)
b3080	Reconductor the 138 kV bus at Seneca		ATSI (100%)
b3081	Replace the 138 kV breaker and reconductor the 138 kV bus at Krendale		ATSI (100%)

Required	Transmission Enhancements	Annual Revenue Requiremen	it Responsible Customer(s)
<u>b3123</u>	<u>At Sammis 345 kV station:</u> <u>Install a new control</u> <u>building in the switchyard,</u> <u>construct a new station</u> <u>access road, install new</u> <u>switchyard power supply to</u> <u>separate from existing</u> <u>generating station power</u> <u>service, separate all</u> <u>communications circuits,</u> <u>and separate all protection</u> <u>and controls schemes</u>		<u>ATSI (100%)</u>
b3124	Separate metering, station power, and communication at Bruce Mansfield 345 kV station		ATSI (100%)
b3127	At Bay Shore 138 kV station: Install new switchyard power supply to separate from existing generating station power service, separate all communications circuits, and construct a new station access road		ATSI (100%)
b3152	Reconductor the 8.4 mile section of the Leroy Center – Mayfield Q1 line between Leroy Center and Pawnee Tap to achieve a rating of at least 160 MVA / 192 MVA (SN/SE)		ATSI (100%)
<u>b3234</u>	Extend both the east and west 138 kV buses at Pine substation, and install one (1) 138 kV breaker, associated disconnect switches, and one (1) 100 MVAR reactor		<u>ATSI (100%)</u>
<u>b3235</u>	Extend 138 kV bus work to the west of Tangy substation for the addition of the 100 MVAR reactor bay and one (1) 138 kV 40 kA circuit breaker		<u>ATSI (100%)</u>
<u>b3236</u>	Extend the Broadview 138 <u>kV</u> bus by adding two (2) <u>new breakers and</u> <u>associated equipment and</u> install a 75 MVAR reactor		<u>ATSI (100%)</u>

Required'	Transmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
	Replace the existing East		
	Akron 138 kV breaker 'B-		
	22' with 3000A		
<u>b3277</u>	continuous, 40 kA		<u>ATSI (100%)</u>
	momentary current		
	interrupting rating circuit		
	<u>breaker</u>		

SCHEDULE 12 – APPENDIX A

(25) East Kentucky Power Cooperative, Inc.

Required '	Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2066	Upgrade the operating temperature of the existing conductor for the JK Smith - Union City - Lake Reba Tap 138 kV line		EKPC (100%)
b2309	Upgrade the bus and jumpers with 750 MCM copper conductor at Green County 69 kV substation		EKPC (100%)
b2310	Increase the maximum operating temperature of the North Springfield - South Springfield 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2311	Increase the maximum operating temperature of the Loretto - Sulphur Creek 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2312	Increase the maximum operating temperature of the South Springfield - Loretto 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2313	Construct 8.8 miles of 69 kV line between the Cave City and Bon Ayr distribution substations. Operate this line normally open		EKPC (100%)
b2314.1	Construct 8.6 miles of 69 kV line between the Mercer County Industrial and Van Arsdell distribution substation. Construct a new 69 kV switching station adjacent to Bonds Bill Substation. Loop NorthSpringfield - Van Arsdell 69 kV line through South Anders		EKPC (100%)

Required	Transmission Enhancements	Annual Revenue Requiremen	nt Responsible Customer(s)
	Construct a new 69 kV		
	switching station ("South		
b2314.2	Anderson") adjacent to the		EKPC (100%)
	LGE/KU Bonds Mill		
	substation		
	Loop the North Springfield -		
	Van Arsdell 69 kV line		
	through South Anderson.		
	Terminate the existing 69		
h0214.2	kV to the LGE/KU Bonds		EVDC (1000)
02314.5	Mill substation at South		EKFC(100%)
	Anderson and establish a		
	second 69 kV from S.		
	Anderson to the LGE/KU		
	Bonds Mill sub		
	Construct 0.12 miles of 69		
	kV line from South		
	Anderson to the Powell		
b2314.4	Taylor distribution		EKPC (100%)
	substation and serve this		
	substation radially from		
	South Anderson		
	Increase the size of the		
h2215	existing HT Adams 69 kV,		EVDC (1000%)
02313	7.2 MVAR capacitor bank		EKFC(100%)
	to 14.28 MVAR		
	Increase the size of the		
h2316	existing Hunt Farm Junction		EKDC(100%)
02310	69 kV, 8.2 MVAR capacitor		EKI C (100%)
	bank to 16.33 MVAR		
	Construct 10.9 miles of 69		
	kV line between the Owen		
	County substation and the		
b2317	Keith distribution		EKPC (100%)
	substation. Operate the		
	existing Penn - Keith 69 kV		
	line normally - open		

Paquirad Transmission Enhancements Annual Payanua Paquirament Pasponsible Customer(s)

Required	Transmission Enhancements	Annual Revenue Requirement	nt Responsible Customer(s)
	Construct 2.7 miles of 69		
	kV line between the Fox		
	Hollow substation and the		
	Parkway distribution		
	substations. Serve the		
b2318	Parkway #1 and #2		EKPC (100%)
	distribution substations		
	radially from Fox Hollow.		
	Operate the Cave City - Bon		
	Ayr 69 kV line normally -		
	closed		
	Increase the maximum		
	operating temperature of the		
b2319	Helechawa - Sublett 69 kV		EKPC (100%)
	line to 167 degrees		
	Fahrenheit		
	Install a 69 kV, 15.31		
b2320	MVAR capacitor bank at		EKPC (100%)
	the Perryville substation		
	Install a 69 kV, 25.51		
b2321	MVAR capacitor bank at		EKPC (100%)
	the Veechdale substation		
	Change the CT setting on		
	circuit breaker N35 - 804 at		
	Dale Station to at least 800		
b2322	amps to increase the relay		EKPC (100%)
	loadability on the Dale -		
	Three Forks 138 kV line to		
	at least 282 MVA		
	Rebuild the existing		
	Cynthiana - Headquarters		
h2323	69 kV line using 556.5		EKPC (100%)
	MCM ACSR conductor and		
	operate this line normally		
	closed		
	Remove the existing 1200 -		
b2324	amp line traps at JK Smith		EKPC (100%)
	and Dale associated with the		× /
	JK Smith - Dale 138 kV line		

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2325	Increase the maximum operating temperature of the Glendale - Hodgenville 69 kV line to 212 degrees Fahrenheit		EKPC (100%)
b2326	Increase the maximum operating temperature of the Fayette - Davis 69 kV line to 248 degrees Fahrenheit		EKPC (100%)
b2327	Increase the maximum operating temperature of the Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit		EKPC (100%)
b2328	Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit		EKPC (100%)
b2329	Increase the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2330	Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit		EKPC (100%)
b2331	Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2332	Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit		EKPC (100%)

Required '	Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Increase the maximum		
	operating temperature of the		
b2333	Elizabethtown - Tunnel Hill		EKPC (100%)
	69 kV line to 284 degrees		
	Fahrenheit		
	Install a 69 kV, 28.06		
b2334	MVAR capacitor bank at		EKPC (100%)
	the Owen County substation		
	Install a 69 kV, 14.29		
h0225	MVAR capacitor bank at		EVDC (1000)
02555	the Magoffin County		EKPC (100%)
	substation		
	Increase the maximum		
	operating temperature of the		
b2336	South Corbin - Bacon Creek		EKPC (100%)
	69 kV line to 212 degrees		
	Fahrenheit		
	Increase the size of the		
h7227	existing Cedar Grove 69		EKDC(100%)
02337	kV, 10.8 MVAR capacitor		EKFC (100%)
	bank to 20.41 MVAR		
	Upgrade the 4/0 copper bus		
	and jumpers at the Nelson		
	County substation		
h2220	associated with the Nelson		EVDC $(1000/)$
02559	County - West Bardstown		EKPC (100%)
	Junction 69 kV line using		
	500 MCM copper or		
	equivalent equipment		
	Increase the Zone 3 distance		
	relay setting at Barren		
h2240	County associated with the		EVDC (1000)
02340	Barren County - Horse Cave		EKPC (100%)
	Tap 69 kV line to at least 85		
	MVA		
b2414	Build the 2nd Summer		
	Shade EKPC - Summer		EKPC (100%)
	Shade TVA 161 kV circuit		
	Increase the MOT of the		
	266.8 MCM ACSR section		
b2544	(1.4 miles), of the Kargle-		EKPC (100%)
	KU Elizabethtown 69 kV		
	line section to 266 degrees F		

Required '	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
	Decouple the double-		
	circuited Spurlock –		
h2614	Maysville Industrial Tap		EVDC(1000/)
02014	138-kV & Spurlock –		EKPC(100%)
	Flemingsburg 138-kV line		
	segments		
	Upgrade the Bullitt County		
b2615	161/69 kV transformer		EKPC (100%)
	facility		
	Increase the size of the		
1-2655	existing Leon 69 kV		EVDC(1000)
02000	capacitor bank from 13.2		EKPC (100%)
	MVAR to 18.36 MVAR		
	Reconductor the Leon –		
	Airport Road 69 kV line		
b2656	section (5.72 miles) using		EKPC (100%)
	556.5 MCM ACTW		
	conductor		
	Add 69 kV breaker at		
b2657	Thelma – AEP Thelma		EKPC (100%)
	69 kV tie		
	Increase the zone 3 distance		
	relay setting at Barren		
47650	County associated with the		EVDC(1000/)
02038	Barren County – Horse		EKPC (100%)
	Cave Junction line to at		
	least 103 MVA		
	Rebuild the Seymour Tap –		
h2650	KU Horse Cave Tap 69 kV		EVDC $(1000/)$
02039	line section (1.98 miles) to		EKFC(100%)
	302 degrees F		
	Increase the zone 3 distance		
	relay setting at		
h2660	Elizabethtown associated		EKDC(1000/)
62660	with the Elizabethtown –		EKPC(100%)
	Smithersville line section to		
	at least 100 MVA		
	Reconductor the Baker Lane		
	– Holloway Junction 69 kV		
b2661	(1.28 miles) line section		EKPC (100%)
	using 556.5 MCM ACTW		
	wire		

Required '	Fransmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2662	Increase the maximum operating temperature of the Hickory Plains – PPG 69 kV line section (0.21 miles) to 266 degrees F		EKPC (100%)
b2663	Increase the zone 3 distance relay setting at EKPC Elizabethtown associated with the EKPC Elizabethtown to KU Elizabethtown 69 kV line to at least 126 MVA		EKPC (100%)
b2664	Increase the maximum operating temperature of the Tharp Tap – KU Elizabethtown 69 kV line section (2.11 miles) to 266 degrees F. (LTE at 248 degrees F)		EKPC (100%)
b2710	Upgrade the Summer Shade bus and CT associated with the 161/69 kV transformer #1		EKPC (100%)
b2711	Install 25.5 MVAR 69 kV capacitor at Sewellton Junction 69 kV substation		EKPC (100%)
b2730	Upgrade Denny – Gregory Tap 69 kV line facility		EKPC (100%)
b2781	Increase maximum operating temperature of Davis – Nicholasville 69 kV line section 266.8 MCM conductor to 284°F (LTE of 266°F)		EKPC (100%)
b2782	Increase the maximum operating temperature of Plumville – Rectorville 69 kV line section 266.8 MCM conductor to 212°F (LTE of 185°F)		EKPC (100%)
b2783	Rebuild the Davis – Fayette 69 kV line section to 556.5 MCM (3.15 miles)		EKPC (100%)

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2784	Increase overcurrent relay at West Berea 138/69 kV to at least 139 MVA Winter LTE		EKPC (100%)
b2785	Install a 13.776 MVAR cap bank at Three Links 69 kV		EKPC (100%)
b2786	Increase Williamstown cap bank to 11.225 MVAR		EKPC (100%)
b2827	Upgrade the current 5% impedance 1200A line reactor, which connects the 4SPURLOCK – 4SPUR- KENT-R and 4SPUR- KENT-R – 4KENTON 138kV line sections, to a 6.5% impedance 1600A line reactor		EKPC (100%)
b2879.2	Reconductor EKPC portion of the Stuart – Spurlock 345 kV line		EKPC (100%)
b2893	Rebuild the existing (1.5 mile), 1/0 MCM ACSR South Bardstown – West Bardstown Jct. 69 kV line using 556.5 MCM ACTW conductor		EKPC (100%)
b2902	Rebuild the Brodhead – Three Links Jct. 69 kV line section (8.2 miles) using 556.5 MCM ACTW wire		EKPC (100%)
b2903	Raise the V-low setting for Summer Shade 69 kV cap bank to 1.01 pu		EKPC (100%)
b2904	Raise the V-low setting for Newby 69 kV cap bank to 0.955 pu		EKPC (100%)
b2905	Resize the Albany 69 kV capacitor bank from 8.4 to 13.776 MVAR		EKPC (100%)

Required '	Transmission Enhancements	Annual Revenue Requirement	nt Responsible Customer(s)
	Increase the Zone 3 distance		
12000	relay setting at Baker Lane		
	associated with the Baker		EKDC(1000/)
02900	Lane - Holloway Jct. 69 kV		EKPC (100%)
	line to at least 142 MVA		
	LTE Winter		
	Upgrade the metering CT		
	associated with the Clay		
	Village - KU Clay Village 69		
	kV tap line section to 600 A;		
h2007	at least 64 MVA Winter		EKDC (100%)
02907	LTE. Upgrade the distance		EKFC (100%)
	relay associated with the		
	Clay Village - KU Clay		
	Village 69 kV tap line		
	section to at least 64 MVA		
	Upgrade the distance relay		
h2008	associated with Dale – JK		EKPC (100%)
02908	Smith 138 kV line section to		EKFC (100%)
	362 MVA normal rating		
	Increase the MOT of the		
	EKPC Elizabethtown –		
b2909	Tharp Tap 69 kV line section		EKPC (100%)
	(1.7 miles) to 302°F (LTE at		
	284°F)		
	Upgrade the distance relay at		
	the Hodgenville station		
b2910	associated with the Glendale		EKPC (100%)
02710	– Hodgenville 69 kV line		LKI C (100%)
	section to at least 90 MVA		
	Winter LTE		
	Upgrade the overcurrent		
	relay setting associated with		
b2911	Powell County 138/69 kV		EKPC (100%)
	transformer to at least 139		
	MVA Winter LTE		
b2912	Upgrade the existing S408-		
	605, 600 A KU Russell		
	Springs Tap – Russell		EKPC (100%)
	County 69 kV disconnect		
	switch to 1200 A		

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2913	Upgrade distance relay at the Stephensburg station associated with Stephensburg – Glendale 69 kV line section to at least Winter		EKPC (100%)
	LTE 100 MVA		
b2914	Rebuild Tharp Tap – KU Elizabethtown 69 kV line section to 795 MCM (2.11 miles)		EKPC (100%)
b2915	Resize the sideview 69 kV capacitor bank from 6.12 MVAR to 9.18 MVAR		EKPC (100%)
b2916	Upgrade the existing metering CTs (Quantity of 2) associated with the East Bardstown - KU Bardstown Industrial Tap 69 kV line section to 1200 A, at least 100 MVA Winter LTE; and upgrade the existing East Bardstown bus and jumpers from 4/0 to 500 MCM copper		EKPC (100%)
b2917	Replace the existing 100 MVA 138/69 kV transformer bank at the West Berea substation with a 150 MVA transformer		EKPC (100%)
b2918	Upgrade the 4/0 bus and jumpers associated with the West Berea Jct. – Three Links Jct. 69 kV line to 500 MCM copper or equivalent equipment at the Three Links Jct. substation		EKPC (100%)
b2919	Install a 69 kV, 15.31 MVAR capacitor bank at South Anderson substation		EKPC (100%)
b2920	Rebuild Boone - Big Bone Tap 69 kV line section using 556.5 MCM ACTW conductor (6.3 miles)		EKPC (100%)

Required '	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
	New TVA 161 kV		
	interconnection to TVA's		
	East Glasgow Tap - East		
	Glasgow 161 kV line section		
	(~1 mile due West of Fox		
	Hollow). Add Fox Hollow		
h2021	161/69 kV 150 MVA		EKPC (100%)
02721	transformer. Construct new		EKI C (10070)
	Fox Hollow - Fox Hollow		
	Jct. 161 kV line section using		
	795 MCM ACSR (~1 mile)		
	and new 161 kV switching		
	station at point of		
	interconnection with TVA		
	Increase the conductor MOT		
	for the Dale – JK Smith 138		
b2939	kV line to 275°F. The new		EKPC (100%)
	summer ratings would be		
	229/296		
	Upgrade the distance relay		
1.00.40	on the Wayne Co – Wayne		EKPC (100%)
b2940	Co KY 161 kV line to		2111 0 (10070)
	increase the line winter rating		
	would be 167/167		
	Increase the MOT of the		
1.00.4.4	double circuit Cooper –		
b3044	Somerset 69 kV line 266.8		EKPC (100%)
	MCM conductor from 212°F		
	Increase the MOT of Liberty		
1 20 45	Church tap – Bacon Creek		
b3045	tap 69 kV line 266.8 MCM		EKPC (100%)
	conductor from 212°F to		
	Increase the MOT of		
1-20.46	Summer Shade – JB		EKPC (100%)
b3046	Galloway Jct. 69 KV line		· · · ·
	200.8 MCM conductor from		
	16/°F to 212°F		

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b3047	Upgrade the existing 4/0 CU line jumpers with double 500 MCM CU associated with the Green Co - KU Green Co 69 kV line section. Also, replace the existing 600 A disconnect switches with 1200 A associated with the Green Co 161/69 kV transformer		EKPC (100%)
b3094	Move 69 kV 12.0 MVAR capacitor bank from Greenbriar to Bullitt Co 69 kV substation		EKPC (100%)
<u>b3266</u>	Upgrade the metering CT associated with the Clay Village – Clay Village T 69 kV line section to increase the line ratings		<u>EKPC (100%)</u>
<u>b3267</u>	Rebuild the 4/0 ACSR Norwood – Shopville 69 kV line section using 556 ACSR/TW		<u>EKPC (100%)</u>

Attachment C

Schedule 12 – Appendix A of the PJM Open Access Transmission Tariff

(Clean Format)

SCHEDULE 12 – APPENDIX A

(1) Atlantic City Electric Company

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
------------------------------------	----------------------------	-------------------------

b2123	Upgrade the 69 kV bus at Laurel	AEC (100%)
b2226	Upgrade the Tackahoe to Mill 69 kV circuit	AEC (100%)
b2227	50 MVAR shunt reactor at Mickleton 230 kV and relocate Mickleton #1 230 69 kV transformer	AEC (100%)
b2228	+150/-100 MVAR SVC at Cedar 230 kV	AEC (100%)
b2296	Replace the Mickleton 230kV breaker PCB U with 63kA breaker	AEC (100%)
b2297	Replace the Mickleton 230kV breaker PCB V with 63kA breaker	AEC (100%)
b2305	Rebuild and reconductor 1.2 miles of the US Silica to US Silica #1 69 kV circuit	AEC (100%)
b2306	Rebuild and reconductor 1.67 miles of the US Silica #1 to W1-089 TAP 69 kV circuit	AEC (100%)
b2351	Reconductor section A of Corson - Sea Isle - Swainton 69 kV line	AEC (100%)
b2353	Upgrade the overcurrent protective relaying at Middle T3 and T4 138/69 kV transformers	AEC (100%)
b2354	Install second 230/69 kV transformer and 230 kV circuit breaker at Churchtown substation	AEC (100%)

Atlantic City Electric Company (cont.)

		1	
b2354.1	Replace Churchtown 69kV breaker 'D'		AEC (100%)
b2476	Install new Dennis 230/69 kV transformer		AEC (100%)
b2477	Upgrade 138 kV and 69 kV breakers at Corson substation		AEC (100%)
b2478	Reconductor 2.74 miles of Sherman - Lincoln 138 kV line and associated substation upgrades		AEC (100%)
b2479	New Orchard - Cardiff 230 kV line (remove, rebuild and reconfigure existing 138 kV line) and associated substation upgrades		AEC (100%)
b2480.1	New Upper Pittsgrove - Lewis 138 kV line and associated substation upgrades		AEC (100%)
b2480.2	Relocate Monroe to Deepwater Tap 138 kV to Landis 138 kV and associated substation upgrades		AEC (100%)
b2480.3	New Landis - Lewis 138 kV line and associated substation upgrades		AEC (100%)
b2481	New Cardiff - Lewis #2 138 kV line and associated substation upgrades		AEC (100%)
b2489	Install a 100 MVAR capacitor at BL England		AEC (100%)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)

Atlantic City Electric Company (cont.)

required 1	ranoninoonon Exinancemento - 1 mit	adi i te vende i te qui entente i te	
b2538	Replace the Mickleton 230kV 'MK' breaker with 63kA breaker		AEC (100%)
b2553	Replace Middle T3 138/69 kV transformer with 225 MVA nameplate		AEC (100%)
b2723.1	Replace the Mickleton 69 kV 'PCB A' breaker with 63kA breaker		AEC (100%)
b2723.2	Replace the Mickleton 69 kV 'PCB B' breaker with 63kA breaker		AEC (100%)
b2723.3	Replace the Mickleton 69 kV 'PCB C' breaker with 63kA breaker		AEC (100%)
b2723.4	Replace the Mickleton 69 kV 'PCB Q' breaker with 63kA breaker		AEC (100%)
b2839	Replace the Sickler 69 kV 'H' breaker with 63kA breaker		AEC (100%)
b2840	Replace the Sickler 69 kV 'M' breaker with 63kA breaker		AEC (100%)
b2841	Replace the Sickler 69 kV 'A' breaker with 63kA breaker		AEC (100%)
b2945.1	Rebuild the BL England – Middle Tap 138 kV line to 2000A on double circuited steel poles and new foundations		AEC (100%)
b2945.2	Reconductor BL England – Merion 138 kV (1.9 miles) line		AEC (100%)
b2945.3	Reconductor Merion – Corson 138 kV (8 miles) line		AEC (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Atlantic City Electric Company (cont.)

Ttequileu I		au nevenue negunement 1	(copolisione Customer(s)
b3135	Install back-up relay on the 138 kV bus at Corson substation		AEC (100%)
b3226	Add 10 MVAR 69 kV capacitor bank at Swainton substation		AEC (100%)
b3227	Rebuild the Corson – Court 69 kV line to achieve ratings equivalent to 795 ACSR conductor or better		AEC (100%)

Require	ed Transmission	Enhancements	Annual Revenue Re	quirement	Responsible (Customer(s)
ruquit	λ manufactor		1 miliuar IXC vonue IXC	quintinent	Tresponsione v	customer(s)

SCHEDULE 12 – APPENDIX A

(2) Baltimore Gas and Electric Company

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Install a 115 kV tie		
	breaker at Wagner to		
b2219	create a separation from		BGE (100%)
	line 110535 and		
	transformer 110-2		
h2220	Install four 115 kV		PCE (1000%)
02220	breakers at Chestnut Hill		BGE (100%)
	Install an SPS to trip		
L0001	approximately 19 MW		DCE $(1000/)$
02221	load at Green St. and		BGE (100%)
	Concord		
	Install a 230/115kV		
	transformer at Raphael		
	Rd and construct		
	approximately 3 miles of		
b2307	115kV line from Raphael		BGE (100%)
	Rd. to Joppatowne.		
	Construct a 115kV three		
	breaker ring at		
	Joppatowne		
	Build approximately 3		
	miles of 115kV		
	underground line from		
	Bestgate tap to Waugh		
b2308	Chapel. Create two		BGE (100%)
	breaker bay at Waugh		
	Chapel to accommodate		
	the new underground		
	circuit		
	Build a new Camp Small		
b2396	115 kV station and install		BGE (100%)
	30 MVAR capacitor		

Baltimore Gas and Electric Company (cont.)

Required I		Annual Revenue Requirement	responsible Customer(s)
h2206 1	Install a tie breaker at		PCE (100%)
02390.1	substation		BOE (100%)
	Ungrade the Diverside		
	115kV substation strain		
	hus conductors on		
	oirouite 115012 and		
h2567	115011 with double		DCE $(1000/)$
02307	hundled 1272 ACSP to		BGE (100%)
	buildled 1272 ACSK to		
	ACHIEVE Fattings OF		
	both transformer leads		
	Papanduator Northwest		
	Northwest #2 115kV		
	110574 substation tie		
b2568	circuit with 2167 ACSP	BGE (100%)	BGE (100%)
	to achieve ratings of		
	A00/A62 MVA SN/SE		
	Conastone 230 kV		
	substation tie-in work		AEP (6 46%) / APS (8 74%) /
	(install a new circuit		BGE (19.74%) / ComEd (2.16%)
	breaker at Conastone		/ Davton (0.59%) / DEOK
b2752.6	230 kV and upgrade any		(1.02%) / DL $(0.01%)$ /
	required terminal		Dominion (39.95%) / EKPC
	equipment to terminate		(0.45%) / PEPCO (20.88%)
	the new circuit)		
			AEP (6.46%) / APS (8.74%) /
	Reconductor/Rebuild the		BGE (19.74%) / ComEd (2.16%)
1.0750 7	two Conastone –		/ Dayton (0.59%) / DEOK
62/52.7	Northwest 230 KV lines		(1.02%) / DL (0.01%) /
	and upgrade terminal		Dominion (39.95%) / EKPC
	equipment on both ends		(0.45%) / PEPCO (20.88%)
	Replace the Conastone		
h2752 8	230 kV '2322 B5'		BCE (100%)
62/52.8	breaker with a 63kA		BOE (100%)
	breaker		

Baltimore Gas and Electric Company (cont.)

b2752.9	Replace the Conastone 230 kV '2322 B6' breaker with a 63kA breaker	BGE (100%)
b2766.1	Upgrade substation equipment at Conastone 500 kV to increase facility rating to 2826 MVA normal and 3525 MVA emergency	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: AEC (3.52%) / APS (9.95%) / ATSI (10.68%) / BGE (6.92%) / DPL (16.32%) / JCPL (11.32%) / NEPTUNE* (1.22%) / PENELEC (2.30%) / PEPCO (12.59%) / PSEG (24.22%) / RE (0.96%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

Baltimore Gas and Electric Company (cont.)

1000000		innaar revenue reeganemer	
b2816	Re-connect the Crane – Windy Edge 110591 & 110592 115 kV circuits into the Northeast Substation with the addition of a new 115 kV 3-breaker bay		BGE (100%)
b2992.1	Reconductor the Conastone to Graceton 230 kV 2323 & 2324 circuits. Replace 7 disconnect switches at Conastone substation		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.2	Add Bundle conductor on the Graceton – Bagley – Raphael Road 2305 & 2313 230 kV circuits		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.3	Replacing short segment of substation conductor on the Windy Edge to Glenarm 110512 115 kV circuit		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b2992.4	Reconductor the Raphael Road – Northeast 2315 & 2337 230 kV circuits		AEP (2.25%) / APS (2.58%) / BGE (44.61%) / ComEd (0.51%) / Dayton (0.40%) / DEOK (1.39%) / DL (0.14%) / Dominion (27.05%) / EKPC (0.52%) / PENELEC (0.02%) / PEPCO (20.53%)
b3228	Replace two (2) relays at Center substation to increase ratings on the Westport to Center 110552 115 kV circuit		BGE (100%)
b3305	Replace Pumphrey 230/115 kV transformer		BGE (100%)

SCHEDULE 12 – APPENDIX A

(3) Delmarva Power & Light Company

Required II	ansinission Lindicements Al	inuar Revenue Requirement	Responsible Customer(s)
b2288	Build a new 138 kV line from Piney Grove – Wattsville		DPL (100%)
b2395	Reconductor the Harmony – Chapel St 138 kV circuit		DPL (100%)
b2569	Replace Terminal equipment at Silverside 69 kV substation		DPL (100%)
b2633.7	Implement high speed relaying utilizing OPGW on Red Lion – Hope Creek 500 kV line		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEC (0.01%) / DPL (99.98%) / JCPL (0.01%)
b2633.10	Interconnect the new Silver Run 230 kV substation with existing Red Lion – Cartanza and Red Lion – Cedar Creek 230 kV lines		AEC (8.01%) / BGE (1.94%) / DPL (12.99%) / JCPL (13.85%) / ME (5.88%) / NEPTUNE* (3.45%) / PECO (17.62%) / PPL (14.85%) / PSEG (20.79%) / RE (0.62%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

Delmarva Power & Light Company (cont.)

Required In	ansmission Enhancements An	nual Revenue Requirement	Responsible Customer(s)
b2695	Rebuild Worcester – Ocean Pine 69 kV ckt. 1 to 1400A capability summer		DPL (100%)
b2946	Convert existing Preston 69 kV substation to DPL's current design standard of a 3-breaker ring bus		DPL (100%)
b2947.1	Upgrade terminal equipment at DPL's Naamans substation (Darley - Naamans 69 kV)		DPL (100%)
b2947.2	Reconductor 0.11 mile section of Darley - Naamans 69 kV circuit		DPL (100%)
b2948	Upgrade terminal equipment at DPL's Silverside Road substation (Dupont Edge Moor – Silver R. 69 kV)		DPL (100%)
b2987	Install a 30 MVAR capacitor bank at DPL's Cool Springs 69 kV substation. The capacitor bank would be installed in two separate 15 MVAR stages allowing DPL operational flexibility		DPL (100%)
b3143.1	Reconductor the Silverside Road – Darley 69 kV circuit		DPL (100%)
b3143.2	Reconductor the Darley – Naamans 69 kV circuit		DPL (100%)
b3143.3	Replace three (3) existing 1200 A disconnect switches with 2000 A disconnect switches and install three (3) new 2000 A disconnect switches at Silverside 69 kV station		DPL (100%)

Delmarva Power & Light Company (cont.)

Required Tra	ansmission Enhancements Ann	nual Revenue Requirement	Responsible Customer(s)
	Replace two (2) 1200 A		
	disconnect switches with		
	2000 A disconnect		
	switches. Replace existing		
	954 ACSR and 500 SDCU		
	stranded bus with two (2)		
h21/2/	954 ACSR stranded bus.		DDI (1000%)
05145.4	Reconfigure four (4) CTs		DFL (100%)
	from 1200 A to 2000 A		
	and install two (2) new		
	2000 A disconnect		
	switches and two (2) new		
	954 ACSR stranded bus at		
	Naamans 69 kV station		
	Replace four (4) 1200 A		
	disconnect switches with		
	2000 A disconnect		
	switches. Replace existing		
	954 ACSR and 1272		
	MCM AL stranded bus		
	with two (2) 954 ACSR		
	stranded bus. Reconfigure		
b3143.5	eight (8) CTs from 1200 A		DPL (100%)
	to 2000 A and install four		
	(4) new 2000 A (310 MVA		
	SE / 351 MVA WE)		
	disconnect switches and		
	two (2) new 954 ACSR		
	(331 MVA SE / 369 MVA		
	WE) stranded bus at		
	Darley 69 kV station		
	Rebuild approx. 12 miles		
b3155	of Wye Mills –		DPL (100%)
	Stevensville line		
	Replace a disconnect		
	switch and reconductor a		
b3224	short span of the Mt.		DPL (100%)
	Pleasant – Middletown tap		
	138 kV line		

SCHEDULE 12 – APPENDIX A

(4) Jersey Central Power & Light Company

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2234	260 MVAR reactor at West Wharton 230 kV		JCPL (100%)
b2270	Advance Raritan River - Replace G1047E breaker at the 230kV Substation		JCPL (100%)
b2271	Advance Raritan River - Replace G1047F breaker at the 230kV Substation		JCPL (100%)
b2272	Advance Raritan River - Replace T1034E breaker at the 230kV Substation		JCPL (100%)
b2273	Advance Raritan River - Replace T1034F breaker at the 230kV Substation		JCPL (100%)
b2274	Advance Raritan River - Replace I1023E breaker at the 230kV Substation		JCPL (100%)
b2275	Advance Raritan River - Replace I1023F breaker at the 230kV Substation		JCPL (100%)
b2289	Freneau Substation - upgrade 2.5 inch pipe to bundled 1590 ACSR conductor at the K1025 230 kV Line Terminal		JCPL (100%)
b2292	Replace the Whippany 230 kV breaker B1 (CAP) with 63kA breaker		JCPL (100%)
b2357	Replace the East Windsor 230 kV breaker 'E1' with 63kA breaker		JCPL (100%)

Required Tra	insmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
	Replace transformer		
b2495	leads on the Glen		ICDI (1000/)
	Gardner 230/34.5 kV #1		JCFL (100%)
	transformer		
	Replace Franklin		
b2/06	115/34.5 kV transformer		ICDI (100%)
02490	#2 with 90 MVA		JCI L (10070)
	transformer		
	Reconductor 0.9 miles of		
	the Captive Plastics to		
b2497	Morris Park 34.5 kV		JCPL (100%)
	circuit (397ACSR) with		
	556 ACSR		
	Extend 5.8 miles of 34.5		
	kV circuit from North		
	Branch substation to		
b2498	Lebanon substation with		JCPL (100%)
	397 ACSR and install		
	34.5 kV breaker at		
	Lebanon substation		
	Upgrade terminal		
	equipment at Monroe on		
b2500	the Englishtown to		JCPL (100%)
	Monroe (H34) 34.5 kV		
	circuit		
	Upgrade limiting		
h2570	terminal facilities at		ICDI (1000%)
02370	Feneau, Parlin, and		JCFL (100%)
	Williams substations		
	Upgrade the limiting		
h2571	terminal facilities at both		ICDI (1000/)
02571	Jackson and North		JCPL (100%)
	Hanover		
	Upgrade the V74 34.5 kV		
h2596	transmission line		ICDI (1000%)
62586	between Allenhurst and		JCPL (100%)
	Elberon Substations		

Required Tra	nsmission Enhancements	Annual Revenue Requirement Responsible Customer(s)
b2633.6	Implement high speed relaying utilizing OPGW on Deans – East Windsor 500 kV	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEC (0.01%) / DPL (99.98%) /
b2633.6.1	Implement high speed relaying utilizing OPGW on East Windsor - New Freedom 500 kV	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEC (0.01%) / DPL (99.98%) / JCPL (0.01%)

Required fra	Institussion Enhancements An	nual Revenue Requirement	Responsible Customer(s)
b2676	Install one (1) 72 MVAR fast switched capacitor at the Englishtown 230 kV substation		JCPL (100%)
b2708	Replace the Oceanview 230/34.5 kV transformer #1		JCPL (100%)
b2709	Replace the Deep Run 230/34.5 kV transformer #1		JCPL (100%)
b2754.2	Install 5 miles of optical ground wire (OPGW) between Gilbert and Springfield 230 kV substations		JCPL (100%)
b2754.3	Install 7 miles of all- dielectric self-supporting (ADSS) fiber optic cable between Morris Park and Northwood 230 kV substations		JCPL (100%)
b2754.6	Upgrade relaying at Morris Park 230 kV		JCPL (100%)
b2754.7	Upgrade relaying at Gilbert 230 kV		JCPL (100%)
b2809	Install a bypass switch at Mount Pleasant 34.5 kV substation to allow the Mount Pleasant substation load to be removed from the N14 line and transfer to O769 line		JCPL (100%)
b3023	Replace West Wharton 115 kV breakers 'G943A' and 'G943B' with 40kA breakers		JCPL (100%)
b3042	Replace substation conductor at Raritan River 230 kV substation on the Kilmer line terminal		JCPL (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Construct seven new 34.5 kV circuits on existing pole lines (total of 53.5 miles), rebuild/reconductor two 34.5 kV circuits (total of 5.5 miles) and install a second 115/34.5 kV transformer (Werner)JCPL (100%)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)JCPL (100%)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
kV circuits on existing pole lines (total of 53.5 miles), rebuild/reconductor two 34.5 kV circuits (total of 5.5 miles) and install a second 115/34.5 kV transformer (Werner)JCPL (100%)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)JCPL (100%)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
b3130lines (total of 53.5 miles), rebuild/reconductor two 34.5 kV circuits (total of 5.5 miles) and install a second 115/34.5 kV transformer (Werner)JCPL (100%)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)JCPL (100%)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
b3130rebuild/reconductor two 34.5 kV circuits (total of 5.5 miles) and install a second 115/34.5 kV transformer (Werner)JCPL (100%)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)JCPL (100%)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
b3130 34.5 kV circuits (total of 5.5 miles) and install a second 115/34.5 kV transformer (Werner) 361 L (100%) b3130.1 Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles) JCPL (100%) b3130.2 Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles) JCPL (100%)
5.5 miles) and install a second 115/34.5 kV transformer (Werner)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
second 115/34.5 kV transformer (Werner)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4
transformer (Werner)b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)b3130.2Construct a new 24.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)
b3130.1Construct a new 34.5 kV circuit from Oceanview to Allenhurst 34.5 kV (4 miles)JCPL (100%)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
b3130.1circuit from Oceanview to Allenhurst 34.5 kV (4 miles)JCPL (100%)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
b3130.1 Allenhurst 34.5 kV (4 miles) b3130.2 Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles) Construct a new 24.5 kV
miles)b3130.2Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles)JCPL (100%)
b3130.2 Construct a new 34.5 kV circuit from Atlantic to Red Bank 34.5 kV (12 miles) JCPL (100%)
b3130.2 circuit from Atlantic to Red Bank 34.5 kV (12 miles) JCPL (100%)
B3130.2 Red Bank 34.5 kV (12 miles) JCFL (100%)
miles)
Construct a new 34.5 KV
circuit from Freneau to
Taylor Lane 34.5 kV (6.5
miles)
Construct a new 34.5 kV
b3130.4 circuit from Keyport to JCPL (100%)
Belford 34.5 kV (6 miles)
Construct a new 34.5 kV
b3130.5 circuit from Red Bank to JCPL (100%)
Belford 34.5 kV (5 miles)
Construct a new 34.5 kV
b3130.6 circuit from Werner to JCPL (100%)
Clark Street (7 miles)
Construct a new 34.5 kV
b3130.7 circuit from Atlantic to JCPL (100%)
Freneau (13 miles)
Rebuild/reconductor the
Atlantic – Camp Woods
Switch Point (3.5 miles)
34.5 kV circuit
Rebuild/reconductor the
b3130.9 Allenhurst – Elberon (2 JCPL (100%)
miles) 34.5 kV circuit
Install 2nd 115/34.5 kV
b3130.10 transformer at Werner JCPL (100%)
substation
Jersey Central Power & Light Company (cont.)

Tequirea In		iau ne venue negunement	
	Replace seven (7)		
	overdutied 34.5 kV		
b3238	breakers with 50 kA rated		JCPL (100%)
	equipment at the Whippany		
	substation		
	Replace fourteen (14)		
b3239	overdutied 34.5 kV		$\mathbf{ICDI} (1000\%)$
	breakers with 63 kA rated		JCFL (100%)
	equipment		

SCHEDULE 12 – APPENDIX A

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2212	Shawville Substation: Relocate 230 kV and 115 kV controls from the generating station building to new control building		PENELEC (100%)
b2293	Replace the Erie South 115 kV breaker 'Buffalo Rd' with 40kA breaker		PENELEC (100%)
b2294	Replace the Johnstown 115 kV breaker 'Bon Aire' with 40kA breaker		PENELEC (100%)
b2302	Replace the Erie South 115 kV breaker 'French #2' with 40kA breaker		PENELEC (100%)
b2304	Replace the substation conductor and switch at South Troy 115 kV substation		PENELEC (100%)
b2371	Install 75 MVAR capacitor at the Erie East 230 kV substation		PENELEC (100%)
b2441	Install +250/-100 MVAR SVC at the Erie South 230 kV station		PENELEC (100%)
b2442	Install three 230 kV breakers on the 230 kV side of the Lewistown #1, #2 and #3 transformers		PENELEC (100%)
b2450	Construct a new 115 kV line from Central City West to Bedford North		PENELEC (100%)
b2463	Rebuild and reconductor 115 kV line from East Towanda to S. Troy and upgrade terminal equipment at East Towanda, Tennessee Gas and South Troy		PENELEC (100%)

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Construct Warren 230 kV		
b2494	ring bus and install a		PENELEC (100%)
	second Warren 230/115		1 ENELLEC (100%)
	kV transformer		
	Reconductor the North		
	Meshoppen – Oxbow-		
b25521	Lackawanna 230 kV		PENELEC (99.00%) / PPL
02332.1	circuit and upgrade		(1.00%)
	terminal equipment		
	(MAIT portion)		
	Replace the Warren 115		
b2573	kV 'B12' breaker with a		PENELEC (100%)
	40kA breaker		
	Reconfigure Pierce Brook		
	345 kV station to a ring		
b2587	bus and install a 125		PENELEC (100%)
	MVAR shunt reactor at		
	the station		
	Replace relays at East		
b2621	Towanda and East Sayre		PENELEC (100%)
	115 kV substations		
	(158/191 MVA SN/SE)		
	Replace wave trap, bus		
10077	conductor and relay at		
62677	Hilltop 115 kV substation.		PENELEC (100%)
	Replace relays at Prospect		
	and Cooper substations		
	Convert the East Towanda		
b2678	115 KV substation to		PENELEC (100%)
	breaker and half		
1.2670	Install a 115 KV Venango		DENIEL EC (1000/)
b2679	Jcl. line breaker at		PENELEC (100%)
b2680	Install a 115 kV breaker		
	on Hooversville #1 115/23		PENELEC (100%)
	K v transformer		
10001	Install a 115 kV breaker		
b2681	on the Eclipse $#2 115/34.5$		PENELEC (100%)
	kV transformer		

		1	1 (/
b2682	Install two 21.6 MVAR capacitors at the Shade Gap 115 kV substation		PENELEC (100%)
b2683	Install a 36 MVAR 115 kV capacitor and associated equipment at Morgan Street substation		PENELEC (100%)
b2684	Install a 36 MVAR 115 kV capacitor at Central City West substation		PENELEC (100%)
b2685	Install a second 115 kV 3000A bus tie breaker at Hooversville substation		PENELEC (100%)
b2735	Replace the Warren 115 kV 'NO. 2 XFMR' breaker with 40kA breaker		PENELEC (100%)
b2736	Replace the Warren 115 kV 'Warren #1' breaker with 40kA breaker		PENELEC (100%)
b2737	Replace the Warren 115 kV 'A TX #1' breaker with 40kA breaker		PENELEC (100%)
b2738	Replace the Warren 115 kV 'A TX #2' breaker with 40kA breaker		PENELEC (100%)
b2739	Replace the Warren 115 kV 'Warren #2' breaker with 40kA breaker		PENELEC (100%)
b2740	Revise the reclosing of the Hooversville 115 kV 'Ralphton' breaker		PENELEC (100%)
b2741	Revise the reclosing of the Hooversville 115 kV 'Statler Hill' breaker		PENELEC (100%)

Required T	ransmission Enhancements Ar	inual Revenue Requirement	Responsible Customer(s)
b2743.2	Tie in new Rice substation to Conemaugh – Hunterstown 500 kV		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2743.3	Upgrade terminal equipment at Conemaugh 500 kV on the Conemaugh – Hunterstown 500 kV circuit		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2748	Install two 28 MVAR capacitors at Tiffany 115 kV substation		PENELEC (100%)
b2767	Construct a new 345 kV breaker string with three (3) 345 kV breakers at Homer City and move the North autotransformer connection to this new breaker string		PENELEC (100%)
b2803	Reconductor 3.7 miles of the Bethlehem – Leretto 46 kV circuit and replace terminal equipment at Summit 46 kV		PENELEC (100%)
b2804	Install a new relay and replace 4/0 CU bus conductor at Huntingdon 46 kV station, on the Huntingdon – C tap 46 kV circuit		PENELEC (100%)
b2805	Install a new relay and replace 4/0 CU & 250 CU substation conductor at Hollidaysburg 46 kV station, on the Hollidaysburg – HCR Tap 46 kV circuit		PENELEC (100%)

Required I	Talishiission Linaicements Ai	inual Revenue Requirement	Responsible Customer(s)
b2806	Install a new relay and replace meter at the Raystown 46 kV substation, on the Raystown – Smithfield 46 kV circuit		PENELEC (100%)
b2807	Replace the CHPV and CRS relay, and adjust the IAC overcurrent relay trip setting; or replace the relay at Eldorado 46 kV substation, on the Eldorado – Gallitzin 46 kV circuit		PENELEC (100%)
b2808	Adjust the JBC overcurrent relay trip setting at Raystown 46 kV, and replace relay and 4/0 CU bus conductor at Huntingdon 46 kV substations, on the Raystown – Huntingdon 46 kV circuit		PENELEC (100%)
b2865	Replace Seward 115 kV breaker "Jackson Road" with 63kA breaker		PENELEC (100%)
b2866	Replace Seward 115 kV breaker "Conemaugh N." with 63kA breaker		PENELEC (100%)
b2867	Replace Seward 115 kV breaker "Conemaugh S." with 63kA breaker		PENELEC (100%)
b2868	Replace Seward 115 kV breaker "No.8 Xfmr" with 63kA breaker		PENELEC (100%)
b2944	Install two 345 kV 80 MVAR shunt reactors at Mainesburg station		PENELEC (100%)

b2951	Seward, Blairsville East, Shelocta work	PENELEC (100%)
b2951.1	Upgrade Florence 115 kV line terminal equipment at Seward SS	PENELEC (100%)
b2951.2	Replace Blairsville East / Seward 115 kV line tuner, coax, line relaying and carrier set at Shelocta SS	PENELEC (100%)
b2951.3	Replace Seward / Shelocta 115 kV line CVT, tuner, coax, and line relaying at Blairsville East SS	PENELEC (100%)
b2952	Replace the North Meshoppen #3 230/115 kV transformer eliminating the old reactor and installing two breakers to complete a 230 kV ring bus at North Meshoppen	PENELEC (100%)
b2953	Replace the Keystone 500 kV breaker "NO. 14 Cabot" with 50kA breaker	PENELEC (100%)
b2954	Replace the Keystone 500 kV breaker "NO. 16 Cabot" with 50kA breaker	PENELEC (100%)
b2984	Reconfigure the bus at Glory and install a 50.4 MVAR 115 kV capacitor	PENELEC (100%)
b3007.2	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - PENELEC portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Blairsville East, the wave trap and breaker disconnects will be replaced	PENELEC (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required 7	Transmission	Enhancements	Annual Revenue Red	quirement Res	ponsible Custome	er(s)
						- (-)

b3008	Upgrade Blairsville East 138/115 kV transformer terminals. This project is an upgrade to the tap of the Seward – Shelocta 115 kV line into Blairsville substation. The project will replace the circuit breaker and adjust relay settings	PENELEC (100%)
b3009	Upgrade Blairsville East 115 kV terminal equipment. Replace 115 kV circuit breaker and disconnects	PENELEC (100%)
b3014	Replace the existing Shelocta 230/115 kV transformer and construct a 230 kV ring bus	PENELEC (100%)
b3016	Upgrade terminal equipment at Corry East 115 kV to increase rating of Four Mile to Corry East 115 kV line. Replace bus conductor	PENELEC (100%)
b3017.1	Rebuild Glade to Warren 230 kV line with hi-temp conductor and substation terminal upgrades. 11.53 miles. New conductor will be 1033 ACSS. Existing conductor is 1033 ACSR	PENELEC (100%)
b3017.2	Glade substation terminal upgrades. Replace bus conductor, wave traps, and relaying	PENELEC (100%)
b3017.3	Warren substation terminal upgrades. Replace bus conductor, wave traps, and relaying	PENELEC (100%)
b3022	Replace Saxton 115 kV breaker 'BUS TIE' with a 40kA breaker	PENELEC (100%)

	Upgrade terminal equipment at Corry East 115 kV to	
b3024	increase rating of Warren to	PENELEC (100%)
	Corry East 115 kV line.	
	Replace bus conductor	
	Install one 115 kV 36	
b3043	MVAR capacitor at West	PENELEC (100%)
	Fall 115 kV substation	
	Replace the Blairsville East	
	138/115 kV transformer and	
b3073	associated equipment such	PENELEC (100%)
	as breaker disconnects and	
	bus conductor	
	Reconductor the Franklin	
b3077	Pike B – Wayne 115 kV line	PENELEC (100%)
	(6.78 miles)	
	Reconductor the 138 kV bus	
1.00-0	and replace the line trap,	
b3078	relays Morgan Street.	PENELEC (100%)
	Reconductor the 138 kV bus	
	at Venango Junction	
b3082	Construct 4-breaker 115 kV	PENELEC (100%)
	ring bus at Geneva	` ´ ´
1.2127	Rebuild 20 miles of the East	DENIEL EC (100%)
03137	I owanda – North	PENELEC (100%)
	Mesnoppen 115 KV line	
	relay papels of the Jackson	
b3144	Pood Nanty Glo 46 kV	PENELEC (100%)
	SIN line	
	Ungrade line relaying and	
	substation conductor on the	
b3144.1	46 kV Nanty Glo line exit at	PENELEC (100%)
	Jackson Road substation	
	Upgrade line relaying and	
	substation conductor on the	
b3144.2	46 kV Jackson Road line	PENELEC (100%)
	exit at Nanty Glo substation	
	Install one (1) 13.2 MVAR	
b3154	46 kV capacitor at the	PENELEC (100%)
03134	Logan substation	

requirea r		
	Replace the existing No. 2	
h2221	Cap Dalik Dreaker at	DENIELEC (100%)
03231	a new breaker with higher	I = NELEC(100%)
	interrupting canability	
	Replace the existing	
	Williamsburg ALH	
	(Hollidaysburg) and bus	
h3232	section breaker at the	PENELEC (100%)
03232	Altoona substation with a	
	new breaker with higher	
	interrupting capability	
	Install one (1) 34 MVAR	
	115 kV shunt reactor and	
1 0000	breaker. Install one (1) 115	
63233	kV circuit breaker to expand	PENELEC (100%)
	the substation to a 4-breaker	
	ring bus	
	Install two (2) 46 kV 6.12	
b3237	MVAR capacitors effective	PENELEC (100%)
	at Mt. Union	
	Construct a new breaker-	
	and-a-half substation near	
	Tiffany substation. All	
	transmission assets and lines	
	will be relocated to the new	
b3245	substation. The two (2)	PENELEC (100%)
	distribution transformers	
	will be fed via two (2)	
	dedicated 115 kV feeds to	
	the existing Tiffany	
	substation	
	Install a second 125 MVAR	
	345 kV shunt reactor and	
1 220 6	associated equipment at	
b3306	Pierce Brook substation.	PENELEC (100%)
	Install a 345 kV breaker on	
	the high side of the $345/230$	
	KV transformer #1	

SCHEDULE 12 – APPENDIX A

(9) **PPL Electric Utilities Corporation**

Required Transmission Enhancements		Annual Revenue Requirer	ment Responsible Customer(s)
b1813.12	Replace the Blooming Grove 230 kV breaker 'Peckville'		PPL (100%)
b2223	Rebuild and reconductor 2.6 miles of the Sunbury - Dauphin 69 kV circuit		PPL (100%)
b2224	Add a 2nd 150 MVA 230/69 kV transformer at Springfield		PPL (100%)
b2237	150 MVAR shunt reactor at Alburtis 500 kV		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: PPL (100%)
b2238	100 MVAR shunt reactor at Elimsport 230 kV		PPL (100%)

* Neptune Regional Transmission System, LLC

Required	Transmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
b2269	Rebuild approximately 23.7 miles of the Susquehanna - Jenkins 230kV circuit. This replaces a temporary SPS that is already planned to mitigate the violation until this solution is implemented		PPL (100%)
b2282	Rebuild the Siegfried- Frackville 230 kV line		PPL (100%)
b2406.1	Rebuild Stanton- Providence 69 kV 2&3 9.5 miles with 795 SCSR		PPL (100%)
b2406.2	Reconductor 7 miles of the Lackawanna - Providence 69 kV #1 and #2 with 795 ACSR		PPL (100%)
b2406.3	Rebuild SUB2 Tap 1 (Lackawanna - Scranton 1) 69 kV 1.5 miles 556 ACSR		PPL (100%)
b2406.4	Rebuild SUB2 Tap 2 (Lackawanna - Scranton 1) 69 kV 1.6 miles 556 ACSR		PPL (100%)
b2406.5	Create Providence - Scranton 69 kV #1 and #2, 3.5 miles with 795 ACSR		PPL (100%)
b2406.6	Rebuild Providence 69 kV switchyard		PPL (100%)
b2406.7	Install 2 - 10.8 MVAR capacitors at EYNO 69 kV		PPL (100%)
b2406.8	Rebuild Stanton 230 kV yard		PPL (100%)

nequirea		Timuai ne venue negune	
b2446	Replace wave trap and protective relays at Montour		PPL (100%)
b2447	Replace wave trap and protective relays at Montour		PPL (100%)
b2448	Install a 2nd Sunbury 900MVA 500-230kV transformer and associated equipment		PPL (100%)
b2552.2	Reconductor the North Meshoppen - Oxbow – Lackawanna 230 kV circuit and upgrade terminal equipment (PPL portion)		PENELEC (98.84%) / PPL (1.16%)
b2574	Replace the Sunbury 230 kV 'MONTOUR NORT' breaker with a 63kA breaker		PPL (100%)
b2690	Reconductor two spans of the Graceton – Safe Harbor 230 kV transmission line. Includes termination point upgrades		PPL (100%)
b2691	Reconductor three spans limiting Brunner Island – Yorkana 230 kV line, add 2 breakers to Brunner Island switchyard, upgrade associated terminal equipment		PPL (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Transmission Enhancements Annual Revenue Requirement Responsible Cu		Annual Revenue Requirement Responsible Customer	(s)
		Load-Ratio Share Allocation	n:
		AEC (1.71%) / AEP (14.04%)/
		APS (5.61%) / ATSI (8.10%))/
		BGE (4.36%) / ComEd (13.14	%)
		/ Dayton (2.15%) / DEOK	
		(3.23%) / DL (1.73%) / DPI	
	Add a 200 MVAD about	(2.65%) / Dominion (13.03%))/
h2716	Add a 200 M VAR shuft	EKPC (1.77%) / JCPL (3.84%	5)/
02/10	Feactor at Lackawanna	ME (1.93%) / NEPTUNE*	
	500 KV substation	(0.45%) / OVEC (0.07%) /	
		PECO (5.29%) / PENELEC	-
		(1.89%) / PEPCO (3.82%) / PE	PL
		(4.72%) / PSEG (6.21%) / R	E
		(0.26%)	
		DFAX Allocation:	
		PPL (100%)	
	Install 7 miles of optical		
	ground wire (OPGW)		
b2754.1	between Gilbert and	PPL (100%)	
	Springfield 230 kV		
	substations		
	Use ~ 40 route miles of		
	existing fibers on PPL		
b2754.4	230 kV system to	PPL (100%)	
	establish direct fiber		
	circuits		
b2754 5	Upgrade relaying at	DDI (100%)	
02754.5	Martins Creek 230 kV	11E (100%)	
h2756	Install 2% reactors at	DDI (100%)	
02750	Martins Creek 230 kV	11E (100%)	
	Expand existing		
b2813	Lycoming 69 kV yard to		
02815	double bus double	FFL (100%)	
	breaker arrangement		

* Neptune Regional Transmission System, LLC

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)		
			Load	-Ratio Share Allocation:
			AEC	(1.71%) / AEP (14.04%) /
			APS	(5.61%) / ATSI (8.10%) /
			BGE (4.36%) / ComEd (13.14%)
			/ D	ayton (2.15%) / DEOK
			(3.2	3%) / DL (1.73%) / DPL
	Reconfigure/Expand the		(2.65	%) / Dominion (13.03%) /
1.0004	Lackawanna 500 KV		EKPC	(1.77%) / JCPL (3.84%) /
02824	substation by adding a		ME	E (1.93%) / NEPTUNE*
	third bay with three		(0.4	45%) / OVEC (0.07%) /
	breakers		PEC	CO (5.29%) / PENELEC
			(1.89%	6) / PEPCO (3.82%) / PPL
			(4.72	?%) / PSEG (6.21%) / RE
				(0.26%)
				DFAX Allocation:
				PPL (100%)
	Build a new 230/69 kV			
	substation by tapping the			
	Montour – Susquehanna			
b2838	230 kV double circuits			PPL (100%)
	and Berwick – Hunlock			
	& Berwick – Colombia			
	69 kV circuits			
	Replace Martins Creek			
b2979	230 kV circuit breakers			PPL (100%)
	with 80 kA rating			
	Replace terminal			
	equipment (bus			
b3221	conductor) on the 230 kV			PPL(100%)
00221	side of the Steel City			
	500/230 kV Transformer			
	#1			
	Install one (1) 7.2 MVAR			
	fixed cap bank on the			
	Lock Haven – Reno 69			
	kV line and one (1) 7.2			
b3222	MVAR fixed cap bank			PPL (100%)
	on the Lock Haven –			
	Flemington 69 kV line			
	near the Flemington			
	69/12 kV substation			

* Neptune Regional Transmission System, LLC

SCHEDULE 12 – APPENDIX A

Required Tra	nsmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
	Reconductor 0.33 miles of		
	the Parkersburg - Belpre		
b2117	line and upgrade		APS (100%)
	Parkersburg terminal		
	equipment		
h2118	Add 44 MVAR Cap at New		ADS(1000%)
02118	Martinsville		AFS (100%)
b2120	Six-Wire Lake Lynn -		APS(100%)
02120	Lardin 138 kV circuits		AIS (10070)
	Replace Weirton 138 kV		
b2142	breaker "Wylie Ridge 210"		APS (100%)
	with 63 kA breaker		
	Replace Weirton 138 kV		
b2143	breaker "Wylie Ridge 216"		APS (100%)
	with 63 kA breaker		
b2174.8	Replace relays at Mitchell		$\Delta PS(100\%)$
02174.0	substation		115(100/0)
b2174.9	Replace primary relay at		APS (100%)
02171.9	Piney Fork substation		110 (10070)
	Perform relay setting		
b2174.10	changes at Bethel Park		APS (100%)
	substation		
	Armstrong Substation:		
	Relocate 138 kV controls		
b2213	from the generating station		APS (100%)
	building to new control		
	building		
	Albright Substation: Install		
	a new control building in		
	the switchyard and relocate		
b2214	controls and SCADA		APS (100%)
	equipment from the		
	generating station building		
	the new control center		
	Rivesville Switching		
	Station: Relocate controls		
b2215	and SCADA equipment		APS (100%)
	from the generating station		110 (10070)
	building to new control		
	building		

Required Tr	ansmission Enhancements A	Annual Revenue Requirement	Responsible Customer(s)
	Willow Island: Install a new		
	138 kV cross bus at		
	Belmont Substation and		
h2216	reconnect and reconfigure		ADS(1000%)
02210	the 138 kV lines to facilitate		AFS (100%)
	removal of the equipment at		
	Willow Island switching		
	station		
h2235	130 MVAR reactor at		APS(100%)
02233	Monocacy 230 kV		AFS (100%)
h2260	Install a 32.4 MVAR		ADS(1000%)
02200	capacitor at Bartonville		AFS (100%)
h2261	Install a 33 MVAR		ADS(1000%)
02201	capacitor at Damascus		AFS (100%)
	Replace 1000 Cu substation		
b2267	conductor and 1200 amp		APS (100%)
	wave trap at Marlowe		
	Reconductor 6.8 miles of		
42268	138kV 336 ACSR with 336		ADS(1000/)
02208	ACSS from Double Toll		APS (100%)
	Gate to Riverton		
	Reconductor from Collins		
b2299	Ferry - West Run 138 kV		APS (100%)
	with 556 ACSS		
h2200	Reconductor from Lake		ADS(1000%)
02300	Lynn - West Run 138 kV		AFS (100%)
	Install 39.6 MVAR		
b2341	Capacitor at Shaffers Corner		APS (100%)
	138 kV Substation		
	Construct a new 138 kV		
	switching station (Shuman		
h7217	Hill substation), which is		ADS(1000%)
02342	next the Mobley 138 kV		AFS (100%)
	substation and install a 31.7		
	MVAR capacitor		
	Install a 31.7 MVAR		
b2343	capacitor at West Union 138		APS (100%)
	kV substation		

Required Tr	ansmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
h2262	Install a 250 MVAR SVC at		ADS(1000())
02302	Squab Hollow 230 kV		APS (100%)
	Install a 230 kV breaker at		
b2362.1	Squab Hollow 230 kV		APS (100%)
	substation		
	Convert the Shingletown		
b2363	230 kV bus into a 6 breaker		APS (100%)
	ring bus		
	Install a new 230/138 kV		
	transformer at Squab		
	Hollow 230 kV substation.		
h2261	Loop the Forest - Elko 230		ADS(100%)
02304	kV line into Squab Hollow.		AFS (100%)
	Loop the Brookville - Elko		
	138 kV line into Squab		
	Hollow		
	Install a 44 MVAR 138 kV		
b2412	capacitor at the Hempfield		APS (100%)
	138 kV substation		
	Install breaker and a half		
	138 kV substation (Waldo		
	Run) with 4 breakers to		
b2/33 1	accommodate service to		APS(100%)
02433.1	MarkWest Sherwood		AI 5 (100%)
	Facility including metering		
	which is cut into Glen Falls		
	Lamberton 138 kV line		
	Install a 70 MVAR SVC at		
b2433.2	the new WaldoRun 138 kV		APS (100%)
	substation		
	Install two 31.7 MVAR		
b24333	capacitors at the new		APS(100%)
02433.3	WaldoRun 138 kV		M S (100%)
	substation		
b2424	Replace the Weirton 138 kV		
	breaker 'WYLIE RID210'		APS (100%)
	with 63 kA breakers		
	Replace the Weirton 138 kV		
b2425	breaker 'WYLIE RID216'		APS (100%)
	with 63 kA breakers		

Required Tr	ansmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
	Replace the Oak Grove 138		
b2426	kV breaker 'OG1' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2427	kV breaker 'OG2' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2428	kV breaker 'OG3' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2429	kV breaker 'OG4' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2430	kV breaker 'OG5' with 63		APS (100%)
	kA breakers		
	Replace the Oak Grove 138		
b2431	kV breaker 'OG6' with 63		APS (100%)
	kA breakers		
	Replace the Ridgeley 138		
b2432	kV breaker 'RC1' with a 40		APS (100%)
	kA rated breaker		
	Replace the Cabot 138kV		
b2440	breaker 'C9-KISKI VLY'		APS (100%)
	with 63kA		
	Replace the Ringgold 138		
b2472	kV breaker 'RCM1' with		APS (100%)
	40kA breakers		
	Replace the Ringgold 138		
b2473	kV breaker '#4 XMFR' with		APS (100%)
	40kA breakers		
	Construct a new line		
b2475	between Oak Mound 138		APS (100%)
02175	kV substation and Waldo		111 B (10070)
	Run 138 kV substation		
	Construct a new 138 kV		
	substation (Shuman Hill		
b2545.1	substation) connected to the		APS (100%)
	Fairview – Willow Island		
	(84) 138 kV line		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2545.2	Install a ring bus station with five active positions and two 52.8 MVAR capacitors with 0.941 mH reactors		APS (100%)
b2545.3	Install a +90/-30 MVAR SVC protected by a 138 kV breaker	7	APS (100%)
b2545.4	Remove the 31.7 MVAR capacitor bank at Mobley 138 kV		APS (100%)
b2546	Install a 51.8 MVAR (rated 138 kV capacitor at Nyswaner 138 kV substation)	APS (100%)
b2547.1	Construct a new 138 kV six breaker ring bus Hillman substation	ζ	APS (100%)
b2547.2	Loop Smith- Imperial 138 kV line into the new Hillman substation		APS (100%)
b2547.3	Install +125/-75 MVAR SVC at Hillman substation		APS (100%)
b2547.4	Install two 31.7 MVAR 138 kV capacitors	3	APS (100%)
b2548	Eliminate clearance de-rate on Wylie Ridge – Smith 133 kV line and upgrade terminals at Smith 138 kV, new line ratings 294 MVA (Rate A)/350 MVA (Rate B	2 8)	APS (100%)
b2612.1	Relocate All Dam 6 138 kV line and the 138 kV line to AE units 1&2	T	APS (100%)
b2612.2	Install 138 kV, 3000A bus- tie breaker in the open bus- tie position next to the Shaffers corner 138 kV line		APS (100%)

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Install a 6-pole manual		
h26123	switch, foundation, control		APS(100%)
02012.3	cable, and all associated		M S (10070)
	facilities		
b2666	Yukon 138 kV Breaker		APS (100%)
02000	Replacement		111 D (10070)
	Replace Yukon 138 kV		
b2666.1	breaker "Y-11(CHARL1)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.2	breaker "Y-13(BETHEL)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.3	breaker "Y-18(CHARL2)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.4	breaker "Y-19(CHARL2)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.5	breaker "Y-4(4B-2BUS)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.6	breaker "Y-5(LAYTON)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.7	breaker "Y-8(HUNTING)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.8	breaker "Y-9(SPRINGD)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.9	breaker "Y-10(CHRL-SP)"		APS (100%)
	with an 80 kA breaker		
b2666.10	Replace Yukon 138 kV		
	breaker "Y-12(1-1BUS)"		APS (100%)
	with an 80 kA breaker		
	Replace Yukon 138 kV		
b2666.11	breaker "Y-14(4-1BUS)"		APS (100%)
	with an 80 kA breaker		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
b2666.12	Replace Yukon 138 kV breaker "Y-2(1B-BETHE)" with an 80 kA breaker		APS (100%)
b2666.13	Replace Yukon 138 kV breaker "Y-21(SHEPJ)" with an 80 kA breaker		APS (100%)
b2666.14	Replace Yukon 138 kV breaker "Y-22(SHEPHJT)" with an 80 kA breaker		APS (100%)
b2672	Change CT Ratio at Seneca Caverns from 120/1 to 160/1 and adjust relay settings accordingly		APS (100%)
b2688.3	Carroll Substation: Replace the Germantown 138 kV wave trap, upgrade the bus conductor and adjust CT ratios		AEP (12.91%) / APS (19.04%) / ATSI (1.24%) / ComEd (0.35%) / Dayton (1.45%) / DEOK (2.30%) / DL (1.11%) / Dominion (44.85%) / EKPC (0.78%) / PEPCO (15.85%) / RECO (0.12%)
b2689.3	Upgrade terminal equipment at structure 27A		APS (100%)
b2696	Upgrade 138 kV substation equipment at Butler, Shanor Manor and Krendale substations. New rating of line will be 353 MVA summer normal/422 MVA emergency		APS (100%)
b2700	Remove existing Black Oak SPS		APS (100%)
b2743.6	Reconfigure the Ringgold 230 kV substation to double bus double breaker scheme		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)

Required Tra	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2743.6.1	Replace the two Ringgold 230/138 kV transformers		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2743.7	Rebuild/Reconductor the Ringgold – Catoctin 138 kV circuit and upgrade terminal equipment on both ends		AEP (6.46%) / APS (8.74%) / BGE (19.74%) / ComEd (2.16%) / Dayton (0.59%) / DEOK (1.02%) / DL (0.01%) / Dominion (39.95%) / EKPC (0.45%) / PEPCO (20.88%)
b2747.1	Relocate the FirstEnergy Pratts 138 kV terminal CVTs at Gordonsville substation to allow for the installation of a new motor operated switch being installed by Dominion		APS (100%)
b2763	Replace the breaker risers and wave trap at Bredinville 138 kV substation on the Cabrey Junction 138 kV terminal		APS (100%)
b2764	Upgrade Fairview 138 kV breaker risers and disconnect leads; Replace 500 CU breaker risers and 556 ACSR disconnect leads with 795 ACSR		APS (100%)
b2964.1	Replace terminal equipment at Pruntytown and Glen Falls 138 kV station		APS (100%)
b2964.2	Reconductor approximately 8.3 miles of the McAlpin - White Hall Junction 138 kV circuit		APS (100%)

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Reconductor the Charleroi –		
	Allenport 138 kV line with		
b2965	954 ACSR conductor.		DL (100%)
	Replace breaker risers at		
	Charleroi and Allenport		
	Reconductor the Yukon –		
	Smithton – Shepler Hill Jct		
b2966	138 kV line with 795 ACSS		APS (100%)
	conductor. Replace Line		
	Disconnect Switch at Yukon		
	Reconductor the Yukon -		
	Smithton - Shepler Hill Jct		
b2966.1	138 kV line and replace		APS (100%)
02700.1	terminal equipment as		
	necessary to achieve		
	required rating		
	Convert the existing 6 wire		
	Butler - Shanor Manor -		
1.00.7	Krendale 138 kV line into		
b2967	two separate 138 kV lines.		APS (100%)
	New lines will be Butler -		
	Keisters and Butler - Shanor		
	Manor - Krendale 138 kV		
b2970	Ringgold – Catoctin		APS (100%)
	Solution		
	Install two new 230 kV		
b2970.1	positions at Ringgold for		APS (100%)
	230/138 kV transformers		
1.0000	Install new 230 kV position		
b2970.2	for Ringgold – Catoctin 230		APS (100%)
	kV line		
b2970.3	Install one new 230 kV		
	breaker at Catoctin		APS (100%)
	substation		
	Install new 230/138 kV		
	transformer at Catoctin		
b2970.4	substation. Convert		APS (100%)
	Ringgold – Catoctin 138 kV		
	line to 230 kV operation		

Required Tra	ansmission Enhancements Annu	al Revenue Requirement	Responsible Customer(s)
h2070 5	Convert Garfield 138/12.5 kV		ADS(1000/)
02970.3	substation to 230/12.5 kV		APS (100%)
1.0000	Construct new Flint Run 500/138		See sub-IDs for cost
02990	kV substation		allocations
	Construct a new 500/138 kV		
	substation as a 4-breaker ring bus		
	with expansion plans for double-		
	breaker-double-bus on the 500		
	kV bus and breaker-and-a-half on		
	the 138 kV bus to provide EHV		
	source to the Marcellus shale		
	load growth area. Projected load		
	growth of additional 160 MVA to		
	current plan of 280 MVA, for a		
	total load of 440 MVA served		
h2006 1	from Waldo Run substation.		ADS(1000/)
02990.1	Construct additional 3-breaker		AFS (100%)
	string at Waldo Run 138 kV bus.		
	Relocate the Sherwood #2 line		
	terminal to the new string.		
	Construct two single circuit Flint		
	Run - Waldo Run 138 kV lines		
	using 795 ACSR (approximately		
	3 miles). After terminal		
	relocation on new 3-breaker		
	string at Waldo Run, terminate		
	new Flint Run 138 kV lines onto		
	the two open terminals		
	Loop the Belmont – Harrison 500		
	kV line into and out of the new		
	Flint Run 500 kV substation (less		
b2996.2	than 1 mile). Replace primary		APS (100%)
	relaying and carrier sets on		
	Belmont and Harrison 500 kV		
	remote end substations		
	Upgrade two (2) existing 138 kV		
b2996.3	breakers (Rider 50 and #1/4		$\Delta PS(100\%)$
	transformer breaker) at Glen Falls		AI D (10070)
	with 63 kA 3000A units		

Required T	ransmission Enhancements An	nual Revenue Requirement	Responsible Customer(s)
b3005	Reconductor 3.1 mile 556 ACSR portion of Cabot to Butler 138 kV with 556 ACSS and upgrade terminal equipment. 3.1 miles of line will be reconductored for this project. The total length of the line is 7.75 miles		APS (100%)
b3006	Replace four Yukon 500/138 kV transformers with three transformers with higher rating and reconfigure 500 kV bus		APS (73.55%) / DL (26.45%)
b3007.1	Reconductor the Blairsville East to Social Hall 138 kV line and upgrade terminal equipment - AP portion. 4.8 miles total. The new conductor will be 636 ACSS replacing the existing 636 ACSR conductor. At Social Hall, meters, relays, bus conductor, a wave trap, circuit breaker and disconnects will be replaced		APS (100%)
b3010	Replace terminal equipment at Keystone and Cabot 500 kV buses. At Keystone, bus tubing and conductor, a wave trap, and meter will be replaced. At Cabot, a wave trap and bus conductor will be replaced		APS (100%)
b3011.1	Construct new Route 51 substation and connect 10 138 kV lines to new substation		DL (100%)
b3011.2	Upgrade terminal equipment at Yukon to increase rating on Yukon to Charleroi #2 138 kV line (New Yukon to Route 51 #4 138 kV line)		DL (100%)

		· · · · · · · · · · · · · · · · · · ·	
b3011.3	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #1 138 kV line		DL (100%)
b3011.4	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #2 138 kV line		DL (100%)
b3011.5	Upgrade terminal equipment at Yukon to increase rating on Yukon to Route 51 #3 138 kV line		DL (100%)
b3011.6	Upgrade remote end relays for Yukon – Allenport – Iron Bridge 138 kV line		DL (100%)
b3012.1	Construct two new 138 kV ties with the single structure from APS's new substation to Duquesne's new substation. The estimated line length is approximately 4.7 miles. The line is planned to use multiple ACSS conductors per phase		ATSI (38.21%) / DL (61.79%)
b3012.3	Construct a new Elrama – Route 51 138 kV No.3 line: reconductor 4.7 miles of the existing line, and construct 1.5 miles of a new line to the reconductored portion. Install a new line terminal at APS Route 51 substation		DL (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b3013	Reconductor Vasco Tap to Edgewater Tap 138 kV line. 4.4 miles. The new conductor will be 336 ACSS replacing the existing 336 ACSR conductor	APS (100%)
b3015.6	Reconductor Elrama to Mitchell 138 kV line – AP portion. 4.2 miles total. 2x 795 ACSS/TW 20/7	DL (100%)
b3015.8	Upgrade terminal equipment at Mitchell for Mitchell – Elrama 138 kV line	APS (100%)
b3028	Upgrade substation disconnect leads at William 138 kV substation	APS (100%)
b3051.1	Ronceverte cap bank and terminal upgrades	APS (100%)
b3052	Install a 138 kV capacitor (29.7 MVAR effective) at West Winchester 138 kV	APS (100%)
b3064.3	Upgrade line relaying at Piney Fork and Bethel Park for Piney For – Elrama 138 kV line and Bethel Park – Elrama 138 kV	APS (100%)

		1 1	
b3068	Reconductor the Yukon – Westraver 138 kV line (2.8 miles), replace the line drops and relays at Yukon 138 kV and replace switches at		APS (100%)
b3069	Reconductor the Westraver – Route 51 138 kV line (5.63 miles) and replace line switches at Westraver 138 kV bus		APS (100%)
b3070	Reconductor the Yukon – Route 51 #1 138 kV line (8 miles), replace the line drops, relays and line disconnect switch at Yukon 138 kV bus		APS (100%)
b3071	Reconductor the Yukon – Route 51 #2 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3072	Reconductor the Yukon – Route 51 #3 138 kV line (8 miles) and replace relays at Yukon 138 kV bus		APS (100%)
b3074	Reconductor the 138 kV bus at Armstrong substation		APS (100%)
b3075	Replace the 500/138 kV transformer breaker and reconductor 138 kV bus at Cabot substation		APS (100%)
b3076	Reconductor the Edgewater – Loyalhanna 138 kV line (0.67 mile)		APS (100%)
b3079	Replace the Wylie Ridge 500/345 kV transformer #7		ATSI (72.30%) / DL (27.70%)
b3083	Reconductor the 138 kV bus at Butler and reconductor the 138 kV bus and replace line trap at Karns City		APS (100%)

b3128	Relocate 34.5 kV lines from		
	generating station roof R.		APS (100%)
	Paul Smith 138 kV station		
	At Enon substation install a		
	second 138 kV, 28.8 MVAR		
b3230	nameplate, capacitor and the		APS (100%)
	associated 138 kV capacitor		
	switcher		
	Upgrade Cherry Run and		
h2240	Morgan terminals to make		ADS(100%)
03240	the transmission line the	APS (100%)	
	limiting component		
	Install 138 kV, 36 MVAR		
	capacitor and a 5 uF reactor		
	protected by a 138 kV		
	capacitor switcher. Install a		
b3241	breaker on the 138 kV		APS (100%)
	Junction terminal. Install a		
	138 kV 3.5 uF reactor on the		
	existing Hardy 138 kV		
	capacitor		
	Reconfigure Stonewall 138		
	kV substation from its		
b3242	current configuration to a		
	six-breaker, breaker-and-a-		APS (100%)
	half layout and add two (2)		
	36 MVAR capacitors with		
	capacitor switchers		

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

SCHEDULE 12 – APPENDIX A

(17) American Electric Power Service Corporation on behalf of its affiliate companies: AEP Appalachian Transmission Company, Inc.; AEP Indiana Michigan Transmission Company, Inc.; AEP Kentucky Transmission Company, Inc.; AEP Ohio Transmission Company, Inc.; AEP West Virginia Transmission Company, Inc.; Appalachian Power Company; Indiana Michigan Power Company; Kentucky Power Company; Kingsport Power Company; Ohio Power Company and Wheeling Power Company

Required III		au nevenue negunement	
b1570.4	Add a 345 kV breaker at Marysville station and a 0.1 mile 345 kV line extension from Marysville to the new 345/69 kV Dayton transformer		AEP (100%)
b1660.1	Cloverdale: install 6-765 kV breakers, incremental work for 2 additional breakers, reconfigure and relocate miscellaneous facilities, establish 500 kV station and 500 kV tie with 765 kV station		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: Dayton (8.37%) / DEOK (21.94%) / Dominion (56.40%) / EKPC (13.29%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

Required Tra	Institussion Enhancements Anni	iai Kevenue Kequilemeni	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%) /
			APS (5.61%) / ATSI (8.10%) /
			BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
			(13.03%) / EKPC (1.77%) /
	Reconductor the AEP		JCPL (3.84%) / ME (1.93%) /
h1707 1	portion of the Cloverdale -		NEPTUNE* (0.45%) / OVEC
01/9/.1	Lexington 500 kV line with		(0.07%) / PECO (5.29%) /
	2-1780 ACSS		PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			AEP (0.79%) / APS (53.70%) /
			Dayton (0.15%) / DEOK
			(0.40%) / Dominion (1.13%) /
			EKPC (0.23%) / PEPCO
			(43.60%)
h2055	Upgrade relay at Brues		A E P (1000/2)
02033	station		ALF (100%)
	Upgrade terminal		
	equipment at Howard on		
b2122.3	the Howard - Brookside		AEP (100%)
	138 kV line to achieve		
	ratings of 252/291 (SN/SE)		
b2122.4	Perform a sag study on the		
	Howard - Brookside 138		AEP (100%)
	kV line		
h2220	Install a 300 MVAR		A E D (1000%)
02229	reactor at Dequine 345 kV		AEF (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

		Load-Ratio Share Allocation:
		AEC (1.71%) / AEP (14.04%) /
		APS (5.61%) / ATSI (8.10%) /
		BGE (4.36%) / ComEd
		(13.14%) / Dayton (2.15%) /
Replace existing 150		DEOK (3.23%) / DL (1.73%) /
MVAP reactor at Amos 765		DPL (2.65%) / Dominion
kV substation on Amos N		(13.03%) / EKPC (1.77%) /
Proctorville Hanging Pock		JCPL (3.84%) / ME (1.93%) /
with 300 MVAP reactor		NEPTUNE* (0.45%) / OVEC
with 500 W VAR reactor		(0.07%) / PECO (5.29%) /
		PENELEC (1.89%) / PEPCO
		(3.82%) / PPL (4.72%) / PSEG
		(6.21%) / RE (0.26%)
		DFAX Allocation:
		AEP (100%)
Install 765 kV reactor		
breaker at Dumont 765 kV		A ED (100%)
substation on the Dumont -	ne Dumont -	MLI (10070)
Wilton Center line		
Install 765 kV reactor		
breaker at Marysville 765		
kV substation on the		AEP (100%)
Marysville - Maliszewski		
line		
Change transformer tap		
settings for the Baker		AEP (100%)
765/345 kV transformer		
Loop the North Muskingum		
- Crooksville 138 kV line		
into AEP's Philo 138 kV		$\mathbf{AED}(10004)$
station which lies		ALF(100%)
approximately 0.4 miles		
from the line		
	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line Install 765 kV reactor breaker at Marysville 765 kV substation on the Marysville - Maliszewski line Change transformer tap settings for the Baker 765/345 kV transformer Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line	Replace existing 150 MVAR reactor at Amos 765 kV substation on Amos - N. Proctorville - Hanging Rock with 300 MVAR reactor breaker at Dumont 765 kV substation on the Dumont - Wilton Center line Install 765 kV reactor breaker at Marysville 765 kV substation on the Baker 765/345 kV transformer Loop the North Muskingum - Crooksville 138 kV line into AEP's Philo 138 kV station which lies approximately 0.4 miles from the line

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

	Install an 86.4 MVAR	
b2253	capacitor bank at Gorsuch	AEP (100%)
	138 kV station in Ohio	
	Rebuild approximately 4.9	
b2254	miles of Corner - Degussa	AEP (100%)
	138 kV line in Ohio	
	Rebuild approximately 2.8	
b2255	miles of Maliszewski -	AEP (100%)
	Polaris 138 kV line in Ohio	
	Upgrade approximately 36	
	miles of 138 kV through	
b2256	path facilities between	AEP (100%)
	Harrison 138 kV station and	
	Ross 138 kV station in Ohio	
	Rebuild the Pokagon -	
	Corey 69 kV line as a	
	double circuit 138 kV line	
b2257	with one side at 69 kV and	AEP (100%)
	the other side as an express	
	circuit between Pokagon	
	and Corey stations	
	Rebuild 1.41 miles of #2	
	CU 46 kV line between	
1-2259	Tams Mountain - Slab Fork	AED (1000/)
02238	to 138 kV standards. The	AEP (100%)
	line will be strung with	
	1033 ACSR	
	Install a new 138/69 kV	
	transformer at George	
b2259	Washington 138/69 kV	AED (1000/)
	substation to provide	AEP (100%)
	support to the 69 kV system	
	in the area	

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required II		an nevenue negunement	Responsible Customer(s)
	Rebuild 4.7 miles of		
	Muskingum River - Wolf		
h2286	Creek 138 kV line and		A ED (1000/2)
02280	remove the 138/138 kV		AEP (100%)
	transformer at Wolf Creek		
	Station		
	Loop in the Meadow Lake -		
b2287	Olive 345 kV circuit into		A = D (1000/)
	Reynolds 765/345 kV		AEF (100%)
	station		

b2344.1	Establish a new 138/12 kV station, transfer and consolidate load from its Nicholsville and Marcellus 34.5 kV stations at this new	AEP (100%)
b2344.2	station Tap the Hydramatic – Valley 138 kV circuit (~ structure 415), build a new 138 kV line (~3.75 miles) to this new station	AEP (100%)
b2344.3	From this station, construct a new 138 kV line (~1.95 miles) to REA's Marcellus station	AEP (100%)
b2344.4	From REA's Marcellus station construct new 138 kV line (~2.35 miles) to a tap point on Valley – Hydramatic 138 kV ckt (~structure 434)	AEP (100%)
b2344.5	Retire sections of the 138 kV line in between structure 415 and 434 (~ 2.65 miles)	AEP (100%)
b2344.6	Retire AEP's Marcellus 34.5/12 kV and Nicholsville 34.5/12 kV stations and also the Marcellus – Valley 34.5 kV line	AEP (100%)
b2345.1	Construct a new 69 kV line from Hartford to Keeler (~8 miles)	AEP (100%)
b2345.2	Rebuild the 34.5 kV lines between Keeler - Sister Lakes and Glenwood tap switch to 69 kV (~12 miles)	AEP (100%)
b2345.3	Implement in - out at Keeler and Sister Lakes 34.5 kV stations	AEP (100%)
---------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------
b2345.4	Retire Glenwood tap switch and construct a new Rothadew station. These new lines will continue to operate at 34.5 kV	AEP (100%)
b2346	Perform a sag study for Howard - North Bellville - Millwood 138 kV line including terminal equipment upgrades	AEP (100%)
b2347	Replace the North Delphos 600A switch. Rebuild approximately 18.7 miles of 138 kV line North Delphos - S073. Reconductor the line and replace the existing tower structures	AEP (100%)
b2348	Construct a new 138 kV line from Richlands Station to intersect with the Hales Branch - Grassy Creek 138 kV circuit	AEP (100%)
b2374	Change the existing CT ratios of the existing equipment along Bearskin - Smith Mountain 138kV circuit	AEP (100%)
b2375	Change the existing CT ratios of the existing equipment along East Danville-Banister 138kV circuit	AEP (100%)

b2376	Replace the Turner 138 kV breaker 'D'	AEP (100%)
b2377	Replace the North Newark 138 kV breaker 'P'	AEP (100%)
b2378	Replace the Sporn 345 kV breaker 'DD'	AEP (100%)
b2379	Replace the Sporn 345 kV breaker 'DD2'	AEP (100%)
b2380	Replace the Muskingum 345 kV breaker 'SE'	AEP (100%)
b2381	Replace the East Lima 138 kV breaker 'E1'	AEP (100%)
b2382	Replace the Delco 138 kV breaker 'R'	AEP (100%)
b2383	Replace the Sporn 345 kV breaker 'AA2'	AEP (100%)
b2384	Replace the Sporn 345 kV breaker 'CC'	AEP (100%)
b2385	Replace the Sporn 345 kV breaker 'CC2'	AEP (100%)
b2386	Replace the Astor 138 kV breaker '102'	AEP (100%)
b2387	Replace the Muskingum 345 kV breaker 'SH'	AEP (100%)
b2388	Replace the Muskingum 345 kV breaker 'SI'	AEP (100%)
b2389	Replace the Hyatt 138 kV breaker '105N'	AEP (100%)
b2390	Replace the Muskingum 345 kV breaker 'SG'	AEP (100%)
b2391	Replace the Hyatt 138 kV breaker '101C'	AEP (100%)
b2392	Replace the Hyatt 138 kV breaker '104N'	AEP (100%)
b2393	Replace the Hyatt 138 kV breaker '104S'	AEP (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2394	Replace the Sporn 345 kV breaker 'CC1'	AEP (100%)
b2409	Install two 56.4 MVAR capacitor banks at the Melmore 138 kV station in Ohio	AEP (100%)
b2410	Convert Hogan Mullin 34.5 kV line to 138 kV, establish 138 kV line between Jones Creek and Strawton, rebuild existing Mullin Elwood 34.5 kV and terminate line into Strawton station, retire Mullin station	AEP (100%)
b2411	Rebuild the 3/0 ACSR portion of the Hadley - Kroemer Tap 69 kV line utilizing 795 ACSR conductor	AEP (100%)
b2423	Install a 300 MVAR shunt reactor at AEP's Wyoming 765 kV station	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEP (100%)

		*	
b2444	Willow - Eureka 138 kV line: Reconductor 0.26 mile of 4/0 CU with 336 ACSS		AEP (100%)
b2445	Complete a sag study of Tidd - Mahans Lake 138 kV line		AEP (100%)
b2449	Rebuild the 7-mile 345 kV line between Meadow Lake and Reynolds 345 kV stations		AEP (100%)
b2462	Add two 138 kV circuit breakers at Fremont station to fix tower contingency '408 2'		AEP (100%)
b2501	Construct a new 138/69 kV Yager station by tapping 2- 138 kV FE circuits (Nottingham-Cloverdale, Nottingham-Harmon)		AEP (100%)
b2501.2	Build a new 138 kV line from new Yager station to Azalea station		AEP (100%)
b2501.3	Close the 138 kV loop back into Yager 138 kV by converting part of local 69 kV facilities to 138 kV		AEP (100%)
b2501.4	Build 2 new 69 kV exits to reinforce 69 kV facilities and upgrade conductor between Irish Run 69 kV Switch and Bowerstown 69 kV Switch		AEP (100%)

Construct new 138 kV switching station Nottingham tapping 6-138 kV FE circuits (Holloway- Brookside, Holloway- Brookside, Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd stationAEP (100%)b2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)b2502.3South Cadiz 69 kV to 138 kVAEP (100%)b2502.4We freebyrd station to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2531Replace the Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2532Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)	100000000		
switching stationNottingham tapping 6-138kV FE circuits (Holloway- Brookside, Holloway- Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd 69 kV to 138 kVb2502.2Convert Freebyrd 69 kV to 138 kVb2502.3Convert Freebyrd- South Cadiz 69 kV circuit to 138 kVb2502.4Upgrade South Cadiz to 138 kV breaker and a halfb2503Replace the Sporn 138 kV breakerb2504Replace the Sporn 138 kV breaker 'O1' with 80kA breakerb2533Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2533Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2535Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2535Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'P2' with 80kA breakerb2535Replace the Sporn 138 kV breaker 'P2' with 80kA breaker		Construct new 138 kV	
Nottingham tapping 6-138 kV FE circuits (Holloway- Brookside, Holloway- Harmon #1 and #2, Holloway-Reeds, Holloway-Reeds, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd 69 kV to 138 kVAEP (100%)b2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Wpgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2530Replace the Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2531Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'D1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'D2' with 80kA breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)		switching station	
kV FE circuits (Holloway- Brookside, Holloway- Harmon #1 and #2, Holloway-New Stacy, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd 69 kV to 138 kVAEP (100%)b2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502.4Eeplace the Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2531Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2532Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2533Breaker 'O1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)b2535Breaker 'O1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)b2535Breaker 'D' with 80kA breakerAEP (100%)b2535Breaker 'D' with 80kA breakerAEP (100%)b2535Breaker 'D' with 80kA breakerAEP (100%)		Nottingham tapping 6-138	
Brookside, Holloway- b2502.1Harmon #1 and #2, Holloway-Reeds, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd 69 kV to 138 kVAEP (100%)b2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 k V breaker and a halfAEP (100%)b2532Replace the Sporn 138 kV breakerAEP (100%)b2533Breaker 'G1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D2' with 80kA breakerAEP (100%)b2533Breaker 'P2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'D2' with 80kA breakerAEP (100%)b2533Breaker 'D2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2535Breaker 'D2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2535Breaker 'D2' with 80kA breakerAEP (100%)b2534Breaker 'D2' with 80kA breakerAEP (100%)b2535Breaker 'D' with 80 kA breakerAEP (100%)b2535Breaker 'D2' with 80 kA breakerAEP (100%)b2535Breaker 'D' with 80 kA breakerAEP (100%)		kV FE circuits (Holloway-	
b2502.1 Harmon #1 and #2, Holloway-Reeds, Holloway-Reeds, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd station AEP (100%) b2502.2 Convert Freebyrd 69 kV to 138 kV AEP (100%) b2502.3 South Cadiz 69 kV circuit to 138 kV AEP (100%) b2502.4 Upgrade South Cadiz to 138 kV breaker and a half AEP (100%) b2502.4 Upgrade South Cadiz to 138 kV breaker and a half AEP (100%) b2530 Breaker 'G1' with 80kA breaker' AEP (100%) b2531 Breaker 'G1' with 80kA breaker' AEP (100%) b2532 breaker 'O1' with 80kA breaker AEP (100%) b2533 Breaker 'O1' with 80kA breaker AEP (100%) b2534 Replace the Sporn 138 kV breaker 'D2' with 80kA breaker AEP (100%) b2534 Breaker 'D1' with 80kA breaker AEP (100%) b2534 Breaker 'U' with 80kA breaker AEP (100%) b2535 Breaker 'O' with 80 kA breaker AEP (100%) b2534 Breaker 'U' with 80 kA breaker AEP (100%) b2535 Breaker 'O' with 80 kA breaker AEP (100%)		Brookside, Holloway-	
Holloway-Reeds, Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd 69 kV to 138 kVAEP (100%)b2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502Upgrade South Cadiz to 138 kV b2530AEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2531Breaker 'G1' with 80kA breakerAEP (100%)b2532Breaker 'G1' with 80kA breaker 'D' with 80kAAEP (100%)b2533Breaker 'D' with 80kA breaker 'D1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2535breaker 'U' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2535breaker 'U' with 80kA breakerAEP (100%)	b2502.1	Harmon #1 and #2,	AEP (100%)
Holloway-New Stacy, Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd stationb2502.2Convert Freebyrd 69 kV to 138 kVb2502.3Convert Freebyrd- South Cadiz 69 kV circuit to 138 kVb2502.4Wpgrade South Cadiz to 138 kV breaker and a halfb2502Replace the Sporn 138 kV breakerb2531Breaker G1' with 80kA breakerb2532Replace the Sporn 138 kV breaker 'D' with 80kAb2533Breaker 'O' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'D' with 80kA breakerb2533Breaker 'O' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'D' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'D' with 80kA breakerb2533Breaker 'D' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerb2534Replace the Sporn 138 kV breakerb2535Breaker 'U' with 80kA breakerb2534Replace the Sporn 138 kV breaker 'U' with 80 kA breakerb2535Breaker 'O' with 80 kA breakerb2535Breaker 'O' with 80 kA breaker		Holloway-Reeds,	
Holloway-Cloverdale). Exit a 138 kV circuit from new station to Freebyrd stationb2502.2Convert Freebyrd 69 kV to 138 kVb2502.3Convert Freebyrd- south Cadiz 69 kV circuit to 138 kVb2502.4Upgrade South Cadiz to 138 kV breaker and a halfB2502.4Upgrade South Cadiz to 138 kV breaker and a halfB2502.4Replace the Sporn 138 kV breakerB2502.4Replace the Sporn 138 kV breaker 'G1' with 80kA breakerB2502Replace the Sporn 138 kV breakerB2531Breaker 'D' with 80kA breakerB2532Replace the Sporn 138 kV breakerB2533Replace the Sporn 138 kV breakerB2534Replace the Sporn 138 kV breakerB2535Breaker 'U' with 80kA breakerB2534Replace the Sporn 138 kV breakerB2535Breaker 'O' with 80 kA breakerB2535Breaker 'O' with 80 kA breakerB2535Breaker 'O' with 80 kA breakerB2535Breaker 'O' with 80 kA breakerB2535Breaker 'O' with 80 kA breaker		Holloway-New Stacy,	
a 138 kV circuit from new station to Freebyrd stationb2502.2Convert Freebyrd 69 kV to 138 kVb2502.3Rebuild/convert Freebyrd- b2502.3b2502.4Rebuild/convert Freebyrd- to 138 kVb2502.4Upgrade South Cadiz to 138 kV breaker and a halfb2502.4Upgrade South Cadiz to 138 kV breaker and a halfReplace the Sporn 138 kV b2530AEP (100%)b2531Breaker 'G1' with 80kA breakerReplace the Sporn 138 kV b2531AEP (100%)b2532breaker 'D' with 80kA breakerB2533Replace the Sporn 138 kV breakerb2534Replace the Sporn 138 kV breakerb2535Breaker 'U' with 80kA breakerb2534Replace the Sporn 138 kV breakerb2535Breaker 'U' with 80kA breakerb2534AEP (100%) breakerb2535Breaker 'O' with 80 kA breakerb2535Breaker 'O' with 80 kA breakerb2535Breaker 'O' with 80 kA breaker		Holloway-Cloverdale). Exit	
station to Freebyrd stationb2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)Bebuild/convert Freebyrd- b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502Replace the Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2531Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)b2532Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)b2533Replace the Sporn 138 kV breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2535breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2535breaker 'O' with 80kA breakerAEP (100%)b2535breaker 'O' with 80kA breakerAEP (100%)b2535breaker 'O' with 80 kA breakerAEP (100%)		a 138 kV circuit from new	
b2502.2Convert Freebyrd 69 kV to 138 kVAEP (100%)b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502Weraker and a halfAEP (100%)b2503Breaker 'G1' with 80kA breakerAEP (100%)b2531Breaker 'G1' with 80kA breakerAEP (100%)b2532Breaker 'D' with 80kA breakerAEP (100%)b2533Breaker 'O1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80kA breakerAEP (100%)		station to Freebyrd station	
b2302.2 138 kV AEP (100%) b2502.3 Rebuild/convert Freebyrd- South Cadiz 69 kV circuit to 138 kV AEP (100%) b2502.4 Upgrade South Cadiz to 138 kV breaker and a half AEP (100%) b2530 Breaker 'G1' with 80kA breaker AEP (100%) b2531 Breaker 'G1' with 80kA breaker AEP (100%) b2532 Breaker 'D' with 80kA breaker AEP (100%) b2533 Breaker 'O1' with 80kA breaker AEP (100%) b2534 Replace the Sporn 138 kV b2534 AEP (100%) b2534 Replace the Sporn 138 kV breaker AEP (100%) b2535 Breaker 'D' with 80kA breaker AEP (100%) b2534 Replace the Sporn 138 kV breaker 'U' with 80kA breaker AEP (100%) b2535 Breaker 'O' with 80 kA breaker AEP (100%)	h2502.2	Convert Freebyrd 69 kV to	A = D(1000%)
Rebuild/convert Freebyrd- South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2530Breaker G1' with 80kA breakerAEP (100%)b2531Breaker G1' with 80kA breaker 'D' with 80kAAEP (100%)b2532Breaker 'D' with 80kA breakerAEP (100%)b2533Breaker 'O1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2534Breaker 'P2' with 80kA breakerAEP (100%)b2534Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)	02302.2	138 kV	AEP (100%)
b2502.3South Cadiz 69 kV circuit to 138 kVAEP (100%)b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)b2502.4Wprade Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2530Breaker 'G1' with 80kA breakerAEP (100%)b2531Breaker 'D' with 80kA breaker 'D' with 80kA breakerAEP (100%)b2532Breaker 'O1' with 80kA breakerAEP (100%)b2533Breaker 'O1' with 80kA breakerAEP (100%)b2534Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)		Rebuild/convert Freebyrd-	
to 138 kVb2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)Replace the Sporn 138 kV breakerAEP (100%)b2530breaker 'G1' with 80kA breakerAEP (100%)b2531Breaker 'D' with 80kA breakerAEP (100%)b2532Breaker 'D' with 80kA breakerAEP (100%)b2533Breaker 'O' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2534Breaker 'D' with 80kA breakerAEP (100%)b2534Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)	b2502.3	South Cadiz 69 kV circuit	AEP (100%)
b2502.4Upgrade South Cadiz to 138 kV breaker and a halfAEP (100%)Barbon 12530Replace the Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2531Breaker 'G1' with 80kA breaker 'D' with 80kA breakerAEP (100%)b2531Breaker 'D' with 80kA breakerAEP (100%)b2532Breaker 'O1' with 80kA breakerAEP (100%)b2533Breaker 'O1' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2534Breaker 'P2' with 80kA breakerAEP (100%)b2534Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)		to 138 kV	
b2502.4 KV breaker and a half AEP (100%) Replace the Sporn 138 kV breaker 'G1' with 80kA AEP (100%) b2530 breaker 'G1' with 80kA AEP (100%) b2531 breaker 'D' with 80kA AEP (100%) b2531 breaker 'D' with 80kA AEP (100%) b2532 breaker 'O' with 80kA AEP (100%) b2532 breaker 'O1' with 80kA AEP (100%) b2533 breaker 'O1' with 80kA AEP (100%) b2533 breaker 'P2' with 80kA AEP (100%) b2534 breaker 'U' with 80kA AEP (100%) b2534 breaker 'U' with 80kA AEP (100%) b2535 breaker 'O' with 80 kA AEP (100%)	h2502 4	Upgrade South Cadiz to 138	A = D (1000/)
Replace the Sporn 138 kV breaker 'G1' with 80kA breakerAEP (100%)b2530Breaker 'G1' with 80kA breakerAEP (100%)b2531Breaker 'D' with 80kA breakerAEP (100%)b2532Breaker 'O1' with 80kA breakerAEP (100%)b2533Breaker 'O1' with 80kA breakerAEP (100%)b2533Breaker 'P2' with 80kA breakerAEP (100%)b2534Breaker 'P2' with 80kA breakerAEP (100%)b2534Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)	02302.4	kV breaker and a half	AEP (100%)
b2530breaker 'G1' with 80kA breakerAEP (100%)Replace the Sporn 138 kV b2531Replace the Sporn 138 kV breakerAEP (100%)b2531breaker 'D' with 80kA breakerAEP (100%)b2532breaker 'O1' with 80kA breakerAEP (100%)b2533breaker 'P2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breakerAEP (100%)b2534Breaker 'P2' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breakerAEP (100%)b2535Breaker 'U' with 80kA breakerAEP (100%)		Replace the Sporn 138 kV	
breakerReplace the Sporn 138 kVb2531Replace the Sporn 138 kVb2531breaker 'D' with 80kAb2532Replace the Sporn 138 kVb2532breaker 'O1' with 80kAb2533BreakerReplace the Sporn 138 kVb2534Replace the Sporn 138 kVb2534Replace the Sporn 138 kVb2535Breaker 'U' with 80kAb2535Breaker 'O' with 80 kAb2535Breaker 'O' with 80 kA	b2530	breaker 'G1' with 80kA	AEP (100%)
Replace the Sporn 138 kV breaker 'D' with 80kA breakerAEP (100%)Beplace the Sporn 138 kV b2532Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)Beplace the Sporn 138 kV b2533Breaker 'P2' with 80kA breakerAEP (100%)Beplace the Sporn 138 kV breakerAEP (100%)		breaker	
b2531breaker 'D' with 80kA breakerAEP (100%)BreakerReplace the Sporn 138 kV breakerAEP (100%)breakerBreaker 'O1' with 80kA breakerAEP (100%)breakerBreaker 'P2' with 80kA breakerAEP (100%)breakerBreaker 'P2' with 80kA breakerAEP (100%)breakerBreaker 'U' with 80kA breakerAEP (100%)breakerBreaker 'U' with 80kA breakerAEP (100%)breakerBreaker 'U' with 80kA breakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)breakerBreakerAEP (100%)		Replace the Sporn 138 kV	
breakerReplace the Sporn 138 kVb2532Breaker 'O1' with 80kAAEP (100%)breakerBreakerAEP (100%)b2533Breaker 'P2' with 80kAAEP (100%)breakerBreaker 'P2' with 80kAAEP (100%)b2534Breaker 'U' with 80kAAEP (100%)b2535Breaker 'O' with 80 kAAEP (100%)	b2531	breaker 'D' with 80kA	AEP (100%)
Replace the Sporn 138 kV breaker 'O1' with 80kA breakerAEP (100%)b2532Breaker 'O1' with 80kA breakerAEP (100%)b2533Breaker 'P2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breaker 'O' with 80 kA breakerAEP (100%)		breaker	
b2532breaker 'O1' with 80kA breakerAEP (100%)Beplace the Sporn 138 kV b2533Replace the Sporn 138 kV breakerAEP (100%)b2534Breaker 'U' with 80kA breaker 'U' with 80kA breakerAEP (100%)b2535Breaker 'O' with 80 kA breaker 'O' with 80 kA breakerAEP (100%)		Replace the Sporn 138 kV	
breakerbreakerb2533Replace the Sporn 138 kV breaker 'P2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'O' with 80 kA breakerAEP (100%)	b2532	breaker 'O1' with 80kA	AEP (100%)
Replace the Sporn 138 kV bz533AEP (100%)b2533breaker 'P2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'O' with 80 kA breakerAEP (100%)		breaker	
b2533breaker 'P2' with 80kA breakerAEP (100%)b2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'O' with 80 kA breakerAEP (100%)		Replace the Sporn 138 kV	
breakerbreakerb2534Replace the Sporn 138 kV breaker 'U' with 80kA breakerAEP (100%)b2535Replace the Sporn 138 kV breaker 'O' with 80 kA breakerAEP (100%)	b2533	breaker 'P2' with 80kA	AEP (100%)
Replace the Sporn 138 kVAEP (100%)b2534breaker 'U' with 80kAAEP (100%)breakerBreakerAEP (100%)b2535breaker 'O' with 80 kAAEP (100%)breakerbreakerBreaker		breaker	
b2534breaker 'U' with 80kA breakerAEP (100%)BreakerBreakerAEP (100%)b2535Breaker 'O' with 80 kA breakerAEP (100%)		Replace the Sporn 138 kV	
breakerb2535Replace the Sporn 138 kV breaker 'O' with 80 kA breakerb2535breaker 'O' with 80 kA breaker	b2534	breaker 'U' with 80kA	AEP (100%)
b2535Replace the Sporn 138 kV breaker 'O' with 80 kA breakerAEP (100%)		breaker	· · · · ·
b2535 breaker 'O' with 80 kA breaker		Replace the Sporn 138 kV	
breaker	b2535	breaker 'O' with 80 kA	AEP (100%)
		breaker	· · · · ·

	Replace the Sporn 138 kV	
b2536	breaker 'O2' with 80 kA	AEP (100%)
	breaker	
	Replace the Robinson Park	
	138 kV breakers A1, A2,	
b2537	B1, B2, C1, C2, D1, D2,	AEP (100%)
	E1, E2, and F1 with 63 kA	
	breakers	
	Reconductor 0.5 miles	
	Tiltonsville – Windsor 138	
h2555	kV and string the vacant	A = D (1000/)
02555	side of the 4.5 mile section	AEP (100%)
	using 556 ACSR in a six	
	wire configuration	
	Install two 138 kV prop	
	structures to increase the	
h2556	maximum operating	A = D (1000/)
02550	temperature of the Clinch	AEP (100%)
	River- Clinch Field 138 kV	
	line	
	Temporary operating	
	procedure for delay of	
	upgrade b1464. Open the	
	Corner 138 kV circuit	
	breaker 86 for an overload	
h2581	of the Corner – Washington	AED (100%)
02381	MP 138 kV line. The tower	AEI (10070)
	contingency loss of	
	Belmont – Trissler 138 kV	
	and Belmont – Edgelawn	
	138 kV should be added to	
	Operational contingency	

b2591	Construct a new 69 kV line approximately 2.5 miles from Colfax to Drewry's. Construct a new Drewry's station and install a new circuit breaker at Colfax station.	AEP (100%)
b2592	Rebuild existing East Coshocton – North Coshocton double circuit line which contains Newcomerstown – N. Coshocton 34.5 kV Circuit and Coshocton – North Coshocton 69 kV circuit	AEP (100%)
b2593	Rebuild existing West Bellaire – Glencoe 69 kV line with 138 kV & 69 kV circuits and install 138/69 kV transformer at Glencoe Switch	AEP (100%)
b2594	Rebuild 1.0 mile of Brantley – Bridge Street 69 kV Line with 1033 ACSR overhead conductor	AEP (100%)
b2595.1	Rebuild 7.82 mile Elkhorn City – Haysi S.S 69 kV line utilizing 1033 ACSR built to 138 kV standards	AEP (100%)
b2595.2	Rebuild 5.18 mile Moss – Haysi SS 69 kV line utilizing 1033 ACSR built to 138 kV standards	AEP (100%)
b2596	Move load from the 34.5 kV bus to the 138 kV bus by installing a new 138/12 kV XF at New Carlisle station in Indiana	AEP (100%)

b2597	Rebuild approximately 1 mi. section of Dragoon- Virgil Street 34.5 kV line between Dragoon and Dodge Tap switch and replace Dodge switch MOAB to increase thermal capability of Dragoon- Dodge Tap branch	AEP (100%)
b2598	Rebuild approximately 1 mile section of the Kline- Virgil Street 34.5 kV line between Kline and Virgil Street tap. Replace MOAB switches at Beiger, risers at Kline, switches and bus at Virgil Street.	AEP (100%)
b2599	Rebuild approximately 0.1 miles of 69 kV line between Albion and Albion tap	AEP (100%)
b2600	Rebuild Fremont – Pound line as 138 kV	AEP (100%)
b2601	Fremont Station Improvements	AEP (100%)
b2601.1	Replace MOAB towards Beaver Creek with 138 kV breaker	AEP (100%)
b2601.2	Replace MOAB towards Clinch River with 138 kV breaker	AEP (100%)
b2601.3	Replace 138 kV Breaker A with new bus-tie breaker	AEP (100%)
b2601.4	Re-use Breaker A as high side protection on transformer #1	AEP (100%)

	Install two (2) circuit	
b2601.5	switchers on high side of	A E D (1000/)
	transformers $\# 2$ and 3 at	AEP (100%)
	Fremont Station	
h2(02.1	Install 138 kV breaker E2 at	AED (1000/)
02002.1	North Proctorville	AEP (100%)
	Construct 2.5 Miles of 138	
h2602.2	kV 1033 ACSR from East	$A \in \mathbb{D}(1000/)$
02002.2	Huntington to Darrah 138	AEP (100%)
	kV substations	
	Install breaker on new line	
b2602.3	exit at Darrah towards East	AEP (100%)
	Huntington	
	Install 138 kV breaker on	
b2602.4	new line at East Huntington	AEP (100%)
	towards Darrah	
	Install 138 kV breaker at	
b2602.5	East Huntington towards	AEP (100%)
	North Proctorville	
b2603	Boone Area Improvements	AEP (100%)
	Purchase approximately a	
h2602 1	200X300 station site near	$A \in \mathbb{D}(1000/)$
02003.1	Slaughter Creek 46 kV	AEP (100%)
	station (Wilbur Station)	
	Install 3 138 kV circuit	
b2603.2	breakers, Cabin Creek to	AEP (100%)
	Hernshaw 138 kV circuit	
	Construct 1 mi. of double	
	circuit 138 kV line on	
	Wilbur – Boone 46 kV line	
b2603.3	with 1590 ACSS 54/19	A ED (1000%)
	conductor @ 482 Degree	ALF (100%)
	design temp. and 1-159 12/7	
	ACSR and one 86 Sq.MM.	
	0.646" OPGW Static wires	
h2604	Bellefonte Transformer	AED (1000/)
02004	Addition	

b2605	Rebuild and reconductor Kammer – George Washington 69 kV circuit and George Washington – Moundsville ckt #1, designed for 138kV. Upgrade limiting equipment at remote ends and at tap	AEP (100%)
b2606	Convert Bane – Hammondsville from 23 kV to 69 kV operation	AEP (100%)
b2607	Pine Gap Relay Limit Increase	AEP (100%)
b2608	Richlands Relay Upgrade	AEP (100%)
b2609	Thorofare – Goff Run – Powell Mountain 138 kV Build	AEP (100%)
b2610	Rebuild Pax Branch – Scaraboro as 138 kV	AEP (100%)
b2611	Skin Fork Area Improvements	AEP (100%)
b2611.1	New 138/46 kV station near Skin Fork and other components	AEP (100%)
b2611.2	Construct 3.2 miles of 1033 ACSR double circuit from new Station to cut into Sundial-Baileysville 138 kV line	AEP (100%)
b2634.1	Replace metering BCT on Tanners Creek CB T2 with a slip over CT with higher thermal rating in order to remove 1193 MVA limit on facility (Miami Fort- Tanners Creek 345 kV line)	AEP (100%)

		^	· · · · · · · · · · · · · · · · · · ·
b2643	Replace the Darrah 138 kV breaker 'L' with 40kA rated breaker		AEP (100%)
b2645	Ohio Central 138 kV Loop		AEP (100%)
b2667	Replace the Muskingum 138 kV bus # 1 and 2		AEP (100%)
b2668	Reconductor Dequine to Meadow Lake 345 kV circuit #1 utilizing dual 954 ACSR 54/7 cardinal conductor		AEP (100%)
b2669	Install a second 345/138 kV transformer at Desoto		AEP (100%)
b2670	Replace switch at Elk Garden 138 kV substation (on the Elk Garden – Lebanon 138 kV circuit)		AEP (100%)
b2671	Replace/upgrade/add terminal equipment at Bradley, Mullensville, Pinnacle Creek, Itmann, and Tams Mountain 138 kV substations. Sag study on Mullens – Wyoming and Mullens – Tams Mt. 138 kV circuits		AEP (100%)

Required Tr	ansmission Enhancements Ann	ual Revenue Requirement	Responsible Customer(s)
b2687.1	Install a +/- 450 MVAR SVC at Jacksons Ferry 765 kV substation		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: AEP (100%)

*Neptune Regional Transmission System, LLC

Required In		Responsible Customer(s)
		Load-Ratio Share Allocation:
		AEC (1.71%) / AEP (14.04%) /
		APS (5.61%) / ATSI (8.10%) /
		BGE (4.36%) / ComEd
		(13.14%) / Dayton (2.15%) /
	Install a 300 MVAR shunt	DEOK (3.23%) / DL (1.73%) /
	line reactor on the	DPL (2.65%) / Dominion
h2687.2	Broadford end of the	(13.03%) / EKPC (1.77%) /
02007.2	Broadford – Jacksons Ferry	JCPL (3.84%) / ME (1.93%) /
	765 kV line	NEPTUNE* (0.45%) / OVEC
	705 K V IIIIC	(0.07%) / PECO (5.29%) /
		PENELEC (1.89%) / PEPCO
		(3.82%) / PPL (4.72%) / PSEG
		(6.21%) / RE (0.26%)
		DFAX Allocation:
		AEP (100%)
	Mitigate violations	
	identified by sag study to	
	operate Fieldale-Thornton-	
b2697.1	Franklin 138 kV overhead	A EP (100%)
02097.1	line conductor at its max.	AEI (100%)
	operating temperature. 6	
	potential line crossings to	
	be addressed.	
b2697.2	Replace terminal equipment	
	at AEP's Danville and East	
	Danville substations to	A = D(1000/)
	improve thermal capacity of	ALF(10070)
	Danville – East Danville	
	138 kV circuit	

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

*Neptune Regional Transmission System, LLC

b2698	Replace relays at AEP's Cloverdale and Jackson's Ferry substations to improve the thermal capacity of Cloverdale – Jackson's Ferry 765 kV line	AEP (100%)
b2701.1	Construct Herlan station as breaker and a half configuration with 9-138 kV CB's on 4 strings and with 2- 28.8 MVAR capacitor banks	AEP (100%)
b2701.2	Construct new 138 kV line from Herlan station to Blue Racer station. Estimated approx. 3.2 miles of 1234 ACSS/TW Yukon and OPGW	AEP (100%)
2701.3	Install 1-138 kV CB at Blue Racer to terminate new Herlan circuit	AEP (100%)
b2714	Rebuild/upgrade line between Glencoe and Willow Grove Switch 69 kV	AEP (100%)
b2715	Build approximately 11.5 miles of 34.5 kV line with 556.5 ACSR 26/7 Dove conductor on wood poles from Flushing station to Smyrna station	AEP (100%)
b2727	Replace the South Canton 138 kV breakers 'K', 'J', 'J1', and 'J2' with 80kA breakers	AEP (100%)

	Convert the Sunnyside –		
b2731	East Sparta – Malvern 23 kV		
	sub-transmission network to		AEP (100%)
	69 kV. The lines are already		
	built to 69 kV standards		
	Replace South Canton 138		
b2733	kV breakers 'L' and 'L2'		AEP (100%)
	with 80 kA rated breakers		
	Retire Betsy Layne		
	138/69/43 kV station and		
b2750 1	replace it with the greenfield		$\Delta FP(100\%)$
02750.1	Stanville station about a half		
	mile north of the existing		
	Betsy Layne station		
	Relocate the Betsy Layne		
	capacitor bank to the		
b2750.2	Stanville 69 kV bus and		AEP (100%)
	increase the size to 14.4		
	MVAR		
	Replace existing George		
	Washington station 138 kV		
	yard with GIS 138 kV		
b2753.1	breaker and a half yard in		AEP (100%)
02,0011	existing station footprint.		
	Install 138 kV revenue		
	metering for new IPP		
	connection		
	Replace Dilles Bottom 69/4		
b2753.2	kV Distribution station as		
	breaker and a half 138 kV		
	yard design including AEP		AEP (100%)
	Distribution facilities but		
	initial configuration will		
	constitute a 3 breaker ring		
	bus		

1100		(~)
	Connect two 138 kV 6-wired circuits from "Point A" (currently de-energized and	
	owned by FirstEnergy) in	
h2752 2	circuit positions previously	A = D(1000%)
02755.5	designated Burger #1 &	AEF (100%)
	Burger #2 138 kV. Install	
	interconnection settlement	
	metering on both circuits	
	exiting Holloway	
	Build double circuit 138 kV	
	line from Dilles Bottom to	
	"Point A". Tie each new	
	AEP circuit in with a 6-wired	
b2753.6	line at Point A. This will	AEP (100%)
	create a Dilles Bottom –	
	Holloway 138 kV circuit and	
	a George Washington –	
	Holloway 138 kV circuit	
	Retire line sections (Dilles	
	Bottom – Bellaire and	
	Moundsville – Dilles Bottom	
	69 kV lines) south of	
b2753.7	FirstEnergy 138 kV line	AEP (100%)
	corridor, near "Point A". Tie	
	George Washington –	
	Moundsville 69 kV circuit to	
	George Washington – West	
	Bellaire 69 KV circuit	
	Rebuild existing 69 kV line	
b2753.8	as double circuit from	
	Bettern 128 kV One singuit	
	Bottom 158 KV. One circuit	AEP (100%)
	138 kV initially and the other	
	will go past with future plane	
	to cut in	

b2760	Perform a Sag Study of the Saltville – Tazewell 138 kV line to increase the thermal rating of the line	AEP (100%)
b2761.1	Replace the Hazard 161/138 kV transformer	AEP (100%)
b2761.2	Perform a Sag Study of the Hazard – Wooten 161 kV line to increase the thermal rating of the line	AEP (100%)
b2761.3	Rebuild the Hazard – Wooton 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating)	AEP (100%)
b2762	Perform a Sag Study of Nagel – West Kingsport 138 kV line to increase the thermal rating of the line	AEP (100%)
b2776	Reconductor the entire Dequine – Meadow Lake 345 kV circuit #2	AEP (100%)
b2777	Reconductor the entire Dequine – Eugene 345 kV circuit #1	<i>EKPC</i> (100%)
b2779.1	Construct a new 138 kV station, Campbell Road, tapping into the Grabill – South Hicksville138 kV line	AEP (100%)
b2779.2	Reconstruct sections of the Butler-N.Hicksville and Auburn-Butler 69 kV circuits as 138 kV double circuit and extend 138 kV from Campbell Road station	AEP (100%)

b2779.3	Construct a new 345/138 kV SDI Wilmington Station which will be sourced from Collingwood 345 kV and serve the SDI load at 345 kV and 138 kV, respectively	AEP (100%)
b2779.4	Loop 138 kV circuits in-out of the new SDI Wilmington 138 kV station resulting in a direct circuit to Auburn 138 kV and an indirect circuit to Auburn and Rob Park via Dunton Lake, and a circuit to Campbell Road; Reconductor 138 kV line section between Dunton Lake – SDI Wilmington	AEP (100%)
b2779.5	Expand Auburn 138 kV bus	AEP (100%)
b2779.6	Construct a 345 kV ring bus at Dunton Lake to serve Steel Dynamics, Inc. (SDI) load at 345 kV via two (2) circuits	AEP (100%)
b2779.7	Retire Collingwood 345 kV station	AEP (100%)
b2787	Reconductor 0.53 miles (14 spans) of the Kaiser Jct Air Force Jct. Sw section of the Kaiser - Heath 69 kV circuit/line with 336 ACSR to match the rest of the circuit (73 MVA rating, 78% loading)	AEP (100%)

		(-)
	Install a new 3-way 69 kV	
	line switch to provide service	
	to AEP's Barnesville	
b2788	distribution station. Remove a	AEP (100%)
	portion of the #1 copper T-	
	Line from the 69 kV through-	
	path	
	Rebuild the Brues - Glendale	
b2789	Heights 69 kV line section (5	A E D (1000%)
	miles) with 795 ACSR (128	AEF (100%)
	MVA rating, 43% loading)	

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
	Install a 3 MVAR, 34.5 kV		
b2790	cap bank at Caldwell		AEP (100%)
	substation		
h2701	Rebuild Tiffin – Howard, new		A = D(1000/)
02791	transformer at Chatfield		AEF (100%)
	Rebuild portions of the East		
	Tiffin - Howard 69 kV line		
	from East Tiffin to West		
b2791.1	Rockaway Switch (0.8 miles)		AEP (100%)
	using 795 ACSR Drake		
	conductor (129 MVA rating,		
	50% loading)		
	Rebuild Tiffin - Howard 69		
	kV line from St. Stephen's		
	Switch to Hinesville (14.7		
b2791.2	miles) using 795 ACSR		AEP (100%)
	Drake conductor (90 MVA		
	rating, non-conductor limited,		
	38% loading)		
	New 138/69 kV transformer		
b2791.3	with 138/69 kV protection at		AEP (100%)
	Chatfield		
h2791 /	New 138/69 kV protection at		$\Delta FP(100\%)$
02771.4	existing Chatfield transformer		ALI (10070)
	Replace the Elliott		
	transformer with a 130 MVA		
	unit, reconductor 0.42 miles		
	of the Elliott – Ohio		
h2792	University 69 kV line with		$\Delta FP(100\%)$
02792	556 ACSR to match the rest		ALI (10070)
	of the line conductor (102		
	MVA rating, 73% loading)		
	and rebuild 4 miles of the		
	Clark Street – Strouds R		

Required Tra	ansmission Enhancements	Annual Revenue Requirer	ment Responsible Customer(s)
	Energize the spare Fremont		
	Center 138/69 kV 130 MVA		
b2793	transformer #3. Reduces		AEP (100%)
	overloaded facilities to 46%		
	loading		
	Construct new 138/69/34 kV		
	station and 1-34 kV circuit		
	(designed for 69 kV) from new		
b2794	station to Decliff station,		AEP (100%)
	approximately 4 miles, with		
	556 ACSR conductor (51		
	MVA rating)		
	Install a 34.5 kV 4.8 MVAR		
b2795	capacitor bank at Killbuck		AEP (100%)
	34.5 kV station		
	Rebuild the Malvern - Oneida		
1.2706	Switch 69 kV line section with		AED (1000/)
02796	795 ACSR (1.8 miles, 125		AEP (100%)
	MVA rating, 55% loading)		
	Rebuild the Ohio Central -		
	Conesville 69 kV line section		
	(11.8 miles) with 795 ACSR		
b2797	conductor (128 MVA rating,		AEP (100%)
	57% loading). Replace the 50		
	MVA Ohio Central 138/69 kV		
	XFMR with a 90 MVA unit		
	Install a 14.4 MVAR capacitor		
	bank at West Hicksville		
h2709	station. Replace ground		A = D(1000/)
02798	switch/MOAB at West		AEP (100%)
	Hicksville with a circuit		
	switcher		
	Rebuild Valley - Almena,		
b2799	Almena - Hartford, Riverside -		
	South Haven 69 kV lines.		A = D(1000/)
	New line exit at Valley		AEP(100%)
	Station. New transformers at		
	Almena and Hartford		

Required Tr	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Rebuild 12 miles of Valley – Almena 69 kV line as a double circuit 138/69 kV line using 795 ACSP conductor		
b2799.1	(360 MVA rating) to introduce a new 138 kV source into the 69 kV load pocket around Almena station		AEP (100%)
b2799.2	Rebuild 3.2 miles of Almena to Hartford 69 kV line using 795 ACSR conductor (90 MVA rating)		AEP (100%)
b2799.3	Rebuild 3.8 miles of Riverside – South Haven 69 kV line using 795 ACSR conductor (90 MVA rating)		AEP (100%)
b2799.4	At Valley station, add new 138 kV line exit with a 3000 A 40 kA breaker for the new 138 kV line to Almena and replace CB D with a 3000 A 40 kA breaker		AEP (100%)
b2799.5	At Almena station, install a 90 MVA 138/69 kV transformer with low side 3000 A 40 kA breaker and establish a new 138 kV line exit towards Valley		AEP (100%)
b2799.6	At Hartford station, install a second 90 MVA 138/69 kV transformer with a circuit switcher and 3000 A 40 kA low side breaker		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Replace Delaware 138 kV		
b2817	breaker 'P' with a 40 kA		AEP (100%)
	breaker		
	Replace West Huntington 138		
b2818	kV breaker 'F' with a 40 kA		AEP (100%)
	breaker		
	Replace Madison 138 kV		
b2819	breaker 'V' with a 63 kA		AEP (100%)
	breaker		
	Replace Sterling 138 kV		
b2820	breaker 'G' with a 40 kA		AEP (100%)
	breaker		
	Replace Morse 138 kV		
L2021	breakers '103', '104', '105',		AED (1000/)
02821	and '106' with 63 kA		AEP (100%)
	breakers		
	Replace Clinton 138 kV		
b2822	breakers '105' and '107' with		AEP (100%)
	63 kA breakers		
	Install 300 MVAR reactor at		
b2826.1	Ohio Central 345 kV		AEP (100%)
	substation		

b2826.2	Install 300 MVAR reactor at West Bellaire 345 kV substation	AEP (100%)
b2831.1	Upgrade the Tanner Creek – Miami Fort 345 kV circuit (AEP portion)	DFAX Allocation: Dayton (61.71%) / DEOK (37.68%) / OVEC (0.61%)
b2832	Six wire the Kyger Creek – Sporn 345 kV circuits #1 and #2 and convert them to one circuit	AEP (100%)
b2833	Reconductor the Maddox Creek – East Lima 345 kV circuit with 2-954 ACSS Cardinal conductor	DFAX Allocation: AEP (80.83%) / Dayton (18.73%) / OVEC (0.44%)
b2834	Reconductor and string open position and sixwire 6.2 miles of the Chemical – Capitol Hill 138 kV circuit	AEP (100%)
b2872	Replace the South Canton 138 kV breaker 'K2' with a 80 kA breaker	AEP (100%)
b2873	Replace the South Canton 138 kV breaker "M" with a 80 kA breaker	AEP (100%)
b2874	Replace the South Canton 138 kV breaker "M2" with a 80 kA breaker	AEP (100%)
b2878	Upgrade the Clifty Creek 345 kV risers	AEP (100%)
b2880	Rebuild approximately 4.77 miles of the Cannonsburg – South Neal 69 kV line section utilizing 795 ACSR conductor (90 MVA rating)	AEP (100%)

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
	Rebuild ~1.7 miles of the		
1-2001	Dunn Hollow – London 46		
	kV line section utilizing 795		A ED (100%)
02001	26/7 ACSR conductor (58		ALF (100%)
	MVA rating, non-conductor		
	limited)		
	Rebuild Reusens - Peakland		
b2882	Switch 69 kV line. Replace		AEP (100%)
	Peakland Switch		
	Rebuild the Reusens -		
	Peakland Switch 69 kV line		
62002 1	(approximately 0.8 miles)		A = D(1000%)
02002.1	utilizing 795 ACSR		AEP (100%)
	conductor (86 MVA rating,		
	non-conductor limited)		
	Replace existing Peakland S.S		
b2882.2	with new 3 way switch phase		AEP (100%)
	over phase structure		
	Rebuild the Craneco – Pardee		
	– Three Forks – Skin Fork 46		
h2883	kV line section		AED (100%)
02885	(approximately 7.2 miles)		AEI (10070)
	utilizing 795 26/7 ACSR		
	conductor (108 MVA rating)		
	Install a second transformer at		
	Nagel station, comprised of 3		
	single phase 250 MVA		
	500/138 kV transformers.		
b2884	Presently, TVA operates their		AEP (100%)
02004	end of the Boone Dam –		ALI (10070)
	Holston 138 kV		
	interconnection as normally		
	open preemptively for the loss		
	of the existing Nagel		
h2885	New delivery point for City		$\Delta FP (100\%)$
02003	of Jackson		ALI (10070)

Required Tr	ansmission Enhancements	Annual Revenue Requir	ement Responsible Customer(s)
	Install a new Ironman Switch		
	to serve a new delivery point		
b2885.1	requested by the City of		AEP (100%)
	Jackson for a load increase		
	request		
	Install a new 138/69 kV		
	station (Rhodes) to serve as a		
b2885.2	third source to the area to help		AEP (100%)
	relieve overloads caused by		
	the customer load increase		
	Replace Coalton Switch with		
b2885.3	a new three breaker ring bus		AEP (100%)
	(Heppner)		
	Install 90 MVA 138/69 kV		
	transformer, new transformer		
67006	high and low side 3000 A 40		A = D (1000%)
02880	kA CBs, and a 138 kV 40 kA		AEP (100%)
	bus tie breaker at West End		
	Fostoria		
	Add 2-138 kV CB's and		
	relocate 2-138 kV circuit exits		
62007	to different bays at Morse		A E D (1000/)
02887	Road. Eliminate 3 terminal		AEP (100%)
	line by terminating Genoa -		
	Morse circuit at Morse Road		
	Retire Poston substation.		
b2888	Install new Lemaster		AEP (100%)
	substation		
L7000 1	Remove and retire the Poston		$\mathbf{AED}(1000/)$
02000.1	138 kV station		AEP (100%)
	Install a new greenfield		
b2888.2	station, Lemaster 138 kV		AEP (100%)
	Station, in the clear		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	ment Responsible Customer(s)
b2888.3	Relocate the Trimble 69 kV AEP Ohio radial delivery point to 138 kV, to be served off of the Poston – Strouds Run – Crooksville 138 kV circuit via a new three-way switch. Retire the Poston – Trimble 69 kV line		AEP (100%)
b2889	Expand Cliffview station		AEP (100%)
b2889.1	Cliffview Station: Establish 138 kV bus. Install two 138/69 kV XFRs (130 MVA), six 138 kV CBs (40 kA 3000 A) and four 69 kV CBs (40 kA 3000 A)		AEP (100%)
b2889.2	Byllesby – Wythe 69 kV: Retire all 13.77 miles (1/0 CU) of this circuit (~4 miles currently in national forest)		AEP (100%)
b2889.3	Galax – Wythe 69 kV: Retire 13.53 miles (1/0 CU section) of line from Lee Highway down to Byllesby. This section is currently double circuited with Byllesby – Wythe 69 kV. Terminate the southern 3/0 ACSR section into the newly opened position at Byllesby		AEP (100%)
b2889.4	Cliffview Line: Tap the existing Pipers Gap – Jubal Early 138 kV line section. Construct double circuit in/out (~2 miles) to newly established 138 kV bus, utilizing 795 26/7 ACSR conductor		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Requirement	ment Responsible Customer(s)
	Rebuild 23.55 miles of the		
	East Cambridge – Smyrna		
b2890.1	34.5 kV circuit with 795		AEP (100%)
	ACSR conductor (128 MVA		
	rating) and convert to 69 kV		
	East Cambridge: Install a		
	2000 A 69 kV 40 kA circuit		
b2890.2	breaker for the East		AEP (100%)
	Cambridge – Smyrna 69 kV		
	circuit		
	Old Washington: Install 69		
b2890.3	kV 2000 A two way phase		AEP (100%)
	over phase switch		
h2800 /	Install 69 kV 2000 A two way		A EP (100%)
02070.4	phase over phase switch		ALI (100%)
	Rebuild the Midland Switch		
	to East Findlay 34.5 kV line		
b2891	(3.31 miles) with 795 ACSR		AEP (100%)
	(63 MVA rating) to match		
	other conductor in the area		
	Install new 138/12 kV		
	transformer with high side		
	circuit switcher at Leon and a		
	new 138 kV line exit towards		
h2892	Ripley. Establish 138 kV at		AFP (100%)
02072	the Ripley station with a new		
	138/69 kV 130 MVA		
	transformer and move the		
	distribution load to 138 kV		
	service		
	Rebuild approximately 6.7		
	miles of 69 kV line between		
	Mottville and Pigeon River		
b2936.1	using 795 ACSR conductor		AEP (100%)
02750.1	(129 MVA rating). New		
	construction will be designed		
	to 138 kV standards but		
	operated at 69 kV		

Required Tr	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Pigeon River Station: Replace existing MOAB Sw. 'W' with a new 69 kV 3000 A 40 kA		
b2936.2	breaker, and upgrade existing relays towards HMD station. Replace CB H with a 3000 A 40 kA breaker		AEP (100%)
b2937	Replace the existing 636 ACSR 138 kV bus at Fletchers Ridge with a larger 954 ACSR conductor		AEP (100%)
b2938	Perform a sag mitigations on the Broadford – Wolf Hills 138 kV circuit to allow the line to operate to a higher maximum temperature		AEP (100%)
b2958.1	Cut George Washington – Tidd 138 kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances		AEP (100%)
b2958.2	Add 2 138 kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station		AEP (100%)
b2968	Upgrade existing 345 kV terminal equipment at Tanner Creek station		AEP (100%)
b2969	Replace terminal equipment on Maddox Creek - East Lima 345 kV circuit		AEP (100%)
b2976	Upgrade terminal equipment at Tanners Creek 345 kV station. Upgrade 345 kV bus and risers at Tanners Creek for the Dearborn circuit		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Requirer	nent Responsible Customer(s)
	Replace the Twin Branch 345		
	kV breaker "JM" with 63 kA		
h2988	breaker and associated		$\Delta FP(100\%)$
02700	substation works including		ALI (100%)
	switches, bus leads, control		
	cable and new DICM		
	Rebuild the Torrey – South		
	Gambrinus Switch –		
h2003	Gambrinus Road 69 kV line		A EP (100%)
02773	section (1.3 miles) with 1033		ALI (100%)
	ACSR 'Curlew' conductor		
	and steel poles		
	Replace South Canton 138 kV		
b3000	breaker 'N' with an 80kA		AEP (100%)
	breaker		
	Replace South Canton 138 kV		
b3001	breaker 'N1' with an 80kA		AEP (100%)
	breaker		
	Replace South Canton 138 kV		
b3002	breaker 'N2' with an 80kA		AEP (100%)
	breaker		
	Rebuild 15.6 miles of		
b3036	Haviland - North Delphos 138		AEP (100%)
	kV line		
b3037	Upgrades at the Natrium		AEP(100%)
03037	substation		AEI (100%)
12020	Reconductor the Capitol Hill		A = D (1000/)
03038	– Coco 138 kV line section		AEP (100%)
1.2020	Line swaps at Muskingum		
03039	138 kV station		AEP (100%)
	Rebuild Ravenswood –		
b3040.1	Racine tap 69 kV line section		
	(~15 miles) to 69 kV		AEP (100%)
	standards, utilizing 795 26/7		· · · ·
	ACSR conductor		

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3040.2	Rebuild existing Ripley – Ravenswood 69 kV circuit (~9 miles) to 69 kV standards, utilizing 795 26/7 ACSR conductor		AEP (100%)
b3040.3	Install new 3-way phase over phase switch at Sarah Lane station to replace the retired switch at Cottageville		AEP (100%)
b3040.4	Install new 138/12 kV 20 MVA transformer at Polymer station to transfer load from Mill Run station to help address overload on the 69 kV network		AEP (100%)
b3040.5	Retire Mill Run station		AEP (100%)
b3040.6	Install 28.8 MVAR cap bank at South Buffalo station		AEP (100%)
b3051.2	Adjust CT tap ratio at Ronceverte 138 kV		AEP (100%)
b3085	Reconductor Kammer – George Washington 138 kV line (approx. 0.08 mile). Replace the wave trap at Kammer 138 kV		AEP (100%)
b3086.1	Rebuild New Liberty – Findlay 34 kV line Str's 1–37 (1.5 miles), utilizing 795 26/7 ACSR conductor		AEP (100%)
b3086.2	Rebuild New Liberty – North Baltimore 34 kV line Str's 1- 11 (0.5 mile), utilizing 795 26/7 ACSR conductor		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Require	ement Responsible Customer(s)
	Rebuild West Melrose –		
h2096 2	Whirlpool 34 kV line Str's		A ED (1000/)
03080.3	55–80 (1 mile), utilizing 795		AEF (100%)
	26/7 ACSR conductor		
	North Findlay station: Install		
	a 138 kV 3000A 63kA line		
h2086 1	breaker and low side 34.5 kV		A ED (1000/)
03080.4	2000A 40kA breaker, high		AEF (100%)
	side 138 kV circuit switcher		
	on T1		
	Ebersole station: Install		
	second 90 MVA 138/69/34		
b3086.5	kV transformer. Install two		AEP (100%)
	low side (69 kV) 2000A		
	40kA breakers for T1 and T2		
	Construct a new greenfield		
	station to the west (approx.		
	1.5 miles) of the existing		
	Fords Branch Station in the		
	new Kentucky Enterprise		
	Industrial Park. This station		
	will consist of six 3000A		
b3087.1	40kA 138 kV breakers laid		AEP (100%)
	out in a ring arrangement, two		
	30 MVA 138/34.5 kV		
	transformers, and two 30		
	MVA 138/12 kV		
	transformers. The existing		
	Fords Branch Station will be		
	retired		
	Construct approximately 5		
	miles of new double circuit		
h2087 2	138 kV line in order to loop		A ED (1000%)
03087.2	the new Kewanee station into		AEF (100%)
	the existing Beaver Creek –		
	Cedar Creek 138 kV circuit		

Required Transmission Enhancements		Annual Revenue Requirement Responsible Customer(s)	
	Remote end work will be		
b3087.3	required at Cedar Creek		AEP (100%)
	Station		
	Install 28.8 MVar switching		
b3087.4	shunt at the new Fords		AEP (100%)
	Branch substation		
	Rebuild Lakin – Racine Tap		
h3095	69 kV line section (9.2 miles)		AFP (100%)
05075	to 69 kV standards, utilizing		
	795 26/7 ACSR conductor		
	Install a 138 kV 3000A 40 kA		
	circuit switcher on the high		
b3099	side of the existing 138/34.5		AEP (100%)
	kV transformer No.5 at		
	Holston station		
	Replace the 138 kV MOAB		
	switcher "YY" with a new		
b3100	138 kV circuit switcher on the		AEP (100%)
	high side of Chemical		
	transformer No.6		
	Rebuild the 1/0 Cu. conductor		
	sections (approx. 1.5 miles) of		
	the Fort Robinson – Moccasin		
	Gap 69 kV line section		
b3101	(approx. 5 miles) utilizing		A EP (100%)
03101	556 ACSR conductor and		ALI (100%)
	upgrade existing relay trip		
	limit (WN/WE: 63 MVA, line		
	limited by remaining		
	conductor sections)		
	Replace existing 50 MVA		
	138/69 kV transformers #1		
b3102	and #2 (both 1957 vintage) at		AEP (100%)
	Fremont station with new 130		
	MVA 138/69 kV transformers		

Required Tr	ansmission Enhancements	Annual Revenue Requirer	ment Responsible Customer(s)
	Install a 138/69 kV		
	transformer at Royerton		
	station. Install a 69 kV bus		
	with one 69 kV breaker		
b3103.1	toward Bosman station.		$\Delta FP(100\%)$
05105.1	Rebuild the 138 kV portion		ALI (100%)
	into a ring bus configuration		
	built for future breaker and a		
	half with four 138 kV		
	breakers		
	Rebuild the		
	Bosman/Strawboard station in		
h3103.2	the clear across the road to		AEP(100%)
05105.2	move it out of the flood plain		ALI (10070)
	and bring it up to 69 kV		
	standards		
	Retire 138 kV breaker L at		
b3103 3	Delaware station and re-		$\Delta FP(100\%)$
05105.5	purpose 138 kV breaker M		ALI (100%)
	for the Jay line		
	Retire all 34.5 kV equipment		
b3103.4	at Hartford City station. Re-		A FP (100%)
03103.4	purpose breaker M for the		ALI (100%)
	Bosman line 69 kV exit		
	Rebuild the 138 kV portion of		
	Jay station as a 6 breaker,		
	breaker and a half station re-		
	using the existing breakers		
b3103.5	"A", "B", and "G." Rebuild		AEP(100%)
05105.5	the 69 kV portion of this		ALI (10070)
	station as a 6 breaker ring bus		
	re-using the 2 existing 69 kV		
	breakers. Install a new 138/69		
	kV transformer		

Required Tr	ansmission Enhancements	Annual Revenue Require	ment Responsible Customer(s)
	Rebuild the 69 kV Hartford		
	City – Armstrong Cork line		
b3103.6	but instead of terminating it		AEP (100%)
	into Armstrong Cork,		
	terminate it into Jay station		
h3103 7	Build a new 69 kV line from		A ED (1000/2)
03103.7	Armstrong Cork – Jay station		ALF (100%)
	Rebuild the 34.5 kV		
	Delaware – Bosman line as		
h2102 0	the 69 kV Royerton –		A = D (1000/)
05105.8	Strawboard line. Retire the		AEP (100%)
	line section from Royerton to		
	Delaware stations		
	Perform a sag study on the		
	Polaris – Westerville 138 kV		
b3104	line (approx. 3.6 miles) to		A E D (1000/2)
03104	increase the summer		ALI (100%)
	emergency rating to 310		
	MVA		
	Rebuild the Delaware – Hyatt		
	138 kV line (approx. 4.3		
b3105	miles) along with replacing		AEP (100%)
	conductors at both Hyatt and		
	Delaware substations		
	Perform a sag study (6.8		
	miles of line) to increase the		
	SE rating to 310 MVA. Note		
b3106	that results from the sag study		AEP (100%)
	could cover a wide range of		
	outcomes, from no work		
	required to a complete rebuild		
	Rebuild 5.2 miles Bethel –		
b3109	Sawmill 138 kV line		AEP (100%)
	including ADSS		

Required Tra	ansmission Enhancements	Annual Revenue Requirer	ment Responsible Customer(s)
	Construct a single circuit 138		
	kv line (approx. 3.5 miles)		
	from Amlin to Dublin using		
10110	1033 ACSR Curlew (296		
63112	MVA SN), convert Dublin		AEP (100%)
	station into a ring		
	configuration, and re-		
	terminating the Britton UG		
	cable to Dublin station		
	Replace existing Mullens		
	138/46 kV 30 MVA		
	transformer No.4 and		
b3116	associated protective		AEP (100%)
00110	equipment with a new 138/46		
	kV 90 MVA transformer and		
	associated protective		
	equipment		
	Expand existing Chadwick		
	station and install a second		
	138/69 kV transformer at a		
	new 138 kV bus tied into the		
	Bellefonte – Grangston 138		
b3118 1	kV circuit. The 69 kV bus		A E P (100%)
03110.1	will be reconfigured into a		ALI (100%)
	ring bus arrangement to tie		
	the new transformer into the		
	existing 69 kV via installation		
	of four 3000A 63 kA 69 kV		
	circuit breakers		
h2110 0	Perform 138 kV remote end		A = D(1000/)
03118.2	work at Grangston station		AEP (100%)
1 21 1 0 2	Perform 138 kV remote end		
03118.3	work at Bellefonte station		AEP (100%)
	Relocate the Chadwick –		
b3118.4	Leach 69 kV circuit within		AEP (100%)
	Chadwick station		
Required Tra	ansmission Enhancements	Annual Revenue Requirement Responsible Customer(s)	
--------------	---------------------------------	----------------------------------------------------	
	Terminate the Bellefonte –		
b3118.5	Grangston 138 kV circuit to	AEP (100%)	
	the Chadwick 138 kV bus		
	Chadwick – Tri-State #2 138		
	kV circuit will be		
	reconfigured within the		
b3118.6	station to terminate into the	AEP (100%)	
	newly established 138 kV bus		
	#2 at Chadwick due to		
	construability aspects		
	Reconductor Chadwick –		
	Leach and Chadwick		
	England Hill 69 kV lines with		
	795 ACSS conductor.		
b3118.7	Perform a LiDAR survey and	AEP (100%)	
	a sag study to confirm that the		
	reconductored circuits would		
	maintain acceptable		
	clearances		
	Replace the 20 kA 69 kV		
	circuit breaker 'F' at South		
1.2110.0	Neal station with a new	AED (1000())	
03118.8	3000A 40 kA 69 kV circuit	AEP (100%)	
	breaker. Replace line risers		
	towards Leach station		
	Rebuild 336 ACSR portion of		
h21100	Leach – Miller S.S 69 kV line	A E D (1000/)	
03116.9	section (approx. 0.3 mile)	AEF (100%)	
	with 795 ACSS conductor		
	Replace 69 kV line risers		
b3118.10	(towards Chadwick) at Leach	AEP (100%)	
	station		
	Rebuild the Jay – Pennville		
	138 kV line as double circuit		
b3119.1	138/69 kV. Build a new 9.8	AED (1000/)	
	mile single circuit 69 kV line	AEP (100%)	
	from near Pennville station to		
	North Portland station		

Required Tr	ansmission Enhancements	Annual Revenue Requirem	nent Responsible Customer(s)
	Install three (3) 69 kV		
	breakers to create the "U"		
b3119.2	string and add a low side		AEP (100%)
	breaker on the Jay		
	transformer 2		
	Install two (2) 69 kV breakers		
b31103	at North Portland station to		A EP (100%)
03117.3	complete the ring and allow		ALI (100%)
	for the new line		
	At Conesville 138 kV station:		
	Remove line leads to		
	generating units, transfer		
h3129	plant AC service to existing		AFP (100%)
03127	station service feeds in		ALL (10070)
	Conesville 345/138 kV yard,		
	and separate and reconfigure		
	protection schemes		
	At East Lima and Haviland		
	138 kV stations, replace line		
b3131	relays and wavetrap on the		AEP (100%)
	East Lima – Haviland 138 kV		
	facility		
	Rebuild 3.11 miles of the		
b3132	LaPorte Junction – New		AEP (100%)
05152	Buffalo 69 kV line with 795		
	ACSR		
	Rebuild the Garden Creek –		
b3139	Whetstone 69 kV line		AEP (100%)
	(approx. 4 miles)		
b3140	Rebuild the Whetstone –		
	Knox Creek 69 kV line		AEP (100%)
	(approx. 3.1 miles)		
	Rebuild the Knox Creek –		
b3141	Coal Creek 69 kV line		AEP (100%)
	(approx. 2.9 miles)		

Required Tr	ansmission Enhancements	Annual Revenue Requir	rement Responsible Customer(s)
	Rebuild the 46 kV Bradley –		
	Scarbro line to 96 kV		
	standards using 795 ACSR to		
	achieve a minimum rate of		
b3148.1	120 MVA. Rebuild the new		AEP (100%)
	line adjacent to the existing		
	one leaving the old line in		
	service until the work is		
	completed		
	Bradley remote end station		
h3148 2	work, replace 46 kV bus,		AFP(100%)
03140.2	install new 12 MVAR		ALI (100%)
	capacitor bank		
	Replace the existing switch at		
h3148 3	Sun substation with a 2-way		AFP(100%)
03140.5	SCADA-controlled motor-		ALI (100%)
	operated air-breaker switch		
	Remote end work and		
b3148.4	associated equipment at		AEP (100%)
	Scarbro station		
	Retire Mt. Hope station and		
b3148.5	transfer load to existing Sun		AEP (100%)
	station		
	Rebuild the 2.3 mile Decatur		
b3149	– South Decatur 69 kV line		AEP (100%)
	using 556 ACSR		
	Rebuild Ferguson 69/12 kV		
	station in the clear as the		
b3150	138/12 kV Bear station and		
	connect it to an approx. 1		
	mile double circuit 138 kV		AEP (100%)
	extension from the Aviation –		
	Ellison Road 138 kV line to		
	remove the load from the 69		
	kV line		

Required Transmission Enhancements		Annual Revenue Requir	rement Responsible Customer(s)
	Rebuild the 30 mile Gateway		
b3151.1	– Wallen 34.5 kV circuit as		AFP (100%)
	the 27 mile Gateway –		/ HEI (10070)
	Wallen 69 kV line		
	Retire approx. 3 miles of the		
b3151.2	Columbia – Whitley 34.5 kV		AEP (100%)
	line		
	At Gateway station, remove		
101710	all 34.5 kV equipment and		
b3151.3	install one (1) 69 kV circuit		AEP (100%)
	breaker for the new Whitley		
	line entrance		
1 2 1 5 1 4	Rebuild Whitley as a 69 kV		
63151.4	station with two (2) lines and		AEP (100%)
	one (1) bus the circuit breaker		
h21515	Replace the Union 34.5 KV		AED (1000/)
03151.5	switch with a 69 kV switch		AEP (100%)
	Structure Deplace the Eel Diver 24.5		
h21516	keplace the Eel Kiver 54.5		A = D (1000/)
03131.0	KV Switch with a 69 KV		AEP (100%)
	Switch structure		
b3151.7	install a 69 KV Boday switch		AEP (100%)
	at woodiand station		
	Chumhuses 24.5 kV stations		
	with the 60 kV Spapper		
	station Snapper station will		
b3151.8	have two (2) line circuit		AEP (100%)
	breakers one (1) bus tie		
	circuit breaker and a 14.4		
	MVAR can bank		
	Remove 34.5 kV circuit		
b3151.9	breaker "AD" at Wallen		AEP (100%)
	station		
	Rebuild the 2.5 miles of the		
b3151.10	Columbia – Gateway 69 kV		AEP (100%)
	line		×/

Required Tr	ansmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3151.11	Rebuild Columbia station in the clear as a 138/69 kV station with two (2) 138/69 kV transformers and 4- breaker ring buses on the high		AEP (100%)
	and low side. Station will reuse 69 kV breakers "J" & "K" and 138 kV breaker "D"		
b3151.12	Rebuild the 13 miles of the Columbia – Richland 69 kV line		AEP (100%)
b3151.13	Rebuild the 0.5 mile Whitley – Columbia City No.1 line as 69 kV		AEP (100%)
b3151.14	Rebuild the 0.5 mile Whitley – Columbia City No.2 line as 69 kV		AEP (100%)
b3151.15	Rebuild the 0.6 mile double circuit section of the Rob Park – South Hicksville / Rob Park – Diebold Road as 69 kV		AEP (100%)
b3160.1	Construct an approx. 2.4 miles double circuit 138 kV extension using 1033 ACSR (Aluminum Conductor Steel Reinforced) to connect Lake Head to the 138 kV network		AEP (100%)
b3160.2	Retire the approx.2.5 miles 34.5 kV Niles – Simplicity Tap line		AEP (100%)
b3160.3	Retire the approx.4.6 miles Lakehead 69 kV Tap		AEP (100%)

Required Tr	ansmission Enhancements	Annual Revenue Requirem	ment Responsible Customer(s)
	Build new 138/69 kV drop down station to feed Lakehead with a 138 kV		
b3160.4	breaker, 138 kV switcher,		AEP (100%)
	138/69 kV transformer and a		
	138 kV Motor-Operated Air		
	Break		
	Rebuild the approx. 1.2 miles		
	Buchanan South 69 kV		
b3160.5	Radial Tap using 795 ACSR		AEP (100%)
	(Aluminum Conductor Steel		
	Reinforced)		
	Rebuild the approx.8.4 miles		
	69 KV Pletcher – Buchanan		
12160 6	Hydro line as the approx. 9		
03160.6	miles Pletcher – Buchanan		AEP (100%)
	South 69 KV line using 795		
	ACSR (Aluminum Conductor		
	Steel Reinforced)		
	Install a POP (Point-of-		
h21607	Presence) switch at Buchanan		A = D (1000/)
03100.7	South station with 2 line		AEP (100%)
	MOABS (Motor-Operated Air		
	Break)		

Required 7	Fransmission Enhancements	Annual Revenue Requiremen	t Responsible Customer(s)
	Retire approximately 38		
	miles of the 44 mile Clifford		
	 Scottsville 46 kV circuit. 		
	Build new 138 kV "in and		
	out" to two new distribution		
	stations to serve the load		
	formerly served by Phoenix,		
	Shipman, Schuyler (AEP),		
	and Rockfish stations.		
	Construct new 138 kV lines		
b3208	from Joshua Falls – Riverville		AEP (100%)
	(approx. 10 miles) and		
	Riverville – Gladstone		
	(approx. 5 miles). Install		
	required station upgrades at		
	Joshua Falls, Riverville and		
	Gladstone stations to		
	accommodate the new 138		
	kV circuits. Rebuild Reusen –		
	Monroe 69 kV (approx. 4		
	miles)		
	Rebuild the 10.5 mile Berne –		
b3209	South Decatur 69 kV line		AEP (100%)
	using 556 ACSR		
	Replace approx. 0.7 mile		
b3210	Beatty – Galloway 69 kV line		AEP (100%)
	with 4000 kcmil XLPE cable		
h2220	Install 14.4 MVAR capacitor		AED (100%)
03220	bank at Whitewood 138 kV		AEP(100%)

Required Transmission Enhancements		Annual Revenue Requi	rement Responsible Customer(s)
b3243	Replace risers at the Bass 34.5 kV station		AEP (100%)
b3244	Rebuild approximately 9 miles of the Robinson Park – Harlan 69 kV line		AEP (100%)
b3248	Install a low side 69 kV circuit breaker at the Albion 138/69 kV transformer #1		AEP (100%)

Required Transmission Enhancements		Annual Revenue Require	ment Responsible Customer(s)
	Install a 3000A 40 kA 138 kV		
	breaker on the high side of		
	138/69 kV transformer #5 at		
b3253	the Millbrook Park station.		AEP (100%)
	The transformer and		
	associated bus protection will		
	be upgraded accordingly		
	Upgrade 795 AAC risers at		
h3255	the Sand Hill 138 kV station		AED (100%)
03233	towards Cricket Switch with		ALI (100%)
	1272 AAC		
	Upgrade 500 MCM Cu risers		
	at Tidd 138 kV station		
b3256	towards Wheeling Steel;		AEP (100%)
	replace with 1272 AAC		
	conductor		
	Replace two spans of 336.4		
b3257	26/7 ACSR on the Twin		$\Delta FP (100\%)$
03237	Branch – AM General #2		ALI (10070)
	34.5 kV circuit		
	Install a 3000A 63 kA 138 kV		
	breaker on the high side of		
	138/69 kV transformer #2 at		
b3258	Wagenhals station. The		AEP (100%)
	transformer and associated		
	bus protection will be		
	upgraded accordingly		
	At West Millersburg station,		
	replace the 138 kV MOAB on		
b3259	the West Millersburg –		AEP (100%)
	Wooster 138 kV line with a		
	3000A 40 kA breaker		
	Upgrade circuit breaker "R1"		
	at Tanners Creek 345 kV.		
h3261	Install Transient Recovery		
00201	Voltage capacitor to increase		
	the rating from 50 kA to 63		
	kA		AEP (100%)

Required 7	Fransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	At West New Philadelphia		
	station, add a high side 138		
h3269	kV breaker on the 138/69 kV		$\Delta FP(100\%)$
03207	Transformer #2 along with a		MLI (10070)
	138 kV breaker on the line		
	towards Newcomerstown		
	Install 1.7 miles of 795 ACSR		
	138 kV conductor along the		
	other side of Dragoon Tap		
	138 kV line, which is		
	currently double circuit tower		
	with one position open.		
	Additionally, install a second		
h2270	138/34.5 kV transformer at		A = D (1000/)
05270	Dragoon, install a high side		AEF (100%)
	circuit switcher on the current		
	transformer at the Dragoon		
	Station, and install two (2)		
	138 kV line breakers on the		
	Dragoon – Jackson 138 kV		
	and Dragoon – Twin Branch		
	138 kV lines		
	Replace Dragoon 34.5 kV		
b3270.1	breakers "B", "C", and "D"		AEP (100%)
	with 40 kA breakers		
	Install a 138 kV circuit		
	breaker at Fremont station on		
b3271	the line towards Fremont		$\Delta FP(100\%)$
03271	Center and install a 9.6		ALI (10070)
	MVAR 69 kV capacitor bank		
	at Bloom Road station		
	Install two 138 kV circuit		
h3272	switchers on the high side of		A E P (100%)
03272	138/34.5 kV Transformers #1		ALI (10070)
	and #2 at Rockhill station		

Required Tr	ansmission Enhancements	Annual Revenue Requ	irement Responsible Customer(s)
	Rebuild and convert the		
	existing 17.6 miles East		
b3273.1	Leipsic – New Liberty 34.5		AEP (100%)
	kV circuit to 138 kV using		
	795 ACSR		
	Convert the existing 34.5		
	kV equipment to 138 kV		
	and expand the existing		
	McComb station to the		
	north and east to allow for		
b3273.2	new equipment to be		AEP (100%)
	installed. Install two (2)		×
	new 138 kV box bays to		
	allow for line positions and		
	two (2) new 138/12 kV		
	transformers		
	Expand the existing East		
	Leipsic 138 kV station to		
	the north to allow for		
	another 138 kV line exit to		
	be installed. The new line		
	exit will involve installing		
b3273.3	a new 138 kV circuit		AEP (100%)
	breaker, disconnect		(,
	switches and the addition		
	of a new dead end structure		
	along with the extension of		
	the existing 138 kV bus		
	work		
	Add one (1) 138 kV circuit		
	breaker and disconnect		
	switches in order to add an		
1.0050.4	additional line position at		
b3273.4	New Liberty 138 kV		AEP (100%)
	station. Install line relaying		
	potential devices and retire		
	the 34.5 kV breaker 'F'		

Required Tr	ansmission Enhancements	Annual Revenue Requirement Responsible Customer(s)
b3274	Rebuild approximately 8.9 miles of 69 kV line between Newcomerstown and Salt Fork Switch with 556 ACSR	AEP (100%)
b3275.1	Rebuild the Kammer Station – Cresaps Switch 69 kV line, approximately 0.5 mile	AEP (100%)
b3275.2	Rebuild the Cresaps Switch – McElroy Station 69 kV, approximately 0.67 mile	AEP (100%)
b3275.3	Replace a single span of 4/0 ACSR from Moundsville - Natrium structure 93L to Carbon Tap switch 69 kV located between the Colombia Carbon and Conner Run stations. Remainder of the line is 336 ACSR	AEP (100%)
b3275.4	Rebuild from Colombia Carbon to Columbia Carbon Tap structure 93N 69 kV, approximately 0.72 mile. The remainder of the line between Colombia Carbon Tap structure 93N and Natrium station is 336 ACSR and will remain	AEP (100%)
b3275.5	Replace the Cresaps 69 kV 3- Way Phase-Over-Phase switch and structure with a new 1200A 3-Way switch and steel pole	AEP (100%)
b3275.6	Replace 477 MCM Alum bus and risers at McElroy 69 kV station	AEP (100%)

Required Tra	ansmission Enhancements	Annual Revenue Requir	rement Responsible Customer(s)
	Replace Natrium 138 kV bus		
	existing between CB-BT1		
	and along the 138 kV Main		
	Bus #1 dropping to CBH1		
b3275.7	from the 500 MCM		AEP (100%)
	conductors to a 1272 KCM		
	AAC conductor. Replace the		
	dead end clamp and strain		
	insulators		
	Rebuild the 2/0 Copper		
	section of the Lancaster –		
	South Lancaster 69 kV line,		
h2076 1	approximately 2.9 miles of		A = D (1000/)
03270.1	the 3.2 miles total length with		AEP (100%)
	556 ACSR conductor. The		
	remaining section has a 336		
	ACSR conductor		
	Rebuild the 1/0 Copper		
	section of the line between		
h2076 0	Lancaster Junction and		A = B (1000/)
05270.2	Ralston station 69 kV,		AEP (100%)
	approximately 2.3 miles of		
	the 3.1 miles total length		
	Rebuild the 2/0 Copper		
	portion of the line between		
b3276.3	East Lancaster Tap and		AEP (100%)
	Lancaster 69 kV,		
	approximately 0.81 mile		
	Rebuild approximately 4		
	miles of existing 69 kV line		
	between West Mount Vernon		
	and Mount Vernon stations.		
b3312	Replace the existing 138/69		AEP (100%)
	kV transformer at West		
	Mount Vernon with a larger		
	90 MVA unit along with		
	existing 69 kV breaker 'C'		

SCHEDULE 12 – APPENDIX A

(18) Duquesne Light Company

riequireu r		iau ne fende negatement nespe	
b2175.1	200 MVAR shunt reactor at Brunot Island 345 kV		DL (100%)
b2175.2	200 MVAR shunt reactor on future Brunot Island – Carson 345 kV circuit		DL (100%)
b2198	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-40 COLLIER'		DL (100%)
b2199	Revise the reclosing for the Brunot Island 138 kV breaker 'Z-41 COLLIER'		DL (100%)
b2200	Revise the reclosing for the Crescent 138 kV breaker 'Z- 29 Beaver'		DL (100%)
b2201	Revise the reclosing for the Crescent 138 kV breaker 'Z- 82 VALLEY'		DL (100%)
b2202	Revise the reclosing for the Crescent 138 kV breaker 'Z- 21 NORTH'		DL (100%)
b2203	Revise the reclosing for the Elrama 138 kV breaker 'Z18-USX CLAI'		DL (100%)
b2204	Revise the reclosing for the Elrama 138 kV breaker 'Z13-WEST MIF'		DL (100%)
b2205	Revise the reclosing for the Elrama 138 kV breaker 'Z15 -DRAVOSBU'		DL (100%)
b2206	Revise the reclosing for the Woodville 138 kV breaker 'Z-106 PINEY'		DL (100%)
b2207	Revise the reclosing for the Woodville 138 kV breaker 'Z-64 COLLIER'		DL (100%)
b2208	Revise the reclosing for the Beaver Valley 138 kV breaker 'Z-28 CRESCEN'		DL (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

1		1
1.0000	Kevise the reclosing for the	
b2209	Cheswick 138 kV breaker	DL (100%)
	Z-51 WILMERD'	
h2280	Replace the USAP 138kV	$DI_{(100\%)}$
02280	breaker 'XFMR'	DE (100%)
	Revise the reclosing to the	
L2202	Dravosburg 138kV breaker	DL(1000)
02303	'Z73 West Mifflin' from 5	DL (100%)
	sec to 15 sec	
	Operate with the Crescent	
	345/138 kV #3	
	autotransformer in-service	
	by replacing 8 overdutied	
b2563	138 kV breakers at	DL (100%)
	Crescent, 3 138 kV breakers	
	at Beaver Valley, install #1	
	section 345 kV breaker for	
	331 circuit at Crescent	
	Replace the Oakland 138	
b2632	kV '7-101 Arsenal' breaker	DL (100%)
	Replace the Crescent	
h2639	138 kV (NO3 - 4.138)	$DI_{(100\%)}$
02037	hreaker with a $63kA$ breaker	DE (100%)
	Replace the Crescent 138	
b2640	kV '7-143 SWCKI V'	$DI_{(100\%)}$
02040	breaker with a $63k\Delta$ breaker	DE (100%)
	Replace the Crescent	
	138 kV '7 24 MONTOUP'	
b2641	brooker with a 62kA	DL (100%)
	breaker	
	Banlaga the Crassont	
h2612	129 1 AV (7 29 DE AVED)	DL(1000)
02042	138 KV Z-28 BEAVER	DL (100%)
	breaker with a 65kA breaker	
		AEC (0.99%) APS
		(66.14%)/ BGE (4.60%)/
	Reconductor approximately	DOM (8.81%)/ DPL
b26891	/ miles of the Woodville –	(5.83%)/ ECP (0.34%)/
	Peters (Z-117) 138 kV	HTP (0.04%)/ Neptune
	circuit	(0.12%)/ PECO (3.39%)/
		PEPCO (6.29%)/ PSEG
		(3.45%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required T	ransmission Enhancements	Annual Revenue Requirement	t Responsible Customer(s)
b2689.2	Reconfigure West Mifflin- USS Clairton (Z-15) 138 kV circuit to establish Dravosburg-USS Clairton (Z-14) 138 kV circuit and West Mifflin-Wilson (Z-15) 138 kV circuit		AEC (0.99%)/ APS (66.14%)/ BGE (4.60%)/ DOM (8.81%)/ DPL (5.83%)/ ECP (0.34%)/ HTP (0.04%)/ Neptune (0.12%)/ PECO (3.39%)/ PEPCO (6.29%)/ PSEG (3.45%)
b3011.7	Replace the line terminal equipment and line breaker #85 at Dravosburg 138 kV substation in the Elwyn Z- 70 line position/bay, with the breaker duty as 63kA		DL (100%)
b3011.8	Upgrade 138 kV breaker "Z-78 Logans" at Dravosburg		DL (100%)
b3012.2	Construct two new ties from a new FirstEnergy substation to a new Duquesne substation by using two separate structures – Duquesne portion		ATSI (38.21%) / DL (61.79%)
b3012.4	Establish the new tie line in place of the existing Elrama – Mitchell 138 kV line		DL (100%)
b3015.1	Construct new Elrama 138 kV substation and connect 7 138 kV lines to new substation		DL (100%)
b3015.2	Reconductor Elrama to Wilson 138 kV line. 4.8 miles		APS (100%)
b3015.3	Reconductor Dravosburg to West Mifflin 138 kV line. 3 miles		DL (100%)
b3015.4	Run new conductor on existing tower to establish the new Dravosburg – Elrama (Z-75) circuit. 10 miles		DL (100%)

Required T	ransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b3015.5	Reconductor Elrama to Mitchell 138 kV line – DL portion. 4.2 miles total. 2x795 ACSS/TW 20/7		DL (100%)
b3015.7	Reconductor Wilson to West Mifflin 138 kV line. 2 miles. 795 ACSS/TW 20/7		DL (100%)
b3061	Reconductor the West Mifflin – Dravosburg (Z-73) and Dravosburg – Elrama (Z-75) 138 kV lines		DL (100%)
b3062	Install 138 kV tie breaker at West Mifflin		DL (100%)
b3063	Reconductor the Wilson – Dravosburg (Z-72) 138 kV line (approx. 5 miles)		DL (100%)
b3064	Expand Elrama 138 kV substation to loop in existing US Steel Clariton – Piney Fork 138 kV line		DL (100%)
b3064.2	Replace the West Mifflin 138 kV breakers "Z-94", "Z-74", "Z-14", and "Z-13" with 63 kA breakers		DL (100%)
b3065	Install 138 kV tie breaker at Wilson		DL (100%)
b3084	Reconductor the Oakland – Panther Hollow 138 kV line (approx. 1 mile)		DL (100%)
b3212	The Crescent 138 kV oil- type breaker "2-5 TIE" is found to be overdutied following a model review and correction to short circuit base case		DL (100%)
b3217	Reconductor Wilson - Mitchell 138 kV line - DL portion		DL (100%)

Required Transmission Enhancements		Annual Revenue Requirement	t Responsible Customer(s)
b3265	Implement slow circulation on existing underground 138 kV high pressure fluid filled (HPFF) cable between the Arsenal and Riazzi substations		DL (100%)

SCHEDULE 12 – APPENDIX A

Required T	ransmission Enhancements Annua	al Revenue Requirement	Responsible Customer(s)
b1698.7	Replace Loudoun 230 kV breaker '203052' with 63kA rating		Dominion (100%)
b1696.1	Replace the Idylwood 230 kV '25112' breaker with 50kA breaker		Dominion (100%)
b1696.2	Replace the Idylwood 230 kV '209712' breaker with 50kA breaker		Dominion (100%)
b1793.1	Remove the Carolina 22 SPS to include relay logic changes, minor control wiring, relay resets and SCADA programming upon completion of project		Dominion (100%)
b2281	Additional Temporary SPS at Bath County		Dominion (100%)
b2350	Reconductor 211 feet of 545.5 ACAR conductor on 59 Line Elmont - Greenwood DP 115 kV to achieve a summer emergency rating of 906 amps or greater		Dominion (100%)
b2358	Install a 230 kV 54 MVAR capacitor bank on the 2016 line at Harmony Village Substation		Dominion (100%)
b2359	Wreck and rebuild approximately 1.3 miles of existing 230 kV line between Cochran Mill - X4-039 Switching Station		Dominion (100%)
b2360	Build a new 39 mile 230 kV transmission line from Dooms - Lexington on existing right- of-way		Dominion (100%)
b2361	Construct 230 kV OH line along existing Line #2035 corridor, approx. 2.4 miles from Idylwood - Dulles Toll Road (DTR) and 2.1 miles on new right-of-way along DTR to new Scott's Run Substation		Dominion (100%)

Required I	Talisilission Linarcements Tinuar	Revenue Requirement	Responsible Customer(s)
b2368	Replace the Brambleton 230 kV breaker '209502' with 63kA breaker		Dominion (100%)
b2369	Replace the Brambleton 230 kV breaker '213702' with 63kA breaker		Dominion (100%)
b2370	Replace the Brambleton 230 kV breaker 'H302' with 63kA breaker		Dominion (100%)
b2373	Build a 2nd Loudoun - Brambleton 500 kV line within the existing ROW. The Loudoun - Brambleton 230 kV line will be relocated as an underbuild on the new 500 kV line		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: APS (25.51%) / Dominion (74.49%)
b2397	Replace the Beaumeade 230 kV breaker '2079T2116' with 63kA		Dominion (100%)
b2398	Replace the Beaumeade 230 kV breaker '2079T2130' with 63kA		Dominion (100%)
b2399	Replace the Beaumeade 230 kV breaker '208192' with 63kA		Dominion (100%)
b2400	Replace the Beaumeade 230 kV breaker '209592' with 63kA		Dominion (100%)
b2401	Replace the Beaumeade 230 kV breaker '211692' with 63kA		Dominion (100%)
b2402	Replace the Beaumeade 230 kV breaker '227T2130' with 63kA		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

The Annual Revenue Requirement for all Virginia Electric and Power Company projects in this Section 20 shall be as specified in Attachment 7 to Appendix A of Attachment H-16A and under the procedures detailed in Attachment H-16B.

*Neptune Regional Transmission System, LLC

Required I	Tansmission Enhancements A	initial Revenue Requirement	Responsible Customer(s)
b2403	Replace the Beaumeade 230 kV breaker '274T2130' with 63kA		Dominion (100%)
b2404	Replace the Beaumeade 230 kV breaker '227T2095' with 63kA		Dominion (100%)
b2405	Replace the Pleasant view 230 kV breaker '203T274' with 63kA		Dominion (100%)
b2443	Construct new underground 230 kV line from Glebe to Station C, rebuild Glebe Substation, construct 230 kV high side bus at Station C with option to install 800 MVA PAR		Dominion (97.11%) / ME (0.18%) / PEPCO (2.71%)
b2443.1	Replace the Idylwood 230 kV breaker '203512' with 50kA		Dominion (100%)
b2443.2	Replace the Ox 230 kV breaker '206342' with 63kA breaker		Dominion (100%)
b2443.3	Glebe – Station C PAR		DFAX Allocation: Dominion (22.57%) / PEPCO (77.43%)
b2443.6	Install a second 500/230 kV transformer at Possum Point substation and replace bus work and associated equipment as needed		Dominion (100%)
b2443.7	Replace 19 63kA 230 kV breakers with 19 80kA 230 kV breakers		Dominion (100%)
b2457	Replace 24 115 kV wood h-frames with 230 kV Dominion pole H-frame structures on the Clubhouse – Purdy 115 kV line		Dominion (100%)
b2458.1	Replace 12 wood H-frame structures with steel H- frame structures and install shunts on all conductor splices on Carolina – Woodland 115 kV		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required I	Talishiission Linaicements A	iniual Revenue Requirement	
b2458.2	Upgrade all line switches and substation components at Carolina 115 kV to meet or exceed new conductor rating of 174 MVA		Dominion (100%)
b2458.3	Replace 14 wood H-frame structures on Carolina – Woodland 115 kV		Dominion (100%)
b2458.4	Replace 2.5 miles of static wire on Carolina – Woodland 115 kV		Dominion (100%)
b2458.5	Replace 4.5 miles of conductor between Carolina 115 kV and Jackson DP 115 kV with min. 300 MVA summer STE rating; Replace 8 wood H-frame structures located between Carolina and Jackson DP with steel H-frames		Dominion (100%)
b2460.1	Replace Hanover 230 kV substation line switches with 3000A switches		Dominion (100%)
b2460.2	Replace wave traps at Four River 230 kV and Elmont 230 kV substations with 3000A wave traps		Dominion (100%)
b2461	Wreck and rebuild existing Remington CT – Warrenton 230 kV (approx. 12 miles) as a double-circuit 230 kV line		Dominion (100%)
b2461.1	Construct a new 230 kV line approximately 6 miles from NOVEC's Wheeler Substation a new 230 kV switching station in Vint Hill area		Dominion (100%)
b2461.2	Convert NOVEC's Gainesville – Wheeler line (approximately 6 miles) to 230 kV		Dominion (100%)
b2461.3	Complete a Vint Hill – Wheeler – Loudoun 230 kV networked line		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required T	ransmission Enhancements Annua	al Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
	Replace Midlothian 500 KV		DEOK (3.23%) / DL (1.73%) /
	operated switches with 3		DPL (2.65%) / Dominion
10471	breaker 500 kV ring bus.		(13.03%) / EKPC (1.77%) /
b24/1	Terminate Lines # 563 Carson		JCPL (3.84%) / ME (1.93%) /
	– Midlothian, #576		NEPTUNE* (0.45%) / OVEC
	Midlothian –North Anna, Transformer #2 in new ring		(0.07%) / PECO (5.29%) /
	Transformer #2 in new ring		PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Rebuild 115 kV Line #32		
	from Halifax-South Boston (6		
b2504	and transfer Welco tap to Line		
02304	#32. Moving Welco to Line		Dominion (100%)
	#32 requires disabling auto-		
	sectionalizing scheme		
	Install structures in river to		
b2505	(Whitestone-Harmony Village		
02303	115 kV) from bridge and		Dominion (100%)
	improve reliability of the line		
1.05.40	Replace the Loudoun 500 kV		
62542	$H_2 I 502$ breaker with a 50k Δ breaker		Dominion (100%)
	Replace the Loudoun 500 kV		
b2543	'H2T584' breaker with a		$\mathbf{D}_{\text{aminion}}$ (100%)
	50kA breaker		Dominion (100%)
10565	Reconductor wave trap at		
b2565	Carver Substation with a 2000 A wave trap		Dominion (100%)
	Reconductor 1.14 miles of		
h2566	existing line between ACCA		
02300	and Hermitage and upgrade		Dominion (100%)
	associated terminal equipment		

Required T	Transmission Enhancements A	nnual Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Rebuild the Elmont		(13.03%) / EKPC (1.77%) /
b2582	Cunningham 500 kV line		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Install 500 kV breaker at		
h2583	Ox Substation to remove		Dominion (100%)
02365	Ox Tx#1 from H1T561		Dominion (100%)
	breaker failure outage.		
	(transformer #5) to $#2028$		
	(Bremo-Charlottesville		
b2584	230 kV) line and		Dominion (100%)
	Cartersville distribution		
	Station to #2027 (Bremo-		
	Reconductor 7 63 miles of		
	existing line between		
b2585	Cranes and Stafford,		PEPCO (100%)
	upgrade associated line		
	switches at Stafford		
	Chesapeake Deep Creek		
	– Bowers Hill – Hodges		
h2(20	Ferry 115 kV line;		\mathbf{D}
02620	minimum rating 239		Dominion (100%)
	MVA normal/emergency,		
	2/5 MVA load dump		
1	rating		

Required 1	ransmission Enhancements Ar	inual Revenue Requirement	Responsible Customer(s)
b2622	Rebuild Line #47 between Kings Dominion 115 kV and Fredericksburg 115 kV to current standards with summer emergency rating of 353 MVA at 115 kV		Dominion (100%)
b2623	Rebuild Line #4 between Bremo and Structure 8474 (4.5 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV		Dominion (100%)
b2624	Rebuild 115 kV Lines #18 and #145 between Possum Point Generating Station and NOVEC's Smoketown DP (approx. 8.35 miles) to current 230 kV standards with a normal continuous summer rating of 524 MVA at 115 kV		Dominion (100%)
b2625	Rebuild 115 kV Line #48 between Thole Street and Structure 48/71 to current standard. The remaining line to Sewells Point is 2007 vintage. Rebuild 115 kV Line #107 line, Sewells Point to Oakwood, between structure 107/17 and 107/56 to current standard.		Dominion (100%)
b2626	Rebuild 115 kV Line #34 between Skiffes Creek and Yorktown and the double circuit portion of 115 kV Line #61 to current standards with a summer emergency rating of 353 MVA at 115 kV		Dominion (100%)
b2627	Rebuild 115 kV Line #1 between Crewe 115 kV and Fort Pickett DP 115 kV (12.2 miles) to current standards with summer emergency rating of 261 MVA at 115 kV		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required 1	Tansmission Enhancements Anno	iai Kevenue Kequitement	Responsible Customer(s)
b2628	Rebuild 115 kV Line #82 Everetts – Voice of America (20.8 miles) to current standards with a summer emergency rating of 261 MVA at 115 kV		Dominion (100%)
b2629	Rebuild the 115 kV Lines #27 and #67 lines from Greenwich 115 kV to Burton 115 kV Structure 27/280 to current standard with a summer emergency rating of 262 MVA at 115 kV		Dominion (100%)
b2630	Install circuit switchers on Gravel Neck Power Station GSU units #4 and #5. Install two 230 kV CCVT's on Lines #2407 and #2408 for loss of source sensing		Dominion (100%)
b2636	Install three 230 kV bus breakers and 230 kV, 100 MVAR Variable Shunt Reactor at Dahlgren to provide line protection during maintenance, remove the operational hazard and provide voltage reduction during light load conditions		Dominion (100%)
b2647	Rebuild Boydton Plank Rd – Kerr Dam 115 kV Line #38 (8.3 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)
b2648	Rebuild Carolina – Kerr Dam 115 kV Line #90 (38.7 miles) to current standards with summer emergency rating of 353 MVA 115 kV.		Dominion (100%)
b2649	Rebuild Clubhouse – Carolina 115 kV Line #130 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required I	ransmission enhancements Annu	lai Revenue Requirement	Responsible Customer(s)
b2649.1	Rebuild of 1.7 mile tap to Metcalf and Belfield DP (MEC) due to poor condition. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor		Dominion (100%)
b2649.2	Rebuild of 4.1 mile tap to Brinks DP (MEC) due to wood poles built in 1962. The existing summer rating of the tap is 48 MVA and existing conductor is 4/0 ACSR and 393.6 ACSR on wood H-frames. The proposed new rating is 176 MVA using 636 ACSR conductor		Dominion (100%)
b2650	Rebuild Twittys Creek – Pamplin 115 kV Line #154 (17.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)

Required Ira	ansmission Enhancements Ann	ual Revenue Requirement	Responsible Customer(s)
b2651	Rebuild Buggs Island – Plywood 115 kV Line #127 (25.8 miles) to current standards with summer emergency rating of 353 MVA at 115 kV. The line should be rebuilt for 230 kV and operated at 115 kV.		Dominion (100%)
b2652	Rebuild Greatbridge – Hickory 115 kV Line #16 and Greatbridge – Chesapeake E.C. to current standard with summer emergency rating of 353 MVA at 115 kV.		Dominion (100%)
b2653.1	Build 20 mile 115 kV line from Pantego to Trowbridge with summer emergency rating of 353 MVA.		Dominion (100%)
b2653.2	Install 115 kV four-breaker ring bus at Pantego		Dominion (100%)
b2653.3	Install 115 kV breaker at Trowbridge		Dominion (100%)
b2654.1	Build 15 mile 115 kV line from Scotland Neck to S Justice Branch with summer emergency rating of 353 MVA. New line will be routed to allow HEMC to convert Dawson's Crossroads RP from 34.5 kV to 115 kV.		Dominion (100%)
b2654.2	Install 115 kV three-breaker ring bus at S Justice Branch		Dominion (100%)
b2654.3	Install 115 kV breaker at Scotland Neck		Dominion (100%)
b2654.3	Install a 2nd 224 MVA 230/115 kV transformer at Hathaway		Dominion (100%)

Required Tra	ansmission Enhancements Annu	ual Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Rebuild the Cunningham -		(13.03%) / EKPC (1.77%) /
b2665	Dooms 500 kV line		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
b2686	Pratts Area Improvement		Dominion (100%)
	Build a 230 kV line from		
1.0.000	Remington Substation to		
b2686.1	Gordonsville Substation		Dominion (100%)
	utilizing existing ROW		
h2696.2	Install a 3rd 230/115 kV		\mathbf{D}
02080.2	Substation		Dominion (100%)
	Upgrade Line 2088		
h2686 3	between Gordonsville		Dominion (100%)
02080.5	Substation and Louisa CT		Dominion (10070)
	Station Replace the Remington CT		
	230 kV breaker		
b2686.4	"2114T2155" with a 63 kA		Dominion (100%)
	breaker		
1000011	Upgrading sections of the		
b2686.11	115 kV circuit		Dominion (100%)
	Upgrading sections of the		
b2686.12	Somerset – Doubleday 115		Dominion (100%)
	kV circuit		
1000010	Upgrading sections of the		D · · · (1000()
02086.13	orange – Somerset 115 KV		Dominion (100%)
	Upgrading sections of the		
b2686.14	Mitchell – Mt. Run 115 kV		Dominion (100%)
	circuit		× ,

*Neptune Regional Transmission System, LLC

Required II		Alliual Revenue Require	ment Responsible Customer(s)
b2717.1	De-energize Davis – Rosslyn #179 and #180 69 kV lines		Dominion (100%)
b2717.2	Remove splicing and stop joints in manholes		Dominion (100%)
b2717.3	Evacuate and dispose of insulating fluid from various reservoirs and cables		Dominion (100%)
b2717.4	Remove all cable along the approx. 2.5 mile route, swab and cap-off conduits for future use, leave existing communication fiber in place		Dominion (100%)
b2719.1	Expand Perth substation and add a 115 kV four breaker ring		Dominion (100%)
b2719.2	Extend the Hickory Grove DP tap 0.28 miles to Perth and terminate it at Perth		Dominion (100%)
b2719.3	Split Line #31 at Perth and terminate it into the new ring bus with 2 breakers separating each of the line terminals to prevent a breaker failure from taking out both 115 kV lines		Dominion (100%)
b2720	Replace the Loudoun 500 kV 'H1T569' breakers with 50kA breaker		Dominion (100%)
b2729	Optimal Capacitors Configuration: New 175 MVAR capacitor at Brambleton, new 175 MVAR capacitor at Ashburn, new 300 MVAR capacitor at Shelhorm, new 150 MVAR capacitor at Liberty		AEC (1.96%) / BGE (14.37%) / Dominion (35.11%) / DPL (3.76%) / ECP (0.29%) / HTP (0.34%) / JCPL (3.31%) / ME (2.51%) / Neptune (0.63%) / PECO (6.26%) / PEPCO (20.23%) / PPL (3.94%) / PSEG (7.29%)

 Required Transmission Enhancements
 Annual Revenue Requirement Responsible Customer(s)

Required Tra	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
h2744	Rebuild the Carson – Rogers		(13.03%) / EKPC (1.77%) /
02744	Rd 500 kV circuit		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Rebuild 21.32 miles of		
b2745	existing line between Chasterfield Lakeside		Dominion (100%)
	230 kV		
	Rebuild Line #137 Ridge Rd		
b27461	– Kerr Dam 115 kV, 8.0		Dominion (100%)
02710.1	miles, for 346 MVA summer		
	Rebuild Line #1009 Ridge Rd		
107460	- Chase City 115 kV, 9.5		D · · · (1000()
62746.2	miles, for 346 MVA summer		Dominion (100%)
	emergency rating		
	Install a second 4.8 MVAR		
b2746.3	bus of each transformer at		Dominion (100%)
	Ridge Rd		
	Install a Motor Operated		
1 07 47	Switch and SCADA control		
b2747	Cordonsville 115 kV bus and		Dominion (100%)
	FirstEnergy's 115 kV line		

b2757	Install a +/-125 MVAr Statcom at Colington 230 kV	Dominion (100%)
b2758 Rebuild Line #549 Valley 500k	Rebuild Line #549 Dooms – Valley 500kV	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
		DFAX Allocation: Dominion (100%)
		Load-Ratio Share Allocation:
b2759	Rebuild Line #550 Mt. Storm – Valley 500kV	AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: APS (97.50%) / ATSL (0.27%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tra	Insmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)	
b2800	The 7 mile section from Dozier to Thompsons Corner of line #120 will be rebuilt to current standards using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Line is proposed to be rebuilt on single circuit steel monopole structure		Dominion (100%)	
b2801	Lines #76 and #79 will be rebuilt to current standard using 768.2 ACSS conductor with a summer emergency rating of 346 MVA at 115 kV. Proposed structure for rebuild is double circuit steel monopole structure		Dominion (100%)	
b2802	Rebuild Line #171 from Chase City – Boydton Plank Road tap by removing end- of-life facilities and installing 9.4 miles of new conductor. The conductor used will be at current standards with a summer emergency rating of 393 MVA at 115kV		Dominion (100%)	
b2815	Build a new Pinewood 115kV switching station at the tap serving North Doswell DP with a 115kV four breaker ring bus		Dominion (100%)	
b2842	Update the nameplate for Mount Storm 500 kV "57272" to be 50kA breaker		Dominion (100%)	
b2843	Replace the Mount Storm 500 kV "G2TY" with 50kA breaker		Dominion (100%)	
b2844	Replace the Mount Storm 500 kV "G2TZ" with 50kA breaker		Dominion (100%)	

Required In	ansinission Ennancements Annua	i Kevenue Kequitement	Responsible Customer(s)
b2845	Update the nameplate for Mount Storm 500 kV "G3TSX1" to be 50kA breaker		Dominion (100%)
b2846	Update the nameplate for Mount Storm 500 kV "SX172" to be 50kA breaker		Dominion (100%)
b2847	Update the nameplate for Mount Storm 500 kV "Y72" to be 50kA breaker		Dominion (100%)
b2848	Replace the Mount Storm 500 kV "Z72" with 50kA breaker		Dominion (100%)
b2871	Rebuild 230 kV line #247 from Swamp to Suffolk (31 miles) to current standards with a summer emergency rating of 1047 MVA at 230 kV		Dominion (100%)
b2876	Rebuild line #101 from Mackeys – Creswell 115 kV, 14 miles, with double circuit structures. Install one circuit with provisions for a second circuit. The conductor used will be at current standards with a summer emergency rating of 262 MVA at 115 kV		Dominion (100%)
b2877	Rebuild line #112 from Fudge Hollow – Lowmoor 138 kV (5.16 miles) to current standards with a summer emergency rating of 314 MVA at 138 kV		Dominion (100%)
b2899	Rebuild 230 kV line #231 to current standard with a summer emergency rating of 1046 MVA. Proposed conductor is 2-636 ACSR		Dominion (100%)
b2900	Build a new 230/115 kV switching station connecting to 230 kV network line #2014 (Earleys – Everetts). Provide a 115 kV source from the new station to serve Windsor DP		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

b2922	Rebuild 8 of 11 miles of 230 kV lines #211 and #228 to current standard with a summer emergency rating of 1046 MVA for rebuilt section. Proposed conductor is 2-636 ACSR	Dominion (100%)
b2928	Rebuild four structures of 500 kV line #567 from Chickahominy to Surry using galvanized steel and replace the river crossing conductor with 3-1534 ACSR. This will increase the line #567 line rating from 1954 MVA to 2600 MVA	Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%) DFAX Allocation: Dominion (100%)
b2929	Rebuild 230 kV line #2144 from Winfall to Swamp (4.3 miles) to current standards with a standard conductor (bundled 636 ACSR) having a summer emergency rating of 1047 MVA at 230 kV	Dominion (100%)
b2960	Replace fixed series capacitors on 500 kV Line #547 at Lexington and on 500 kV Line #548 at Valley	See sub-IDs for cost allocations

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tra	ansmission Enhancements Annua	Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
	Replace fixed series capacitors on 500 kV Line #547 at Lexington	2	DPL (2.65%) / Dominion
			(13.03%) / EKPC (1.77%) /
b2960.1			JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			DEOK (5.63%) / Dominion
			(91.06%) / EKPC (3.31%)
Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
--------------	---------------------------------------------------------	---------------------	------------------------------
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Replace fixed series		(13.03%) / EKPC (1.77%) /
b2960.2	capacitors on 500 kV Line		JCPL (3.84%) / ME (1.93%) /
	#548 at Valley		NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			DEOK (17.57%) / Dominion
			(74.24%) / EKPC (8.19%)
	Rebuild approximately 3		Dominion (100%)
b2961	miles of Line #205 & Line #2003 from Chesterfield to	e	
	Locks & Poe respectively		
	Split Line #227 (Brambleton		
h2062	- Beaumeade 230 kV) and		Dominion (100%)
02902	terminate into existing		
	Belmont substation		
b2062 1	kV breaker "274T2081" with		Dominion (100%)
02702.1	63kA breaker		Dominion (10070)
	Replace the NIVO 230 kV		
b2962.2	breaker "2116T2130" with		Dominion (100%)
	63kA breaker		
	to Occoguan 230 kV line		
b2963	segment of Line #2001 with		Dominion (100%)
	1047 MVA conductor and		
	replace line terminal		
	equipment at Possum Point,		
	woodbridge, and Occoquan		

Required Tr	ansmission Enhancements Ann	ual Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%) /
			APS (5.61%) / ATSI (8.10%) /
			BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
	Install 2 125 MVAP		DEOK (3.23%) / DL (1.73%) /
	STATCOMe at Pawlings		DPL (2.65%) / Dominion
h2078	and 1-125 MVAR		(13.03%) / EKPC (1.77%) /
02778	STATCOM at Clover 500		JCPL (3.84%) / ME (1.93%) /
	kV substations		NEPTUNE* (0.45%) / OVEC
	K V Substations		(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Rebuild 115 kV Line #43		
	between Staunton and		
h2980	Harrisonburg (22.8 miles)		Dominion (100%)
02700	to current standards with a		
	summer emergency rating		
	of 261 MVA at 115 kV		
	Rebuild 115 kV Line #29		
	segment between		
	Fredericksburg and Aquia		
	Harbor to current 230 kV		
	standards (operating at 115		
b2981	kV) utilizing steel H-frame		Dominion (100%)
	structures with 2-636		
	ACSR to provide a normal		
	continuous summer rating		
	of 524 MVA at 115 kV		
	(1047 MVA at 230 kV)		

*Neptune Regional Transmission System, LLC

Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
b2989	Install a second 230/115 kV Transformer (224 MVA) approximately 1 mile north of Bremo and tie 230 kV Line #2028 (Bremo – Charlottesville) and 115 kV Line #91 (Bremo - Sherwood) together. A three breaker 230 kV ring bus will split Line #2028 into two lines and Line #91 will also be split into two lines with a new three breaker 115 kV ring bus. Install a temporary 230/115 kV transformer at Bremo substation for the interim until the new substation is complete		Dominion (100%)
b2990	Chesterfield to Basin 230 kV line – Replace 0.14 miles of 1109 ACAR with a conductor which will increase the line rating to approximately 706 MVA		Dominion (100%)
b2991	Chaparral to Locks 230 kV line – Replace breaker lead		Dominion (100%)
b2994	Acquire land and build a new switching station (Skippers) at the tap serving Brink DP with a 115 kV four breaker ring to split Line #130 and terminate the end points		Dominion (100%)
b3018	Rebuild Line #49 between New Road and Middleburg substations with single circuit steel structures to current 115 kV standards with a minimum summer emergency rating of 261 MVA		Dominion (100%)

Page 127

Required Tra	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
	Rebuild 500 kV Line #552		(13.03%) / EKPC (1.77%) /
b3019	Bristers to Chancellor – 21.6 miles long		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (89.20%) / PEPCO
			(10.80%)
1.0010.1	Update the nameplate for		
b3019.1	Morrisville 500 kV breaker " $H1T504$ " to be 50kA		Dominion (100%)
	Undate the namenlate for		
b3019.2	Morrisville 500 kV breaker		Dominion (100%)
	"H1T545" to be 50kA		(100,0)

Required Tra	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
			Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
			(13.03%) / EKPC (1.77%) /
	Rebuild 500 kV Line #574		JCPL (3.84%) / ME (1.93%) /
b3020	Ladysmith to Elmont – 26.2		NEPTUNE* (0.45%) / OVEC
	miles long		(0.07%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL (4.72%) / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			APS (16.36%) / DEOK
			(11.61%) / Dominion (51.27%)
			/ EKPC (5.30%) / PEPCO
			(15.46%)
	Rebuild 500 kV Line #581		Load-Ratio Share Allocation:
			AEC (1.71%) / AEP (14.04%)
			/ APS (5.61%) / ATSI (8.10%)
			/ BGE (4.36%) / ComEd
			(13.14%) / Dayton (2.15%) /
			DEOK (3.23%) / DL (1.73%) /
			DPL (2.65%) / Dominion
b3021			(13.03%)/EKPC(1.77%)/
03021	15.2 miles long		JCPL (3.84%) / ME (1.93%) /
			NEPTUNE* (0.45%) / OVEC
			(0.0/%) / PECO (5.29%) /
			PENELEC (1.89%) / PEPCO
			(3.82%) / PPL $(4./2%)$ / PSEG
			(6.21%) / RE (0.26%)
			DFAX Allocation:
			Dominion (100%)
	Reconductor Line #274 (Pleasant View Ashburn		
1.000 4	Beaumeade 230 kV) with a		
b3026	minimum rating of 1200		Dominion (100%)
	MVA. Also upgrade terminal		
	equipment		

Required In		Revenue Requirement	Responsible Customer(s)
b3027.1	Add a 2nd 500/230 kV 840 MVA transformer at Dominion's Ladysmith substation		Dominion (100%)
b3027.2	Reconductor 230 kV Line #2089 between Ladysmith and Ladysmith CT substations to increase the line rating from 1047 MVA to 1225 MVA		Dominion (100%)
b3027.3	Replace the Ladysmith 500 kV breaker "H1T581" with 50kA breaker		Dominion (100%)
b3027.4	Update the nameplate for Ladysmith 500 kV breaker "H1T575" to be 50kA breaker		Dominion (100%)
b3027.5	Update the nameplate for Ladysmith 500 kV breaker "568T574" (will be renumbered as "H2T568") to be 50kA breaker		Dominion (100%)
b3055	Install spare 230/69 kV transformer at Davis substation		Dominion (100%)
b3056	Partial rebuild 230 kV Line #2113 Waller to Lightfoot		Dominion (100%)
b3057	Rebuild 230 kV Lines #2154 and #19 Waller to Skiffes Creek		Dominion (100%)
b3058	Partial rebuild of 230 kV Lines #265, #200 and #2051		Dominion (100%)
b3059	Rebuild 230 kV Line #2173 Loudoun to Elklick		Dominion (100%)

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
b3060	Rebuild 4.6 mile Elklick – Bull Run 230 kV Line #295 and the portion (3.85 miles) of the Clifton – Walney 230 kV Line #265 which shares structures with Line #295		Dominion (100%)
b3088	Rebuild 4.75 mile section of Line #26 between Lexington and Rockbridge with a minimum summer emergency rating of 261 MVA		Dominion (100%)
b3089	Rebuild 230 kV Line #224 between Lanexa and Northern Neck utilizing double circuit structures to current 230 kV standards. Only one circuit is to be installed on the structures with this project with a minimum summer emergency rating of 1047 MVA		Dominion (100%)
b3090	Convert the overhead portion (approx. 1500 feet) of 230 kV Lines #248 & #2023 to underground and convert Glebe substation to gas insulated substation		Dominion (100%)
b3096	Rebuild 230 kV line No.2063 (Clifton – Ox) and part of 230 kV line No.2164 (Clifton – Keene Mill) with double circuit steel structures using double circuit conductor at current 230 kV northern Virginia standards with a minimum rating of 1200 MVA		Dominion (100%)
b3097	Rebuild 4 miles of 115 kV Line #86 between Chesterfield and Centralia to current standards with a minimum summer emergency rating of 393 MVA		Dominion (100%)
b3098	Rebuild 9.8 miles of 115 kV Line #141 between Balcony Falls and Skimmer and 3.8 miles of 115 kV Line #28 between Balcony Falls and Cushaw to current standards with a minimum rating of 261 MVA		Dominion (100%)

b3098.1	Rebuild Balcony Falls 115 kV substation	Dominion (100%)
b3110.1	Rebuild Line #2008 between Loudoun to Dulles Junction using single circuit conductor at current 230 kV northern Virginia standards with minimum summer ratings of 1200 MVA. Cut and loop Line #265 (Clifton – Sully) into Bull Run substation. Add three (3) 230 kV breakers at Bull Run to accommodate the new line and upgrade the substation	Dominion (100%)
b3110.2	Replace the Bull Run 230 kV breakers "200T244" and "200T295" with 50 kA breakers	Dominion (100%)
b3110.3	Replace the Clifton 230 kV breakers "201182" and "XT2011" with 63 kA breakers	Dominion (100%)
b3113	Rebuild approximately 1 mile of 115 kV Lines #72 and #53 to current standards with a minimum summer emergency rating of 393 MVA. The resulting summer emergency rating of Line #72 segment from Brown Boveri to Bellwood is 180 MVA. There is no change to Line #53 ratings	Dominion (100%)
b3114	Rebuild the 18.6 mile section of 115 kV Line #81 which includes 1.7 miles of double circuit Line #81 and 230 kV Line #2056. This segment of Line #81 will be rebuilt to current standards with a minimum rating of 261 MVA. Line #2056 rating will not change	Dominion (100%)
b3121	Rebuild Clubhouse – Lakeview 230 kV Line #254 with single- circuit wood pole equivalent structures at the current 230 kV standard with a minimum rating of 1047 MVA	Dominion (100%)

Required Tra	ansmission Enhancements Annua	l Revenue Requirement	Responsible Customer(s)
b3122	Rebuild Hathaway – Rocky Mount (Duke Energy Progress) 230 kV Line #2181 and Line #2058 with double circuit steel structures using double circuit conductor at current 230 kV standards with a minimum rating of 1047 MVA		Dominion (100%)
b3161.1	Split Chesterfield-Plaza 115 kV Line No. 72 by rebuilding the Brown Boveri tap line as double circuit loop in-and-out of the Brown Boveri Breaker station		Dominion (100%)
b3161.2	Install a 115 kV breaker at the Brown Boveri Breaker station. Site expansion is required to accommodate the new layout		Dominion (100%)
b3162	Acquire land and build a new 230 kV switching station (Stevensburg) with a 224 MVA, 230/115 kV transformer. Gordonsville- Remington 230 kV Line No. 2199 will be cut and connected to the new station. Remington-Mt. Run 115 kV Line No.70 and Mt. Run-Oak Green 115 kV Line No. 2 will also be cut and connected to the new station		Dominion (100%)
b3211	Rebuild the 1.3 mile section of 500 kV Line No. 569 (Loudoun – Morrisville) with single-circuit 500 kV structures at the current 500 kV standard. This will increase the rating of the line to 3424 MVA		Dominion (100%)
b3213	Install 2nd Chickahominy 500/230 kV transformer		Dominion (100%)
b3213.1	Replace the eight (8) Chickahominy 230 kV breakers with 63 kA breakers: "SC122", "205022", "209122", 210222-2", "28722", "H222", "21922" and "287T2129"		Dominion (100%)

Required Tra	ansmission Enhancements Annual	l Revenue Requirement	Responsible Customer(s)
	Install a second 230 kV		
	circuit with a minimum		
	summer emergency rating of		
	1047 MVA between Lanexa		
	and Northern Next		
	substations. The second		
b3223.1	circuit will utilize the vacant		Dominion (100%)
	arms on the double-circuit		
	structures that are being		
	installed on Line #224		
	(Lanexa – Northern Next) as		
	part of the End-of-Life		
	rebuild project (b3089)		
	Expand the Northern Neck		
h2222.2	terminal from a 230 kV, 4-		Dominion (100%)
03223.2	breaker ring bus to a 6-		Dominion (100%)
	breaker ring bus		
	Expand the Lanexa terminal		
h2222 3	from a 6-breaker ring bus to a		Dominion (100%)
03223.3	breaker-and-a-half		Dominion (100%)
	arrangement		
	Convert 115 kV Line #172		
	Liberty – Lomar and 115 kV		
	Line #197 Cannon Branch –		
	Lomar to 230 kV to provide a		
	new 230 kV source between		
	Cannon Branch and Liberty.		
	The majority of 115 kV Line		
	#172 Liberty – Lomar and		
b3246.1	Line #197 Cannon Branch –		Dominion (100%)
	Lomar is adequate for 230 kV		
	operation. Rebuild 0.36 mile		
	segment between the Lomar		
	and Cannon Branch junction.		
	Lines will have a summer		
	rating of		
	1047MVA/1047MVA		
	(SN/SE)		
	Perform substation work for		
	the 115 kV to 230 kV line		
b3246.2	conversion at Liberty,		Dominion (100%)
	Wellington, Godwin, Pioneer,		
	Sandlot and Cannon Branch		

Required Tra	ansmission Enhancements Annual	Revenue Requirement	Responsible Customer(s)
b3246.3	Extend 230 kV Line #2011 Cannon Branch – Clifton to Winters Branch by removing the existing Line #2011 termination at Cannon Branch and extending the line to Brickyard creating 230 kV Line #2011 Brickyard - Clifton. Extend a new 230 kV line between Brickyard and Winters Branch with a summer rating of 1572MVA/1572MVA (SN/SE)		Dominion (100%)
b3246.4	Perform substation work at Cannon Branch, Brickyard and Winters Branch for the 230 kV Line #2011 Cannon Branch – Clifton extension		Dominion (100%)
b3246.5	Replace the Gainesville 230 kV 40 kA breaker "216192" with a 50 kA breaker		Dominion (100%)
b3247	Replace 13 towers with galvanized steel towers on Doubs – Goose Creek 500 kV. Reconductor 3 mile section with three (3) 1351.5 ACSR 45/7. Upgrade line terminal equipment at Goose Creek substation to support the 500 kV line rebuild		Load-Ratio Share Allocation: AEC (1.71%) / AEP (14.04%) / APS (5.61%) / ATSI (8.10%) / BGE (4.36%) / ComEd (13.14%) / Dayton (2.15%) / DEOK (3.23%) / DL (1.73%) / DPL (2.65%) / Dominion (13.03%) / EKPC (1.77%) / JCPL (3.84%) / ME (1.93%) / NEPTUNE* (0.45%) / OVEC (0.07%) / PECO (5.29%) / PENELEC (1.89%) / PEPCO (3.82%) / PPL (4.72%) / PSEG (6.21%) / RE (0.26%)
			DFAX Allocation: Dominion (100%)
b3300	Reconductor 230 kV Line #2172 from Brambleton to Evergreen Mills along with upgrading the line leads at Brambleton to achieve a summer emergency rating of 1574 MVA		Dominion (100%)

Required Tra	ansmission Ennancements Annua	i Revenue Requirement	Responsible Customer(s)
b3301	Reconductor 230 kV Line #2210 from Brambleton to Evergreen Mills along with upgrading the line leads at Brambleton to achieve a summer emergency rating of 1574 MVA		Dominion (100%)
b3302	Reconductor 230 kV Line #2213 from Cabin Run to Yardley Ridge along with upgrading the line leads at Yardley to achieve a summer emergency rating of 1574 MVA		Dominion (100%)
b3303.1	Extend a new single circuit 230 kV Line #9250 from Farmwell substation to Nimbus substation		Dominion (100%)
b3303.2	Remove Beaumeade 230 kV Line #2152 line switch		Dominion (100%)
b3304	Midlothian area improvements for 300 MW load drop relief		Dominion (100%)
b3304.1	Cut 230 kV Line #2066 at Trabue junction		Dominion (100%)
b3304.2	Reconductor idle 230 kV Line #242 (radial from Midlothian to Trabue junction) to allow a minimum summer rating of 1047 MVA and connect to the section of 230 kV Line #2066 between Trabue junction and Winterpock, re-number 230 kV Line #242 structures to Line #2066		Dominion (100%)
b3304.3	Use the section of idle 115 kV Line #153, between Midlothian and Trabue junction to connect to the section of (former) 230 kV Line #2066 between Trabue junction and Trabue to create new Midlothian – Trabue lines with new line numbers #2218 and #2219		Dominion (100%)
b3304.4	Create new line terminations at Midlothian for the new Midlothian – Trabue 230 kV lines		Dominion (100%)

SCHEDULE 12 – APPENDIX A

(23) American Transmission Systems, Inc.

Required '	Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2019.2	Terminate Burger – Longview 138 kV, Burger – Brookside 138 kV, Burger – Cloverdale 138 kV #1, and Burger – Harmon 138 kV #2 into Holloway substation; Loop Burger – Harmon #1 138 kV and Burger – Knox 138 kV into Holloway substation		ATSI (100%)
b2019.3	Reconfigure Burger 138 kV substation to accommodate two 138 kV line exits and generation facilities		ATSI (100%)
b2019.4	Remove both Burger 138 kV substations (East and West 138 kV buses) and all 138 kV lines on the property		ATSI (100%)
b2019.5	Terminate and de- energize the 138 kV lines on the last structure before the Burger Plant property		ATSI (100%)
b2122.1	Reconductor the ATSI portion of the Howard – Brookside 138 kV line		ATSI (100%)
b2122.2	Upgrade terminal equipment at Brookside on the Howard – Brookside 138 kV line to achieve ratings of 252/291 (SN/SE)		ATSI (100%)
b2188	Revise the reclosing for the Bluebell 138 kV breaker '301-B-94'		ATSI (100%)
b2192	Replace the Longview 138 kV breaker '651-B- 32'		ATSI (100%)
b2193	Replace the Lowellville 138 kV breaker '1-10-B 4'		ATSI (100%)

Required 7	Fransmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
b2195	Replace the Roberts 138 kV breaker '601-B-60'		ATSI (100%)
b2196	Replace the Sammis 138 kV breaker '780-B-76'		ATSI (100%)
b2262	New Castle Generating Station – Relocate 138kV, 69kV, and 23kV controls from the generating station building to new control building		ATSI (100%)
b2263	Niles Generation Station – Relocate 138kV and 23kV controls from the generation station building to new control building		ATSI (100%)
b2265	Ashtabula Generating Station – Relocate 138kV controls from the generating station building to new control building		ATSI (100%)
b2284	Increase the design operating temperature on the Cloverdale – Barberton 138kV line		ATSI (100%)
b2285	Increase the design operating temperature on the Cloverdale – Star 138kV line		ATSI (100%)
b2301	Reconductor 0.7 miles of 605 ACSR conductor on the Beaver Black River 138kV line		ATSI (100%)
b2301.1	Wave trap and line drop replacement at Beaver (312/380 MVA SN/SE)		ATSI (100%)
b2349	Replace the East Springfield 138kV breaker 211-B-63 with 40kA		ATSI (100%)
b2367	Replace the East Akron 138kV breaker 36-B-46 with 40kA		ATSI (100%)

		1 1	
b2413	Replace a relay at McDowell 138 kV substation		ATSI (100%)
b2434	Build a new London – Tangy 138 kV line		ATSI (100%)
b2435	Build a new East Springfield – London #2 138 kV line		Dayton (100%)
b2459	Install +260/-150 MVAR SVC at Lake Shore		ATSI (100%)
b2492	Replace the Beaver 138 kV breaker '426-B-2' with 63kA breaker		ATSI (100%)
b2493	Replace the Hoytdale 138kV breaker '83-B-30' with 63kA breaker		ATSI (100%)
b2557	At Avon substation, replace the existing 345/138 kV 448 MVA #92 transformer with a 560 MVA unit		ATSI (100%)
b2558	Close normally open switch A 13404 to create a Richland J Bus – Richland K Bus 138 kV line		ATSI (100%)
b2559	Reconductor the Black River – Lorain 138 kV line and upgrade Black River and Lorain substation terminal end equipment		ATSI (100%)
b2560	Construct a second 138 kV line between West Fremont and Hayes substation on open tower position of the West Fremont –Groton –Hayes 138 kV line		ATSI (100%)
b2616	Addition of 4th 345/138 kV transformer at Harding		ATSI (100%)

		 ••••••••••••••••••••••••••••••
b2673	Rebuild the existing double circuit tower line section from Beaver substation to Brownhelm Jct. approx. 2.8 miles	ATSI (100%)
b2674	Rebuild the 6.6 miles of Evergreen to Ivanhoe 138 kV circuit with 477 ACSS conductor	ATSI (100%)
b2675	Install 26.4 MVAR capacitor and associated terminal equipment at Lincoln Park 138 kV substation	ATSI (100%)
b2725	Build new 345/138 kV Lake Avenue substation w/ breaker and a half high side (2 strings), 2-345/138 kV transformers and breaker and a half (2 strings) low side (138 kV). Substation will tie Avon – Beaver 345 kV #1/#2 and Black River – Johnson #1/#2 lines	ATSI (100%)
b2725.1	Replace the Murray 138 kV breaker '453-B-4' with 40kA breaker	ATSI (100%)
b2742	Replace the Hoytdale 138 kV '83-B-26' and '83-B- 30' breakers with 63kA breakers	ATSI (100%)
b2753.4	Double capacity for 6 wire "Burger-Cloverdale No. 2" 138 kV line and connect at Holloway and "Point A"	ATSI (100%)
b2753.5	Double capacity for 6 wire "Burger-Longview" 138 kV line and connect at Holloway and "Point A"	ATSI (100%)
b2778	Add 2nd 345/138 kV transformer at Chamberlin substation	ATSI (100%)
b2780	Replace Bruce Mansfield 345 kV breaker 'B57' with an 80 kA breaker, and associated gang-operated disconnect switches D56 and D58	ATSI (100%)

		1 1	
b2869	Replace the Crossland 138 kV breaker "B-16" with a 40kA breaker		ATSI (100%)
b2875	Relocate the Richland to Ridgeville 138 kV line from Richland J bus to K, extend the K bus and install a new breaker		ATSI (100%)
b2896	Rebuild/Reconductor the Black River – Lorain 138 kV circuit		ATSI (100%)
b2897	Reconductor the Avon – Lorain 138 kV section and upgrade line drop at Avon		ATSI (100%)
b2898	Reconductor the Beaver – Black River 138 kV with 954Kcmil ACSS conductor and upgrade terminal equipment on both stations		ATSI (100%)
b2942.1	Install a 100 MVAR 345 kV shunt reactor at Hayes substation		ATSI (100%)
b2942.2	Install a 200 MVAR 345 kV shunt reactor at Bayshore substation		ATSI (100%)
b2972	Reconductor limiting span of Lallendorf – Monroe 345 kV		MISO (11.00%) / AEP (5.38%) / APS (4.27%) / ATSI (66.48%) / Dayton (2.71%) / Dominion (5.31%) / DL (4.85%)
b3031	Transfer load off of the Leroy Center - Mayfield Q2 138 kV line by reconfiguring the Pawnee substation primary source, via the existing switches, from the Leroy Center - Mayfield Q2 138 kV line to the Leroy Center - Mayfield Q1 138 kV line		ATSI (100%)

Required Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)

Required 7	Transmission Enhancements	Annual Revenue Requirement	nt Responsible Customer(s)
b3032	Greenfield - NASA 138 kV terminal upgrades: NASA substation, Greenfield exit: Revise CT tap on breaker B22 and adjust line relay settings; Greenfield substation, NASA exit: Revise CT tap on breaker B1 and adjust line relay settings; replace 336.4 ACSR line drop with 1033.5 AL		ATSI (100%)
b3033	Ottawa – Lakeview 138 kV reconductor and substation upgrades		ATSI (100%)
b3034	Lakeview – Greenfield 138 kV reconductor and substation upgrades		ATSI (100%).
b3066	Reconductor the Cranberry – Jackson 138 kV line (2.1 miles), reconductor 138 kV bus at Cranberry bus and replace 138 kV line switches at Jackson bus		ATSI (100%)
b3067	Reconductor the Jackson – Maple 138 kV line (4.7 miles), replace line switches at Jackson 138 kV and replace the line traps and relays at Maple 138 kV bus		ATSI (100%)
b3080	Reconductor the 138 kV bus at Seneca		ATSI (100%)
b3081	Replace the 138 kV breaker and reconductor the 138 kV bus at Krendale		ATSI (100%)

Required'	Transmission Enhancements	Annual Revenue Requirement	nt Responsible Customer(s)
	At Sammis 345 kV station:		•
	Install a new control		
	building in the switchyard,		
	construct a new station		
	access road, install new		
h2122	switchyard power supply to		$\Lambda TSI (10004)$
03123	separate from existing		AISI (10070)
	generating station power		
	service, separate all		
	communications circuits,		
	and separate all protection		
	and controls schemes		
	Separate metering, station		
b3124	power, and communication		ATSI (100%)
03121	at Bruce Mansfield 345 kV		
	station		
	At Bay Shore 138 KV		
	station: Install new		
	switchyard power supply to		
1 2 1 2 7	separate from existing		
b3127	generating station power		AISI (100%)
	service, separate all		
	and construct a new station		
	and construct a new station		
	Reconductor the 8.4 mile		
	section of the Leroy Center		
	– Mayfield O1 line		
b3152	between Leroy Center and		ATSI (100%)
05152	Pawnee Tap to achieve a		
	rating of at least 160 MVA		
	/ 192 MVA (SN/SE)		
	Extend both the east and		
	west 138 kV buses at Pine		
	substation, and install one		
b3234	(1) 138 kV breaker,		ATSI (100%)
	associated disconnect		
	switches, and one (1) 100		
	MVAR reactor		
	Extend 138 kV bus work to		
	the west of Tangy		
b3235	substation for the addition		ATSI (100%)
03233	of the 100 MVAR reactor		
	bay and one (1) 138 KV 40		
	KA circuit breaker		
	Extend the Broadview 138		
1-202C	KV bus by adding two (2)		
63236	new dreakers and		AISI (100%)
	install a 75 MVAD reactor		
	mstan a 75 wiv AK reactor		

Required Transmission Enhancements		Annual Revenue Requirem	nent Responsible Customer(s)
	Replace the existing East		
	Akron 138 kV breaker 'B-		
	22' with 3000A		
b3277	continuous, 40 kA		ATSI (100%)
	momentary current		
	interrupting rating circuit		
	breaker		

SCHEDULE 12 – APPENDIX A

(25) East Kentucky Power Cooperative, Inc.

Required	Transmission Enhancements	Annual Revenue Requiremen	t Responsible Customer(s)
b2066	Upgrade the operating temperature of the existing conductor for the JK Smith - Union City - Lake Reba Tap 138 kV line		EKPC (100%)
b2309	Upgrade the bus and jumpers with 750 MCM copper conductor at Green County 69 kV substation		EKPC (100%)
b2310	Increase the maximum operating temperature of the North Springfield - South Springfield 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2311	Increase the maximum operating temperature of the Loretto - Sulphur Creek 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2312	Increase the maximum operating temperature of the South Springfield - Loretto 69 kV line to 167 degrees Fahrenheit		EKPC (100%)
b2313	Construct 8.8 miles of 69 kV line between the Cave City and Bon Ayr distribution substations. Operate this line normally open		EKPC (100%)
b2314.1	Construct 8.6 miles of 69 kV line between the Mercer County Industrial and Van Arsdell distribution substation. Construct a new 69 kV switching station adjacent to Bonds Bill Substation. Loop NorthSpringfield - Van Arsdell 69 kV line through South Anders		EKPC (100%)

Required '	Transmission Enhancements	Annual Revenue Requiremen	t Responsible Customer(s)
	Construct a new 69 kV		
	switching station ("South		
b2314.2	Anderson") adjacent to the		EKPC (100%)
	LGE/KU Bonds Mill		
	substation		
	Loop the North		
	Springfield - Van Arsdell 69		
	kV line through South		
	Anderson. Terminate the		
	existing 69 kV to the		
b2314.3	LGE/KU Bonds Mill		EKPC (100%)
	substation at South		
	Anderson and establish a		
	second 69 kV from S.		
	Anderson to the LGE/KU		
	Bonds Mill sub		
	Construct 0.12 miles of 69		
	kV line from South		
	Anderson to the Powell		
b2314.4	Taylor distribution		EKPC (100%)
	substation and serve this		
	substation radially from		
	South Anderson		
	Increase the size of the		
b2315	existing HT Adams 69 kV,		FKPC (100%)
02313	7.2 MVAR capacitor bank		EKI C (10070)
	to 14.28 MVAR		
	Increase the size of the		
b2316	existing Hunt Farm Junction		EKPC (100%)
02310	69 kV, 8.2 MVAR capacitor		EKI C (10070)
	bank to 16.33 MVAR		
	Construct 10.9 miles of 69		
	kV line between the Owen		
	County substation and the		
b2317	Keith distribution		EKPC (100%)
	substation. Operate the		
	existing Penn - Keith 69 kV		
	line normally - open		

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
	Construct 2.7 miles of 69		
	kV line between the Fox		
	Hollow substation and the		
	Parkway distribution		
	substations. Serve the		
b2318	Parkway #1 and #2		EKPC (100%)
	distribution substations		
	radially from Fox Hollow.		
	Operate the Cave City - Bon		
	Ayr 69 kV line		
	normally - closed		
	Increase the maximum		
	operating temperature of the		
b2319	Helechawa - Sublett 69 kV		EKPC (100%)
	line to 167 degrees		
	Fahrenheit		
	Install a 69 kV, 15.31		
b2320	MVAR capacitor bank at		EKPC (100%)
	the Perryville substation		
	Install a 69 kV, 25.51		
b2321	MVAR capacitor bank at		EKPC (100%)
	the Veechdale substation		
	Change the CT setting on		
	circuit breaker N35 - 804 at		
	Dale Station to at least 800		
b2322	amps to increase the relay		EKPC (100%)
	loadability on the		
	Dale - Three Forks 138 kV		
	line to at least 282 MVA		
	Rebuild the existing		
	Cynthiana - Headquarters		
b2323	69 kV line using 556.5		EKPC (100%)
02020	MCM ACSR conductor and		
	operate this line normally		
	closed		
	Remove the existing		
	1200 - amp line traps at JK		
b2324	Smith and Dale associated		EKPC (100%)
	with the JK Smith - Dale		
	138 kV line		

Increase the maximum operating temperature of the KV line to 212 degrees FahrenheitEKPC (100%)b2326Glendale - Hodgenville 69 kV line to 212 degrees FahrenheitEKPC (100%)b2326operating temperature of the Fayette - Davis 69 kV line to 248 degrees FahrenheitEKPC (100%)b2327Boone - Boone Distribution operating temperature of the b2327Boone - Boone Distribution of kV line to 302 degrees Fahrenheitb2328Increase the maximum operating temperature of the West Bardstown of 9 kV line to 248 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown 69 kV line to 244 degrees FahrenheitEKPC (100%)b2329Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)	Required	Transmission Enhancements	Annual Revenue Requirement	nt Responsible Customer(s)
operating temperature of the Glendale - Hodgenville 69 KV line to 212 degrees Fahrenheit EKPC (100%) b2326 Fahrenheit EKPC (100%) operating temperature of the Fayette - Davis 69 kV line to 248 degrees Fahrenheit EKPC (100%) b2327 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2328 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2330 Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)		Increase the maximum		
b2325 Glendale - Hodgenville 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2326 Increase the maximum operating temperature of the Fayette - Davis 69 kV line to 248 degrees Fahrenheit EKPC (100%) b2327 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 184 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2330 Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the BACON Creek - Liberty EKPC (100%) b2332 Increase the maximum operating temperature of the IX Smith - Dale 138 kV line to 275 degrees Fahrenheit<		operating temperature of the		
kV line to 212 degrees Fahrenheit Fahrenheit b2326 Increase the maximum operating temperature of the Fayette - Davis 69 kV line to 248 degrees Fahrenheit EKPC (100%) b2327 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2327 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2330 Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2332 Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)	b2325	Glendale - Hodgenville 69		EKPC (100%)
FahrenheitIncrease the maximum operating temperature of the Fayette - Davis 69 kV line to 248 degrees FahrenheitEKPC (100%)b2327Boone - Boone Distribution operating temperature of the b2327EKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 167 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)		kV line to 212 degrees		
b2326Increase the maximum operating temperature of the Fayette - Davis 69 kV line to 248 degrees FahrenheitEKPC (100%)b2327Increase the maximum operating temperature of the Boone - Boone Distribution 69 kV line to 302 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the b2329EKPC (100%)b2320Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 121 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creck - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)		Fahrenheit		
b2326operating temperature of the Fayette - Davis 69 kV line to 248 degrees FahrenheitEKPC (100%)b2327Increase the maximum operating temperature of the Boone - Boone Distribution 69 kV line to 302 degrees FahrenheitEKPC (100%)b2327Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Hecaquaters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)		Increase the maximum		
02320 Fayette - Davis 69 kV line to 248 degrees Fahrenheit EKPC (100%) Increase the maximum operating temperature of the b2327 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2330 Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2332 EKPC (100%)	h2326	operating temperature of the		EKPC (100%)
to 248 degrees Fahrenheit Increase the maximum operating temperature of the Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit Fahrenheit Increase the maximum operating temperature of the West Bardstown b2328 Increase the maximum operating temperature of the West Bardstown b2328 Increase the maximum operating temperature of the West Bardstown b2329 Fahrenheit Junction - West Bardstown EKPC (100%) b2329 Magnolia - Summersville 69 EKPC (100%) b2320 Magnolia - Summersville 69 EKPC (100%) b2330 Increase the maximum EKPC (100%) operating temperature of the Bacon Creek - Liberty EKPC (100%) Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the EKPC (100%) b23321 Increase the maximum operating temperature of the EKPC (100%) b23321 Increase the maximum EKPC (100%) EKPC (100%) b23322 Increase the maximum EKPC (100%)	02320	Fayette - Davis 69 kV line		EKi C (100%)
Increase the maximum operating temperature of the Boone - Boone Distribution 69 kV line to 302 degrees FahrenheitEKPC (100%)b2327Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the b2329EKPC (100%)b2320Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the b2331EKPC (100%)b2332Kmith - Dale 138 kV line Uncrease the maximum operating temperature of the degrees FahrenheitEKPC (100%)		to 248 degrees Fahrenheit		
operating temperature of the Boone - Boone Distribution 69 kV line to 302 degrees FahrenheitEKPC (100%)b2327Boone - Boone Distribution 69 kV line to 302 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the b2331EKPC (100%)b2332Kprease the maximum operating temperature of the b2331EKPC (100%)b2332Killersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2333Increase the maximum operating temperature of the Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)		Increase the maximum		
b2327 Boone - Boone Distribution 69 kV line to 302 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2329 Increase the maximum operating temperature of the b2329 EKPC (100%) b2329 Increase the maximum operating temperature of the b2320 EKPC (100%) b2320 Increase the maximum operating temperature of the b2330 EKPC (100%) b2331 Increase the maximum operating temperature of the b2331 EKPC (100%) b2331 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the Increase the maximum operating temperature of the IK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)		operating temperature of the		
69 kV line to 302 degrees Fahrenheit Fahrenheit Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2328 Increase the maximum operating temperature of the b2329 EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2330 Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%) b2332 Increase the maximum operating temperature of the b2331 EKPC (100%)	b2327	Boone - Boone Distribution		EKPC (100%)
FahrenheitFahrenheitIncrease the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2328Increase the maximum operating temperature of the b2329EKPC (100%)b2329Magnolia - Summersville 69 KV line to 167 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Increase the maximum operating temperature of the Increase the maximum operating temperature of the IIncrease the maximum operating temperature of the IIncrease the maximum operating temperature of the III Increase the maximum operating temperature of the III Increase the maximum operating temperature of the III Increase the maximum operating temperature of the III III IIII IIII IIII IIIIIIIIIIIIII		69 kV line to 302 degrees		
Increase the maximum operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)Increase the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacan Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Fahrenheit		
operating temperature of the West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)Increase the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Bacan Creek - Liberty Church 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2322Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Increase the maximum		
b2328West Bardstown Junction - West Bardstown 69 kV line to 284 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the b2329EKPC (100%)b2329Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		operating temperature of the		
b2323 Junction - West Bardstown 69 kV line to 284 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2329 Magnolia - Summersville 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2330 Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheit EKPC (100%) b2331 Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2332 Increase the maximum operating temperature of the HEAdquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2332 Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)	h7270	West Bardstown		EVDC $(1000/)$
69 kV line to 284 degrees FahrenheitIncrease the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees Fahrenheitb2329Magnolia - Summersville 69 kV line to 167 degrees Fahrenheitb2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees Fahrenheitb2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheitb2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheitb2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheitb2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit	02328	Junction - West Bardstown		EKFC (100%)
FahrenheitIncrease the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2329Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		69 kV line to 284 degrees		
Increase the maximum operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)b2329Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Fahrenheit		
operating temperature of the Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)kV line to 167 degrees FahrenheitIncrease the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Increase the maximum		
b2329Magnolia - Summersville 69 kV line to 167 degrees FahrenheitEKPC (100%)kV line to 167 degrees FahrenheitIncrease the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		operating temperature of the		
kV line to 167 degrees FahrenheitKV line to 167 degrees FahrenheitIncrease the maximum operating temperature of the Bacon Creek - LibertyEKPC (100%)b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)	b2329	Magnolia - Summersville 69		EKPC (100%)
FahrenheitIncrease the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		kV line to 167 degrees		
Increase the maximum operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2330Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Fahrenheit		
operating temperature of the Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)1Increase the maximum operating temperature of the Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2331Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Increase the maximum		
b2330Bacon Creek - Liberty Church 69 kV line to 212 degrees FahrenheitEKPC (100%)Increase the maximum operating temperature of the b2331Increase the maximum operating temperature of the Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		operating temperature of the		
Church 69 kV line to 212 degrees FahrenheitEKPC (100%)b2331Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)	b2330	Bacon Creek - Liberty		EKPC (100%)
degrees FahrenheitIncrease the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Church 69 kV line to 212		
Increase the maximum operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		degrees Fahrenheit		
b2331operating temperature of the Headquarters - Millersburg Junction 69 kV line to 167 degrees FahrenheitEKPC (100%)b2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Increase the maximum		
b2331 Headquarters - Millersburg Junction 69 kV line to 167 degrees Fahrenheit EKPC (100%) b2332 Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)	b2331	operating temperature of the		
Junction 69 kV line to 167 Junction 69 kV line to 167 degrees Fahrenheit Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)		Headquarters - Millersburg		EKPC (100%)
degrees Fahrenheitb2332Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)		Junction 69 kV line to 167		
b2332 Increase the maximum operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)		degrees Fahrenheit		
b2332 operating temperature of the JK Smith - Dale 138 kV line to 275 degrees Fahrenheit EKPC (100%)		Increase the maximum		
D2332JK Smith - Dale 138 kV line to 275 degrees FahrenheitEKPC (100%)	b2332	operating temperature of the		
to 275 degrees Fahrenheit		JK Smith - Dale 138 kV line		EKPC (100%)
		to 275 degrees Fahrenheit		

Required Transmission Enhancements Annual Revenue Requirement Responsible Customer(s)

Required	Transmission Enhancements	Annual Revenue Requirement	Responsible Customer(s)
	Increase the maximum		
	operating temperature of the		
b2333	Elizabethtown - Tunnel Hill		EKPC (100%)
	69 kV line to 284 degrees		
	Fahrenheit		
	Install a 69 kV, 28.06		
b2334	MVAR capacitor bank at		EKPC (100%)
	the Owen County substation		
	Install a 69 kV, 14.29		
1.0005	MVAR capacitor bank at		$\mathbf{E}\mathbf{V}\mathbf{D}\mathbf{C}$ (1000()
02555	the Magoffin County		EKPC (100%)
	substation		
	Increase the maximum		
	operating temperature of the		
b2336	South Corbin - Bacon Creek		EKPC (100%)
	69 kV line to 212 degrees		
	Fahrenheit		
	Increase the size of the		
1-0227	existing Cedar Grove 69		EVDC $(1000/)$
02337	kV, 10.8 MVAR capacitor		EKPC (100%)
	bank to 20.41 MVAR		
	Upgrade the 4/0 copper bus		
	and jumpers at the Nelson		
	County substation		
1 2220	associated with the Nelson		
62339	County - West Bardstown		EKPC (100%)
	Junction 69 kV line using		
	500 MCM copper or		
	equivalent equipment		
	Increase the Zone 3 distance		
	relay setting at Barren		
1 02 40	County associated with the		
b2340	Barren County - Horse Cave		EKPC (100%)
	Tap 69 kV line to at least 85		
	MVA		
	Build the 2nd Summer		
b2414	Shade EKPC - Summer		EKPC (100%)
	Shade TVA 161 kV circuit		
<u> </u>	Increase the MOT of the		
b2544	266.8 MCM ACSR section		
	(1.4 miles), of the Kargle-		EKPC (100%)
	KU Elizabethtown 69 kV		` '
	line section to 266 degrees F		

Required '	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
	Decouple the double-		
	circuited Spurlock –		
h2614	Maysville Industrial Tap		EVDC (100%)
02014	138-kV & Spurlock –		EKPC(100%)
	Flemingsburg 138-kV line		
	segments		
	Upgrade the Bullitt County		
b2615	161/69 kV transformer		EKPC (100%)
	facility		
	Increase the size of the		
1-2655	existing Leon 69 kV		EVDC(1000())
02000	capacitor bank from 13.2		EKPC (100%)
	MVAR to 18.36 MVAR		
	Reconductor the Leon –		
	Airport Road 69 kV line		
b2656	section (5.72 miles) using		EKPC (100%)
	556.5 MCM ACTW		
	conductor		
	Add 69 kV breaker at		
b2657	Thelma – AEP Thelma		EKPC (100%)
	69 kV tie		
	Increase the zone 3 distance		
	relay setting at Barren		
10(50	County associated with the		
b2658	Barren County – Horse		EKPC (100%)
	Cave Junction line to at		
	least 103 MVA		
	Rebuild the Seymour Tap –		
10050	KU Horse Cave Tap 69 kV		
b2659	line section (1.98 miles) to		EKPC (100%)
	302 degrees F		
	Increase the zone 3 distance		
b2660	relay setting at		
	Elizabethtown associated		
	with the Elizabethtown –		EKPC (100%)
	Smithersville line section to		
	at least 100 MVA		
	Reconductor the Baker Lane		
b2661	– Holloway Junction 69 kV		
	(1.28 miles) line section		EKPC (100%)
	using 556.5 MCM ACTW		× /
	wire		

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2662	Increase the maximum operating temperature of the Hickory Plains – PPG 69 kV line section (0.21 miles) to 266 degrees F		EKPC (100%)
b2663	Increase the zone 3 distance relay setting at EKPC Elizabethtown associated with the EKPC Elizabethtown to KU Elizabethtown 69 kV line to at least 126 MVA		EKPC (100%)
b2664	Increase the maximum operating temperature of the Tharp Tap – KU Elizabethtown 69 kV line section (2.11 miles) to 266 degrees F. (LTE at 248 degrees F)		EKPC (100%)
b2710	Upgrade the Summer Shade bus and CT associated with the 161/69 kV transformer #1		EKPC (100%)
b2711	Install 25.5 MVAR 69 kV capacitor at Sewellton Junction 69 kV substation		EKPC (100%)
b2730	Upgrade Denny – Gregory Tap 69 kV line facility		EKPC (100%)
b2781	Increase maximum operating temperature of Davis – Nicholasville 69 kV line section 266.8 MCM conductor to 284°F (LTE of 266°F)		EKPC (100%)
b2782	Increase the maximum operating temperature of Plumville – Rectorville 69 kV line section 266.8 MCM conductor to 212°F (LTE of 185°F)		EKPC (100%)
b2783	Rebuild the Davis – Fayette 69 kV line section to 556.5 MCM (3.15 miles)		EKPC (100%)

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2784	Increase overcurrent relay at West Berea 138/69 kV to at least 139 MVA Winter LTE		EKPC (100%)
b2785	Install a 13.776 MVAR cap bank at Three Links 69 kV		EKPC (100%)
b2786	Increase Williamstown cap bank to 11.225 MVAR		EKPC (100%)
b2827	Upgrade the current 5% impedance 1200A line reactor, which connects the 4SPURLOCK – 4SPUR- KENT-R and 4SPUR- KENT-R – 4KENTON 138kV line sections, to a 6.5% impedance 1600A line reactor		EKPC (100%)
b2879.2	Reconductor EKPC portion of the Stuart – Spurlock 345 kV line		EKPC (100%)
b2893	Rebuild the existing (1.5 mile), 1/0 MCM ACSR South Bardstown – West Bardstown Jct. 69 kV line using 556.5 MCM ACTW conductor		EKPC (100%)
b2902	Rebuild the Brodhead – Three Links Jct. 69 kV line section (8.2 miles) using 556.5 MCM ACTW wire		EKPC (100%)
b2903	Raise the V-low setting for Summer Shade 69 kV cap bank to 1.01 pu		EKPC (100%)
b2904	Raise the V-low setting for Newby 69 kV cap bank to 0.955 pu		EKPC (100%)
b2905	Resize the Albany 69 kV capacitor bank from 8.4 to 13.776 MVAR		EKPC (100%)

Required '	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2906	Increase the Zone 3 distance relay setting at Baker Lane associated with the Baker Lane - Holloway Jct. 69 kV line to at least 142 MVA		EKPC (100%)
	LTE Winter		
b2907	Upgrade the metering CT associated with the Clay Village - KU Clay Village 69 kV tap line section to 600 A; at least 64 MVA Winter LTE. Upgrade the distance relay associated with the Clay Village - KU Clay Village 69 kV tap line		EKPC (100%)
	section to at least 64 MVA		
b2908	Upgrade the distance relay associated with Dale – JK Smith 138 kV line section to 362 MVA normal rating		EKPC (100%)
b2909	Increase the MOT of the EKPC Elizabethtown – Tharp Tap 69 kV line section (1.7 miles) to 302°F (LTE at 284°F)		EKPC (100%)
b2910	Upgrade the distance relay at the Hodgenville station associated with the Glendale – Hodgenville 69 kV line section to at least 90 MVA Winter LTE		EKPC (100%)
b2911	Upgrade the overcurrent relay setting associated with Powell County 138/69 kV transformer to at least 139 MVA Winter LTE		EKPC (100%)
b2912	Upgrade the existing S408- 605, 600 A KU Russell Springs Tap – Russell County 69 kV disconnect switch to 1200 A		EKPC (100%)

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
b2913	Upgrade distance relay at the Stephensburg station associated with Stephensburg – Glendale 69 kV line section to at least Winter		EKPC (100%)
	LTE 100 MVA		
b2914	Rebuild Tharp Tap – KU Elizabethtown 69 kV line section to 795 MCM (2.11 miles)		EKPC (100%)
b2915	Resize the sideview 69 kV capacitor bank from 6.12 MVAR to 9.18 MVAR		EKPC (100%)
b2916	Upgrade the existing metering CTs (Quantity of 2) associated with the East Bardstown - KU Bardstown Industrial Tap 69 kV line section to 1200 A, at least 100 MVA Winter LTE; and upgrade the existing East Bardstown bus and jumpers from 4/0 to 500 MCM copper		EKPC (100%)
b2917	Replace the existing 100 MVA 138/69 kV transformer bank at the West Berea substation with a 150 MVA transformer		EKPC (100%)
b2918	Upgrade the 4/0 bus and jumpers associated with the West Berea Jct. – Three Links Jct. 69 kV line to 500 MCM copper or equivalent equipment at the Three Links Jct. substation		EKPC (100%)
b2919	Install a 69 kV, 15.31 MVAR capacitor bank at South Anderson substation		EKPC (100%)
b2920	Rebuild Boone - Big Bone Tap 69 kV line section using 556.5 MCM ACTW conductor (6.3 miles)		EKPC (100%)

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
	New TVA 161 kV		
	interconnection to TVA's		
	East Glasgow Tap - East		
	Glasgow 161 kV line section		
	(~1 mile due West of Fox		
	Hollow). Add Fox Hollow		
h2021	161/69 kV 150 MVA		EKPC (100%)
02721	transformer. Construct new		EKI C (10070)
	Fox Hollow - Fox Hollow		
	Jct. 161 kV line section using		
	795 MCM ACSR (~1 mile)		
	and new 161 kV switching		
	station at point of		
	interconnection with TVA		
	Increase the conductor MOT		
	for the Dale – JK Smith 138		
b2939	kV line to 275°F. The new		EKPC (100%)
	summer ratings would be		
	229/296		
	Upgrade the distance relay		
	on the Wayne Co – Wayne		EKPC (100%)
b2940	Co KY 161 kV line to		
	increase the line winter rating		
	would be 167/167		
	Increase the MOT of the		
1.00.44	double circuit Cooper –		
b3044	Somerset 69 kV line 266.8		EKPC (100%)
	MCM conductor from 212°F		
	to 266°F		
	Increase the MOT of Liberty		
b3045	Church tap – Bacon Creek		
	tap 69 kV line 266.8 MCM		EKPC (100%)
	conductor from 212°F to		
	266°F		
b3046	Increase the MOT of		
	Summer Shade – JB		EKPC (100%)
	Galloway Jct. 69 kV line		/
	266.8 MCM conductor from		
	167°F to 212°F		

Required	Transmission Enhancements	Annual Revenue Requireme	ent Responsible Customer(s)
	Upgrade the existing 4/0 CU		
	line jumpers with double 500		
	MCM CU associated with		
	the Green Co - KU Green Co		
h2017	69 kV line section. Also,		EKDC(100%)
03047	replace the existing 600 A		EKFC (100%)
	disconnect switches with		
	1200 A associated with the		
	Green Co 161/69 kV		
	transformer		
	Move 69 kV 12.0 MVAR		
h3004	capacitor bank from		EKPC(100%)
03094	Greenbriar to Bullitt Co 69		EKI C (100%)
	kV substation		
	Upgrade the metering CT		
	associated with the Clay		
b3266	Village – Clay Village T 69		EKPC (100%)
	kV line section to increase		
	the line ratings		
b3267	Rebuild the 4/0 ACSR		
	Norwood – Shopville 69 kV		EKPC(100%)
	line section using 556		EKIC(10070)
	ACSR/TW		